

Application Type Renewal  
Facility Type Municipal  
Major / Minor Major

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0020567  
APS ID 1068718  
Authorization ID 1405388

**Applicant and Facility Information**

Applicant Name	<u>Northumberland Borough, Northumberland County</u>	Facility Name	<u>Northumberland Sewer Authority WWTP</u>
Applicant Address	<u>175 Orange Street</u> <u>Northumberland, PA 17857-1669</u>	Facility Address	<u>100 Water Street</u> <u>Northumberland, PA 17857-1945</u>
Applicant Contact	<u>Jeremy Deitrick, Superintendent</u>	Facility Contact	<u>Jeremy Deitrick, Superintendent</u>
Applicant Phone	<u>(570) 473-1992</u>	Facility Phone	<u>(570) 473-1992</u>
Client ID	<u>61468</u>	Site ID	<u>459358</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Northumberland Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Northumberland</u>
Date Application Received	<u>August 4, 2022</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>August 17, 2022</u>	If No, Reason	<u>Major Facility, Significant CB Discharge</u>
Purpose of Application	<u>Renewal of a Major NPDES permit for a POTW</u>		

**Summary of Review**

The subject facility is a major Publicly Owned Treatment Works (POTW) serving Northumberland Borough and portions of Point and Upper August Townships in Northumberland County.

A map of the discharge location is attached (Attachment A).

Sludge use and disposal description and location(s): The facility's dewatered sludge is disposed by landfill. Per the application 99.897 dry tons were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	May 4, 2022
✓		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 5, 2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>1.125</u>
Latitude	<u>40° 52' 59.42"</u>	Longitude	<u>-76° 47' 40.55"</u>
Quad Name	<u>Northumberland, PA</u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Susquehanna River (WWF)</u>	Stream Code	<u>6685</u>
NHD Com ID	<u>65643397</u>	RMI	<u>125.7</u>
Drainage Area	<u>11,300 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0988</u>
Q <sub>7-10</sub> Flow (cfs)	<u>1116</u>	Q <sub>7-10</sub> Basis	<u>USGS Gage 01540500, Susquehanna R. @ Danville (1981-2008)</u>
Elevation (ft)	<u>430</u>	Slope (ft/ft)	<u>0.0009</u>
Watershed No.	<u>5-E</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Not attaining</u>		
Cause(s) of Impairment	<u>PCB and Mercury</u>		
Source(s) of Impairment	<u>Source Unknown</u>		
TMDL Status	<u>Final, 3/12/99</u>	Name	<u>Susquehanna River PCB TMDL</u>
Nearest Downstream Public Water Supply Intake	<u>Sunbury Municipal Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Distance from Outfall (mi)	<u>1.8</u>

Changes Since Last Permit Issuance: The above stream and drainage characteristics were determined for a previous review and remain adequate.

Other Comments:

This discharge is not affecting the above-listed impairment for PCBs in the River and is not identified as a contributor to the impairment in the TMDL. The impairment to the River for PCBs is due to legacy contamination and is not reasonably expected to be discharged by the Northumberland Borough. No potential sources such as landfills or incineration activities contribute to the discharge. Per the TMDL "PCB present in the main stem of the Susquehanna River is believed to reside primarily in sediment due to historic use." Mercury was not detected at a detection level of 0.16 µg/L which is less than the Target QL of 0.2 µg/L. Therefore, no additional monitoring will be required at this time related to these impairments.

The discharge is not expected to affect any downstream water supply at this time with the limitations and monitoring proposed. It is noted that while this discharge is only 1.8 miles upstream from the Sunbury Water Authority withdrawal, the discharge is to the western side of the North Branch of the River and the Sunbury withdrawal is from the Eastern side of the combined River.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Northumberland Borough STP				
WQM Permit No.	Issuance Date	Permit For:		
4913404	A-1 – 2/11/14	Amendment to increase size of VLRs, add two digesters, and move Chlorine contact tank and sludge pumping		
	Original – 5/13/13	New treatment facilities including grit removal, 3 VLRs, 2 final clarifiers, phosphorus removal, and hypochlorite disinfection, modification to aerobic digesters, and upgrades to the Queen Street Pump Station.		
4913402	4/14/13	Transfer from Northumberland Sewer Authority and consolidation of seven previous permits covering the Northumberland Borough conveyance system.		
4913401	4/1/13	Transfer and consolidation of five previous permits covering the Northumberland Borough treatment system.		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge	Hypochlorite	1.125
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
1.125	2346	Not Overloaded	Aerobic Digestion	Landfill

Changes Since Last Permit Issuance: None.

Other Comments: Treatment consists of Bar Screen and mechanical screen at the Queen Street Pump Station and Grit removal, Vertical Loop Reactors, Alum addition, Secondary Clarifiers, Liquid hypochlorite disinfection, aerobic digesters, and sludge press.

Stormwater Requirements
<p>The permittee has identified one stormwater outfall discharging from the facility, 002.</p> <p>Stormwater requirements will be included in the NPDES permit because the discharge from the facility meets the definition of a storm water discharges associated with industrial activity in 40 CFR §122.26(b)(14)(ix).</p> <p>The requirements of the December 2022 PAG-03 Appendix J are appropriate for this discharge and will be included in this permit. The requirements include twice per year monitoring of stormwater outfalls for Total Nitrogen, Total Phosphorus, TSS, Oil and Grease, pH, and Chemical Oxygen Demand. Benchmark monitoring levels from the PAG-03 for TSS (100 mg/L), Oil and Grease (30 mg/L), pH (9), and COD (120 mg/L) will be included in the draft permit.</p> <p>These stormwater discharges also are not expected to affect any downstream water supply at this time with the monitoring proposed.</p>

**Industrial Users**

The facility does not have any significant industrial users. The industrial users identified in the application include:

- Butter Krust Baking Co. (3042 GPD)
- Keystone Forging Company (500 GPD)
- River Run Foods (650 GPD)

**Hauled-In-Waste**

Per the application, the facility has not received any hauled-in wastes over the past three years and the Borough does not anticipate receiving any over the next permit term.

Compliance History

DMR Data for Outfall 001 (from February 1, 2022 to January 31, 2023)

Parameter	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22
Flow (MGD) Average Monthly	0.838	0.793	0.571	0.523	0.523	0.457	0.464	0.546	0.836	0.832	0.758	0.921
Flow (MGD) Daily Maximum	1.233	2.037	1.112	0.96	0.8	0.554	0.553	1.045	2.675	1.364	0.947	2.714
pH (S.U.) Minimum	6.5	6.6	6.5	6.4	6.6	6.4	6.8	6.7	6.9	6.9	6.6	6.7
pH (S.U.) Maximum	6.9	7.1	7.2	7.3	7.1	7.1	7.2	7.2	7.2	7.3	7.1	7.4
TRC (mg/L) Average Monthly	0.3	0.5	0.3	0.5	0.3	0.5	0.4	0.5	0.4	0.4	0.3	0.4
TRC (mg/L) Instantaneous Maximum	0.9	1.1	0.4	3.0	0.4	0.9	0.6	0.7	0.6	0.6	0.7	0.7
CBOD5 (lbs/day) Average Monthly	< 19	25	< 17	20	23	< 13	15	15	< 14	< 16	< 18	< 12
CBOD5 (lbs/day) Weekly Average	24	41	27	32	30	16	17	17	< 19	< 21	28	< 14
CBOD5 (mg/L) Average Monthly	< 3	4	< 4	4	5	< 3	4	4	< 2	< 2	< 3	< 2
CBOD5 (mg/L) Weekly Average	3.4	6.3	4.1	4.1	6.6	4.1	4.5	4.2	< 2.4	< 2.2	3.7	< 2.2
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	1052	1095	1192	1299	958	1553	1343	1370	1359	1493	1881	1412
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	1393	1805	2251	2110	1421	2763	3308	2104	1631	2704	6013	1808
BOD5 (mg/L) Raw Sewage Influent Average Monthly	161	195	266	268	213	398	349	322	233	225	325	263
TSS (lbs/day) Average Monthly	< 27	< 62	< 24	< 26	< 24	< 21	< 15	< 21	< 27	< 32	< 31	< 33
TSS (lbs/day) Raw Sewage Influent Average Monthly	1056	1736	736	847	914	1148	969	947	1012	1099	945	869

**NPDES Permit Fact Sheet**  
**Northumberland Sewer Authority WWTP**

**NPDES Permit No. PA0020567**

TSS (lbs/day) Raw Sewage Influent Daily Maximum	2288	5466	1117	1521	1900	2090	2020	1639	1330	2606	1922	1134
TSS (lbs/day) Weekly Average	< 34	177	43	< 39	37	34	< 16	34	< 32	< 38	49	40
TSS (mg/L) Average Monthly	< 4	< 10	< 5	< 6	< 5	< 5	< 4	< 5	< 5	< 5	< 5	< 6
TSS (mg/L) Raw Sewage Influent Average Monthly	167	298	164	178	206	294	253	223	175	165	158	166
TSS (mg/L) Weekly Average	< 4	26	7	< 7	7	9	< 4	7	< 6	< 6	7	< 8
Fecal Coliform (CFU/100 ml) Geometric Mean	14	< 21	23	< 92	15	6	11	4	< 4	< 30	< 269	< 3
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	461.1	6294	1046.2	1986.3	98	12	23.5	40.8	10.9	866.4	4611	26.9
Nitrate-Nitrite (mg/L) Average Monthly	2.62	3	3.51	3.5	3.58	4.63	4.55	4.43	1.37	1.34	2.38	2.22
Nitrate-Nitrite (lbs) Total Monthly	534	528.8	522.4	510.8	530.6	557.3	539.4	566.1	230.7	276.1	447.9	310
Total Nitrogen (mg/L) Average Monthly	< 3.76	< 5.88	< 5.68	< 5.2	5.11	6.76	5.96	< 6.74	< 2.67	< 2.68	5.04	5.6
Total Nitrogen (lbs) Total Monthly	< 775.7	< 1076.8	< 913.8	< 756.5	761.6	811.6	706.8	< 863.1	< 463	< 557.2	1009.8	819.6
Ammonia (mg/L) Average Monthly	< 0.16	< 1.02	< 0.17	< 0.11	< 0.13	0.28	< 0.1	< 0.1	< 0.1	< 0.11	< 0.63	2.11
Ammonia (lbs) Total Monthly	< 35.4	< 184.6	< 24.3	< 16.6	< 20.8	33	< 12.3	< 13.2	< 18.8	< 24.9	< 143.1	323.5
TKN (mg/L) Average Monthly	< 1.1	< 2.9	< 2.2	< 1.7	1.5	2.1	1.4	< 2.3	< 1.3	< 1.3	2.7	3.4
TKN (lbs) Total Monthly	< 241.7	< 548	< 391.4	< 245.7	< 231	254.3	167.3	< 297	< 232.4	< 281.1	561.9	509.6
Total Phosphorus (mg/L) Average Monthly	1.09	2.7	2.3	3.5	2.6	7.03	3.79	4.02	2.44	0.5	0.99	0.62
Total Phosphorus (lbs) Total Monthly	226	493.3	327.7	496.9	361.7	843.7	449.7	522.7	420.1	105.7	195.3	95.7

**Compliance History, Cont'd**

**Effluent Violations for Outfall 001, from: February 1, 2022 to January 31, 2023**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	10/31/22	IMAX	3.0	mg/L	1.6	mg/L

**Compliance History, Cont'd**

<b>Summary of Inspections:</b>		The facility has been inspected at least annually by the Department over the past permit term. The most recent full inspection of the facility on October 31, 2022 identified an eDMR effluent violation. A Chesapeake Bay inspection on November 22, 2022 did not identify any violations.
<b>Other Comments:</b>		A query in WMS found open violations in eFACTS for Northumberland Borough for effluent violations.

**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	234	375 Wkly Avg	XXX	25	40 Wkly Avg	50	2/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Suspended Solids	281	422 Wkly Avg	XXX	30	45 Wkly Avg	60	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite



Existing Effluent Limitations and Monitoring Requirements – Chesapeake Bay								
Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs) Effluent Net	XXX	20,548 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs) Effluent Net	XXX	2,740 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) 1.125  
 Latitude 40° 53' 3.20" Longitude -76° 47' 43.10"  
 Wastewater Description: Sewage Effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and are included in the existing permit.

**Water Quality-Based Limitations**

**DO, CBOD<sub>5</sub> and NH<sub>3</sub>-N**

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD<sub>5</sub>), and ammonia-nitrogen (NH<sub>3</sub>-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH<sub>3</sub>-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD<sub>5</sub> and NH<sub>3</sub>-N. WQM7.0 modeling was performed (see Attachment B) for the discharge to the Susquehanna River and showed that no limitations are necessary for these parameters beyond the technology-based secondary treatment limits listed above.

**Total Residual Chlorine**

The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. The attached results of the TRC spreadsheet (see Attachment C) show that the technology-based limit of 0.5 mg/l is adequate to protect the receiving stream.

**Water Quality Toxics Management**

A "Reasonable Potential Analysis" was performed to determine additional parameters with the reasonable potential to violate water quality standards (see the Toxics Management Spreadsheet, Attachment D). The Toxics Management Spreadsheet (TMS) is a mass-balance water quality analysis model that includes consideration for mixing and other factors to determine recommended water quality-based effluent limits. The model incorporates the water quality criteria of 25 Pa.Code §93.

The parameters listed below were determined by a reasonable potential analysis, based on sampling provided in the application, to be candidates for monitoring or limitations in the draft permit. The Reasonable Potential Analysis recommends limits when the highest sampling result is greater than 50% of the WQBEL and recommends monitoring when the result is greater than 10% of the WQBEL for conservative pollutants, consistent with the Department's SOPs. The Department assumes that results for pollutants at detection levels higher than the Department's Target Quantitation Limits (TQLs) are potentially present at concentrations near the higher detection level. The table below shows the permittee's sample results, the WQ-based monthly average limitation, and the Target Quantitation Limit for each parameter. The Toxics Management Spreadsheet applies the Department's instream criteria from 25 PA Code

93 accounting for available instream dilution.

Because all sampling for these parameters below were below detection, the lowest of the non-detectable values for each are included in this table.

Pollutant	Sample Results (µg/L)	WQBEL (µg/L)	Target Quantitation Limit (µg/L)	TMS Result
Pentachlorophenol	<14.7	16.1	10	Limit
Benzo(a)anthracene	<7.5	0.54	2.5	Limit
Benzo(a)pyrene	<7.5	0.054	2.5	Limit
3,4-Benzofluoranthene or benzo(b)fluoranthene	<7.2	0.54	2.5	Limit
Benzo(k)Fluoranthene	<7.0	5.36	2.5	Limit
Bis(2-Chloroethyl)Ether	<5.2	16.1	5	Monitor
Butyl Benzyl Phthalate	<15.7	12.2	5	Limit
Dibenzo(a,h)Anthracene	<7.4	0.054	2.5	Limit
3,3-Dichlorobenzidine	<8.1	26.8	5	Monitor
Hexachlorobenzene	<6.6	0.043	5	Limit
Indeno(1,2,3-cd)Pyrene	<6.8	0.54	2.5	Limit
n-Nitrosodi-n-Propylamine	<5.8	2.68	5	Limit

Should Northumberland Borough conduct an additional round of sampling during the draft comment period that shows that levels of the above parameters in the effluent are undetectable at or below the Department's TQL then the Department will consider removing the monitoring/limitations for these from the final permit.

**Chesapeake Bay/Nutrient Requirements**

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania in order to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. Northumberland Borough is considered a Phase 3, Significant Chesapeake Bay discharger. Nutrient cap loads have previously been established for this facility pursuant to the Phase III Watershed Implementation Plan. The permittee generates 5,950 lbs/yr of TN offsets.

The discharge's cap loadings as well as the actual Total Nitrogen and Total Phosphorus loadings for the past two cycle years are listed in the table below.

Nutrient	Total Nitrogen (lbs)	Total Phosphorus (lbs)
<b>Nutrient Cap Loads for PA0020567</b>	20,548	2,740
<b>10/1/20 – 9/30/21 Net Loadings</b>	<4,890	2,711
<b>10/1/20 – 9/30/21 Offsets Used</b>	1,258	-
<b>10/1/20 – 9/30/21 Credits Purchased</b>	-	1,353
<b>10/1/20 – 9/30/21 Total Mass Load</b>	<9,582	4,064
<b>10/1/21 – 9/30/22 Net Loadings</b>	<4,509	2,712
<b>10/1/21 – 9/30/22 Offsets Used</b>	2,765	-
<b>10/1/21 – 9/30/22 Credits Purchased</b>	-	1,261
<b>10/1/21 – 9/30/22 Total Mass Load</b>	<7,694	3,973

**Best Professional Judgment (BPJ) Limitations**

Comments: No additional BPJ limitations are necessary at this time beyond the technology and water quality-based limitations noted above.

**Anti-Backsliding**

No proposed limitations have been made less stringent consistent with the Anti-degradation requirements of The Clean Water Act and 40 CFR 122.44(l).

**Whole Effluent Toxicity (WET)**

For Outfall 001,  Acute  Chronic WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other: **Annually over the permit term**

The dilution series used for the tests was: 100%, 60%, 30%, 2%, and 1%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 1.

**Summary of Four Most Recent Test Results**

(NOTE – Enter results into one table, depending on which data analysis method was used).

NOEC/LC50 Data Analysis

Test Date	Ceriodaphnia Results (% Effluent)			Pimephales Results (% Effluent)			Pass? *
	NOEC Survival	NOEC Reproduction	LC50	NOEC Survival	NOEC Growth	LC50	
Sept 2019	>100	>100	100	>100	>100	100	Pass
April 2020	>100	>100	100	>100	>100	100	Pass
January 2021	>100	>100	100	>100	>100	100	Pass
March 2022	>100	>100	100	>100	>100	100	Pass

\* A "passing" result is that which is greater than or equal to the TIWC value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? (NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).

- YES  NO

**Comments:** The Department notes that the application also includes WET results from December 2019 for which the P. Promelas tests passed but the C. dubia tests were invalid for Test Acceptability Criteria not being met.

**Evaluation of Test Type, IWC and Dilution Series for Renewed Permit**

Acute Partial Mix Factor (PMFa): **0.027**

Chronic Partial Mix Factor (PMFc): **0.187**

**1. Determine IWC – Acute (IWCa):**

$$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$$

$$[(1.125 \text{ MGD} \times 1.547) / ((1116 \text{ cfs} \times 0.027) + (1.125 \text{ MGD} \times 1.547))] \times 100 = \mathbf{5.46\%}$$

Is IWCa < 1%?  YES  NO

**Type of Test for Permit Renewal: Chronic**

**2b. Determine Target IWCc (If Chronic Tests Required)**

$$(Q_d \times 1.547) / (Q_{7-10} \times PMFc) + (Q_d \times 1.547)$$

$$[(1.125 \text{ MGD} \times 1.547) / ((1116 \text{ cfs} \times 0.187) + (1.125 \text{ MGD} \times 1.547))] \times 100 = \mathbf{0.83\%} \Rightarrow \mathbf{TIWCc = 1}$$

**3. Determine Dilution Series**

(NOTE – check Attachment C of WET SOP for dilution series based on TIWCa or TIWCc, whichever applies).

Dilution Series = 100%, 60%, 30%, 2%, and 1%.

**WET Limits**

Has reasonable potential been determined?  YES  NO

Will WET limits be established in the permit?  YES  NO

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	234	375 Wkly Avg	XXX	25	40 Wkly Avg	50	2/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Suspended Solids	281	422 Wkly Avg	XXX	30	45 Wkly Avg	60	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report	XXX	1/month	Grab
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
3,3-Dichlorobenzidine (ug/L)	Report	Report	XXX	Report	Report	XXX	2/month	24-Hr Composite
Pentachlorophenol (ug/L)	0.15	0.24	XXX	16.1	25.1	40.2	2/month	24-Hr Composite
Hexachlorobenzene (ug/L)	0.0004	0.0006	XXX	0.043	0.067	0.11	2/month	24-Hr Composite
Benzo(a)Anthracene (ug/L)	0.005	0.008	XXX	0.54	0.84	1.34	2/month	24-Hr Composite
Benzo(a)Pyrene (ug/L)	0.0005	0.0008	XXX	0.054	0.084	0.13	2/month	24-Hr Composite
Benzo(k)Fluoranthene (ug/L)	0.05	0.078	XXX	5.36	8.36	13.4	2/month	24-Hr Composite
3,4-Benzofluoranthene (ug/L)	0.005	0.008	XXX	0.54	0.84	1.34	2/month	24-Hr Composite
Butyl Benzyl Phthalate (ug/L)	0.11	0.18	XXX	12.2	19.0	30.4	2/month	24-Hr Composite
Bis(2-Chloroethyl)Ether (ug/L)	Report	Report	XXX	Report	Report	XXX	2/month	24-Hr Composite
Dibenzo(a,h)Anthracene (ug/L)	0.0005	0.0008	XXX	0.054	0.084	0.13	2/month	24-Hr Composite
Indeno(1,2,3-cd)Pyrene (ug/L)	0.005	0.008	XXX	0.54	0.84	1.34	2/month	24-Hr Composite
N-Nitrosodi-N-Propylamine (ug/L)	0.025	0.039	XXX	2.68	4.18	6.7	2/month	24-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: E. coli monitoring is new consistent with recent changes to Chapter 93 of the Department's regulations and current Department policy. Dissolved Oxygen monitoring is also new consistent with Department policy for WWTP discharges. New monitoring and limitations are included for twelve toxic parameters.



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 002, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
pH (S.U.)	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
Chemical Oxygen Demand (COD)	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
Total Suspended Solids	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
Oil and Grease	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Calculation
Total Phosphorus	XXX	XXX	XXX	XXX	Report	XXX	1/6 months	Grab

Compliance Sampling Location: Outfall 002

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

**Outfall 001**, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs) Effluent Net	XXX	20,548 <sup>(3)</sup> Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs) Effluent Net	XXX	2,740 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation


Compliance Sampling Location: Outfall 001

- (3) The permittee is authorized to use 5,950 lbs/year of Total Nitrogen (TN) Offsets towards compliance with the Annual Net TN mass load limitations (Cap Load) in accordance with Part C of this permit. These offsets may be applied throughout the Compliance Year or during the Truing Period. The application of Offsets must be reported to DEP as described in Part C. The Offsets are authorized for the following pollutant load reduction activities:
- Connection of 238 on-lot sewage disposal systems to the public sewers after January 1, 2003 in which 25 lbs/year of TN offsets are granted per connection.


Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment <b>B</b> )
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment <b>D</b> )
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment <b>C</b> )
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment <b> </b> )
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP(s): Establishing Effluent Limitations for Individual Industrial Permits, 9/10/13, Establishing WQBELs for Toxic Pollutants and Permit Conditions for Toxic Pollutants, 5/20/21
<input type="checkbox"/>	Other: <b> </b>

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Model
- C. TRC Spreadsheet
- D. Toxics Screening Spreadsheet
- E. WETT Spreadsheet



Northumberland  
Borough  
PA0020567  
Outfall 001



## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07K	6685	SUSQUEHANNA RIVER	<b>125.700</b>	440.00	11300.00	0.00000	0.00	<input checked="" type="checkbox"/>

### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
<b>Q7-10</b>	0.099	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Northumberland	PA0020567	1.1250	0.0000	0.0000	0.000	25.00	7.00

### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07K	6685	SUSQUEHANNA RIVER	<b>125.500</b>	439.00	18300.00	0.00000	0.00	<input checked="" type="checkbox"/>

### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Tributary pH	Stream Temp (°C)	Stream pH
	<b>Q7-10</b>	0.099	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
<b>Q1-10</b>		0.00	0.00	0.000	0.000							
<b>Q30-10</b>		0.00	0.00	0.000	0.000							

### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

## WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
07K		6685				SUSQUEHANNA RIVER						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
125.700	1118.70	0.00	1118.70	1.7404	0.00095	1.109	733.58	661.62	1.38	0.009	20.01	7.00
<b>Q1-10 Flow</b>												
125.700	715.97	0.00	715.97	1.7404	0.00095	NA	NA	NA	1.07	0.011	20.01	7.00
<b>Q30-10 Flow</b>												
125.700	1521.43	0.00	1521.43	1.7404	0.00095	NA	NA	NA	1.64	0.007	20.01	7.00



## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
07K	6685	SUSQUEHANNA RIVER

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
125.700	Northumberland	16.74	50	16.74	50	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
125.700	Northumberland	1.89	25	1.89	25	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
125.70	Northumberland	25	25	25	25	3	3	0	0

## WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07K	6685	SUSQUEHANNA RIVER		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
125.700	1.125	20.008		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
733.579	1.109	661.621		1.378
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.04	0.028	0.04		0.700
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
8.235	6.086	Tsivoglou		5
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.009	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	0.001	2.04	0.04	8.24
	0.002	2.04	0.04	8.24
	0.003	2.04	0.04	8.24
	0.004	2.04	0.04	8.24
	0.004	2.04	0.04	8.24
	0.005	2.04	0.04	8.24
	0.006	2.04	0.04	8.24
	0.007	2.04	0.04	8.24
	0.008	2.04	0.04	8.24
	0.009	2.04	0.04	8.24

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
07K	6685	SUSQUEHANNA RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
125.700	Northumberland	PA0020567	1.125	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

<b>TRC EVALUATION</b>					
Input appropriate values in A3:A9 and D3:D9					
1116	= Q stream (cfs)		0.5	= CV Daily	
1.125	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 204.575		1.3.2.iii	WLA_cfc = 199.437
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 76.229		5.1d	LTA_cfc = 115.943
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

# Discharge Information

Instructions

**Discharge**

Stream

Facility: **Northumberland Borough**

NPDES Permit No.: **PA0020567**

Outfall No.: **001**

Evaluation Type **Major Sewage / Industrial Waste**

Wastewater Description: **Treated Sewage**

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
1.125	144	7.4						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl	
Group 1	Total Dissolved Solids (PWS)	mg/L	412									
	Chloride (PWS)	mg/L	96									
	Bromide	mg/L	< 0.09									
	Sulfate (PWS)	mg/L	74									
	Fluoride (PWS)	mg/L										
Group 2	Total Aluminum	µg/L	< 0.42									
	Total Antimony	µg/L	< 0.5									
	Total Arsenic	µg/L	< 0.5									
	Total Barium	µg/L	34.2									
	Total Beryllium	µg/L	< 0.2									
	Total Boron	µg/L	221									
	Total Cadmium	µg/L	< 0.1									
	Total Chromium (III)	µg/L	< 0.6									
	Hexavalent Chromium	µg/L	2									
	Total Cobalt	µg/L	< 0.35									
	Total Copper	µg/L	< 2.1									
	Free Cyanide	µg/L										
	Total Cyanide	µg/L	< 16									
	Dissolved Iron	µg/L	45.3									
	Total Iron	µg/L	61.4									
	Total Lead	µg/L	< 0.5									
	Total Manganese	µg/L	42.4									
	Total Mercury	µg/L	< 0.2									
	Total Nickel	µg/L	< 1.5									
	Total Phenols (Phenolics) (PWS)	µg/L	< 0.2									
	Total Selenium	µg/L	< 0.8									
	Total Silver	µg/L	0.5									
	Total Thallium	µg/L	< 0.1									
Total Zinc	µg/L	65.6										
Total Molybdenum	µg/L	< 1.1										
Acrolein	µg/L	4										
Acrylamide	µg/L	<										
Acrylonitrile	µg/L	< 1.4										
Benzene	µg/L	< 0.41										
Bromoform	µg/L	1.5										
Carbon Tetrachloride	µg/L	0.52										





# Stream / Surface Water Information

Northumberland Borough, NPDES Permit No. PA0020567, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: Susquehanna River

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	006685	125.7	440	11300			Yes
End of Reach 1	006685	125.5	439	18300			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	125.7	0.099										100	7		
End of Reach 1	125.5	0.099													

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	125.7														
End of Reach 1	125.5														



# Model Results

Northumberland Borough, NPDES Permit No. PA0020567, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

**Hydrodynamics**

Q<sub>7-10</sub>

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
125.7	1118.70		1118.70	1.74	0.00095	1.109	733.579	661.622	1.378	0.009	20466.696
125.5	1811.70		1811.7								

Q<sub>h</sub>

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
125.7	3432.14		3432.14	1.74	0.00095	1.815	733.579	404.199	2.579	0.005	9793.464
125.5	5230.657		5230.66								

**Wasteload Allocations**

**AFC**

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	13,801	
Total Antimony	0	0		0	1,100	1,100	20,242	
Total Arsenic	0	0		0	340	340	6,257	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	386,436	
Total Boron	0	0		0	8,100	8,100	149,054	
Total Cadmium	0	0		0	2.061	2.19	40.2	Chem Translator of 0.943 applied
Total Chromium (III)	0	0		0	580.897	1,838	33,828	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	300	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	1,748	
Total Copper	0	0		0	13.742	14.3	263	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	

Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	66,264	84.1	1,548	Chem Translator of 0.788 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1,400	1.65	30.3	Chem Translator of 0.85 applied
Total Nickel	0	0		0	477,690	479	8,808	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	3,350	3.94	72.5	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	1,196	
Total Zinc	0	0		0	119,550	122	2,249	Chem Translator of 0.978 applied
Acrolein	0	0		0	3	3.0	55.2	
Acrylonitrile	0	0		0	650	650	11,961	
Benzene	0	0		0	640	640	11,777	
Bromoform	0	0		0	1,800	1,800	33,123	
Carbon Tetrachloride	0	0		0	2,800	2,800	51,525	
Chlorobenzene	0	0		0	1,200	1,200	22,082	
Chlorodibromomethane	0	0		0	N/A	N/A	N/A	
2-Chloroethyl Vinyl Ether	0	0		0	18,000	18,000	331,231	
Chloroform	0	0		0	1,900	1,900	34,963	
Dichlorobromomethane	0	0		0	N/A	N/A	N/A	
1,2-Dichloroethane	0	0		0	15,000	15,000	276,026	
1,1-Dichloroethylene	0	0		0	7,500	7,500	138,013	
1,2-Dichloropropane	0	0		0	11,000	11,000	202,419	
1,3-Dichloropropylene	0	0		0	310	310	5,705	
Ethylbenzene	0	0		0	2,900	2,900	53,365	
Methyl Bromide	0	0		0	550	550	10,121	
Methyl Chloride	0	0		0	28,000	28,000	515,249	
Methylene Chloride	0	0		0	12,000	12,000	220,821	
1,1,2,2-Tetrachloroethane	0	0		0	1,000	1,000	18,402	
Tetrachloroethylene	0	0		0	700	700	12,881	
Toluene	0	0		0	1,700	1,700	31,283	
1,2-trans-Dichloroethylene	0	0		0	6,800	6,800	125,132	
1,1,1-Trichloroethane	0	0		0	3,000	3,000	55,205	
1,1,2-Trichloroethane	0	0		0	3,400	3,400	62,566	
Trichloroethylene	0	0		0	2,300	2,300	42,324	
Vinyl Chloride	0	0		0	N/A	N/A	N/A	
2-Chlorophenol	0	0		0	560	560	10,305	
2,4-Dichlorophenol	0	0		0	1,700	1,700	31,283	
2,4-Dimethylphenol	0	0		0	660	660	12,145	
4,6-Dinitro-o-Cresol	0	0		0	80	80.0	1,472	
2,4-Dinitrophenol	0	0		0	660	660	12,145	
2-Nitrophenol	0	0		0	8,000	8,000	147,214	
4-Nitrophenol	0	0		0	2,300	2,300	42,324	
p-Chloro-m-Cresol	0	0		0	160	160	2,944	
Pentachlorophenol	0	0		0	8.851	8.85	163	
Phenol	0	0		0	N/A	N/A	N/A	
2,4,6-Trichlorophenol	0	0		0	460	460	8,465	
Acenaphthene	0	0		0	83	83.0	1,527	

Anthracene	0	0		0	N/A	N/A	N/A	
Benzidine	0	0		0	300	300	5,521	
Benzo(a)Anthracene	0	0		0	0.5	0.5	9.2	
Benzo(a)Pyrene	0	0		0	N/A	N/A	N/A	
3,4-Benzofluoranthene	0	0		0	N/A	N/A	N/A	
Benzo(k)Fluoranthene	0	0		0	N/A	N/A	N/A	
Bis(2-Chloroethyl)Ether	0	0		0	30,000	30,000	552,052	
Bis(2-Chloroisopropyl)Ether	0	0		0	N/A	N/A	N/A	
Bis(2-Ethylhexyl)Phthalate	0	0		0	4,500	4,500	82,808	
4-Bromophenyl Phenyl Ether	0	0		0	270	270	4,968	
Butyl Benzyl Phthalate	0	0		0	140	140	2,576	
2-Chloronaphthalene	0	0		0	N/A	N/A	N/A	
Chrysene	0	0		0	N/A	N/A	N/A	
Dibenzo(a,h)Anthracene	0	0		0	N/A	N/A	N/A	
1,2-Dichlorobenzene	0	0		0	820	820	15,089	
1,3-Dichlorobenzene	0	0		0	350	350	6,441	
1,4-Dichlorobenzene	0	0		0	730	730	13,433	
3,3-Dichlorobenzidine	0	0		0	N/A	N/A	N/A	
Diethyl Phthalate	0	0		0	4,000	4,000	73,607	
Dimethyl Phthalate	0	0		0	2,500	2,500	46,004	
Di-n-Butyl Phthalate	0	0		0	110	110	2,024	
2,4-Dinitrotoluene	0	0		0	1,600	1,600	29,443	
2,6-Dinitrotoluene	0	0		0	990	990	18,218	
1,2-Diphenylhydrazine	0	0		0	15	15.0	276	
Fluoranthene	0	0		0	200	200	3,680	
Fluorene	0	0		0	N/A	N/A	N/A	
Hexachlorobenzene	0	0		0	N/A	N/A	N/A	
Hexachlorobutadiene	0	0		0	10	10.0	184	
Hexachlorocyclopentadiene	0	0		0	5	5.0	92.0	
Hexachloroethane	0	0		0	60	60.0	1,104	
Indeno(1,2,3-cd)Pyrene	0	0		0	N/A	N/A	N/A	
Isophorone	0	0		0	10,000	10,000	184,017	
Naphthalene	0	0		0	140	140	2,576	
Nitrobenzene	0	0		0	4,000	4,000	73,607	
n-Nitrosodimethylamine	0	0		0	17,000	17,000	312,829	
n-Nitrosodi-n-Propylamine	0	0		0	N/A	N/A	N/A	
n-Nitrosodiphenylamine	0	0		0	300	300	5,521	
Phenanthrene	0	0		0	5	5.0	92.0	
Pyrene	0	0		0	N/A	N/A	N/A	
1,2,4-Trichlorobenzene	0	0		0	130	130	2,392	

 **CFC**

 CCT (min): 

 PMF: 

 Analysis Hardness (mg/l): 

 Analysis pH: 

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	

Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	26,744	
Total Arsenic	0	0		0	150	150	18,234	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	498,407	
Total Boron	0	0		0	1,600	1,600	194,500	
Total Cadmium	0	0		0	0.247	0.27	33.0	Chem Translator of 0.909 applied
Total Chromium (III)	0	0		0	74.334	86.4	10,507	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	1,264	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	2,310	
Total Copper	0	0		0	8.983	9.36	1,138	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	965,689	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.527	3.2	389	Chem Translator of 0.79 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	110	Chem Translator of 0.85 applied
Total Nickel	0	0		0	52.166	52.3	6,360	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	606	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	1,580	
Total Zinc	0	0		0	118.501	120	14,610	Chem Translator of 0.986 applied
Acrolein	0	0		0	3	3.0	365	
Acrylonitrile	0	0		0	130	130	15,803	
Benzene	0	0		0	130	130	15,803	
Bromoform	0	0		0	370	370	44,978	
Carbon Tetrachloride	0	0		0	560	560	68,075	
Chlorobenzene	0	0		0	240	240	29,175	
Chlorodibromomethane	0	0		0	N/A	N/A	N/A	
2-Chloroethyl Vinyl Ether	0	0		0	3,500	3,500	425,470	
Chloroform	0	0		0	390	390	47,409	
Dichlorobromomethane	0	0		0	N/A	N/A	N/A	
1,2-Dichloroethane	0	0		0	3,100	3,100	376,845	
1,1-Dichloroethylene	0	0		0	1,500	1,500	182,344	
1,2-Dichloropropane	0	0		0	2,200	2,200	267,438	
1,3-Dichloropropylene	0	0		0	61	61.0	7,415	
Ethylbenzene	0	0		0	580	580	70,506	
Methyl Bromide	0	0		0	110	110	13,372	
Methyl Chloride	0	0		0	5,500	5,500	668,595	
Methylene Chloride	0	0		0	2,400	2,400	291,751	
1,1,2,2-Tetrachloroethane	0	0		0	210	210	25,528	
Tetrachloroethylene	0	0		0	140	140	17,019	
Toluene	0	0		0	330	330	40,116	
1,2-trans-Dichloroethylene	0	0		0	1,400	1,400	170,188	
1,1,1-Trichloroethane	0	0		0	610	610	74,153	

1,1,2-Trichloroethane	0	0		0	680	680	82,663
Trichloroethylene	0	0		0	450	450	54,703
Vinyl Chloride	0	0		0	N/A	N/A	N/A
2-Chlorophenol	0	0		0	110	110	13,372
2,4-Dichlorophenol	0	0		0	340	340	41,331
2,4-Dimethylphenol	0	0		0	130	130	15,803
4,6-Dinitro-o-Cresol	0	0		0	16	16.0	1,945
2,4-Dinitrophenol	0	0		0	130	130	15,803
2-Nitrophenol	0	0		0	1,600	1,600	194,500
4-Nitrophenol	0	0		0	470	470	57,134
p-Chloro-m-Cresol	0	0		0	500	500	60,781
Pentachlorophenol	0	0		0	6.790	6.79	825
Phenol	0	0		0	N/A	N/A	N/A
2,4,6-Trichlorophenol	0	0		0	91	91.0	11,062
Acenaphthene	0	0		0	17	17.0	2,067
Anthracene	0	0		0	N/A	N/A	N/A
Benzidine	0	0		0	59	59.0	7,172
Benzo(a)Anthracene	0	0		0	0.1	0.1	12.2
Benzo(a)Pyrene	0	0		0	N/A	N/A	N/A
3,4-Benzofluoranthene	0	0		0	N/A	N/A	N/A
Benzo(k)Fluoranthene	0	0		0	N/A	N/A	N/A
Bis(2-Chloroethyl)Ether	0	0		0	6,000	6,000	729,377
Bis(2-Chloroisopropyl)Ether	0	0		0	N/A	N/A	N/A
Bis(2-Ethylhexyl)Phthalate	0	0		0	910	910	110,622
4-Bromophenyl Phenyl Ether	0	0		0	54	54.0	6,564
Butyl Benzyl Phthalate	0	0		0	35	35.0	4,255
2-Chloronaphthalene	0	0		0	N/A	N/A	N/A
Chrysene	0	0		0	N/A	N/A	N/A
Dibenzo(a,h)Anthracene	0	0		0	N/A	N/A	N/A
1,2-Dichlorobenzene	0	0		0	160	160	19,450
1,3-Dichlorobenzene	0	0		0	69	69.0	8,388
1,4-Dichlorobenzene	0	0		0	150	150	18,234
3,3-Dichlorobenzidine	0	0		0	N/A	N/A	N/A
Diethyl Phthalate	0	0		0	800	800	97,250
Dimethyl Phthalate	0	0		0	500	500	60,781
Di-n-Butyl Phthalate	0	0		0	21	21.0	2,553
2,4-Dinitrotoluene	0	0		0	320	320	38,900
2,6-Dinitrotoluene	0	0		0	200	200	24,313
1,2-Diphenylhydrazine	0	0		0	3	3.0	365
Fluoranthene	0	0		0	40	40.0	4,863
Fluorene	0	0		0	N/A	N/A	N/A
Hexachlorobenzene	0	0		0	N/A	N/A	N/A
Hexachlorobutadiene	0	0		0	2	2.0	243
Hexachlorocyclopentadiene	0	0		0	1	1.0	122
Hexachloroethane	0	0		0	12	12.0	1,459

Indeno(1,2,3-cd)Pyrene	0	0		0	N/A	N/A	N/A	
Isophorone	0	0		0	2,100	2,100	255,282	
Naphthalene	0	0		0	43	43.0	5,227	
Nitrobenzene	0	0		0	810	810	98,466	
n-Nitrosodimethylamine	0	0		0	3,400	3,400	413,313	
n-Nitrosodi-n-Propylamine	0	0		0	N/A	N/A	N/A	
n-Nitrosodiphenylamine	0	0		0	59	59.0	7,172	
Phenanthrene	0	0		0	1	1.0	122	
Pyrene	0	0		0	N/A	N/A	N/A	
1,2,4-Trichlorobenzene	0	0		0	26	26.0	3,161	

 **THH**

 CCT (min): 

 PMF: 

 Analysis Hardness (mg/l): 

 Analysis pH: 

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.6	5.6	681	
Total Arsenic	0	0		0	10	10.0	1,216	
Total Barium	0	0		0	2,400	2,400	291,751	
Total Boron	0	0		0	3,100	3,100	376,845	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	300	300	36,469	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	121,563	
Total Mercury	0	0		0	0.050	0.05	6.08	
Total Nickel	0	0		0	610	610	74,153	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	29.2	
Total Zinc	0	0		0	N/A	N/A	N/A	
Acrolein	0	0		0	3	3.0	365	
Acrylonitrile	0	0		0	N/A	N/A	N/A	
Benzene	0	0		0	N/A	N/A	N/A	
Bromoform	0	0		0	N/A	N/A	N/A	
Carbon Tetrachloride	0	0		0	N/A	N/A	N/A	
Chlorobenzene	0	0		0	100	100.0	12,156	

Chlorodibromomethane	0	0		0	N/A	N/A	N/A
2-Chloroethyl Vinyl Ether	0	0		0	N/A	N/A	N/A
Chloroform	0	0		0	5.7	5.7	693
Dichlorobromomethane	0	0		0	N/A	N/A	N/A
1,2-Dichloroethane	0	0		0	N/A	N/A	N/A
1,1-Dichloroethylene	0	0		0	33	33.0	4,012
1,2-Dichloropropane	0	0		0	N/A	N/A	N/A
1,3-Dichloropropylene	0	0		0	N/A	N/A	N/A
Ethylbenzene	0	0		0	68	68.0	8,266
Methyl Bromide	0	0		0	100	100.0	12,156
Methyl Chloride	0	0		0	N/A	N/A	N/A
Methylene Chloride	0	0		0	N/A	N/A	N/A
1,1,2,2-Tetrachloroethane	0	0		0	N/A	N/A	N/A
Tetrachloroethylene	0	0		0	N/A	N/A	N/A
Toluene	0	0		0	57	57.0	6,929
1,2-trans-Dichloroethylene	0	0		0	100	100.0	12,156
1,1,1-Trichloroethane	0	0		0	10,000	10,000	1,215,628
1,1,2-Trichloroethane	0	0		0	N/A	N/A	N/A
Trichloroethylene	0	0		0	N/A	N/A	N/A
Vinyl Chloride	0	0		0	N/A	N/A	N/A
2-Chlorophenol	0	0		0	30	30.0	3,647
2,4-Dichlorophenol	0	0		0	10	10.0	1,216
2,4-Dimethylphenol	0	0		0	100	100.0	12,156
4,6-Dinitro-o-Cresol	0	0		0	2	2.0	243
2,4-Dinitrophenol	0	0		0	10	10.0	1,216
2-Nitrophenol	0	0		0	N/A	N/A	N/A
4-Nitrophenol	0	0		0	N/A	N/A	N/A
p-Chloro-m-Cresol	0	0		0	N/A	N/A	N/A
Pentachlorophenol	0	0		0	N/A	N/A	N/A
Phenol	0	0		0	4,000	4,000	486,251
2,4,6-Trichlorophenol	0	0		0	N/A	N/A	N/A
Acenaphthene	0	0		0	70	70.0	8,509
Anthracene	0	0		0	300	300	36,469
Benzidine	0	0		0	N/A	N/A	N/A
Benzo(a)Anthracene	0	0		0	N/A	N/A	N/A
Benzo(a)Pyrene	0	0		0	N/A	N/A	N/A
3,4-Benzofluoranthene	0	0		0	N/A	N/A	N/A
Benzo(k)Fluoranthene	0	0		0	N/A	N/A	N/A
Bis(2-Chloroethyl)Ether	0	0		0	N/A	N/A	N/A
Bis(2-Chloroisopropyl)Ether	0	0		0	200	200	24,313
Bis(2-Ethylhexyl)Phthalate	0	0		0	N/A	N/A	N/A
4-Bromophenyl Phenyl Ether	0	0		0	N/A	N/A	N/A
Butyl Benzyl Phthalate	0	0		0	0.1	0.1	12.2
2-Chloronaphthalene	0	0		0	800	800	97,250
Chrysene	0	0		0	N/A	N/A	N/A

Dibenzo(a,h)Anthracene	0	0		0	N/A	N/A	N/A	
1,2-Dichlorobenzene	0	0		0	1,000	1,000	121,563	
1,3-Dichlorobenzene	0	0		0	7	7.0	851	
1,4-Dichlorobenzene	0	0		0	300	300	36,469	
3,3-Dichlorobenzidine	0	0		0	N/A	N/A	N/A	
Diethyl Phthalate	0	0		0	600	600	72,938	
Dimethyl Phthalate	0	0		0	2,000	2,000	243,126	
Di-n-Butyl Phthalate	0	0		0	20	20.0	2,431	
2,4-Dinitrotoluene	0	0		0	N/A	N/A	N/A	
2,6-Dinitrotoluene	0	0		0	N/A	N/A	N/A	
1,2-Diphenylhydrazine	0	0		0	N/A	N/A	N/A	
Fluoranthene	0	0		0	20	20.0	2,431	
Fluorene	0	0		0	50	50.0	6,078	
Hexachlorobenzene	0	0		0	N/A	N/A	N/A	
Hexachlorobutadiene	0	0		0	N/A	N/A	N/A	
Hexachlorocyclopentadiene	0	0		0	4	4.0	486	
Hexachloroethane	0	0		0	N/A	N/A	N/A	
Indeno(1,2,3-cd)Pyrene	0	0		0	N/A	N/A	N/A	
Isophorone	0	0		0	34	34.0	4,133	
Naphthalene	0	0		0	N/A	N/A	N/A	
Nitrobenzene	0	0		0	10	10.0	1,216	
n-Nitrosodimethylamine	0	0		0	N/A	N/A	N/A	
n-Nitrosodi-n-Propylamine	0	0		0	N/A	N/A	N/A	
n-Nitrosodiphenylamine	0	0		0	N/A	N/A	N/A	
Phenanthrene	0	0		0	N/A	N/A	N/A	
Pyrene	0	0		0	20	20.0	2,431	
1,2,4-Trichlorobenzene	0	0		0	0.07	0.07	8.51	

 **CRL**

 CCT (min): 

 PMF: 

 Analysis Hardness (mg/l): 

 Analysis pH: 

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	



Dissolved Iron	0	0		0	N/A	N/A	N/A
Total Iron	0	0		0	N/A	N/A	N/A
Total Lead	0	0		0	N/A	N/A	N/A
Total Manganese	0	0		0	N/A	N/A	N/A
Total Mercury	0	0		0	N/A	N/A	N/A
Total Nickel	0	0		0	N/A	N/A	N/A
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A
Total Selenium	0	0		0	N/A	N/A	N/A
Total Silver	0	0		0	N/A	N/A	N/A
Total Thallium	0	0		0	N/A	N/A	N/A
Total Zinc	0	0		0	N/A	N/A	N/A
Acrolein	0	0		0	N/A	N/A	N/A
Acrylonitrile	0	0		0	0.06	0.06	32.1
Benzene	0	0		0	0.58	0.58	311
Bromoform	0	0		0	7	7.0	3,750
Carbon Tetrachloride	0	0		0	0.4	0.4	214
Chlorobenzene	0	0		0	N/A	N/A	N/A
Chlorodibromomethane	0	0		0	0.8	0.8	429
2-Chloroethyl Vinyl Ether	0	0		0	N/A	N/A	N/A
Chloroform	0	0		0	N/A	N/A	N/A
Dichlorobromomethane	0	0		0	0.95	0.95	509
1,2-Dichloroethane	0	0		0	9.9	9.9	5,304
1,1-Dichloroethylene	0	0		0	N/A	N/A	N/A
1,2-Dichloropropane	0	0		0	0.9	0.9	482
1,3-Dichloropropylene	0	0		0	0.27	0.27	145
Ethylbenzene	0	0		0	N/A	N/A	N/A
Methyl Bromide	0	0		0	N/A	N/A	N/A
Methyl Chloride	0	0		0	N/A	N/A	N/A
Methylene Chloride	0	0		0	20	20.0	10,714
1,1,2,2-Tetrachloroethane	0	0		0	0.2	0.2	107
Tetrachloroethylene	0	0		0	10	10.0	5,357
Toluene	0	0		0	N/A	N/A	N/A
1,2-trans-Dichloroethylene	0	0		0	N/A	N/A	N/A
1,1,1-Trichloroethane	0	0		0	N/A	N/A	N/A
1,1,2-Trichloroethane	0	0		0	0.55	0.55	295
Trichloroethylene	0	0		0	0.6	0.6	321
Vinyl Chloride	0	0		0	0.02	0.02	10.7
2-Chlorophenol	0	0		0	N/A	N/A	N/A
2,4-Dichlorophenol	0	0		0	N/A	N/A	N/A
2,4-Dimethylphenol	0	0		0	N/A	N/A	N/A
4,6-Dinitro-o-Cresol	0	0		0	N/A	N/A	N/A
2,4-Dinitrophenol	0	0		0	N/A	N/A	N/A
2-Nitrophenol	0	0		0	N/A	N/A	N/A
4-Nitrophenol	0	0		0	N/A	N/A	N/A
p-Chloro-m-Cresol	0	0		0	N/A	N/A	N/A

Pentachlorophenol	0	0		0	0.030	0.03	16.1
Phenol	0	0		0	N/A	N/A	N/A
2,4,6-Trichlorophenol	0	0		0	1.5	1.5	804
Acenaphthene	0	0		0	N/A	N/A	N/A
Anthracene	0	0		0	N/A	N/A	N/A
Benzidine	0	0		0	0.0001	0.0001	0.054
Benzo(a)Anthracene	0	0		0	0.001	0.001	0.54
Benzo(a)Pyrene	0	0		0	0.0001	0.0001	0.054
3,4-Benzofluoranthene	0	0		0	0.001	0.001	0.54
Benzo(k)Fluoranthene	0	0		0	0.01	0.01	5.36
Bis(2-Chloroethyl)Ether	0	0		0	0.03	0.03	16.1
Bis(2-Chloroisopropyl)Ether	0	0		0	N/A	N/A	N/A
Bis(2-Ethylhexyl)Phthalate	0	0		0	0.32	0.32	171
4-Bromophenyl Phenyl Ether	0	0		0	N/A	N/A	N/A
Butyl Benzyl Phthalate	0	0		0	N/A	N/A	N/A
2-Chloronaphthalene	0	0		0	N/A	N/A	N/A
Chrysene	0	0		0	0.12	0.12	64.3
Dibenzo(a,h)Anthracene	0	0		0	0.0001	0.0001	0.054
1,2-Dichlorobenzene	0	0		0	N/A	N/A	N/A
1,3-Dichlorobenzene	0	0		0	N/A	N/A	N/A
1,4-Dichlorobenzene	0	0		0	N/A	N/A	N/A
3,3-Dichlorobenzidine	0	0		0	0.05	0.05	26.8
Diethyl Phthalate	0	0		0	N/A	N/A	N/A
Dimethyl Phthalate	0	0		0	N/A	N/A	N/A
Di-n-Butyl Phthalate	0	0		0	N/A	N/A	N/A
2,4-Dinitrotoluene	0	0		0	0.05	0.05	26.8
2,6-Dinitrotoluene	0	0		0	0.05	0.05	26.8
1,2-Diphenylhydrazine	0	0		0	0.03	0.03	16.1
Fluoranthene	0	0		0	N/A	N/A	N/A
Fluorene	0	0		0	N/A	N/A	N/A
Hexachlorobenzene	0	0		0	0.00008	0.00008	0.043
Hexachlorobutadiene	0	0		0	0.01	0.01	5.36
Hexachlorocyclopentadiene	0	0		0	N/A	N/A	N/A
Hexachloroethane	0	0		0	0.1	0.1	53.6
Indeno(1,2,3-cd)Pyrene	0	0		0	0.001	0.001	0.54
Isophorone	0	0		0	N/A	N/A	N/A
Naphthalene	0	0		0	N/A	N/A	N/A
Nitrobenzene	0	0		0	N/A	N/A	N/A
n-Nitrosodimethylamine	0	0		0	0.0007	0.0007	0.37
n-Nitrosodi-n-Propylamine	0	0		0	0.005	0.005	2.68
n-Nitrosodiphenylamine	0	0		0	3.3	3.3	1,768
Phenanthrene	0	0		0	N/A	N/A	N/A
Pyrene	0	0		0	N/A	N/A	N/A
1,2,4-Trichlorobenzene	0	0		0	N/A	N/A	N/A

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Pentachlorophenol	0.15	0.24	16.1	25.1	40.2	µg/L	16.1	CRL	Discharge Conc ≥ 50% WQBEL (RP)
Benzo(a)Anthracene	0.005	0.008	0.54	0.84	1.34	µg/L	0.54	CRL	Discharge Conc ≥ 50% WQBEL (RP)
Benzo(a)Pyrene	0.0005	0.0008	0.054	0.084	0.13	µg/L	0.054	CRL	Discharge Conc ≥ 50% WQBEL (RP)
3,4-Benzofluoranthene	0.005	0.008	0.54	0.84	1.34	µg/L	0.54	CRL	Discharge Conc ≥ 50% WQBEL (RP)
Benzo(k)Fluoranthene	0.05	0.078	5.36	8.36	13.4	µg/L	5.36	CRL	Discharge Conc ≥ 50% WQBEL (RP)
Bis(2-Chloroethyl)Ether	Report	Report	Report	Report	Report	µg/L	16.1	CRL	Discharge Conc > 25% WQBEL (no RP)
Butyl Benzyl Phthalate	0.11	0.18	12.2	19.0	30.4	µg/L	12.2	THH	Discharge Conc ≥ 50% WQBEL (RP)
Dibenzo(a,h)Anthracene	0.0005	0.0008	0.054	0.084	0.13	µg/L	0.054	CRL	Discharge Conc ≥ 50% WQBEL (RP)
3,3-Dichlorobenzidine	Report	Report	Report	Report	Report	µg/L	26.8	CRL	Discharge Conc > 25% WQBEL (no RP)
Hexachlorobenzene	0.0004	0.0006	0.043	0.067	0.11	µg/L	0.043	CRL	Discharge Conc ≥ 50% WQBEL (RP)
Indeno(1,2,3-cd)Pyrene	0.005	0.008	0.54	0.84	1.34	µg/L	0.54	CRL	Discharge Conc ≥ 50% WQBEL (RP)
n-Nitrosodi-n-Propylamine	0.025	0.039	2.68	4.18	6.7	µg/L	2.68	CRL	Discharge Conc ≥ 50% WQBEL (RP)

**Other Pollutants without Limits or Monitoring**

### DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test Chronic  
 Species Tested Ceriodaphnia  
 Endpoint Survival  
 TIWC (decimal) 0.01  
 No. Per Replicate 1  
 TST b value 0.75  
 TST alpha value 0.2

**Facility Name**

Northumberland Borough WWTP

**Permit No.**

PA0020567

**Test Completion Date**

9/23/2019

Replicate No.	Control	TIWC
1	1	1
2	1	1
3	1	1
4	1	1
5	1	1
6	1	1
7	1	1
8	1	1
9	1	1
10	1	1
11		
12		
13		
14		
15		

Mean            1.000        1.000  
 Std Dev.       0.000        0.000  
 # Replicates    10            10

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail PASS

**Test Completion Date**

5/4/2020

Replicate No.	Control	TIWC
1	1	1
2	1	1
3	1	1
4	1	1
5	1	1
6	1	1
7	1	1
8	1	1
9	1	1
10	1	1
11		
12		
13		
14		
15		

Mean            1.000        1.000  
 Std Dev.       0.000        0.000  
 # Replicates    10            10

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail PASS

**Test Completion Date**

1/11/2021

Replicate No.	Control	TIWC
1	1	1
2	1	1
3	1	1
4	1	1
5	1	1
6	1	1
7	1	1
8	1	1
9	1	1
10	1	1
11		
12		
13		
14		
15		

Mean            1.000        1.000  
 Std Dev.       0.000        0.000  
 # Replicates    10            10

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail PASS

**Test Completion Date**

3/28/2022

Replicate No.	Control	TIWC
1	1	1
2	1	1
3	1	1
4	1	1
5	1	1
6	1	1
7	1	1
8	1	1
9	1	1
10	1	1
11		
12		
13		
14		
15		

Mean            1.000        1.000  
 Std Dev.       0.000        0.000  
 # Replicates    10            10

T-Test Result  
 Deg. of Freedom  
 Critical T Value  
 Pass or Fail PASS

### DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test Chronic  
 Species Tested Ceriodaphnia  
 Endpoint Reproduction  
 TIWC (decimal) 0.01  
 No. Per Replicate 1  
 TST b value 0.75  
 TST alpha value 0.2

**Facility Name**

Northumberland Borough WWTP

**Permit No.**

PA0020567

**Test Completion Date**

9/23/2019

Replicate No.	Control	TIWC
1	32	36
2	40	39
3	21	15
4	30	34
5	35	28
6	24	30
7	32	34
8	36	39
9	37	34
10	16	36
11		
12		
13		
14		
15		

Mean 30.300 32.500  
 Std Dev. 7.675 7.059  
 # Replicates 10 10

T-Test Result 3.3937  
 Deg. of Freedom 17  
 Critical T Value 0.8633  
 Pass or Fail PASS

**Test Completion Date**

5/4/2020

Replicate No.	Control	TIWC
1	24	36
2	36	30
3	36	34
4	34	25
5	40	19
6	36	17
7	32	31
8	27	37
9	33	36
10	34	32
11		
12		
13		
14		
15		

Mean 33.200 29.700  
 Std Dev. 4.662 7.119  
 # Replicates 10 10

T-Test Result 1.9138  
 Deg. of Freedom 14  
 Critical T Value 0.8681  
 Pass or Fail PASS

**Test Completion Date**

1/11/2021

Replicate No.	Control	TIWC
1	34	28
2	32	23
3	14	37
4	31	19
5	29	29
6	18	33
7	26	36
8	19	36
9	20	31
10	25	19
11		
12		
13		
14		
15		

Mean 24.800 29.100  
 Std Dev. 6.779 6.822  
 # Replicates 10 10

T-Test Result 3.9024  
 Deg. of Freedom 16  
 Critical T Value 0.8647  
 Pass or Fail PASS

**Test Completion Date**

3/28/2022

Replicate No.	Control	TIWC
1	27	27
2	21	29
3	23	22
4	26	30
5	31	27
6	29	29
7	30	33
8	27	29
9	15	23
10	25	15
11		
12		
13		
14		
15		

Mean 25.400 26.400  
 Std Dev. 4.766 5.147  
 # Replicates 10 10

T-Test Result 3.7093  
 Deg. of Freedom 16  
 Critical T Value 0.8647  
 Pass or Fail PASS

### DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet

Type of Test	Chronic
Species Tested	Pimephales
Endpoint	Survival
TIWC (decimal)	0.01
No. Per Replicate	10
TST b value	0.75
TST alpha value	0.25

Facility Name	Northumberland Borough WWTP
---------------	-----------------------------

Permit No.	PA0020567
------------	-----------

Test Completion Date		
9/24/2019		
Replicate No.	Control	TIWC
1	10	10
2	10	9
3	10	10
4	10	10
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Test Completion Date		
5/5/2020		
Replicate No.	Control	TIWC
1	9	9
2	10	10
3	10	10
4	9	9
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean	10.000	9.750
Std Dev.	0.000	0.500
# Replicates	4	4

Mean	9.500	9.500
Std Dev.	0.577	0.577
# Replicates	4	4

T-Test Result	7.6643
Deg. of Freedom	3
Critical T Value	0.7649
Pass or Fail	<b>PASS</b>

T-Test Result	5.6564
Deg. of Freedom	5
Critical T Value	0.7267
Pass or Fail	<b>PASS</b>

Test Completion Date		
1/12/2021		
Replicate No.	Control	TIWC
1	10	10
2	10	10
3	10	10
4	10	10
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Test Completion Date		
3/29/2022		
Replicate No.	Control	TIWC
1	8	10
2	6	9
3	9	9
4	9	6
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean	10.000	10.000
Std Dev.	0.000	0.000
# Replicates	4	4

Mean	8.000	8.500
Std Dev.	1.414	1.732
# Replicates	4	4

T-Test Result	2.7794
Deg. of Freedom	5
Critical T Value	0.7267
Pass or Fail	<b>PASS</b>

T-Test Result	2.7794
Deg. of Freedom	5
Critical T Value	0.7267
Pass or Fail	<b>PASS</b>

**DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet**

Type of Test	Chronic
Species Tested	Pimephales
Endpoint	Growth
TIWC (decimal)	0.01
No. Per Replicate	4
TST b value	0.75
TST alpha value	0.25

<b>Facility Name</b>
Northumberland Borough WWTP

<b>Permit No.</b>
PA0020567

Test Completion Date		
9/24/2019		
Replicate No.	Control	TIWC
1	0.716	0.538
2	0.68	0.584
3	0.487	0.692
4	0.496	0.66
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Test Completion Date		
5/5/2020		
Replicate No.	Control	TIWC
1	0.643	0.578
2	0.49	0.67
3	0.558	0.633
4	0.494	0.528
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean	0.595	0.619
Std Dev.	0.120	0.070
# Replicates	4	4

Mean	0.546	0.602
Std Dev.	0.072	0.062
# Replicates	4	4

T-Test Result	3.0182
Deg. of Freedom	5
Critical T Value	0.7267
Pass or Fail	<b>PASS</b>

T-Test Result	4.6824
Deg. of Freedom	5
Critical T Value	0.7267
Pass or Fail	<b>PASS</b>

Test Completion Date		
1/12/2021		
Replicate No.	Control	TIWC
1	0.36	0.374
2	0.343	0.315
3	0.325	0.324
4	0.286	0.285
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Test Completion Date		
3/29/2022		
Replicate No.	Control	TIWC
1	0.443	0.507
2	0.305	0.472
3	0.503	0.487
4	0.558	0.439
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		

Mean	0.329	0.325
Std Dev.	0.032	0.037
# Replicates	4	4

Mean	0.452	0.476
Std Dev.	0.109	0.029
# Replicates	4	4

T-Test Result	3.5535
Deg. of Freedom	5
Critical T Value	0.7267
Pass or Fail	<b>PASS</b>

T-Test Result	3.1688
Deg. of Freedom	5
Critical T Value	0.7267
Pass or Fail	<b>PASS</b>

## WET Summary and Evaluation

<b>Facility Name</b>	Northumberland Borough WWTP
<b>Permit No.</b>	PA0020567
<b>Design Flow (MGD)</b>	1.125
<b>Q<sub>7-10</sub> Flow (cfs)</b>	1116
<b>PMF<sub>a</sub></b>	0.027
<b>PMF<sub>c</sub></b>	0.187

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Survival	9/23/19	5/4/20	1/11/21	3/28/22
		PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Reproduction	9/23/19	5/4/20	1/11/21	3/28/22
		PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Survival	9/24/19	5/5/20	1/12/21	3/29/22
		PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Growth	9/24/19	5/5/20	1/12/21	3/29/22
		PASS	PASS	PASS	PASS

**Reasonable Potential?** NO

**Permit Recommendations**

Test Type                    **Chronic**  
 TIWC                         **1**        % Effluent  
 Dilution Series           **1, 2, 30, 60, 100** % Effluent  
 Permit Limit                **None**  
 Permit Limit Species