

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0020745
APS ID 582466
Authorization ID 1380141

Applicant and Facility Information

Applicant Name	<u>Nescopeck Borough</u>	Facility Name	<u>Nescopeck WWTP</u>
Applicant Address	<u>501 Raber Avenue</u> <u>Nescopeck, PA 18635-1101</u>	Facility Address	<u>45 Mifflin Road</u> <u>Nescopeck, PA 18635-1101</u>
Applicant Contact	<u>Sheri Custer</u>	Facility Contact	<u>George Myers</u>
Applicant Phone	<u>(570) 752-6008</u>	Facility Phone	<u>(570) 458-5710</u>
Client ID	<u>44150</u>	Site ID	<u>443229</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Nescopeck Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Luzerne</u>
Date Application Received	<u>December 21, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 21, 2022</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES sewage permit.</u>		

Summary of Review

The applicant is requesting renewal of an NPDES permit to discharge 0.25 MGD of treated sewage to Nescopeck Creek, a TSF/MF designated receiving stream in state water plan basin 05-D (Nescopeck Creek). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use.

Low-flow data from USGS StreamStats was used to model the discharge, resulting in a Q₇₋₁₀ flow of 29.9 cfs and calculated low flow yield (LFY) of 0.17 cfs/mi². For modeling inputs, RMI values were obtained using the "PA Historic Streams" feature of eMapPA as well as the "measure" tool. Drainage areas were delineated using USGS's StreamStats and elevations were obtained using the elevation profile feature of StreamStats (all results attached). Partial mixing factors were obtained from the Toxics Management Spreadsheet. The default stream hardness and pH values used for modeling are consistent with data from WQN station 309, which is approximately ¼ mile-upstream of Outfall 001. The application indicates no industrial or commercial users discharge to the system, therefore, sampling results for Total Copper, Total Lead and Total Zinc were not required to be included with the permit application. The Toxics Management Spreadsheet, TRC Spreadsheet, and WQM 7.0 did not recommend new or more stringent limitations for any parameter.

The pH, CBOD₅, TSS, TRC and Fecal Coliform limits are technology-based limits carried over from the previous permit. TRC only needs to be sampled for when the permittee is using chlorine for backup disinfection, cleaning, or other purposes (see Part C.II.D). Monitoring/reporting requirements for Total Phosphorus and Total Nitrogen (TKN + NO₂+NO₃-N) are carried over from the previous permit and are in accordance with DEP's Phase 3 Watershed Implementation Plan Wastewater Supplement (Revised, September 13, 2021). Monitoring/reporting requirements for Ammonia-Nitrogen, Dissolved Oxygen, influent BOD₅, and influent TSS are carried over from the previous permit. Annual monitoring/reporting for Total Aluminum, Total Iron, and Total Manganese are carried over from the previous permit as they're parameters of concern in the Black Creek, Little Nescopeck Creek and Unnamed Tributary to Little Nescopeck Creek Watershed TMDL for acid mine drainage. As per current DEP guidance, 1/quarter E. Coli monitoring/reporting is added to the permit.

Approve	Deny	Signatures	Date
X		<i>Brian Burden</i> Brian Burden, E.I.T. / Project Manager	August 4, 2022
X		Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager	8-22-22

Summary of Review

The 2021 Chapter 94 report shows no projected hydraulic/organic overloads at the WWTP. Two years of eDMR results revealed no effluent limitation exceedances. There are no open WPC NPDES violations for the client that would warrant withholding the issuance of the final permit. EPA waiver is in effect.

The previous permit renewal draft fact sheet states: "Available Organic Capacity (595 lbs BOD5/day) in E-facts and Chapter 94 Report assumption appears inaccurate. The WQM Application indicated a design based on 255 mg/l BOD5 influent and 25 mg/l BOD5 effluent (i.e. 230 mg/l reduction at a 0.25 MGD design basis flow). At 255 mg/l BOD5 design basis loading, this facility is limited to 531.67 lbs BOD5/day. The Applicant consultant indicated the Borough could not substantiate the 595 lbs BOD5/day figure, but might arrange a file review to investigate further. The more stringent figure will be used in the Draft NPDES Permit, with the Borough having the opportunity to provide public comment." This draft permit will continue the assumption of design BOD₅ as 531 lbs/day and the Borough may provide public comment on that figure during this draft permit comment period.

Sludge use and disposal description and location(s): The application indicates 6.206 dry tons of sludge/biosolids were hauled by Beaver Valley Environmental to the Greater Hazleton Joint Sewer Authority WWTP in the previous year.

The previously issued permit expires on August 31, 2022 and the application for renewal was submitted in a timely manner.



WQM
Modeling.pdf



TRC Calculation.pdf
TMS PA0020745.pdf



StreamStats
Outfall
001.pdf



StreamStats
Susquehanna.pdf



WQN309.pdf



Chapter 94.pdf

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.25</u>
Latitude	<u>41° 2' 54.6"</u>	Longitude	<u>-76° 13' 29.9"</u>
Quad Name	<u>Berwick</u>	Quad Code	<u>1036</u>
Wastewater Description: <u>Sewage Effluent</u>			

Receiving Waters	<u>Nescopeck Creek (TSF, MF)</u>	Stream Code	<u>28102</u>
NHD Com ID	<u>65639413</u>	RMI	<u>0.7</u>
Drainage Area	<u>175 mi²</u>	Yield (cfs/mi ²)	<u>0.17</u>
Q ₇₋₁₀ Flow (cfs)	<u>29.9</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u>481</u>	Slope (ft/ft)	<u>0.0032</u>
Watershed No.	<u>5-D</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>

Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Metals, pH</u>		
Source(s) of Impairment	<u>Acid Mine Drainage</u>		
TMDL Status	<u>Final</u>	Name	<u>Little Nescopeck Creek</u>

Background/Ambient Data		Data Source	
pH (SU)	<u>-</u>	See WQN station 309 results attached	
Temperature (°F)	<u>-</u>	"	
Hardness (mg/L)	<u>-</u>	"	
Other:	<u>-</u>	"	

Nearest Downstream Public Water Supply Intake	<u>Danville Municipal Water Authority</u>		
PWS Waters	<u>Susquehanna River</u>	Flow at Intake (cfs)	<u>1123</u>
PWS RMI	<u>122.5</u>	Distance from Outfall (mi)	<u>~23.5</u>

Treatment Facility Summary				
Treatment Facility Name: Nescopeck WWTP				
WQM Permit No.		Issuance Date		
4000401		8/30/2000		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Ultraviolet	0.25
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.25	531	Not Overloaded	Aerobic Digestion	Landfill

Development of Effluent Limitations

Outfall No. 001
 Latitude 41° 2' 54.6"
 Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.25
 Longitude -76° 13' 29.9"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25.0	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40.0	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
	50.0	IMAX	-	-
Total Suspended Solids	30.0	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45.0	Average Weekly	133.102(b)(2)	92a.47(a)(2)
	60.0	IMAX	-	-
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
	1.17	IMAX	-	-