

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0020818
APS ID 755
Authorization ID 1316406

Applicant and Facility Information

Applicant Name	<u>Glen Rock Borough Sewer Authority York County</u>	Facility Name	<u>Glen Rock STP</u>
Applicant Address	<u>PO Box 205 Glen Rock, PA 17327-0205</u>	Facility Address	<u>11714 N Main Street Ext Glen Rock, PA 17327-9424</u>
Applicant Contact	<u>Dale Getz</u>	Facility Contact	<u>Dale Getz</u>
Applicant Phone	<u>(717) 235-2082</u>	Facility Phone	<u>(717) 235-2082</u>
Client ID	<u>87472</u>	Site ID	<u>447424</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Glen Rock Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>York</u>
Date Application Received	<u>May 5, 2020</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>July 10, 2020</u>	If No, Reason	<u>Significant CB Discharge</u>
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

C.S. Davidson, Inc., on behalf of the Glen Rock Sewer Authority, has applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. This is a new NPDES permit for the existing facility located at 11714 North Main Extension, Glen Rock, PA. The permit was reissued on October 21, 2015 and became effective on November 1, 2015. The permit expired on October 31, 2020 but the terms and conditions of the permit have been extended since that time.

This facility receives 82% of its flow from Glen Rock Borough and 18% from Shrewsbury Township. There are no industrial contributors. The facility has average annual design flow 0.6 MGD and hydraulic design capacity of 0.74 MGD.

The WQM Permit No. 6798405 was issued on May 26, 1998.

Sludge use and disposal description and location(s): N/A due to the sludge is hauled to Krone farms.

Changes from the previous permit: Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml. The E. Coli. monitoring and report requirements will add to the proposed permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	July 30, 2021
X		<i>Maria D. Bebenek for Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	August 9, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.6
Latitude	39° 47' 56.88"	Longitude	-76° 44' 13.18"
Quad Name	Glen Rock	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	South Branch Codorus Creek (WWF)	Stream Code	08093
NHD Com ID	57474123	RMI	16.25
Drainage Area	16.3 mi. ²	Yield (cfs/mi ²)	0.15
Q ₇₋₁₀ Flow (cfs)	2.51	Q ₇₋₁₀ Basis	USGSStreamStats
Elevation (ft)	530.38	Slope (ft/ft)	
Watershed No.	7-H	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	NUTRIENTS, TOTAL SUSPENDED SOLIDS (TSS)		
Source(s) of Impairment	AGRICULTURE		
TMDL Status	Final, 8/09/2003	Name	South Branch Codorus Creek
Nearest Downstream Public Water Supply Intake	York Water Company		
PWS Waters	South Branch Codorus Creek	Flow at Intake (cfs)	
PWS RMI	0.75	Distance from Outfall (mi)	Approximate 16 mile

Changes Since Last Permit Issuance: none

Drainage Area

The discharges are to South Branch Codorus Creek at RMI 16.25 miles. A drainage area upstream of the discharge is estimated to be 16.3 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the discharge point in the receiving stream has a Q₇₋₁₀ of 2.51 cfs and a drainage area of 16.3 mi², which results in a Q₇₋₁₀ low flow yield of 0.15 cfs/mi². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 2.51 \text{ cfs} \\
 \text{Low Flow Yield} &= 2.51 \text{ cfs} / 16.3 \text{ mi}^2 = 0.15 \text{ cfs/mi}^2 \\
 Q_{30-10} &= 1.36 * 2.51 \text{ cfs} = 3.41 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 2.51 \text{ cfs} = 1.61 \text{ cfs}
 \end{aligned}$$

The resulting Q₇₋₁₀ dilution ratio is: $Q_{\text{stream}} / Q_{\text{discharge}} = 2.51 \text{ cfs} / [0.6 \text{ MGD} * (1.55 \text{ cfs/MGD})] = 2.7:1$.

South Branch Codorus Creek

25 Pa. Code § 93.9f classifies South Branch Codorus Creek as Warm Water and Migratory Fishes (WWF & MF) surface water. Based on the 2020 Integrated Report, South Branch Codorus Creek, assessment unit ID 8, is impaired due to agriculture-nutrients/total suspended solids. The TMDL document was prepared on July 9, 2003 to address use impairments caused by siltation and nutrients. The document was approved by EPA on August 9, 2003. This TMDL currently contains the wasteload allocations (WLAs) for the Glen Rock STP which will be discussed later in this factsheet.

Public Water Supply

The nearest downstream public water supply intake is the York Water Co. on South Branch Codorus Creek in York County, approximately 16 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Glen Rock STP				
WQM Permit No.		Issuance Date		
6798405		5/26/1998		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge	Ultraviolet	0.6
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.74	2233	Not Overloaded	Aerobic Digestion	Combination of methods

Changes Since Last Permit Issuance: none

The WWTP train is as follows:

Fine screen → Mixing chamber → Anaerobic zones (2) → Anoxic zones (4) → Aeration zones (4) → Re-Aeration zones (2) → Diversion box → Clarifiers (2) → UV Disinfection units (2) → Sludge digesters (2) → Discharge.

The system incorporates the chemical addition of ferric chloride (for Phosphorus removal).

Compliance History	
Summary of DMRs:	The DMRs reported from June 1, 2020 to May 31, 2021 are summarized in the Table below (Pages # 5, 6, & 7).
Summary of Inspections:	<p>05/12/2021: Heather Dock, DEP Water Quality Specialist, conducted an administrative review of Glen Rock STP's Chesapeake Bay nutrient data. There were no violations noted during inspection. The recommendations were to complete all sections of the Chesapeake Bay supplemental form at the top with as much information as is available to determine compliance, to revise compliance year 2021 DMRs to include nitrite non-detect sample results within 30 days of receipt of the report and include non-detect- sample results in future in future reports. The effluent was clear.</p> <p>08/26/2019: Austen Randecker, DEP WQS, conducted a compliance evaluation inspection. There were no violations noted during inspection. The recommendations were to set up effluent composite sampler to be flow proportional, maintain a daily operations log and repair/maintenance log, remove vegetation/debris from surface of aeration and anoxic tanks, and update DEP 24 hours Emergency response number. The field test results were within permit limits.</p> <p>5/11/2017: Sheena Ripple, DEP WQS, conducted a compliance evaluation inspection. There were no violations noted during inspection. The field test results were within permit limits.</p>
Other Comments:	There are currently no open violations associated to the permittee or the facility.

Other Comments:

The table below summarizes the influent/effluent testing results submitted along with the application.

<i>Influent Testing Results</i>			<i>Effluent Testing Results</i>		
Parameter	Min/Max Value	Average Value	Parameter	Min/Max Value	Average Value
BOD ₅ (mg/L)	297 mg/L	202 mg/L	pH (minimum)	6.1 S.U.	
BOD ₅ (lbs/day)	3037 lbs/day	793 lbs/day	pH (maximum)	7.8 S.U.	
TSS (mg/L)	545 mg/L	297 mg/L	D.O (minimum)	5.9 mg/L	7.69 mg/L
TSS (lbs/day)	1103 lbs/day	6126 lbs/day	TRC	NA mg/L	NA mg/L
TN (mg/L)	17.62 mg/L	mg/L	Fecal Coliform	241 No./100mL	16.1 No./100mL
TN (lbs/day)	57.01 lbs/day	lbs/day	CBOD ₅	3.4 mg/L	16.1 mg/L
TP (mg/L)	2.7 mg/L	mg/L	TSS	5.3 mg/L	3.1 mg/L
TP (lbs/day)	8.74 lbs/day	lbs/day	NH ₃ -N	0.6 mg/L	0.12 mg/L
NH ₃ -N (mg/L)	14 mg/L	mg/L	TN	10.8 mg/L	6.52 mg/L
NH ₃ -N (lbs/day)	45.3 lbs/day	lbs/day	TP	1.2 mg/L	0.44 mg/L
TDS (mg/L)	344 mg/L	mg/L	Temp	80.0 F	56.0 F
TDS (lbs/day)	1113 lbs/day	lbs/day	TKN	0.5 mg/L	mg/L
TKN	mg/L	mg/L	NO ₂ -N + NO ₃ -N	6.4 mg/L	mg/L
NO ₂ -N + NO ₃ -N	mg/L	mg/L	TDS	344 mg/L	mg/L
			Chloride	96 mg/L	mg/L
			Bromide	0.5 mg/L	mg/L
			Sulfate	21 mg/L	mg/L
			Oil and Grease	5.0 mg/L	mg/L
			Total Copper	<0.005 mg/L	mg/L
			Total Lead	< 0.001 mg/L	mg/L
			Total Zinc	0.013 mg/L	mg/L

Compliance History

DMR Data for Outfall 001 (from June 1, 2020 to May 31, 2021)

Parameter	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20
Flow (MGD) Average Monthly	0.383	0.405	0.466	0.398	0.402	0.423	0.355	0.356	0.357	0.391	0.373	0.403
Flow (MGD) Daily Maximum	0.468	0.485	0.698	0.493	0.501	0.932	0.439	0.458	0.548	0.683	0.482	0.493
pH (S.U.) Minimum	6.6	6.3	6.3	6.8	6.7	6.7	6.8	6.7	6.4	6.5	6.8	6.7
pH (S.U.) Maximum	7.0	7.0	7.3	7.0	7.0	7.3	7.2	7.2	7.4	7.2	7.1	7.1
DO (mg/L) Minimum	7.4	8.1	8.7	9.4	9.5	8.2	8.3	6.9	7.0	6.8	6.7	7.0
CBOD5 (lbs/day) Average Monthly	1.0	8.1	9.4	9.1	9.6	9.4	8.9	8.5	8.6	11.5	9.3	10.1
CBOD5 (lbs/day) Weekly Average	8.0	8.5	10.7	10.3	10.6	10.8	10.6	8.7	9.4	17.8	11.1	10.8
CBOD5 (mg/L) Average Monthly	2.4	< 2.4	2.5	2.8	3.0	3.0	3.0	3.0	3.0	3.8	3.0	3.0
CBOD5 (mg/L) Weekly Average	2.4	< 2.4	2.6	3.0	3.0	3.0	3.0	3.0	3.0	6.0	3.0	3.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	56.3	603.9	981.9	590.6	569.4	817.7	708.8	941.4	614.2	465	280.6	367.9
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	681.8	1003.1	1603.3	919.4	915.1	1248.1	804.6	1844.0	1536.6	882.3	476.4	487.5
BOD5 (mg/L) Raw Sewage Influent Average Monthly	140	177	247	180	175	267	242	332	218	152	94	109
TSS (lbs/day) Average Monthly	1.0	9.4	11.5	6.5	8.6	13.6	10.7	11.4	9.3	13.9	12.1	15.8
TSS (lbs/day) Raw Sewage Influent Average Monthly	77.5	762.6	1405.5	612.5	650.6	1067.5	917.8	922.2	742.4	753.1	435.3	438.6
TSS (lbs/day) Raw Sewage Influent Daily Maximum	1019.6	1288.1	3135.3	926.5	1407.8	2204	1285.2	1735.4	1855.1	1444.8	694.8	520
TSS (lbs/day) Weekly Average	10.0	10.6	19.8	7.1	14.9	23.0	17.7	17.0	14.0	31.9	22.3	32.2
TSS (mg/L) Average Monthly	2.5	2.8	3.0	2.0	2.8	4.4	3.5	4.0	3.3	4.3	3.8	4.8

**NPDES Permit Fact Sheet
Glen Rock STP**

NPDES Permit No. PA0020818

TSS (mg/L) Raw Sewage Influent Average Monthly	193.0	224.4	342.5	186.5	196.0	353.6	315	324.8	262.0	247.0	140.0	130.5
TSS (mg/L) Weekly Average	3.0	3.0	5.0	2.0	5.0	8.0	5.0	6.0	5.0	9.0	6.0	10.0
Fecal Coliform (CFU/100 ml) Geometric Mean	2	1	4	2	1	1	1	1	1	2	1	1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	4	1	21	37	1	3	1	1	4	5	1	1
UV Intensity (mW/cm ²) Minimum	2.70	6.8	7.10	7.5	9.6	7.0	3.6	3.4	2.70	2.00	3.10	6.00
Nitrate-Nitrite (mg/L) Average Monthly	1.04	2.13	4.98	4.48	3.61	3.31	2.18	2.73	3.48	4.11	0.95	1.00
Nitrate-Nitrite (lbs) Total Monthly	101.7	212.7	627.9	436.0	368.6	343.6	198.4	244.3	322.5	397.5	91.2	102.0
Total Nitrogen (mg/L) Average Monthly	2.41	2.72	5.49	4.99	4.11	3.86	2.73	3.46	4.30	5.54	2.14	1.89
Total Nitrogen (lbs) Effluent Net Total Monthly	234.5	271.2	689.8	486.7	419.5	399.2	249.3	309.2	385.5	537.0	204.2	186.7
Total Nitrogen (lbs) Total Monthly	234.5	271.2	689.8	486.7	419.5	399.2	249.3	309.2	398.5	537.0	204.2	192.5
Total Nitrogen (lbs) Effluent Net Total Annual									10283			
Total Nitrogen (lbs) Total Annual									6222			
Ammonia (lbs/day) Average Monthly	0.3	0.5	1.4	0.3	0.4	0.3	0.5	0.4	0.6	2.1	0.9	0.8
Ammonia (mg/L) Average Monthly	0.4	0.2	0.4	0.1	0.1	0.1	0.2	0.1	0.2	0.7	0.3	0.2
Ammonia (lbs) Total Monthly	36.9	15.9	44.3	10.8	12.5	10.7	16.1	12.9	17.1	66.5	28.2	24.3
Ammonia (lbs) Total Annual									244			
TKN (mg/L) Average Monthly	1.37	0.59	0.51	0.52	0.50	0.55	0.56	0.73	0.82	1.43	1.18	0.89
TKN (lbs) Total Monthly	132.8	58.5	61.9	50.7	50.9	55.6	50.9	64.9	76.0	139.5	113.0	90.5
Total Phosphorus (lbs/day) Average Monthly	0.17	0.60	0.51	0.60	0.39	0.46	0.67	1.92	3.57	3.93	2.54	1.56

NPDES Permit Fact Sheet

NPDES Permit No. PA0020818

Glen Rock STP

Total Phosphorus (mg/L) Average Monthly	0.2	0.2	0.1	0.2	0.1	0.1	0.2	0.7	1.2	1.2	0.8	0.5
Total Phosphorus (lbs) Effluent Net Total Monthly	20.01	18.0	15.67	18.54	12.09	14.26	20.91	59.65	107.1	121.69	78.86	46.89
Total Phosphorus (lbs) Effluent Net Total Monthly	20.01	18.0	15.67	18.4	12.09	14.26	20.91	59.65	110.63	121.69	78.86	48.35
Total Phosphorus (lbs) Effluent Net Total Annual									803			
Total Phosphorus (lbs) Total Annual									611			

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.6</u>
Latitude <u>39° 47' 57.05"</u>	Longitude <u>-76° 44' 13.09"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

- Discharge pH 7.0 (Default per 391-2000-007)
- Discharge Temperature 20°C (Default per 391-2000-007)
- Stream pH 7.0 (Default per 391-2000-006)
- Stream Temperature 25°C (Default per 391-2000-003)
- Background NH₃-N 0 mg/L (Assumed)

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 8.06 mg/L as a monthly average and 16.12 mg/L IMAX are necessary to protect the aquatic life from toxicity effects at the point of discharge. However, the existing limits of 8.0 mg/L monthly average & 16.0 mg/L IMAX will remain in the proposed permit. The winter effluent limit will be set at three-times the summer limits. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Summer average monthly mass limit: 8.0 mg/L x 0.6 MGD x 8.34 = 40.0 lbs/day
 Winter average monthly mass limit: 24.0 mg/L x 0.6 MGD x 8.34 = 120.0 lbs/day

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. The existing limits of 25.0 mg/L average monthly, 40.0 mg/L weekly average, and 50.0 mg/L instantaneous maximum will remain in the proposed permit. The facility has consistently achieved CBOD₅ levels well below these limits. Mass limits are calculated as follows:

Average monthly mass limit: 25.0 mg/L x 0.6 MGD x 8.34 = 125.1 (125.0) lbs/day
 Average weekly mass limit: 40.0 mg/L x 0.6 MGD x 8.34 = 200.16 (200.0) lbs/day

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa Code § 95.2(1).

Total Suspended Solids (TSS):

The existing limits of 30.0 mg/L average monthly, 45.0 mg/L average weekly, and 60.0 mg/L instantaneous maximum will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving concentrations well below these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 30.0 \text{ mg/L} \times 0.6 \text{ MGD} \times 8.34 = 150.1 \text{ (150.0) lbs/day} \\ \text{Average weekly mass limit: } & 45.0 \text{ mg/L} \times 0.5=6 \text{ MGD} \times 8.34 = 225.18 \text{ (225.0) lbs/day} \end{aligned}$$

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP’s current Standard Operating Procedure (SOP) No. BPNPSM-PMT-033 and has been applied to other point source dischargers throughout the state.

Fecal Coliform:

The recent coliform guidance in 25 PA code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

E. Coli:

As recommended by DEP’s SOP No. BPNPSM-PMT-033, routine monitoring for E. Coli will be included in the proposed permit under 25 Pa Code §92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/week will be included in the permit to be consistent with the recommendation from this SOP.

UV:

The UV system monitor and report the UV intensity (mW/cm²) after update to replace chlorine disinfection to UV disinfection system will remain in the proposed permit.

Toxics:

DEP utilizes a Toxics Management Spreadsheet (last modified on March 2021 ver. 1.3) to facilitate calculations necessary for completing a reasonable potential analysis and determining WQBELs for toxic pollutants. The worksheet output indicates that there are no toxic pollutants of concern. Additionally, there is no industrial or commercial user contributing industrial wastewater to the sewer system and no known environmental concern associated with any toxic pollutants within this watershed. Therefore, there are no monitoring & reporting requirements necessary.

Total Maximum Daily Load (TMDL):

The TMDL South Branch Codorus Creek Watershed York County was prepared by DEP on July 9, 2003 to address use impairments caused by siltation and nutrients (mainly total phosphorus) as a result of agricultural activities. While this TMDL was mainly focused on loadings for nonpoint sources, the TMDL still considers the following wasteload allocation for the Glen Rock STP which is summarized in the table below.

Table of the South Branch Codorus Creek TMDL		
	Phosphorus Load (lbs/yr)	
	Existing (Calculated from December 1999 thru June 1999 DMRs; Used in AVGWLF)	TMDL WLA (Used in EMPR Scenario)
Subbasin 1 Glen Rock PA0020818	1,754.00	3,650.00

The Total Phosphorus WLA of 3,650 lbs/yr was not included in the existing NPDES permit because the calculated Total Phosphorus “cap load” associated with the Chesapeake Bay TMDL was more stringent than the WLA associated with the South Branch Codorus Creek TMDL. This is a reasonable approach and should remain unchanged for this permit renewal.

Based on this information, the following condition will be included in Part C.I.C.2 of the draft permit: *“Glen Rock Sewer Authority is included on the South Branch Codorus Creek TMDL, which has a load allocation of 3,650 lbs/year for the facility. As indicated in Part A.I.B., the Chesapeake Bay Watershed Implementation Plan is requiring a more stringent Cap Load of 1,461 lbs/year. Therefore, Credits may be purchased for any phosphorus loading that is in excess of the Bay Cap Load – but only up to the TMDL annual load of 3,650 lbs/year, which is not to be exceeded (i.e., credits may only be purchased for up to 2,189 lbs/year of phosphorus loading).”*

It is noteworthy that credits purchased under the Bay TMDL should not be applied to the South Branch Codorus Creek TMDL.

Chesapeake Bay Strategy:

In the Phase 2 WIP Wastewater Supplement revised on December 17, 2019, Table 5 - Significant Chesapeake Bay Sewage NPDES Permits (pages # 6-14) of this document shows that Glen Rock Sewer Authority has been allocated 10,959 lbs/year of TN and 1,461 lbs/year of TP. This approach, consistent with the Chesapeake Bay TMDL, was based on the actual performance data previously evaluated by the Department. Since the permittee is easily capable of achieving compliance with these loads, the Department determines that no "compliance schedule" for the requirements associated with the Chesapeake Bay Strategy is necessary. Accordingly, the Chesapeake Bay nutrient (i.e., Ammonia-N, Kjeldahl-N, Nitrate-Nitrite as N, and Total Phosphorus) existing limitations and monitoring frequency (2/week) requirements will remain in the proposed permit.

Total Phosphorus:

Previous permit had average monthly concentration monitoring requirement 2.0 mg/L and instantaneous maximum limit of 4.0 mg/L with a minimum monitoring frequency of 2/week. Accordingly, existing TP limits will remain in the proposed permit. See the EPA guidance, Nutrient Criteria Technical Guidance Manual – Rivers and Streams, 07/2000 EPA-822-B-00-002, for more information about nutrient impacts on streams. Mass limits are calculated as follows:

$$\text{Average monthly mass limit: } 2.0 \text{ mg/L} \times 0.6 \text{ MGD} \times 8.34 = 10.0 \text{ lbs/day}$$

Influent Monitoring:

As a result of negotiation with EPA, influent monitoring of TSS and BOD₅ are required for any POTWs; therefore, existing influent monitoring requirements will remain in the proposed permit. The sample type and monitoring frequency also remain unchanged in the draft permit.

Total Dissolved Solids (TDS):

Total Dissolved Solids and its major constituents including Bromide, Chloride, and Sulfate have become statewide pollutants of concern and threats to DEP's mission to prevent violations of water quality standards. The requirement to monitor these pollutants is necessary under the following DEP Central Office directive:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

- *Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.*
- *Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.*

The facility has no record of monitoring these pollutants. However, the application shows a maximum influent concentration of 344 mg/L for TDS. The effluent concentration is not expected to exceed 1,000 mg/L. No monitoring is necessary.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

303(d) Listed Streams:

The discharge is located on a stream segment that is designated on the 303(d) list as impaired. There is a recreational impairment for agriculture-nutrients/total suspended solids. The permit includes a limit for fecal coliform at outfall 001.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding Requirement:


All permit requirements proposed in this fact sheet are at least as stringent as the existing requirements per 40 CFR § 122.44(l)(1).

NPDES Permit Fact Sheet
Glen Rock STP
WQM 7.0:

NPDES Permit No. PA0020818

Node 1: Outfall 001 on South Branch Codorus Creek (08093)
Elevation: 530.38 ft (USGS National Map Viewer)
Drainage Area: 16.3 mi² (USGS PA StreamStats)
River Mile Index: 16.25 (PA DEP eMapPA)
Low Flow Yield: 0.15 cfs/mi²
Discharge Flow: 0.6 MGD (NPDES Application)

Node 2: Just before confluence with UNT 08179
Elevation: 528.85 ft (USGS National Map Viewer)
Drainage Area: 18.1 mi² (USGS PA StreamStats)
River Mile Index: 16.03 (PA DEP eMapPA)
Low Flow Yield: 0.15 cfs/mi²
Discharge Flow: 0.000 MGD



USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Continue

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	16.3	square miles
BSLOPD	Mean basin slope measured in degrees	6.3115	degrees
ROCKDEP	Depth to rock	4.6	feet
URBAN	Percentage of basin with urban development	6.777	percent

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	16.3	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.3115	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.6	feet	4.13	5.21
URBAN	Percent Urban	6.777	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	4.74	ft ³ /s	46	46
30 Day 2 Year Low Flow	5.81	ft ³ /s	38	38
7 Day 10 Year Low Flow	2.51	ft ³ /s	51	51
30 Day 10 Year Low Flow	3.14	ft ³ /s	46	46
90 Day 10 Year Low Flow	4.23	ft ³ /s	41	41

Low-Flow Statistics Citations

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Continue

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	18.1	square miles
BSLOPD	Mean basin slope measured in degrees	6.3605	degrees
ROCKDEP	Depth to rock	4.5	feet
URBAN	Percentage of basin with urban development	6.215	percent

Low-Flow Statistics Parameters [Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	18.1	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.3605	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.5	feet	4.13	5.21
URBAN	Percent Urban	6.215	percent	0	89

Low-Flow Statistics Flow Report [Low Flow Region 1]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	4.79	ft ³ /s	46	46
30 Day 2 Year Low Flow	5.94	ft ³ /s	38	38
7 Day 10 Year Low Flow	2.5	ft ³ /s	51	51
30 Day 10 Year Low Flow	3.17	ft ³ /s	46	46
90 Day 10 Year Low Flow	4.31	ft ³ /s	41	41

Low-Flow Statistics Citations

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Analysis Results WQM 7.0

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | Effluent Limitations

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
16.25	Glen Rock STP	PA0020818	0.6000

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	8.06	16.12	
Dissolved Oxygen			5

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

rptEffLimits

WQM 7.0 Effluent Limits

STP Basin	Stream Code	Stream Name					
07H	8003	SOUTH BRANCH CODOURUS CREEK					
R/W	Name	Permit Number	Disc. Flow (mgd)	Parameter	5D% Limit (mg/L)	5D% Limit Maximum (mg/L)	5D% Limit Minimum (mg/L)
16.250	Glen Rock STP	PA0020818	0.630	CSOD5	25		
				NH4-N	8.06	16.12	
				Dissolved Oxygen			5

Tuesday, July 27, 2021 Version 1.1 Page 1 of 1

Page: 1 | No Filter

rpt_WLA

WQM 7.0 Wasteload Allocations

STP Basin	Stream Code	Stream Name							
07H	8003	SOUTH BRANCH CODOURUS CREEK							
NH3-N Acute Allocations									
R/W	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
16.250	Glen/Rock STP	1.436	35.35	14.36	35.36	0	0		
NH3-N Chronic Allocations									
R/W	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
16.250	Glen/Rock STP	1.76	8.06	1.76	8.06	0	0		
Dissolved Oxygen Allocations									
R/W	Discharge Name	CSOD5 Baseline (mg/L)	Multiple (mg/L)	NH4-N Baseline (mg/L)	Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Multiple (mg/L)	Critical Reach	Percent Reduction
16.25	Glen/Rock STP	25	25	8.06	8.06	5	5	0	0

Tuesday, July 27, 2021 Version 1.1 Page 1 of 1

Page: 1 | No Filter

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name		
07H	8923	SOUTH BRANCH CODOHUS CREEK		
HM	Total Discharge Flow (mgd)	Analyte Temperature (°C)	Analyte pH	
16.250	0.600	21.376	7.000	
Reach Width (ft)	Reach Depth (ft)	Reach WQV Ratio	Reach Velocity (ft/s)	
0.42	40.100	0.003	0.478	
Reach CSOQS (mg/L)	Reach K ₁ (1/day)	Reach NP3-N (mg/L)	Reach K ₂ (1/day)	
8.33	1.294	2.22	0.778	
Reach DO (mg/L)	Reach K ₃ (1/day)	K ₄ Equiv Ratio	Reach DO Goal (mg/L)	
7.055	0.026	0.0000	8	
Reach Travel Time (days)	Subreach Results			
0.026	Time (days)	CSOQS (mg/L)	NP3-N (mg/L)	D.O. (mg/L)
	0.003	8.30	2.21	7.25
	0.006	8.27	2.21	7.21
	0.008	8.24	2.20	7.15
	0.011	8.21	2.20	7.08
	0.014	8.18	2.19	7.01
	0.017	8.15	2.19	6.95
	0.020	8.12	2.18	6.88
	0.022	8.09	2.18	6.81
	0.025	8.06	2.17	6.75
	0.026	8.03	2.17	6.68

Tuesday, July 27, 2021 Version 1.1 Page 1 of 1

Page: 1 | No Filter

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameter	Value	Use Inputted Q1-10 and Q25-10 Flows
WLA Method	EMPR	<input type="checkbox"/>
Q1-10/Q1-10 Ratio	0.84	<input type="checkbox"/>
Q25-10/Q1-10 Ratio	1.36	<input type="checkbox"/>
D.O. Saturation	90.00%	<input checked="" type="checkbox"/>
D.O. Goal	8	<input type="checkbox"/>
		Use Inputted WQV Ratio <input type="checkbox"/>
		Use Inputted Reach Travel Times <input type="checkbox"/>
		Temperature Adjust K ₁ <input checked="" type="checkbox"/>
		Use Balanced Technology <input checked="" type="checkbox"/>

Tuesday, July 27, 2021 Version 1.1 Page 1 of 1

Page: 1 | No Filter

rptHydro

rptGeneral

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
07H	08B	SOUTH BRANCH CROOKS CREEK										
Flow	W/S	Vel	Disc	Reach	Depth	Width	W/D	Velocity	Reach	Analysis	Analysis	
(cfs)	(cfs)	(ft/s)	(ft/s)	(ft)	(ft)	(ft)	(ft)	(ft/s)	(ft)	(Temp)	(pH)	
Q7-10 Flow												
16.250	2.44	0.00	2.44	9/252/5/20/430	49.755	.14	0	0.48	0.026	21.38	7.00	
Q1-10 Flow												
16.250	1.36	0.00	1.36	9/252/5/20/430	NA	NA	NA	0.40	0.033	21.86	7.00	
Q30-10 Flow												
16.250	3.33	0.00	3.33	9/252/5/20/430	NA	NA	NA	0.54	0.025	21.09	7.00	

Tuesday, July 27, 2021

Version 1.1

Page 1 of 1

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	Flow	Elevation	Drainage Area	Slope	PHS	Apply			
07H	8092	SOUTH BRANCH CROOKS CREEK	16.250	5332.000	16.30	0.00000	0.00	<input checked="" type="checkbox"/>			
Stream Data											
Design Cond.	LFY	Tab Flow	Stream Flow	Rech Flow	Rech Velocity	W/D Ratio	Rech Width	Rech Depth	Tab Temp	Stream Temp	Stream pH
(cfs)	(cfs)	(cfs)	(cfs)	(ft/s)	(ft/s)	(ft)	(ft)	(ft)	(°C)	(°C)	(pH)
Q7-10	0.150	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10	0.00	0.00	0.00	0.000	0.000						
Q30-10	0.00	0.00	0.00	0.000	0.000						

Discharge Data							
Name	Permit Number	Disc Flow (mgd)	Disc Flow (mgd)	Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Glen Rock STP	PA0020818	0.0000	08.000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Tab Conc (mg/L)	Stream Conc (mg/L)	Fate Conc (mg/L)			
CODCr	25.00	20.0	0.00	1.50			
Dissolved Oxygen	5.00	8.4	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

Tuesday, July 27, 2021

Version 1.1

Page 1 of 2

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply PC
07H	8023	SOUTH BRANCH COGORUS CREEK	16.030	528.55	16.10	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Const.	LFY	Trib			Stream			Tributary			Stream	
		Flow (cfs)	Flow (cfs)	Flow Time (Mins)	Flow (Mgpd)	Velocity (ft/s)	WD Ratio	Width (ft)	Depth (ft)	Temp (°C)	pH	Temp (°C)
Q7-10	0.150	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q8-10		0.00	0.00	0.000	0.000							
Q9-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Dis. Flow (mgd)	Permitted Dis. Flow (mgd)	Design Dis. Flow (mgd)	Reserve Factor	Dis. Temp (°C)	Dis. pH
Glen Rock STP	PA0020818	0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Dis. Conc. (mg/L)	Trib Conc. (mg/L)	Stream Conc. (mg/L)	Fate Coef. (1/Day)
COD5	25.00	200	0.00	1.50
Dissolved Oxygen	5.00	824	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD ₅	125	200 Wkly Avg	XXX	25	40	50	1/week	8-Hr Composite
TSS	150	225 Wkly Avg	XXX	30	45	60	1/week	8-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Ammonia May 1 - Oct 31	40	XXX	XXX	8.0	XXX	16	2/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	120	XXX	XXX	24	XXX	48	2/week	8-Hr Composite
Total Phosphorus	10	XXX	XXX	2.0	XXX	4	2/week	8-Hr Composite

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Net Total Nitrogen	Report	10,959	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	1,461	XXX	XXX	XXX	XXX	1/month	Calculation

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD ₅	125.0	200.0 Wkly Avg	XXX	25.0	40.0	50.0	1/week	8-Hr Composite
TSS	150.0	225.0 Wkly Avg	XXX	30.0	45.0	60.0	1/week	8-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/week	Grab
Ammonia May 1 - Oct 31	40.0	XXX	XXX	8.0	XXX	16.0	2/week	8-Hr Composite
Ammonia Nov 1 - Apr 30	120.0	XXX	XXX	24.0	XXX	48.0	2/week	8-Hr Composite
Total Phosphorus	10.0	XXX	XXX	2.0	XXX	4.0	2/week	8-Hr Composite

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Net Total Nitrogen	Report	10,959	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	1,461	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]