

Application Type Renewal
Facility Type Municipal
Major / Minor Major

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0020885
APS ID 320084
Authorization ID 1374719

Applicant and Facility Information

Applicant Name	<u>Mechanicsburg Borough</u>	Facility Name	<u>Mechanicsburg STP</u>
Applicant Address	<u>36 W Allen Street</u> <u>Mechanicsburg, PA 17055-6257</u>	Facility Address	<u>842 W Church Road</u> <u>Mechanicsburg, PA 17055-3103</u>
Applicant Contact	<u>Curtis Huey</u>	Facility Contact	<u>Curtis Huey</u>
Applicant Phone	<u>(717) 691-3320</u>	Facility Phone	<u>(717) 691-3320</u>
Client ID	<u>117422</u>	Site ID	<u>451764</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Mechanicsburg Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Cumberland</u>
Date Application Received	<u>October 29, 2021</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>November 2, 2021</u>	If No, Reason	<u>Major Facility, Significant CB Discharge</u>
Purpose of Application	<u>NPDES Permit Renewal</u>		

Summary of Review

Mechanicsburg Borough (Mechanicsburg) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on April 27, 2017 and became effective on May 1, 2017. The permit expired on April 30, 2022 but the terms and conditions of the permit have been extended since that time.

Based on the review, it is recommended that the permit be issued.

Sludge use and disposal description and location(s): Sludge is processed onsite prior to being land applied under PAG083523 and PAG073523.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jinsu Kim Jinsu Kim / Environmental Engineering Specialist	October 6 2022
X		Daniel W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager	November 15, 022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	2.08
Latitude	40° 15' 9.00"	Longitude	77° 0' 27.15"
Quad Name	Wertzville	Quad Code	1629
Wastewater Description: Treated sewage			
Receiving Waters	Conodoguinet Creek	Stream Code	10194
NHD Com ID	56404001	RMI	15.75
Drainage Area	485	Yield (cfs/mi ²)	0.153
Q ₇₋₁₀ Flow (cfs)	74.4	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)		Slope (ft/ft)	
Watershed No.	7-B	Chapter 93 Class.	WWF, MF
Existing Use	WWF, MF	Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Organic Enrichment		
Source(s) of Impairment	Unknown		
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Steelton Borough		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	3,204
PWS RMI	68.36	Distance from Outfall (mi)	19.3

Drainage Area

The discharge is to Conodoguinet Creek at RM 15.75. A drainage area upstream of the discharge point is estimated to be 485 sq.mi, according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

USGS Streamflow produced a Q₇₋₁₀ flow of 74.4 at the discharge point.

Conodoguinet Creek

25 Pa Code §93.9o lists Conodoguinet Creek from PA997 at Roxbury to Mouth as warm water and migratory fishes. No special protection water is impacted by this discharge. DEP's latest integrated water quality report finalized in 2022 indicates that the receiving stream is impaired for organic enrichment as a result of unknown source. A TMDL was developed in December 2000 to address nutrient and sediment impairments identified within the Conodoguinet Creek basin. However, this TMDL mainly identified agriculture, construction and urban runoff/storm sewers as the sources of these impairments. The TMDL covered subwatersheds, not the main stem. The integrated water quality identified organic enrichment impairment under Category 5 which requires a TMDL.

Public Water Supply Intake

The fact sheet developed for the last permit renewal indicates that the nearest downstream intake is Steelton Borough on Susquehanna River, approximately 19.3 miles downstream of the discharge. Given the distance, the discharge is not expected to affect the water supply.

Treatment Facility Summary				
Treatment Facility Name: Mechanicsburg WWTP				
WQM Permit No.	Issuance Date			
2109402	Last amended on 4/22/2022			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Activated Sludge	Gas Chlorine	2.08
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
3.328	4694	Not Overloaded	Anaerobic Digestion	Compost

Mechanicsburg owns and operates a municipal wastewater treatment plant serving the areas of Mechanicsburg Borough (66.5%), Monroe Township (7.5%), Silver Spring Township (17.7%), Upper Allen Township (0.4%) and Hampden Township (7.99%). All sewer systems are 100% separated. The facility utilizes trickling filter-MLE activated sludge treatment process consisting of primary screening treatment, primary clarification (2), trickling filters (4), MLE anoxic/aerobic tanks (2), final clarification (3), sand denitrification filter, chlorine contact and outfall structure. The facility is rated for 2.05 MGD (annual average design flow), 3.328 MGD (hydraulic design capacity) and 4,694 lbs BOD/day (organic design capacity).

Chlorine gas is used for disinfection, Aluminum Sulfate and polymer are used for coagulant, settling and phosphorus control.

A sludge thickener, digesters (2) and filter press are used for sludge processing. Any solids generated from this facility will be land applied under PAG083523 and PAG073523.

The application reported a number of industrial/commercial users connected to this sewer system. These users are shown below:

Name	Description of Industry	Wastewater Volume (GPD)	Significant Industrial User?
Advanced Coating Technologies	Custom metal finishing	1,650 (process)	No
Nestle Purina	Pet food manufacturing	16,169 (process)	Yes
Fry Communication, Inc.	Magazine and direct mail printers	2,985 (process)	No

The application indicates that Mechanicsburg is not implementing an approved pretreatment program administered by EPA.

Compliance History

Summary of DMRs:	A summary of past 12-month DMR is presented on the next page.
Summary of Inspections:	01/05/22: Brandon Bettinger, DEP Water Quality Specialist, conducted a routine inspection and noted that the facility's grit system has been offline for approximately one year, failed to maintain permitted treatment units in operable condition. No violations were noted at the time of inspection. 03/08/21: Mike Benham, former DEP Water Quality Specialist, conducted a routine inspection. A number of recommendations were made at the time of inspection but no violations were noted. 02/27/20: Mike Benham conducted a routine inspection. No violations were noted at the time of inspection.
Other Comments:	Since the last reissuance, there have been a number of violations reported by the permittee or identified by DEP. A table below summarizes these violations. DEP's database shows that there is no open violation associated with this permittee or facility.

Date	Violation Description	Category	PARAMETER	Sample Results	Limits	Units	SBC	Comments
Aug-17	Sample collection less frequent than required	Other Violations	Nitrate-Nitrite as N					
Aug-17	Sample type not in accordance with permit	Other Violations	Nitrate-Nitrite as N					
Nov-17	Sample type not in accordance with permit	Other Violations	Nitrate-Nitrite as N					
Jul-19	Violation of permit condition	Effluent	Total Nitrogen (Total Load, lbs)	41140	37990	lbs	Total Annual	
Mar-18	Late DMR Submission	Other Violations						
Jun-18	Violation of permit condition	Effluent	Fecal Coliform	15900	1000	CFU/100 ml	Instantaneous Maximum	Testing was performed during high flow due to sand filter bypass. In the past, when flow has been high, the chlorine flow has been reduced to prevent exceeding the instantaneous maximum for residual chlorine. The combination of reduced chlorine and reduced contact time from high flow resulted in high fecal coliform results. In the future, we will alter our SOP to better treat for fecal coliform during high flow while trying not to exceed the instantaneous maximum.
Jul-18	Violation of permit condition	Effluent	Fecal Coliform	1650	1000	CFU/100 ml	Instantaneous Maximum	
Aug-18	Violation of permit condition	Effluent	Fecal Coliform	> 503	200	CFU/100 ml	Geometric Mean	
Aug-18	Violation of permit condition	Effluent	Fecal Coliform	3300	1000	CFU/100 ml	Instantaneous Maximum	
Sep-18	Violation of permit condition	Effluent	Ammonia-Nitrogen	9.4	9.0	mg/L	Average Monthly	
Sep-18	Violation of permit condition	Effluent	Fecal Coliform	2500	1000	CFU/100 ml	Instantaneous Maximum	
Oct-18	Violation of permit condition	Effluent	Fecal Coliform	4150	1000	CFU/100 ml	Instantaneous Maximum	
Dec-18	Late DMR Submission	Other Violations						
Jun-20	Late DMR Submission	Other Violations						
Oct-19	Violation of permit condition	Effluent	Total Suspended Solids	37	30	mg/L	Average Monthly	
Oct-19	Violation of permit condition	Effluent	Total Suspended Solids	51	45	mg/L	Weekly Average	
Nov-19	Violation of permit condition	Effluent	Total Suspended Solids	36	30	mg/L	Average Monthly	
Nov-19	Violation of permit condition	Effluent	Total Suspended Solids	71	45	mg/L	Weekly Average	
Dec-19	Violation of permit condition	Effluent	Total Suspended Solids	160	45	mg/L	Weekly Average	
Dec-19	Violation of permit condition	Effluent	Total Suspended Solids	58	30	mg/L	Average Monthly	
Mar-20	Violation of permit condition	Effluent	Total Suspended Solids	47	45	mg/L	Weekly Average	Our lab's accreditation was suspended by the Bureau of Laboratories. The contract lab we were using was getting very high results for influent and effluent suspended solids. The accreditation was reinstated in February, and we got much better numbers and expect to be in compliance going forward.
Aug-20	Violation of permit condition	Effluent	Carbonaceous Biochemical Oxygen	49	40	mg/L	Weekly Average	See Attachment
Mar-21	Violation of permit condition	Effluent	Fecal Coliform	> 1468	2000	CFU/100 ml	Geometric Mean	
Mar-21	Violation of permit condition	Effluent	Fecal Coliform	> 2420	10000	CFU/100 ml	Instantaneous Maximum	
Apr-21	Violation of permit condition	Effluent	Fecal Coliform	> 1053	2000	CFU/100 ml	Geometric Mean	
Apr-21	Violation of permit condition	Effluent	Fecal Coliform	> 2420	10000	CFU/100 ml	Instantaneous Maximum	
Jul-21	Violation of permit condition	Effluent	Fecal Coliform	1416	1000	CFU/100 ml	Instantaneous Maximum	At the time of sampling, there was no known issue that would have caused a high fecal. 2 days later, the fecal was 49 with no process changes.
Sep-21	Violation of permit condition	Effluent	Fecal Coliform	1553	1000	CFU/100 ml	Instantaneous Maximum	The residual chlorine was low on 8/5. After getting a high fecal, the chlorine feed was increased and the chlorine contact tank walls were cleaned to reduce chlorine demand from algae.
Mar-22	Late DMR Submission	Other Violations						

Effluent Data

DMR Data for Outfall 001 (from April 1, 2021 to March 31, 2022)

Parameter	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21
Flow (MGD) Average Monthly	0.551	0.623	0.574	0.58	0.626	0.74	1.234	601	0.633	0.556	0.636	0.618
Flow (MGD) Daily Maximum	0.601	1.032	0.733	0.656	0.888	1.017	3.56	0.751	1.062	0.681	0.947	0.983
pH (S.U.) Minimum	6.5	6.7	6.8	7.0	7.1	7.3	7.2	7.2	7.1	7.1	6.9	6.9
pH (S.U.) Instantaneous Maximum	6.9	7.0	7.2	7.4	7.6	7.6	7.6	7.6	7.5	7.4	7.3	7.2
DO (mg/L) Minimum	7.9	8.2	8.0	7.8	8.0	7.7	7.6	7.4	7.5	7.8	7.8	7.9
TRC (mg/L) Average Monthly	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.10	0.20	0.10	0.20	0.10
TRC (mg/L) Instantaneous Maximum	0.20	0.82	0.21	0.14	0.80	0.31	0.19	0.20	0.53	0.25	0.27	0.40
CBOD5 (lbs/day) Average Monthly	< 13	13	12	< 12	< 17	< 13	< 20	< 18	< 12	< 12	< 9	11
CBOD5 (lbs/day) Weekly Average	19	19	13	15	< 24	22	< 38	< 23	< 15	20	15	14
CBOD5 (mg/L) Average Monthly	< 3	3	3	< 2	< 3	< 2	< 2	< 3	< 2	< 3	< 2	2
CBOD5 (mg/L) Weekly Average	4	4	3	3	< 4	4	3	5	3	4	3	3
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	330	1470	1466	2297	1825	1857	2123	1673	1484	1614	1486	1544
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	536	2386	1631	3593	2708	2664	3157	2750	2313	2988	2097	1884
BOD5 (mg/L) Raw Sewage Influent Average Monthly	1758	256	261	386	302	292	242	277	246	295	268	281
TSS (lbs/day) Average Monthly	65	31	37	46	22	25	93	75	45	30	22	24
TSS (lbs/day) Raw Sewage Influent Average Monthly	1851	2707	2815	3516	2728	5692	2012	2237	2852	2763	2530	3091

**NPDES Permit Fact Sheet
Mechanicsburg STP**

NPDES Permit No. PA0020885

Parameter	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21
TSS (lbs/day) Raw Sewage Influent Daily Maximum	2809	6999	5173	5076	4548	10881	4811	2971	4209	3361	3348	4501
TSS (lbs/day) Weekly Average	65	36	39	57	20	31	342	150	83	47	46	29
TSS (mg/L) Average Monthly	16	6	7	10	4	4	5	13	9	6	4	4
TSS (mg/L) Raw Sewage Influent Average Monthly	353	495	480	603	459	836	207	356	450	501	452	537
TSS (mg/L) Weekly Average	42	7	8	11	4	5	13	20	18	10	9	5
Fecal Coliform (CFU/100 ml) Geometric Mean	154	231	494	838	468	301	< 61	146	95	129	37	1452
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	1986	2420	2420	2420	1046	770	816	1553	488	1416	75	6130
Nitrate-Nitrite (mg/L) Average Monthly	< 16.02	< 16.47	< 20.36	< 14.87	< 16.79	< 10.91	< 8.27	11.8	< 12.16	< 12.41	< 14.26	< 14.86
Nitrate-Nitrite (lbs) Total Monthly	< 2163	< 2224	< 2560	< 2160	< 2563	< 2068	< 1884	1956	< 2058	< 1756	< 2357	< 2280
Total Nitrogen (mg/L) Average Monthly	< 19.37	< 20.16	< 22.99	< 18.95	< 19.19	< 13.1	< 8.8	< 12.3	< 12.66	< 12.91	< 14.79	< 15.36
Total Nitrogen (lbs) Effluent Net Total Monthly	< 2612	< 2719	< 3386	< 2765	< 2928	< 2488	< 2007	< 2039	< 2144	< 1888	< 2446	< 2356
Total Nitrogen (lbs) Total Monthly	< 2612	< 2719	< 3386	< 2765	< 2928	< 2488	< 2007	< 2039	< 2144	< 1827	< 2446	< 2356
Total Nitrogen (lbs) Effluent Net Total Annual							< 30105					
Total Nitrogen (lbs) Total Annual							< 30755					
Ammonia (lbs/day) Average Monthly	< 0.3	0.2	< 0.2	< 0.2	< 0.2	< 0.3	< 0.4	< 0.4	< 0.2	< 0.2	< 0.2	< 0.7
Ammonia (mg/L) Average Monthly	< 0.07	0.05	< 0.05	< 0.04	< 0.05	< 0.04	< 0.06	< 0.06	< 0.04	< 0.04	< 0.04	< 0.13
Ammonia (lbs) Total Monthly	< 10	7	< 7	< 6	< 7	< 8	< 12	< 13	< 7	< 6	< 7	< 20
Ammonia (lbs) Total Annual							< 129					

**NPDES Permit Fact Sheet
Mechanicsburg STP**

NPDES Permit No. PA0020885

Parameter	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21
TKN (mg/L) Average Monthly	< 3.36	3.69	5.4	4.08	2.4	2.19	< 0.52	< 0.5	< 0.5	< 0.5	< 0.53	< 0.5
TKN (lbs) Total Monthly	< 449	495	826	604	365	421	< 124	< 83	< 86	< 71	< 88	< 3
Total Phosphorus (lbs/day) Average Monthly	3	3	3	4	3	4	3	5	4	3	3	3
Total Phosphorus (mg/L) Average Monthly	0.76	0.53	0.7	0.81	0.61	0.67	0.43	0.93	0.65	0.69	0.55	0.58
Total Phosphorus (lbs) Effluent Net Total Monthly	102	71	102	120	93	127	96	164	113	101	92	90
Total Phosphorus (lbs) Total Monthly	102	71	102	120	93	127	96	164	113	98	92	90
Total Phosphorus (lbs) Effluent Net Total Annual							1383					
Total Phosphorus (lbs) Total Annual							1383					
Total Copper (lbs/day) Daily Maximum	0.033			0.041			0.057			0.082		
Total Copper (mg/L) Daily Maximum	0.0074			0.0072			0.0103			0.015		

Existing Effluent Limits and Monitoring Requirements

Tables below summarize effluent limits and monitoring requirements specified in the current permit.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.45	XXX	1.48	1/day	Grab
CBOD5	433	693	XXX	25	40	50	2/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Suspended Solids	520	780	XXX	30	45	60	2/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Ammonia-Nitrogen May 1 - Oct 31	156	XXX	XXX	9.0	XXX	18	2/week	24-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	277	XXX	XXX	16	XXX	32	2/week	24-Hr Composite
Total Phosphorus	34	XXX	XXX	2.0	XXX	4.0	2/week	24-Hr Composite
Copper, Total	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Net Total Nitrogen	Report	37990*	XXX	XXX	XXX	XXX	1/month	Calculation
Net Total Phosphorus	Report	5065*	XXX	XXX	XXX	XXX	1/month	Calculation

*The permittee is authorized to use 650 lbs/year as Total Nitrogen (TN) Offsets toward compliance with the Annual Net TN mass load limitations (Cap Loads), in accordance with Part C of this permit. These Offsets may be applied throughout the Compliance Year or during the Turing Period. The application of offsets must be reported to DEP as described in Part C. The Offsets are authorized for the following pollutant load reduction activities:

- Connection of 26 on-lot sewage disposal systems to the public sewer system after January 1, 2003, in which 25 lbs/year of TN offsets are granted per connection.

Development of Effluent Limitations and Monitoring Requirements

Outfall No. <u>001</u>	Design Flow (MGD) <u>2.08</u>
Latitude <u>40° 15' 9.00"</u>	Longitude <u>-77° 0' 27.16"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

CBOD5, NH3-N and Dissolved Oxygen (DO)

WQM 7.0 is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP’s guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. DEP recently updated this model (ver. 1.1) to include new ammonia criteria that has been approved by US EPA as part of the 2017 Triennial Review. The model output indicates that all existing effluent limits for these pollutants are still appropriate. No changes are therefore recommended.

Toxic Pollutants

DEP utilizes a Toxics Management Spreadsheet (last modified on March 2021 ver. 1.3) to facilitate calculations necessary for completing a reasonable potential analysis and determining WQBELs for toxic pollutants. The worksheet combines the functionality of DEP’s Toxics Screening Analysis worksheet and PENTOXSD. The current permit requires a quarterly sampling for Total Copper as Total Copper was detected at levels higher than the water quality criteria yet no reasonable potential was determined. During the last permit renewal review process, DEP determined that a quarterly sampling requirement would produce ample data for further analysis. The results from April 2017 through July 2022 (a total of 22 datasets) were summarized below.

Total Copper (mg/L)	
Maximum	0.082
Minimum	<0.022
No. of Non-Detect Results	8

DEP’s TOXCON worksheet was utilized to produce an average monthly effluent concentration and daily coefficient of variation. These values were then entered into Toxics Management Spreadsheet. The TMS no longer requires any further monitoring for Total Copper. As a result, it is recommended that the existing quarterly sampling requirement for Total Copper be removed from the permit.

The TMD indicates that WQBELs are needed for Total Mercury. However, Mechanicsburg may not be able to achieve compliance with these WQBELs. As a result, DEP’s pre-draft permit survey was sent on May 19, 2022. This survey form allows DEP to develop appropriate permit requirements and to understand facility’s current capabilities or plans to treat or control the pollutant of concern. This approach is consistent with DEP’s SOP no. BCW.PMT-037. Mechanicsburg submitted the survey form on June 23, 2022 and indicated that Mechanicsburg will further collect samples for Total Mercury to supplement the application. DEP received results of ten (10) additional samples on both influent and effluent on October 5, 2022. These results are summarized below.

Sample Date	Influent (ug/L)*	Effluent (ug/L)*	Sample Date	Influent (ug/L)*	Effluent (ug/L)*
8/16/2022	<0.2	<0.2	8/30/2022	<0.2	<0.2
8/18/2022	0.4	<0.2	9/5/2022	<0.2	<0.2
8/23/2022	<0.2	<0.2	9/7/2022	<0.2	<0.2
8/24/2022	<0.2	<0.2	9/12/2022	<0.2	<0.2
8/25/2022	<0.2	<0.2	9/14/2022	0.3	<0.2

*DEP’s current Target QL for Total Mercury = 0.2 ug/L.

As shown above, while Total Mercury was detected slightly higher than DEP’s Target QL in two of ten influent samples, Total Mercury was consistently not detected in effluent at DEP’s target QL. Given a number of non-detected results, a statistical analysis using DEP’s TOXCON worksheet cannot be performed. At this time, DEP determined based on additional sample results that Total Mercury level in the discharge is not of concern and ultimately no reasonable potential is determined. Therefore, no WQBELs are recommended. In case DEP determines, during the upcoming permit term, that permit requirements for Total Mercury are needed, DEP may reopen this permit to include any necessary permit requirements per 40 CFR §§122.41(h) and 122.62.

Total Residual Chlorine

DEP’s TRC_CALC worksheet was utilized to determine appropriate permit requirements for TRC. The worksheet shows that existing effluent limits are still appropriate. No change is therefore recommended.

Whole Effluent Toxicity Testing

Mechanicsburg is required under 40 CFR §122.21(h)(5)(ii)(A) to conduct WETT and submit the results to DEP. See WETT section of this fact sheet for more details on the results submitted by Mechanicsburg.

Best Professional Judgment (BPJ) Limitations

Dissolved Oxygen

The existing minimum DO effluent limit is the current warm water fishery water quality criterion for DO listed in 25 Pa Code §93.7(a). It is recommended that this limit be maintained in the permit to ensure the protection of water quality standards. This approach is consistent with DEP’s current Standard Operating Procedure (SOP) no. BPNPSM-PMT-033 and has been applied to other point source dischargers throughout the state.

Total Phosphorus

The existing permit contains average monthly and instantaneous maximum (IMAX) effluent limits of 2.0 mg/L and 4.0 mg/L, respectively. Historically a TP effluent limit of 2.0 mg/L was established in the permit when DEP generally determines that the facility is expected to contribute 0.25% or more of the total point source phosphorus loading at the point of impact (page 17 of DEP’s technical guidance no. 391-2000-018). DEP previously documented that the discharge contributes more than 0.25% and phosphorus controls were therefore needed. There is no reason to relax or remove these effluent limits; therefore, continuation of existing effluent limits is still appropriate in accordance with 40 CFR §122.44(l)(1).

Additional Considerations

Flow Monitoring Requirement

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

Influent BOD & TSS Monitoring Requirement

As a result of negotiation with EPA, the existing influent monitoring reporting requirement for TSS and BOD5 will be maintained in the draft permit. This requirement has been consistently assigned to all municipal wastewater treatment facilities.

Total Dissolved Solids (TDS)

TDS and its associated solids including Bromide, Chloride, and Sulfate have become statewide pollutants of concern. The requirement to monitor these pollutants must be considered under the criteria specified in 25 Pa. Code § 95.10 and the following January 23, 2014 DEP Central Office Directive:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

-Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.

-Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.

-Where the concentration of 1,4-dioxane (CAS 123-91-1) in a discharge exceeds 10 µg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for 1,4-dioxane. Discharges of 0.1 MGD or less should monitor and report for 1,4-dioxane if the concentration of 1,4-dioxane in the discharge exceeds 100 µg/L.

Mechanicsburg reported maximum concentrations of 726 mg/L for TDS, 0.2 mg/L for bromide, and < 10.0 µg/L for 1,4-dioxane. Accordingly, the requirement to monitor for these pollutants is not necessary.

Mass Loading Limitations

All effluent mass loading limits will be based on the formula: design flow x concentration limit x conversion factor of 8.34.

Stormwater Requirements

Stormwater discharges from any POTWs (SIC Code 4952) described in 40 CFR § 122.26(b)(14)(ix) require coverage under an NPDES permit. DEP's standard Part C stormwater requirements and site-specific best management practices (BMPs) will be included in the permit as this is a standard approach for major sewage facilities over 1.0 MGD.

E. Coli Monitoring Requirement

As recommended by DEP's SOP no. BPNPSM-PMT-033, a routine monitoring for E. Coli will be included in the permit under 25 Pa Code §92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/month will be included permit to be consistent with the recommendation from this SOP.

Chesapeake Bay TMDL

On March 30, 2012, DEP finalized Pennsylvania's Chesapeake Watershed Implementation Plan Phase 2 (i.e., Phase 2 WIP) to address U.S EPA's expectations for the Chesapeake Bay TMDL. The Chesapeake Bay TMDL identifies the necessary pollution reductions from major sources of nitrogen, phosphorus and sediment across the Bay jurisdictions and sets pollution limits necessary to meet water quality standards. The Phase 2 WIP is an update to the Pennsylvania's Chesapeake Bay TMDL Strategy (2004) and the Chesapeake WIP Phase I (2011). In August 2019, DEP finalized Phase 3 Chesapeake Bay Watershed Implementation Plan to provide the plans in place by 2025 to further achieve the nutrient and sediment reduction targets. The more details on the TMDL are available at www.dep.pa.gov.

As part of the Phase 3 WIP process, a Supplement to the Phase 3 WIP was developed, providing an update on TMDL implementation for point sources and a discussion of adjustments to the permitting strategy as a result of implementation experience. According to this document, Mechanicsburg Borough WWTP is a Phase 3 significant discharger located within the Chesapeake Bay watershed. The following Cap Loads specified in the current Supplement to the Phase 3 WIP will be included in the draft permit:

**NPDES Permit Fact Sheet
Mechanicsburg STP**

NPDES Permit No. PA0020885

NPDES Permit No.	Phase	Facility	Latest Permit Issuance Date	Permit Expiration Date	Cap Load Compliance Start Date	TN Cap Load (lbs/yr)	TN Offsets Included in Cap Load (lbs/yr)	TP Cap Load (lbs/yr)	TN Delivery Ratio	TP Delivery Ratio
PA0020885	1	Mechanicsburg Borough MA	4/27/2017	04/30/2022	10/1/2012	37,990	-	5,065	0.951	0.436

The permittee is currently authorized to use 650 lbs/year as Total Nitrogen (TN) Offsets toward compliance with the Annual Net TN mass load limitations (Cap Loads) as a result of the connection of 26 on-lot sewage disposal systems to the public sewer system after January 1, 2003, in which 25 lbs/year of TN offsets are granted per connection. No further offset request was received during the last permit reissuance.

Class A Wild Trout Fishery

A Class A Wild Trout stream is not impacted by this discharge.

Anti-backsliding Requirements

Unless stated otherwise in this fact sheet, all permit requirements proposed in this fact sheet are at least as stringent as those specified in the existing permit.

Whole Effluent Toxicity (WET)

For Outfall 001, Acute Chronic WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other:

The dilution series used for the tests was: 100%, 60%, 30%, 5%, and 2%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 5%.

Summary of Four Most Recent Test Results

NOEC/LC50 Data Analysis

Test Date	Ceriodaphnia Results (% Effluent)			Pimephales Results (% Effluent)			Pass? *
	NOEC Survival	NOEC Reproduction	LC50	NOEC Survival	NOEC Growth	LC50	
August 2020	100	100		100	100		Yes
July 2019	100	30		100	100		Yes
August 2018	100	100		100	100		Yes
October 2017	100	100		100	60		Yes

* A "passing" result is that which is greater than or equal to the TIWC value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? (NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).

- YES NO

Comments: DEP's Whole Effluent Toxicity Analysis Spreadsheet is attached to this fact sheet.

Evaluation of Test Type, IWC and Dilution Series for Renewed Permit

Acute Partial Mix Factor (PMFa): **0.116** Chronic Partial Mix Factor (PMFc): **0.801**

1. Determine IWC – Acute (IWCa):

$$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$$

$$[(2.08 \text{ MGD} \times 1.547) / ((74.4 \text{ cfs} \times 0.116) + (2.08 \text{ MGD} \times 1.547))] \times 100 = 27\%$$

Is IWCa < 1%? YES NO **(YES - Acute Tests Required OR NO - Chronic Tests Required)**

Type of Test for Permit Renewal: Chronic

2b. Determine Target IWCC (If Chronic Tests Required)

$$(Q_d \times 1.547) / (Q_{7-10} \times PMFc) + (Q_d \times 1.547)$$

$$[(2.8 \text{ MGD} \times 1.547) / ((74.4 \text{ cfs} \times 0.801) + (2.08 \text{ MGD} \times 1.547))] \times 100 = 5\%$$

3. Determine Dilution Series

(NOTE – check Attachment C of WET SOP for dilution series based on TIWCa or TIWCC, whichever applies).

Dilution Series = 100%, 60%, 30%, 5%, and 2%.

WET Limits

Has reasonable potential been determined? YES NO

Will WET limits be established in the permit? YES NO

If WET limits will be established, identify the species and the limit values for the permit (TU).

N/A

If WET limits will not be established, but reasonable potential was determined, indicate the rationale for not establishing WET limits:

N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.45	XXX	1.48	1/day	Grab
CBOD5	433	693	XXX	25	40	50	2/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS	520	780	XXX	30	45	60	2/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
Nitrate-Nitrite	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Nitrogen (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia Nov 1 - Apr 30	277	XXX	XXX	16	XXX	32	2/week	24-Hr Composite
Ammonia May 1 - Oct 31	156	XXX	XXX	9.0	XXX	18	2/week	24-Hr Composite
Ammonia (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
TKN	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TKN (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus	34	XXX	XXX	2.0	XXX	4	2/week	24-Hr Composite
Total Phosphorus (lbs)	Report Total Mo	XXX	XXX	XXX	XXX	XXX	1/month	Calculation
E. Coli (No./100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/month	Grab

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Total Nitrogen (lbs) Effluent Net	XXX	37990 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Nitrogen (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Ammonia (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs) Effluent Net	XXX	5065 Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation
Total Phosphorus (lbs)	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/year	Calculation

*The permittee is authorized to use 650 lbs/year as Total Nitrogen (TN) Offsets toward compliance with the Annual Net TN mass load limitations (Cap Loads), in accordance with Part C of this permit. These Offsets may be applied throughout the Compliance Year or during the Turing Period. The application of offsets must be reported to DEP as described in Part C. The Offsets are authorized for the following pollutant load reduction activities:

- Connection of 26 on-lot sewage disposal systems to the public sewer system after January 1, 2003, in which 25 lbs/year of TN offsets are granted per connection.

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

Attachments


1. USGS Streamflow

10/6/22, 8:35 AM

StreamStats

StreamStats Report

Region ID: PA
 Workspace ID: PA20221006123316108000
 Clicked Point (Latitude, Longitude): 40.25336, -77.00699
 Time: 2022-10-06 08:33:37 -0400



Collapse All

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	40.45	percent
DRNAREA	Area that drains to a point on a stream	485	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.6	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.62	miles per square mile

10/6/22, 8:35 AM

StreamStats

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	485	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	1.62	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.6	feet	3.32	5.65
CARBON	Percent Carbonate	40.45	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PIl: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	112	ft ³ /s	38	38
30 Day 2 Year Low Flow	132	ft ³ /s	33	33
7 Day 10 Year Low Flow	74.4	ft ³ /s	51	51
30 Day 10 Year Low Flow	87.9	ft ³ /s	46	46
90 Day 10 Year Low Flow	108	ft ³ /s	36	36

Low-Flow Statistics Citations

Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

2. WQM 7.0 ver. 1.1

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10194	CONODOGUINET CREEK	15.840	343.00	468.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.143	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Silver Spring	PA0083593	1.2000	1.2000	1.2000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	18.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10194	CONODOGUINET CREEK	15.750	342.00	485.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	74.40	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Mechanicsburg	PA0020885	2.0800	2.0800	2.0800	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	9.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10194	CONODOGUINET CREEK	14.140	338.00	488.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	74.80	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10194	CONODOGUINET CREEK	10.210	325.00	495.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	75.20	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07B	10194	CONODOGUINET CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
15.840	1.200	25.000		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
126.316	1.008	125.372		0.540
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
2.62	0.383	0.49		1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
8.155	5.973	Tsvoglou		5
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.010	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.001	2.62	0.49	7.54
	0.002	2.62	0.48	7.54
	0.003	2.62	0.48	7.54
	0.004	2.62	0.48	7.54
	0.005	2.61	0.48	7.54
	0.006	2.61	0.48	7.54
	0.007	2.61	0.48	7.54
	0.008	2.61	0.48	7.54
	0.009	2.61	0.48	7.54
	0.010	2.61	0.48	7.54
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
15.750	3.280	25.000		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
146.295	1.058	138.268		0.513
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
3.46	0.621	0.78		1.029
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
7.502	1.289	Tsvoglou		5
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.192	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.019	3.41	0.77	7.38
	0.038	3.36	0.75	7.26
	0.057	3.31	0.74	7.15
	0.077	3.26	0.72	7.04
	0.096	3.21	0.71	6.94
	0.115	3.16	0.69	6.84
	0.134	3.11	0.68	6.74
	0.153	3.07	0.67	6.65
	0.172	3.02	0.65	6.57
	0.192	2.98	0.64	6.49

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
07B		10194				CONODOGUINET CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
15.840	66.92	0.00	66.92	1.8564	0.00210	1.008	126.32	125.37	0.54	0.010	25.00	7.00
15.750	74.40	0.00	74.40	5.0742	0.00047	1.058	146.29	138.27	0.51	0.192	25.00	7.00
14.140	74.80	0.00	74.80	5.0742	0.00063	1.049	144.67	137.98	0.53	0.456	25.00	7.00
Q1-10 Flow												
15.840	42.83	0.00	42.83	1.8564	0.00210	NA	NA	NA	0.42	0.013	25.00	7.00
15.750	47.62	0.00	47.62	5.0742	0.00047	NA	NA	NA	0.41	0.241	25.00	7.00
14.140	47.87	0.00	47.87	5.0742	0.00063	NA	NA	NA	0.42	0.574	25.00	7.00
Q30-10 Flow												
15.840	91.02	0.00	91.02	1.8564	0.00210	NA	NA	NA	0.64	0.009	25.00	7.00
15.750	101.18	0.00	101.18	5.0742	0.00047	NA	NA	NA	0.60	0.163	25.00	7.00
14.140	101.73	0.00	101.73	5.0742	0.00063	NA	NA	NA	0.62	0.388	25.00	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
07B	10194	CONODOGUINET CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
15.840	Silver Spring	11.07	36	11.07	36	0	0
15.750	Mechanicsburg	11.07	18	11.07	18	0	0
14.140		NA	NA	11.07	NA	NA	NA

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
15.840	Silver Spring	1.37	18	1.37	18	0	0
15.750	Mechanicsburg	1.37	9	1.37	9	0	0
14.140		NA	NA	1.37	NA	NA	NA

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CROD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
15.84	Silver Spring	25	25	18	18	5	5	0	0
15.75	Mechanicsburg	25	25	9	9	5	5	0	0
14.14		NA	NA	NA	NA	NA	NA	NA	NA

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
07B		10194		CONODOGUINET CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
15.840	Silver Spring	PA0083593	1.200	CBOD5	25		
				NH3-N	18	36	
				Dissolved Oxygen			5
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
15.750	Mechanicsburg	PA0020885	2.080	CBOD5	25		
				NH3-N	9	18	
				Dissolved Oxygen			5

3. Toxics Management Spreadsheet



Toxics Management Spreadsheet
Version 1.3, March 2021

Discharge Information

Instructions Discharge Stream

Facility: Mechanicsburg Borough NPDES Permit No.: PA0020885 Outfall No.: 001
Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Sewage

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h
2.08	201	7						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl	
Group 1	Total Dissolved Solids (PWS)	mg/L	728									
	Chloride (PWS)	mg/L	100									
	Bromide	mg/L	0.2									
	Sulfate (PWS)	mg/L	75.7									
	Fluoride (PWS)	mg/L										
Group 2	Total Aluminum	µg/L	0.983									
	Total Antimony	µg/L	0.00065									
	Total Arsenic	µg/L	0.000472									
	Total Barium	µg/L	0.0128									
	Total Beryllium	µg/L	< 1									
	Total Boron	µg/L	0.22									
	Total Cadmium	µg/L	< 0.2									
	Total Chromium (III)	µg/L	0.000732									
	Hexavalent Chromium	µg/L	0.077									
	Total Cobalt	µg/L	0.000415									
	Total Copper	µg/L	0.0699704			0.8608						
	Free Cyanide	µg/L	4.4									
	Total Cyanide	µg/L	0.0032									
	Dissolved Iron	µg/L	< 20									
	Total Iron	µg/L	0.11									
	Total Lead	µg/L	0.000328									
	Total Manganese	µg/L	0.0341									
	Total Mercury	µg/L	< 0.2									
	Total Nickel	µg/L	0.0018									
	Total Phenols (Phenolics) (PWS)	µg/L	0.003									
	Total Selenium	µg/L	0.00521									
	Total Silver	µg/L	< 0.4									
	Total Thallium	µg/L	< 2									
	Total Zinc	µg/L	0.0797									
	Total Molybdenum	µg/L	0.012									
	Acrolein	µg/L	< 0.5									
Acrylamide	µg/L	< 0.5										
Acrylonitrile	µg/L	< 0.5										
Benzene	µg/L	< 0.5										
Bromoform	µg/L	< 0.5										
Carbon Tetrachloride	µg/L	< 0.5										



Stream / Surface Water Information

Mechanicsburg Borough, NPDES Permit No. PA0020885, Outfall 001

Instructions **Discharge** **Stream**

Receiving Surface Water Name: Conodoguinet Creek

No. Reaches to Model: 1

- Statewide Criteria
 Great Lakes Criteria
 ORSANCO Criteria

Location	Stream Code *	RMI *	Elevation (ft) *	DA (mi ²) *	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria *
Point of Discharge	010194	15.75	342	485			Yes
End of Reach 1	010194	14.14	338	488			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²) *	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis		
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH	
Point of Discharge	15.75	0.1	74.4										252	7		
End of Reach 1	14.14	0.1	74.8													

Q_h

Location	RMI	LFY (cfs/mi ²) *	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis		
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH	
Point of Discharge	15.75															
End of Reach 1	14.14															



Toxics Management Spreadsheet
Version 1.3, March 2021

Mechanicsburg Borough, NPDES Permit No. PA0020885, Outfall 001

Model Results

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Q_{7-10}

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
15.75	74.40		74.40	3.218	0.00047	1.057	144.939	137.136	0.507	0.194	1122.456
14.14	74.80		74.8								

Q_h

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
15.75	321.18		321.18	3.218	0.00047	1.983	144.939	73.091	1.129	0.087	465.965
14.14	322.685		322.69								

Wasteload Allocations

AFC

CCT (min): 15

PMF: 0.116

Analysis Hardness (mg/l): 238.11

Analysis pH: 7.00

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	2,755	
Total Antimony	0	0		0	1,100	1,100	4,040	
Total Arsenic	0	0		0	340	340	1,249	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	77,131	
Total Boron	0	0		0	8,100	8,100	29,750	
Total Cadmium	0	0		0	4,677	5.15	18.9	Chem Translator of 0.908 applied
Total Chromium (III)	0	0		0	1159,530	3,669	13,477	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	59.8	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	349	
Total Copper	0	0		0	30,435	31.7	116	Chem Translator of 0.96 applied
Free Cyanide	0	0		0	22	22.0	80.8	
Dissolved Iron	0	0		0	N/A	N/A	N/A	

Model Results

10/6/2022

Page 5

Total Iron	0	0	0	0	N/A	N/A	N/A	905	Chem Translator of 0.665 applied
Total Lead	0	0	0	163.730	248	905	905	905	Chem Translator of 0.665 applied
Total Manganese	0	0	0	N/A	N/A	N/A	N/A	N/A	
Total Mercury	0	0	0	1.400	1.65	6.05	6.05	6.05	Chem Translator of 0.85 applied
Total Nickel	0	0	0	975.496	977	3,590	3,590	3,590	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0	0	N/A	N/A	N/A	N/A	N/A	
Total Selenium	0	0	0	N/A	N/A	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0	0	14.305	16.8	61.8	61.8	61.8	Chem Translator of 0.85 applied
Total Thallium	0	0	0	65	65.0	239	239	239	
Total Zinc	0	0	0	244.403	250	918	918	918	Chem Translator of 0.978 applied
Acrolein	0	0	0	3	3.0	11.0	11.0	11.0	
Acrylamide	0	0	0	N/A	N/A	N/A	N/A	N/A	
Acrylonitrile	0	0	0	650	650	2,387	2,387	2,387	
Benzene	0	0	0	640	640	2,351	2,351	2,351	
Bromoform	0	0	0	1,800	1,800	6,611	6,611	6,611	
Carbon Tetrachloride	0	0	0	2,800	2,800	10,284	10,284	10,284	
Chlorobenzene	0	0	0	1,200	1,200	4,407	4,407	4,407	
Chlorobromomethane	0	0	0	N/A	N/A	N/A	N/A	N/A	
2-Chloroethyl Vinyl Ether	0	0	0	18,000	18,000	66,112	66,112	66,112	
Chloroform	0	0	0	1,900	1,900	6,978	6,978	6,978	
Dichlorobromomethane	0	0	0	N/A	N/A	N/A	N/A	N/A	
1,2-Dichloroethane	0	0	0	15,000	15,000	55,093	55,093	55,093	
1,1-Dichloroethylene	0	0	0	7,500	7,500	27,547	27,547	27,547	
1,2-Dichloropropane	0	0	0	11,000	11,000	40,402	40,402	40,402	
1,3-Dichloropropylene	0	0	0	310	310	1,139	1,139	1,139	
Ethylbenzene	0	0	0	2,900	2,900	10,651	10,651	10,651	
Methylene Chloride	0	0	0	12,000	12,000	44,075	44,075	44,075	
1,1,2,2-Tetrachloroethane	0	0	0	1,000	1,000	3,673	3,673	3,673	
Tetrachloroethylene	0	0	0	700	700	2,571	2,571	2,571	
Toluene	0	0	0	1,700	1,700	6,244	6,244	6,244	
1,2-trans-Dichloroethylene	0	0	0	6,800	6,800	24,976	24,976	24,976	
1,1,1-Trichloroethane	0	0	0	3,000	3,000	11,019	11,019	11,019	
1,1,2-Trichloroethane	0	0	0	3,400	3,400	12,488	12,488	12,488	
Trichloroethylene	0	0	0	2,300	2,300	8,448	8,448	8,448	
Vinyl Chloride	0	0	0	N/A	N/A	N/A	N/A	N/A	
2-Chlorophenol	0	0	0	560	560	2,057	2,057	2,057	
2,4-Dichlorophenol	0	0	0	1,700	1,700	6,244	6,244	6,244	
2,4-Dimethylphenol	0	0	0	660	660	2,424	2,424	2,424	
2,4-Dinitrophenol	0	0	0	660	660	2,424	2,424	2,424	
2-Nitrophenol	0	0	0	8,000	8,000	29,383	29,383	29,383	
4-Nitrophenol	0	0	0	2,300	2,300	8,448	8,448	8,448	
Pentachlorophenol	0	0	0	8,723	8,723	32.0	32.0	32.0	
Phenol	0	0	0	N/A	N/A	N/A	N/A	N/A	
2,4,6-Trichlorophenol	0	0	0	460	460	1,690	1,690	1,690	
Acenaphthene	0	0	0	83	83.0	305	305	305	
Anthracene	0	0	0	N/A	N/A	N/A	N/A	N/A	
Benzidine	0	0	0	300	300	1,102	1,102	1,102	
Benzo(a)Anthracene	0	0	0	0.5	0.5	1.84	1.84	1.84	
Benzo(e)Pyrene	0	0	0	N/A	N/A	N/A	N/A	N/A	

Benzo(k)Fluoranthene	0	0	0	0	N/A	N/A	N/A	N/A	110,187
Bis(2-Chloroethyl)Ether	0	0	0	0	30,000	30,000	30,000	N/A	
Bis(2-Chloroisopropyl)Ether	0	0	0	0	N/A	N/A	N/A	N/A	
Bis(2-Ethylhexyl)Phthalate	0	0	0	0	4,500	4,500	4,500	16,528	
4-Bromophenyl Phenyl Ether	0	0	0	0	270	270	270	992	
Butyl Benzyl Phthalate	0	0	0	0	140	140	140	514	
2-Chloronaphthalene	0	0	0	0	N/A	N/A	N/A	N/A	
Chrysene	0	0	0	0	N/A	N/A	N/A	N/A	
Dibenzo(a,h)Anthracene	0	0	0	0	N/A	N/A	N/A	N/A	
1,2-Dichlorobenzene	0	0	0	0	820	820	820	3,012	
1,3-Dichlorobenzene	0	0	0	0	350	350	350	1,286	
1,4-Dichlorobenzene	0	0	0	0	730	730	730	2,681	
3,3-Dichlorobenzidine	0	0	0	0	N/A	N/A	N/A	N/A	
Diethyl Phthalate	0	0	0	0	4,000	4,000	4,000	14,692	
Dimethyl Phthalate	0	0	0	0	2,500	2,500	2,500	9,182	
Di-n-Butyl Phthalate	0	0	0	0	110	110	110	404	
2,4-Dinitrotoluene	0	0	0	0	1,600	1,600	1,600	5,877	
2,6-Dinitrotoluene	0	0	0	0	990	990	990	3,636	
1,2-Diphenylhydrazine	0	0	0	0	15	15	15.0	55.1	
Fluoranthene	0	0	0	0	200	200	200	735	
Fluorene	0	0	0	0	N/A	N/A	N/A	N/A	
Hexachlorobenzene	0	0	0	0	N/A	N/A	N/A	N/A	
Hexachlorobutadiene	0	0	0	0	10	10	10.0	36.7	
Hexachlorocyclopentadiene	0	0	0	0	5	5	5.0	18.4	
Hexachloroethane	0	0	0	0	60	60	60.0	220	
Indeno(1,2,3-cd)Pyrene	0	0	0	0	N/A	N/A	N/A	N/A	
Isophorone	0	0	0	0	10,000	10,000	10,000	36,729	
Naphthalene	0	0	0	0	140	140	140	514	
Nitrobenzene	0	0	0	0	4,000	4,000	4,000	14,692	
n-Nitrosodimethylamine	0	0	0	0	17,000	17,000	17,000	62,439	
n-Nitrosodi-n-Propylamine	0	0	0	0	N/A	N/A	N/A	N/A	
n-Nitrosodiphenylamine	0	0	0	0	300	300	300	1,102	
Phenanthrene	0	0	0	0	5	5	5.0	18.4	
Pyrene	0	0	0	0	N/A	N/A	N/A	N/A	
1,2,4-Trichlorobenzene	0	0	0	0	130	130	130	477	

CFC CCT (min): 720 PMF: 0.801 Analysis Hardness (mg/l): 249.39 Analysis pH: 7.00

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	4,294	
Total Arsenic	0	0		0	150	150	2,928	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	80,025	
Total Boron	0	0		0	1,600	1,600	31,229	

Total Cadmium	0	0	0	0	0.464	0.53	10.4	Chem Translator of 0.871 applied
Total Chromium (III)	0	0	0	0	156.855	182	3,555	Chem Translator of 0.88 applied
Hexavalent Chromium	0	0	0	0	10	10.4	203	Chem Translator of 0.962 applied
Total Cobalt	0	0	0	0	19	18.0	371	
Total Copper	0	0	0	0	19,554	20.4	398	Chem Translator of 0.98 applied
Free Cyanide	0	0	0	0	5.2	5.2	101	
Dissolved Iron	0	0	0	0	N/A	N/A	N/A	
Total Iron	0	0	0	0	1,500	1,500	36,183	WQC = 30 day average; PMF = 1
Total Lead	0	0	0	0	6,699	10.2	199	Chem Translator of 0.658 applied
Total Manganese	0	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0	0.770	0.91	17.7	Chem Translator of 0.85 applied
Total Nickel	0	0	0	0	112,871	113	2,206	Chem Translator of 0.997 applied
Total Phenolics (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	0	4,600	4.99	97.4	Chem Translator of 0.922 applied
Total Silver	0	0	0	0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0	0	0	13	13.0	254	
Total Zinc	0	0	0	0	256,250	260	5,073	Chem Translator of 0.988 applied
Acrolein	0	0	0	0	3	3.0	58.6	
Acrylamide	0	0	0	0	N/A	N/A	N/A	
Acrylonitrile	0	0	0	0	130	130	2,537	
Benzene	0	0	0	0	130	130	2,537	
Bromoform	0	0	0	0	370	370	7,222	
Carbon Tetrachloride	0	0	0	0	560	560	10,930	
Chlorobenzene	0	0	0	0	240	240	4,684	
Chlorobromomethane	0	0	0	0	N/A	N/A	N/A	
2-Chloroethyl Vinyl Ether	0	0	0	0	3,500	3,500	68,314	
Chloroform	0	0	0	0	390	390	7,812	
Dichlorobromomethane	0	0	0	0	N/A	N/A	N/A	
1,2-Dichloroethane	0	0	0	0	3,100	3,100	60,507	
1,1-Dichloroethylene	0	0	0	0	1,500	1,500	29,277	
1,2-Dichloropropane	0	0	0	0	2,200	2,200	42,940	
1,3-Dichloropropylene	0	0	0	0	61	61.0	1,191	
Ethylbenzene	0	0	0	0	580	580	11,321	
Methylene Chloride	0	0	0	0	2,400	2,400	46,844	
1,1,2,2-Tetrachloroethane	0	0	0	0	210	210	4,099	
Tetrachloroethylene	0	0	0	0	140	140	2,733	
Toluene	0	0	0	0	330	330	6,441	
1,2-trans-Dichloroethylene	0	0	0	0	1,400	1,400	27,326	
1,1,1-Trichloroethane	0	0	0	0	610	610	11,906	
1,1,2-Trichloroethane	0	0	0	0	680	680	13,272	
Trichloroethylene	0	0	0	0	450	450	8,763	
Vinyl Chloride	0	0	0	0	N/A	N/A	N/A	
2-Chlorophenol	0	0	0	0	110	110	2,147	
2,4-Dichlorophenol	0	0	0	0	340	340	6,636	
2,4-Dimethylphenol	0	0	0	0	130	130	2,537	
2,4-Dinitrophenol	0	0	0	0	130	130	2,537	
2-Nitrophenol	0	0	0	0	1,600	1,600	31,229	

4-Nitrophenol	0	0	0	0	470	470	9,174	
Pentachlorophenol	0	0	0	0	6,693	6,69	131	
Phenol	0	0	0	0	N/A	N/A	N/A	
2,4,6-Trichlorophenol	0	0	0	0	91	91.0	1,776	
Acenaphthene	0	0	0	0	17	17.0	332	
Anthracene	0	0	0	0	N/A	N/A	N/A	
Benzidine	0	0	0	0	59	59.0	1,152	
Benzo(a)Anthracene	0	0	0	0	0.1	0.1	1.95	
Benzo(a)Pyrene	0	0	0	0	N/A	N/A	N/A	
Benzo(k)Fluoranthene	0	0	0	0	N/A	N/A	N/A	
Bis(2-Chloroethyl)Ether	0	0	0	0	6,000	6,000	117,110	
Bis(2-Chloroisopropyl)Ether	0	0	0	0	N/A	N/A	N/A	
Bis(2-Ethylhexyl)Phthalate	0	0	0	0	910	910	17,762	
4-Bromophenyl Phenyl Ether	0	0	0	0	54	54.0	1,054	
Butyl Benzyl Phthalate	0	0	0	0	35	35.0	683	
2-Chloronaphthalene	0	0	0	0	N/A	N/A	N/A	
Chrysene	0	0	0	0	N/A	N/A	N/A	
Dibenzo(a,h)Anthracene	0	0	0	0	N/A	N/A	N/A	
1,2-Dichlorobenzene	0	0	0	0	160	160	3,123	
1,3-Dichlorobenzene	0	0	0	0	69	69.0	1,347	
1,4-Dichlorobenzene	0	0	0	0	150	150	2,928	
3,3-Dichlorobenzidine	0	0	0	0	N/A	N/A	N/A	
Diethyl Phthalate	0	0	0	0	800	800	15,615	
Dimethyl Phthalate	0	0	0	0	500	500	9,759	
Di-n-Butyl Phthalate	0	0	0	0	21	21.0	410	
2,4-Dinitrotoluene	0	0	0	0	320	320	6,246	
2,6-Dinitrotoluene	0	0	0	0	200	200	3,904	
1,2-Diphenylhydrazine	0	0	0	0	3	3.0	58.6	
Fluoranthene	0	0	0	0	40	40.0	781	
Fluorene	0	0	0	0	N/A	N/A	N/A	
Hexachlorobenzene	0	0	0	0	N/A	N/A	N/A	
Hexachlorobutadiene	0	0	0	0	2	2.0	39.0	
Hexachlorocyclopentadiene	0	0	0	0	1	1.0	19.5	
Hexachloroethane	0	0	0	0	12	12.0	234	
Indeno(1,2,3-cd)Pyrene	0	0	0	0	N/A	N/A	N/A	
Isophorone	0	0	0	0	2,100	2,100	40,988	
Naphthalene	0	0	0	0	43	43.0	839	
Nitrobenzene	0	0	0	0	810	810	15,810	
n-Nitrosodimethylamine	0	0	0	0	3,400	3,400	66,362	
n-Nitrosodi-n-Propylamine	0	0	0	0	N/A	N/A	N/A	
n-Nitrosodiphenylamine	0	0	0	0	59	59.0	1,152	
Phenanthrene	0	0	0	0	1	1.0	19.5	
Pyrene	0	0	0	0	N/A	N/A	N/A	
1,2,4-Trichlorobenzene	0	0	0	0	26	26.0	507	

THH CCT (min): 720 PMF: 0.801 Analysis Hardness (mg/l): N/A Analysis pH: N/A
Model Results 10/6/2022 Page 9

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	5.8	5.8	109	
Total Arsenic	0	0		0	10	10.0	195	
Total Barium	0	0		0	2,400	2,400	48,844	
Total Boron	0	0		0	3,100	3,100	60,507	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Free Cyanide	0	0		0	4	4.0	78.1	
Dissolved Iron	0	0		0	300	300	5,855	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	19,518	
Total Mercury	0	0		0	0.050	0.05	0.98	
Total Nickel	0	0		0	810	810	11,908	
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	0.24	0.24	4.68	
Total Zinc	0	0		0	N/A	N/A	N/A	
Acrolein	0	0		0	3	3.0	58.6	
Acrylamide	0	0		0	N/A	N/A	N/A	
Acrylonitrile	0	0		0	N/A	N/A	N/A	
Benzene	0	0		0	N/A	N/A	N/A	
Bromoform	0	0		0	N/A	N/A	N/A	
Carbon Tetrachloride	0	0		0	N/A	N/A	N/A	
Chlorobenzene	0	0		0	100	100.0	1,952	
Chlorodibromomethane	0	0		0	N/A	N/A	N/A	
2-Chloroethyl Vinyl Ether	0	0		0	N/A	N/A	N/A	
Chloroform	0	0		0	5.7	5.7	111	
Dichlorobromomethane	0	0		0	N/A	N/A	N/A	
1,2-Dichloroethane	0	0		0	N/A	N/A	N/A	
1,1-Dichloroethylene	0	0		0	33	33.0	644	
1,2-Dichloropropane	0	0		0	N/A	N/A	N/A	
1,3-Dichloropropylene	0	0		0	N/A	N/A	N/A	
Ethylbenzene	0	0		0	68	68.0	1,327	
Methylene Chloride	0	0		0	N/A	N/A	N/A	
1,1,2,2-Tetrachloroethane	0	0		0	N/A	N/A	N/A	
Tetrachloroethylene	0	0		0	N/A	N/A	N/A	
Toluene	0	0		0	57.106	57.106	1,113	

Nitrobenzene	0	0	0	0	10	10.0	195
n-Nitrosodimethylamine	0	0	0	0	N/A	N/A	N/A
n-Nitrosodi-n-Propylamine	0	0	0	0	N/A	N/A	N/A
n-Nitrosodiphenylamine	0	0	0	0	N/A	N/A	N/A
Phenanthrene	0	0	0	0	N/A	N/A	N/A
Pyrene	0	0	0	0	20	20.0	390
1,2,4-Trichlorobenzene	0	0	0	0	0.07	0.07	1.37

CCT (min): ##### PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Free Cyanide	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	
Acrolein	0	0		0	N/A	N/A	N/A	
Acrylamide	0	0		0	0.07	0.07	7.06	
Acrylonitrile	0	0		0	0.06	0.06	6.05	
Benzene	0	0		0	0.58	0.58	58.5	
Bromoform	0	0		0	7	7.0	706	
Carbon Tetrachloride	0	0		0	0.4	0.4	40.3	
Chlorobenzene	0	0		0	N/A	N/A	N/A	
Chlorodibromomethane	0	0		0	0.8	0.8	80.7	
2-Chloroethyl Vinyl Ether	0	0		0	N/A	N/A	N/A	
Chloroform	0	0		0	N/A	N/A	N/A	

Dichlorobromomethane	0	0	0	0	0.95	0.95	95.8
1,2-Dichloroethane	0	0	0	0	9.9	9.9	998
1,1-Dichloroethylene	0	0	0	0	N/A	N/A	N/A
1,2-Dichloropropane	0	0	0	0	0.9	0.9	90.7
1,3-Dichloropropylene	0	0	0	0	0.27	0.27	27.2
Ethylbenzene	0	0	0	0	N/A	N/A	N/A
Methylene Chloride	0	0	0	0	20	20.0	2,016
1,1,2,2-Tetrachloroethane	0	0	0	0	0.2	0.2	20.2
Tetrachloroethylene	0	0	0	0	10	10.0	1,008
Toluene	0	0	0	0	N/A	N/A	N/A
1,2-trans-Dichloroethylene	0	0	0	0	N/A	N/A	N/A
1,1,1-Trichloroethane	0	0	0	0	N/A	N/A	N/A
1,1,2-Trichloroethane	0	0	0	0	0.55	0.55	55.4
Trichloroethylene	0	0	0	0	0.6	0.6	60.5
Vinyl Chloride	0	0	0	0	0.02	0.02	2.02
2-Chlorophenol	0	0	0	0	N/A	N/A	N/A
2,4-Dichlorophenol	0	0	0	0	N/A	N/A	N/A
2,4-Dimethylphenol	0	0	0	0	N/A	N/A	N/A
2,4-Dinitrophenol	0	0	0	0	N/A	N/A	N/A
2-Nitrophenol	0	0	0	0	N/A	N/A	N/A
4-Nitrophenol	0	0	0	0	N/A	N/A	N/A
Pentachlorophenol	0	0	0	0	0.030	0.03	3.02
Phenol	0	0	0	0	N/A	N/A	N/A
2,4,6-Trichlorophenol	0	0	0	0	1.5	1.5	151
Acenaphthene	0	0	0	0	N/A	N/A	N/A
Anthracene	0	0	0	0	N/A	N/A	N/A
Benzdine	0	0	0	0	0.0001	0.0001	0.01
Benzo(a)Anthracene	0	0	0	0	0.001	0.001	0.1
Benzo(a)Pyrene	0	0	0	0	0.0001	0.0001	0.01
Benzo(k)Fluoranthene	0	0	0	0	0.01	0.01	1.01
Bis(2-Chloroethyl)Ether	0	0	0	0	0.03	0.03	3.02
Bis(2-Chloroisopropyl)Ether	0	0	0	0	N/A	N/A	N/A
Bis(2-Ethylhexyl)Phthalate	0	0	0	0	0.32	0.32	32.3
4-Bromophenyl Phenyl Ether	0	0	0	0	N/A	N/A	N/A
Butyl Benzyl Phthalate	0	0	0	0	N/A	N/A	N/A
2-Chloronaphthalene	0	0	0	0	N/A	N/A	N/A
Chrysene	0	0	0	0	0.12	0.12	12.1
Dibenzo(a,h)Anthracene	0	0	0	0	0.0001	0.0001	0.01
1,2-Dichlorobenzene	0	0	0	0	N/A	N/A	N/A
1,3-Dichlorobenzene	0	0	0	0	N/A	N/A	N/A
1,4-Dichlorobenzene	0	0	0	0	N/A	N/A	N/A
3,3-Dichlorobenzidine	0	0	0	0	0.05	0.05	5.04
Diethyl Phthalate	0	0	0	0	N/A	N/A	N/A
Dimethyl Phthalate	0	0	0	0	N/A	N/A	N/A
Di-n-Butyl Phthalate	0	0	0	0	N/A	N/A	N/A
2,4-Dinitrotoluene	0	0	0	0	0.05	0.05	5.04
Model Result 2,6-Dinitrotoluene	0	0	0	0	0.05	0.05	5.04

1,2-Diphenylhydrazine	0	0	0	0	0.03	0.03	3.02			
Fluoranthene	0	0	0	0	N/A	N/A	N/A			
Fluorene	0	0	0	0	N/A	N/A	N/A			
Hexachlorobenzene	0	0	0	0	0.00008	0.00008	0.008			
Hexachlorobutadiene	0	0	0	0	0.01	0.01	1.01			
Hexachlorocyclopentadiene	0	0	0	0	N/A	N/A	N/A			
Hexachloroethane	0	0	0	0	0.1	0.1	10.1			
Indeno(1,2,3-cd)Pyrene	0	0	0	0	0.001	0.001	0.1			
Isophorone	0	0	0	0	N/A	N/A	N/A			
Naphthalene	0	0	0	0	N/A	N/A	N/A			
Nitrobenzene	0	0	0	0	N/A	N/A	N/A			
n-Nitrosodimethylamine	0	0	0	0	0.0007	0.0007	0.071			
n-Nitrosodi-n-Propylamine	0	0	0	0	0.005	0.005	0.5			
n-Nitrosodiphenylamine	0	0	0	0	3.3	3.3	333			
Phenanthrene	0	0	0	0	N/A	N/A	N/A			
Pyrene	0	0	0	0	N/A	N/A	N/A			
1,2,4-Trichlorobenzene	0	0	0	0	N/A	N/A	N/A			

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits			Concentration Limits			Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	1,766	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	109	µg/L	Discharge Conc ≤ 10% WQBEL
Total Arsenic	195	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	46,844	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	19,069	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cadmium	10.4	µg/L	Discharge Conc < TQL
Total Chromium (III)	3,555	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	38.4	µg/L	Discharge Conc ≤ 10% WQBEL

Model Results
10/6/2022

Total Cobalt	224	µg/L	Discharge Conc ≤ 10% WQBEL
Total Copper	104	µg/L	Discharge Conc ≤ 10% WQBEL
Free Cyanide	51.8	µg/L	Discharge Conc ≤ 25% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	5,855	µg/L	Discharge Conc < TQL
Total Iron	36,183	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	199	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	19,518	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.98	µg/L	Discharge Conc < TQL
Total Nickel	2,206	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)			PWS Not Applicable
Total Selenium	97.4	µg/L	Discharge Conc ≤ 10% WQBEL
Total Silver	39.6	µg/L	Discharge Conc < TQL
Total Thallium	4.68	µg/L	Discharge Conc < TQL
Total Zinc	588	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS
Acrolein	7.06	µg/L	Discharge Conc < TQL
Acrylamide	7.06	µg/L	Discharge Conc ≤ 25% WQBEL
Acrylonitrile	6.05	µg/L	Discharge Conc < TQL
Benzene	68.5	µg/L	Discharge Conc < TQL
Bromoform	706	µg/L	Discharge Conc < TQL
Carbon Tetrachloride	40.3	µg/L	Discharge Conc < TQL
Chlorobenzene	1,952	µg/L	Discharge Conc ≤ 25% WQBEL
Chlorobromomethane	80.7	µg/L	Discharge Conc ≤ 25% WQBEL
Chloroethane	N/A	N/A	No WQS
2-Chloroethyl Vinyl Ether	42,375	µg/L	Discharge Conc < TQL
Chloroform	111	µg/L	Discharge Conc ≤ 25% WQBEL
Dichlorobromomethane	95.8	µg/L	Discharge Conc < TQL
1,1-Dichloroethane	N/A	N/A	No WQS
1,2-Dichloroethane	998	µg/L	Discharge Conc < TQL
1,1-Dichloroethylene	644	µg/L	Discharge Conc < TQL
1,2-Dichloropropane	60.7	µg/L	Discharge Conc < TQL
1,3-Dichloropropylene	27.2	µg/L	Discharge Conc < TQL
1,4-Dioxane	N/A	N/A	No WQS
Ethylbenzene	1,327	µg/L	Discharge Conc < TQL
Methylene Chloride	2,016	µg/L	Discharge Conc < TQL
1,1,2,2-Tetrachloroethane	20.2	µg/L	Discharge Conc < TQL
Tetrachloroethylene	1,008	µg/L	Discharge Conc < TQL
Toluene	1,113	µg/L	Discharge Conc < TQL
1,2-trans-Dichloroethylene	1,952	µg/L	Discharge Conc < TQL
1,1,1-Trichloroethane	7,083	µg/L	Discharge Conc < TQL
1,1,2-Trichloroethane	55.4	µg/L	Discharge Conc < TQL
Trichloroethylene	60.5	µg/L	Discharge Conc < TQL
Vinyl Chloride	2.02	µg/L	Discharge Conc < TQL
2-Chlorophenol	586	µg/L	Discharge Conc < TQL
2,4-Dichlorophenol	195	µg/L	Discharge Conc < TQL
2,4,6-Trichlorophenol	1,554	µg/L	Discharge Conc < TQL

Model Results 4-Dimethylphenol 10/18/2022

2,4-Dinitrophenol	195	µg/L	Discharge Conc < TQL
2-Nitrophenol	18,833	µg/L	Discharge Conc < TQL
4-Nitrophenol	5,415	µg/L	Discharge Conc < TQL
Pentachlorophenol	3.02	µg/L	Discharge Conc < TQL
Phenol	78,073	µg/L	Discharge Conc < TQL
2,4,6-Trichlorophenol	151	µg/L	Discharge Conc < TQL
Acenaphthene	195	µg/L	Discharge Conc < TQL
Acenaphthylene	N/A	N/A	No WQS
Anthracene	5,855	µg/L	Discharge Conc < TQL
Benzdine	0.01	µg/L	Discharge Conc < TQL
Benzo(a)Anthracene	0.1	µg/L	Discharge Conc < TQL
Benzo(a)Pyrene	0.01	µg/L	Discharge Conc < TQL
Benzo(ghi)Perylene	N/A	N/A	No WQS
Benzo(k)Fluoranthene	1.01	µg/L	Discharge Conc < TQL
Bis(2-Chloroethoxy)Methane	N/A	N/A	No WQS
Bis(2-Chloroethyl)Ether	3.02	µg/L	Discharge Conc < TQL
Bis(2-Chloroisopropyl)Ether	3,904	µg/L	Discharge Conc < TQL
Bis(2-Ethylhexyl)Phthalate	32.3	µg/L	Discharge Conc < TQL
4-Bromophenyl Phenyl Ether	636	µg/L	Discharge Conc < TQL
Butyl Benzyl Phthalate	1.95	µg/L	Discharge Conc < TQL
2-Chloronaphthalene	15,615	µg/L	Discharge Conc < TQL
4-Chlorophenyl Phenyl Ether	N/A	N/A	No WQS
Chrysene	12.1	µg/L	Discharge Conc < TQL
Dibenzo(a,h)Anthracene	0.01	µg/L	Discharge Conc < TQL
1,2-Dichlorobenzene	1,930	µg/L	Discharge Conc < TQL
1,3-Dichlorobenzene	137	µg/L	Discharge Conc < TQL
1,4-Dichlorobenzene	1,719	µg/L	Discharge Conc < TQL
3,3-Dichlorobenzidine	5.04	µg/L	Discharge Conc < TQL
Diethyl Phthalate	9,417	µg/L	Discharge Conc < TQL
Dimethyl Phthalate	5,885	µg/L	Discharge Conc < TQL
Di-n-Butyl Phthalate	259	µg/L	Discharge Conc < TQL
2,4-Dinitrotoluene	5.04	µg/L	Discharge Conc < TQL
2,6-Dinitrotoluene	5.04	µg/L	Discharge Conc < TQL
Di-n-Octyl Phthalate	N/A	N/A	No WQS
1,2-Diphenylhydrazine	3.02	µg/L	Discharge Conc < TQL
Fluoranthene	390	µg/L	Discharge Conc < TQL
Fluorene	976	µg/L	Discharge Conc < TQL
Hexachlorobenzene	0.008	µg/L	Discharge Conc < TQL
Hexachlorobutadiene	1.01	µg/L	Discharge Conc < TQL
Hexachlorocyclopentadiene	11.8	µg/L	Discharge Conc < TQL
Hexachloroethane	10.1	µg/L	Discharge Conc < TQL
Indeno(1,2,3-cd)Pyrene	0.1	µg/L	Discharge Conc < TQL
Isophorone	664	µg/L	Discharge Conc < TQL
Naphthalene	330	µg/L	Discharge Conc < TQL
Nitrobenzene	195	µg/L	Discharge Conc < TQL
n-Nitrosodimethylamine	0.071	µg/L	Discharge Conc < TQL
n-Nitrosodi-n-Propylamine	0.5	µg/L	Discharge Conc < TQL

Model Ref: 10/18/2022

n-Nitrosodiphenylamine	333	µg/L	Discharge Conc < TQL
Phenanthrene	11.8	µg/L	Discharge Conc < TQL
Pyrene	390	µg/L	Discharge Conc < TQL
1,2,4-Trichlorobenzene	1.37	µg/L	Discharge Conc < TQL

4. Total Mercury

Dear Permittee:

The Department of Environmental Protection (DEP) has reviewed your NPDES permit application and has reached a preliminary finding that new or more stringent water quality-based effluent limitations (WQBELs) for toxic pollutant(s) should be established in the permit. This finding is based on DEP's assessment that reasonable potential exists to exceed water quality criteria under Chapter 93 in the receiving waters during design flow conditions. The following WQBELs are anticipated based on the information available to DEP during its review:

Outfall No.	Pollutant	Average Monthly ($\mu\text{g/L}$)	Maximum Daily ($\mu\text{g/L}$)	IMAX ($\mu\text{g/L}$)
001	Total Mercury	0.98	1.52	2.44

Attached is a survey that DEP requests that you complete and return to DEP in 30 days. Completion of this survey will help DEP develop the draft NPDES permit and allow DEP to understand your current capabilities or plans to treat or control these pollutant(s). If you decide not to complete and return the survey, DEP will proceed with developing the draft NPDES permit based on all available information and certain assumptions. Your response to this notice does not constitute an official comment for DEP response but will be taken under consideration. When the draft NPDES permit is formally noticed in the *Pennsylvania Bulletin*, you may make official comments for DEP's further consideration and response.

Please contact me if you have any questions about this information or the attached survey.

Sincerely,

Jinsu Kim
Environmental Engineering Specialist
Clean Water Program



**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
PRE-DRAFT PERMIT SURVEY FOR TOXIC POLLUTANTS**

Permittee Name: Mechanicsburg Borough Cumberland County Permit No.: PA0020885

Pollutant(s) identified by DEP that may require WQBELs: Total Mercury

Is the permittee aware of the source(s) of the pollutant(s)? Yes No Suspected

If Yes or Suspected, describe the known or suspected source(s) of pollutant(s) in the effluent.

Infiltration of Ground Water and precipitation-induced I/I appears to be increasing concentration in influent; possibly failed seals on trickling filter distributors may increase concentration in effluent. Current influent testing is being performed and indicates that groundwater and I/I increases the concentration in the WWTP influent.

Has the permittee completed any studies in the past to control or treat the pollutant(s)? Yes No

If Yes, describe prior studies and results:

Does the permittee believe it can achieve the proposed WQBELs now? Yes No Uncertain

If No, describe the activities, upgrades or process changes that would be necessary to achieve the WQBELs, if known.

Continue to analyze influent samples to confirm suspected increase of pollutant from groundwater and/or precipitation-induced I/I; determine ability to limit I/I into WWTP. Although a low likelihood, if pollutant concentration in effluent is a result of trickling filter seal failure, replace the seals on the trickling filter distributors.

Estimated date by which the permittee could achieve the proposed WQBELs: _____ Uncertain

Will the permittee conduct additional sampling for the pollutant(s) to supplement the application? Yes No

Check the appropriate box(es) below to indicate site-specific data that have been collected by the permittee in the past. If any of these data have not been submitted to DEP, please attach to this survey.

- | | |
|---|------------------|
| <input type="checkbox"/> Discharge pollutant concentration coefficient(s) of variability | Year(s) Studied: |
| <input type="checkbox"/> Discharge and background Total Hardness concentrations (metals) | Year(s) Studied: |
| <input type="checkbox"/> Background / ambient pollutant concentrations | Year(s) Studied: |
| <input type="checkbox"/> Chemical translator(s) (metals) | Year(s) Studied: |
| <input type="checkbox"/> Slope and width of receiving waters | Year(s) Studied: |
| <input type="checkbox"/> Velocity of receiving waters at design conditions | Year(s) Studied: |
| <input type="checkbox"/> Acute and/or chronic partial mix factors (mixing at design conditions) | Year(s) Studied: |
| <input type="checkbox"/> Volatilization rates (highly volatile organics) | Year(s) Studied: |
| <input type="checkbox"/> Site-specific criteria (e.g., Water Effect Ratio or related study) | Year(s) Studied: |

Please submit this survey to the DEP regional office that is reviewing the permit application within 30 days of receipt.

Kim, Jin Su

From: Mendinsky, Justin <jmendinsky@hrg-inc.com>
Sent: Thursday, June 23, 2022 4:43 PM
To: Kim, Jin Su; Curtis Huey
Cc: Martin, Daniel; Luongo, Erica; Pollart, Yves
Subject: RE: [External] RE: Mechanicsburg Borough NPDES Permit Renewal Application
Attachments: PA0020885 Pre-Draft Permit Survey (Total Mercury) (002).docx

Hi Jinsu. Please see attached survey form. Thank you.

Justin J. Mendinsky, PE
Group Manager | Water & Wastewater

HERBERT, ROWLAND & GRUBIC, INC.
369 East Park Drive
Harrisburg, PA 17111
717.564.1121 (o) | 717.461.6864 (c)
jmendinsky@hrg-inc.com | [vCard](#)
hrg-inc.com | [LinkedIn](#) | [Facebook](#)



From: Kim, Jin Su <jikim@pa.gov>
Sent: Wednesday, June 22, 2022 8:08 AM
To: Mendinsky, Justin <jmendinsky@hrg-inc.com>; Curtis Huey <chuey@mechanicsburgborough.org>
Cc: Martin, Daniel <daniemarti@pa.gov>; Luongo, Erica <eluongo@hrg-inc.com>; Pollart, Yves <ypollart@hrg-inc.com>
Subject: RE: [External] RE: Mechanicsburg Borough NPDES Permit Renewal Application

Hi Justin,

That is fine. However, could you please complete and submit the survey form I provided previously by the end of this week?

Jinsu

Jinsu Kim | Permits Section
Department of Environmental Protection | Clean Water Program
Southcentral Regional Office
909 Elmerton Avenue | Harrisburg, Pa 17110-8200
Phone: 717.705.4825 | Fax: 717.705.4760
www.dep.state.pa.us

From: Mendinsky, Justin <jmendinsky@hrg-inc.com>
Sent: Monday, June 20, 2022 11:46 AM
To: Kim, Jin Su <jikim@pa.gov>; Curtis Huey <chuey@mechanicsburgborough.org>

Kim, Jin Su

From: Curtis Huey <chuey@mechanicsburgborough.org>
Sent: Wednesday, October 5, 2022 10:11 AM
To: Kim, Jin Su; Mendinsky, Justin
Cc: Martin, Daniel; Luongo, Erica; Pollart, Yves
Subject: RE: [External] RE: Mechanicsburg Borough NPDES Permit Renewal Application

Jin Su,

Below are the results of 10 additional mercury tests for our NPDES permit renewal.

Curtis

Date	Influent					Effluent				
	Flow (MGD)	Hg (mg/L)	Hg (mg/L)	Hg (lbs/day)	Hg (lbs/day)	Flow (MGD)	Hg (mg/L)	Hg (mg/L)	Hg (mg/L)	Hg (mg/L)
8/16/2022	0.658	<	0.0002	<	0.0011	0.554	<	0.0002	<	0.0002
8/18/2022	0.706		0.0004		0.00236	0.594	<	0.0002	<	0.0002
8/23/2022	0.666	<	0.0002	<	0.00111	0.559	<	0.0002	<	0.0002
8/24/2022	0.675	<	0.0002	<	0.00113	0.573	<	0.0002	<	0.0002
8/25/2022	0.715	<	0.0002	<	0.00119	0.631	<	0.0002	<	0.0002
8/30/2022	0.799	<	0.0002	<	0.00133	0.657	<	0.0002	<	0.0002
9/5/2022	0.924	<	0.0002	<	0.00154	0.885	<	0.0002	<	0.0002
9/7/2022	0.752	<	0.0002	<	0.00125	0.681	<	0.0002	<	0.0002
9/12/2022	0.705	<	0.0002	<	0.00118	0.639	<	0.0002	<	0.0002
9/14/2022	0.656		0.0003		0.00164	0.538	<	0.0002	<	0.0002

5. TRC_CALC Worksheet

TRC_CALC

1A	B	C	D	E	F	G
2	TRC EVALUATION					
3	Input appropriate values in B4:B8 and E4:E7					
4	74.4	= Q stream (cfs)		0.5	= CV Daily	
5	2.08	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		1	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.45	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)			= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations	Reference	CFC Calculations	
11	TRC	1.3.2.iii	WLA_afc = 7.395	1.3.2.ii	WLA_cfc = 7.202	
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581	
13	PENTOXSD TRG	5.1b	LTA_afc = 2.755	5.1d	LTA_cfc = 4.187	
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.450		BAT/BPJ	
18			INST MAX LIMIT (mg/l) = 1.472			
	WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)]^2 (1 - FOS / 100)$				
	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
	LTA_afc	$wla_afc \cdot LTAMULT_afc$				
	WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)]^2 (1 - FOS / 100)$				
	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
	LTA_cfc	$wla_cfc \cdot LTAMULT_cfc$				
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
	AVG MON LIMIT	$MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$				
	INST MAX LIMIT	$1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$				

7. Whole Effluent Toxicity Analysis Spreadsheet

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet					
Type of Test	Chronic		Facility Name		
Species Tested	Pimephales		Mechanicsburg Borough		
Endpoint	Survival		Permit No.		
TIWC (decimal)	0.05		PA0020885		
No. Per Replicate	10				
TST b value	0.75				
TST alpha value	0.25				
Test Completion Date			Test Completion Date		
11/7/2017			5/21/2018		
Replicate No.	Control	TIWC	Replicate No.	Control	TIWC
1	10	10	1	10	10
2	10	10	2	9	10
3	10	9	3	10	10
4	9	8	4	10	10
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		
Mean	9.750	9.250	Mean	9.750	10.000
Std Dev.	0.500	0.957	Std Dev.	0.500	0.000
# Replicates	4	4	# Replicates	4	4
T-Test Result	3.3502		T-Test Result	12.5523	
Deg. of Freedom	4		Deg. of Freedom	3	
Critical T Value	0.7407		Critical T Value	0.7649	
Pass or Fail	PASS		Pass or Fail	PASS	
Test Completion Date			Test Completion Date		
8/7/2019			8/11/2020		
Replicate No.	Control	TIWC	Replicate No.	Control	TIWC
1	10	10	1	10	10
2	10	10	2	10	10
3	10	10	3	10	10
4	10	10	4	10	9
5			5		
6			6		
7			7		
8			8		
9			9		
10			10		
11			11		
12			12		
13			13		
14			14		
15			15		
Mean	10.000	10.000	Mean	10.000	9.750
Std Dev.	0.000	0.000	Std Dev.	0.000	0.500
# Replicates	4	4	# Replicates	4	4
T-Test Result			T-Test Result	7.6643	
Deg. of Freedom			Deg. of Freedom	3	
Critical T Value			Critical T Value	0.7649	
Pass or Fail	PASS		Pass or Fail	PASS	

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet						
Type of Test	Chronic		Facility Name			
Species Tested	Pimephales		Mechanicsburg Borough			
Endpoint	Growth		Permit No.			
TIWC (decimal)	0.05		PA0020885			
No. Per Replicate	10					
TST b value	0.75					
TST alpha value	0.25					
Test Completion Date			Test Completion Date			
Replicate	11/7/2017		Replicate	8/20/2018		
No.	Control	TIWC	No.	Control	TIWC	
1	0.256	0.391	1	0.573	0.477	
2	0.347	0.37	2	0.497	0.486	
3	0.402	0.24	3	0.603	0.51	
4	0.349	0.305	4	0.505	0.486	
5			5			
6			6			
7			7			
8			8			
9			9			
10			10			
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	0.339	0.327	Mean	0.545	0.480	
Std Dev.	0.081	0.088	Std Dev.	0.052	0.014	
# Replicates	4	4	# Replicates	4	4	
T-Test Result	1.7703		T-Test Result	3.9359		
Deg. of Freedom	5		Deg. of Freedom	5		
Critical T Value	0.7267		Critical T Value	0.7267		
Pass or Fail	PASS		Pass or Fail	PASS		
Test Completion Date			Test Completion Date			
Replicate	8/7/2019		Replicate	8/11/2020		
No.	Control	TIWC	No.	Control	TIWC	
1	0.223	0.347	1	0.428	0.493	
2	0.319	0.347	2	0.387	0.423	
3	0.309	0.35	3	0.377	0.499	
4	0.32	0.355	4	0.341	0.387	
5			5			
6			6			
7			7			
8			8			
9			9			
10			10			
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	0.293	0.350	Mean	0.378	0.446	
Std Dev.	0.047	0.004	Std Dev.	0.036	0.083	
# Replicates	4	4	# Replicates	4	4	
T-Test Result	7.3811		T-Test Result	4.7320		
Deg. of Freedom	3		Deg. of Freedom	4		
Critical T Value	0.7649		Critical T Value	0.7407		
Pass or Fail	PASS		Pass or Fail	PASS		

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet					
Type of Test	Chronic		Facility Name		
Species Tested	Ceriodaphnia		Mechanicsburg Borough		
Endpoint	Survival		Permit No.		
TIWC (decimal)	0.05		PA0020885		
No. Per Replicate	1				
TST b value	0.75				
TST alpha value	0.2				
Test Completion Date			Test Completion Date		
Replicate	11/7/2017		Replicate	8/20/2018	
No.	Control	TIWC	No.	Control	TIWC
1	1	1	1	1	1
2	1	1	2	1	1
3	1	1	3	1	1
4	1	1	4	1	1
5	1	1	5	1	1
6	1	1	6	1	1
7	1	1	7	1	1
8	1	1	8	1	1
9	1	1	9	1	1
10	1	1	10	1	1
11			11		
12			12		
13			13		
14			14		
15			15		
Mean	1.000	1.000	Mean	1.000	1.000
Std Dev.	0.000	0.000	Std Dev.	0.000	0.000
# Replicates	10	10	# Replicates	10	10
T-Test Result			T-Test Result		
Deg. of Freedom			Deg. of Freedom		
Critical T Value			Critical T Value		
Pass or Fail	PASS		Pass or Fail	PASS	
Test Completion Date			Test Completion Date		
Replicate	8/6/2019		Replicate	8/10/2020	
No.	Control	TIWC	No.	Control	TIWC
1	1	1	1	1	1
2	1	1	2	1	1
3	1	1	3	1	1
4	1	1	4	1	1
5	1	1	5	1	1
6	1	1	6	1	1
7	1	1	7	1	1
8	1	1	8	1	0
9	1	1	9	1	1
10	1	1	10	1	1
11			11		
12			12		
13			13		
14			14		
15			15		
Mean	1.000	1.000	Mean	1.000	0.900
Std Dev.	0.000	0.000	Std Dev.	0.000	0.316
# Replicates	10	10	# Replicates	10	10
T-Test Result			T-Test Result	1.5000	
Deg. of Freedom			Deg. of Freedom	9	
Critical T Value			Critical T Value	0.8834	
Pass or Fail	PASS		Pass or Fail	PASS	

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet						
Type of Test	Chronic		Facility Name			
Species Tested	Ceriodaphnia		Mechanicsburg Borough			
Endpoint	Reproduction		Permit No.			
TIWC (decimal)	0.05		PA0020885			
No. Per Replicate	10					
TST b value	0.75					
TST alpha value	0.2					
Test Completion Date			Test Completion Date			
Replicate	11/7/2017		Replicate	8/20/2018		
No.	Control	TIWC	No.	Control	TIWC	
1	24	26	1	27	32	
2	25	32	2	30	38	
3	34	30	3	31	40	
4	31	35	4	30	37	
5	30	26	5	30	32	
6	25	31	6	29	31	
7	34	28	7	38	34	
8	36	35	8	35	28	
9	32	33	9	34	34	
10	30	20	10	34	31	
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	30.100	29.600	Mean	31.800	33.500	
Std Dev.	4.202	4.695	Std Dev.	3.327	3.472	
# Replicates	10	10	# Replicates	10	10	
T-Test Result	3.9286		T-Test Result	7.1373		
Deg. of Freedom	16		Deg. of Freedom	16		
Critical T Value	0.8647		Critical T Value	0.8647		
Pass or Fail	PASS		Pass or Fail	PASS		
Test Completion Date			Test Completion Date			
Replicate	8/6/2019		Replicate	8/10/2020		
No.	Control	TIWC	No.	Control	TIWC	
1	32	38	1	16	16	
2	34	37	2	30	30	
3	30	33	3	28	35	
4	25	28	4	18	37	
5	36	36	5	34	38	
6	30	24	6	28	32	
7	33	46	7	22	34	
8	35	38	8	28	0	
9	30	37	9	30	36	
10	31	32	10	20	27	
11			11			
12			12			
13			13			
14			14			
15			15			
Mean	31.600	34.900	Mean	25.400	28.500	
Std Dev.	3.189	6.084	Std Dev.	5.987	11.909	
# Replicates	10	10	# Replicates	10	10	
T-Test Result	5.4381		T-Test Result	2.3489		
Deg. of Freedom	13		Deg. of Freedom	13		
Critical T Value	0.8702		Critical T Value	0.8702		
Pass or Fail	PASS		Pass or Fail	PASS		

WET Summary and Evaluation

Facility Name	Mechanicsburg Borough
Permit No.	PA0020885
Design Flow (MGD)	2.08
Q ₇₋₁₀ Flow (cfs)	74.4
PMF _a	0.116
PMF _c	0.801

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Survival	11/7/17	5/21/18	8/7/19	8/11/20
		PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Growth	11/7/17	8/20/18	8/7/19	8/11/20
		PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Survival	11/7/17	8/20/18	8/6/19	8/10/20
		PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Reproduction	11/7/17	8/20/18	8/6/19	8/10/20
		PASS	PASS	PASS	PASS

Reasonable Potential? NO

Permit Recommendations

Test Type Chronic
 TIWC 5 % Effluent
 Dilution Series 2, 5, 30, 60, 100 % Effluent
 Permit Limit None
 Permit Limit Species

