



Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Minor

Application No. PA0020940  
APS ID 598462  
Authorization ID 1464225

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<b>Tunkhannock Borough Municipal Authority</b>	Facility Name	<b>Tunkhannock Borough Municipal Authority</b>
Applicant Address	201 W. Tioga Street	Facility Address	26 McCord Street
	Tunkhannock, PA 18657-6655		Tunkhannock, PA 18657
Applicant Contact	Roger E. Hadsall, Manager	Facility Contact	Roger E. Hadsall, Manager
Applicant Phone	(570) 836-3493	Facility Phone	(570) 836-3493
Client ID	73970	Site ID	256620
Ch 94 Load Status	Existing overloads	Municipality	Tunkhannock Borough
Connection Status	No Limitations	County	Wyoming
Date Application Received	<u>November 27, 2023</u>	EPA Waived?	Yes
Date Application Accepted	<u>December 11, 2023</u>	If No, Reason	-
Purpose of Application	Renewal of NPDES permit for discharge of treated sewage.		

**Summary of Review**

The applicant is requesting the renewal of an NPDES permit to discharge up to 0.3 MGD of treated sewage into Tunkhannock Creek, a Trout Stocking, Migratory Fish (TSF, MF) receiving stream in State Water Plan Basin 4-F (Tunkhannock Creek). As per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than its designated use. This stream segment is not designated as a naturally reproducing trout stream as per PA Fish & Boat Commission. This discharge is not expected to affect public water supplies. The Tunkhannock Creek is impaired for Mercury by an unknown source.

Limitations for pH, CBOD<sub>5</sub>, Total Suspended Solids (TSS), and Fecal Coliform are technology-based and carried over from the previous permit.

A BPJ-based limitation of 5.0 mg/L for Dissolved Oxygen (DO) has been added to the permit. The new limit will come into effect three years after the permit effective date. Monitoring and reporting for DO will be required until the limitation becomes effective.

The BPJ based standard summertime effluent limitations for Ammonia-Nitrogen have been added to the permit. The limitations will come into effect three years after the permit effective date. Monitoring and reporting for Ammonia-Nitrogen will be required until the limitations become effective. Monitoring and reporting for Ammonia-Nitrogen in the wintertime will also be required at the permit effective date. WQM 7.0 modeling did not recommend stricter water quality limitations.

The Total Residual Chlorine (TRC) Calculation Spreadsheet did not recommend stricter limitations than the previous permit. The TRC limits from the previous permit have been maintained in this permit renewal.

Approve	Deny	Signatures	Date
X		 Allison Seyfried Zukosky / Project Manager	October 8, 2025
X		 Edward Dudick, P.E. / Environmental Engineer Manager	October 8, 2025

### Summary of Review

Sewage discharges now require monitoring and reporting for E. Coli. A monitoring frequency of 1/month for design flows >= 1 MGD, 1/quarter for design flows >= 0.05 and < 1 MGD, 1/year for design flows of 0.002 – 0.05 MGD will be utilized.

Pollutant sampling results submitted with the permit application were entered into the Toxic Management Spreadsheet (TMS). The TMS recommended monitoring and reporting for Total Copper. Therefore, quarterly monitoring and reporting has been added to the permit for Total Copper to gather more data for the next permit renewal.

The facility is a Phase 4 Non-Significant sewage facility in the Chesapeake Bay Watershed. Per the Phase 3 Watershed Implementation Plan Wastewater Supplement, the quarterly monitoring/reporting for Total Nitrogen, Total Phosphorous, Total Kjeldahl Nitrogen, and Nitrate-Nitrite as N has been increased to monthly in this permit.

Per current Standard Operating Procedures for Publicly Owned Treatment Plants, the raw sewage influent monitoring/reporting for TSS and BOD<sub>5</sub> has been maintained in the permit.

For this permit renewal, all monitoring frequencies for parameters with limitations are consistent with the Department's *Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits* (document no. 362-0400-001).

24-hour composite sampling is now required in place of 8-hour composite sampling.

Data from the upstream stream gage 1534000 (Tunkhannock Creek near Tunkhannock, PA) was used to model the discharge, resulting in a low flow yield (LFY) of 0.045 cfs/mi<sup>2</sup> and Q<sub>7-10</sub> of 18.63 cfs. For modeling inputs, RMI values were obtained using the "PA Historic Streams" feature of eMapPA, drainage areas were delineated using USGS's StreamStats Interactive Map, and elevations were obtained using the elevation profile feature of StreamStats.

The 2023 Chapter 94 Reports indicate there is existing organic overloading. The Report indicates that the high BOD<sub>5</sub> loadings in January 2019 and May 2022 were temporary and not representative of the true organic loading.

The existing permit expired on July 31, 2024 and the application for renewal was received on time.

A Water Management System Inspection query indicated that on August 21, 2023 a Compliance Evaluation was performed.

There are currently no open violations for this client that warrant withholding issuance of this permit.

Sludge use and disposal description and location(s): As per the permittee's NPDES Renewal Application, sludge is hauled to the Keystone Sanitary Landfill located in Dunmore, PA by J.P. Mascaro & Sons.

### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.3
Latitude	41° 32' 14.89"	Longitude	-75° 56' 34.88"
Quad Name	Tunkhannock	Quad Code	0638
Wastewater Description:	Sewage Effluent		
Receiving Waters	Tunkhannock Creek (TSF, MF)	Stream Code	28784
NHD Com ID	66407243	RMI	0.40
Drainage Area	414 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.045
Q <sub>7-10</sub> Flow (cfs)	18.63	Q <sub>7-10</sub> Basis	USGS Stream gage 1534000
Elevation (ft)	578.26	Slope (ft/ft)	-
Watershed No.	4-F	Chapter 93 Class.	TSF, MF
Existing Use	-	Existing Use Qualifier	-
Exceptions to Use	-	Exceptions to Criteria	-
Assessment Status	Impaired		
Cause(s) of Impairment	MERCURY		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status	-	Name	-
Nearest Downstream Public Water Supply Intake	Danville Municipal Water Authority		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	-
PWS RMI	122.5	Distance from Outfall (mi)	~ 81.5

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Tunkhannock Borough Municipal Authority				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
6612401	4/4/2012			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Contact Stabilization	Chlorination	0.215 (2020-2022)
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.3	620	Existing Organic Overload	Aerobic Digestion/Press	Hauled/Landfill

Compliance History

DMR Data for Outfall 001 (from August 1, 2024 to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.223	0.259	0.284	0.244	0.220	0.191	0.200	0.206	0.184	0.169	0.197	0.440
Flow (MGD) Daily Maximum	0.934	1.203	0.423	0.323	0.419	0.276	0.249	0.409	0.286	0.212	0.258	3.670
pH (S.U.) Instantaneous Minimum	7.2	7.3	7.4	6.8	7.0	7.0	7.1	7.0	6.9	7.0	7.1	7.0
pH (S.U.) Instantaneous Maximum	7.7	7.7	7.8	7.6	7.5	7.7	7.7	7.4	7.5	7.6	7.5	7.5
TRC (mg/L) Average Monthly	< 0.02	< 0.04	< 0.05	< 0.03	< 0.04	< 0.1	< 0.10	< 0.04	< 0.1	< 0.04	< 0.05	< 0.04
TRC (mg/L) Instantaneous Maximum	0.07	0.18	0.35	0.11	0.21	0.39	0.45	0.20	0.76	0.16	0.17	0.09
CBOD5 (lbs/day) Average Monthly	7.9	13.7	13.6	10.4	19.8	9.7	11.6	< 6.8	14.6	18.2	10.9	20.0
CBOD5 (lbs/day) Weekly Average	12	19	17	14	56	14	19	12	42	31	17	24
CBOD5 (mg/L) Average Monthly	5.0	7.0	6.0	5.0	7.0	6.0	7.0	< 4.0	10.0	13.0	7.0	11.0
CBOD5 (mg/L) Weekly Average	7.0	10.0	7.0	7.0	16.0	8.0	11.0	6.0	31.0	22.0	10.0	12.0
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	300	326	427	474	499	393	404	425	443	315	308	305
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	191	173	184	235	218	247	235	243	297	216	182	160
TSS (lbs/day) Average Monthly	8	16	15	12	20	22	21	18	17	14	9	11
TSS (lbs/day) Raw Sewage Influent   Average Monthly	59	62	99	105	115	152	203	256	343	196	182	134
TSS (lbs/day) Weekly Average	12	19	21	16	45	27	31	27	24	19	10	13

## NPDES Permit Fact Sheet

Tunkhannock Borough Municipal Authority

NPDES Permit No. PA0020940

TSS (mg/L) Average Monthly	5.0	8.0	< 6.0	6.0	8.0	14.0	12.0	9.0	12.0	10.0	5.0	6.0
TSS (mg/L) Raw Sewage Influent   Average Monthly	39	33	43	53	49	97	118	164	247	135	110	71
TSS (mg/L) Weekly Average	8.0	10.0	8.0	9.0	13.0	16.0	16.0	10.0	14.0	12.0	6.0	7.0
Fecal Coliform (No./100 ml) Geometric Mean	28	55	< 55	10	< 1	< 1	7	< 8	17	26	5	27
Fecal Coliform (No./100 ml) Instantaneous Maximum	260	210	1553	81	2	5	19	40	39	133	36	61
Nitrate-Nitrite (lbs/day) Average Quarterly		7.2			7.6			15.6			18.1	
Nitrate-Nitrite (mg/L) Average Quarterly		3.11			4.65			10.8			9.54	
Total Nitrogen (lbs/day) Average Quarterly		45.0			49.2			39.7			23.3	
Total Nitrogen (mg/L) Average Quarterly		19.4			30.1			27.5			12.3	
TKN (lbs/day) Average Quarterly		37.8			41.5			24.1			5.2	
TKN (mg/L) Average Quarterly		16.3			25.4			16.7			2.73	
Total Phosphorus (lbs/day) Average Quarterly		5.9			4.3			4.5			3.3	
Total Phosphorus (mg/L) Average Quarterly		2.55			2.65			3.10			1.75	

## Compliance History

Effluent Violations for Outfall 001, from: September 1, 2024 To: July 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	05/31/25	IMAX	1553	No./100 ml	1000	No./100 ml

## Development of Effluent Limitations

**Outfall No.** 001  
**Latitude** 41° 32' 15.00"  
**Wastewater Description:** Sewage Effluent

**Design Flow (MGD)** 0.3  
**Longitude** -75° 56' 29.00"

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25.0	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40.0	Average Weekly	133.102(a)(4)(ii)	
	50.0	IMAX	-	92a.47(a)(2)
Total Suspended Solids	30.0	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45.0	Average Weekly	133.102(b)(2)	
	60.0	IMAX	-	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
	1.6	IMAX		
E. Coli	Report	IMAX	-	92a.61
Dissolved Oxygen	5.0	Minimum	-	BPJ
Ammonia-Nitrogen May 1 - Oct 31	25.0	Average Monthly	-	BPJ
	50.0	IMAX		
Ammonia-Nitrogen Nov 1 - Apr 30	Report	Average Monthly		

### Water Quality-Based Limitations

The following limitations were determined through water quality modeling:

Parameter	Limit (mg/l)	SBC	Model
Total Copper	Report	Average Quarterly	Toxic Modeling Spreadsheet (TMS)
Biochemical Oxygen Demand (BOD <sub>5</sub> ) Raw Sewage Influent	Report	Average Monthly	POTW Requirement
Total Suspended Solids Raw Sewage Influent	Report	Average Monthly	
Total Nitrogen	Report	Average Monthly	Phase 3 Watershed Implementation Plan Wastewater Supplement
Total Phosphorus	Report	Average Monthly	
Nitrate-Nitrite as N	Report	Average Monthly	
Total Kjeldahl Nitrogen	Report	Average Monthly	

### Anti-Backsliding

No limitations were made less stringent.

## Modeling Using USGS Stream Gage

Stream Gage: 1534000 – Tunkhannock Creek near Tunkhannock, PA

Name	Value
USGS Station Number	01534000
Station Name	Tunkhannock Creek near Tunkhannock, Pa.
Station Type	Gaging Station, continuous record
Latitude	41.55841
Longitude	-75.89464
NWIS Latitude	41.55841008
NWIS Longitude	-75.89464168
Is regulated?	false
Agency	United States Geological Survey
NWIS Discharge Period of Record	02/01/1914 - 09/08/2025

Characteristic Name	Value	Units
Drainage Area	383	square miles

Statistic Name	Value	Units	Preferred?	Years of Record	Standard Error, percent	Citation	Comments
1 Day 10 Year Low F low	15.2	cubic feet per second	✓	94		49	Statistic Date Range 4/1/1914 - 3/31/2008
7 Day 2 Year Low Fl ow	35.9	cubic feet per second	✓	94		49	Statistic Date Range 4/1/1914 - 3/31/2008
7 Day 10 Year Low F low	17.3	cubic feet per second	✓	94		49	Statistic Date Range 4/1/1914 - 3/31/2008

$$\text{Low Flow Yield using StreamStats Gage Data} = \frac{17.3 \text{ ft}^3/\text{sec}}{383 \text{ mi}^2} = 0.045 \frac{\text{ft}^3/\text{sec}}{\text{mi}^2}$$

$$Q_{7-10} \text{ at Outfall 001 using StreamStats Gage Data} = 0.045 \frac{\text{ft}^3/\text{sec}}{\text{mi}^2} \times 414 \text{ mi}^2 = 18.63 \text{ cfs}$$

## USGS StreamStats Data:

## At Outfall 001 on the Tunkhannock Creek:

RMI	Elevation (ft)	Drainage Area (mi <sup>2</sup> )	Q <sub>7-10</sub> Flow (cfs)
0.40	578.26	414	19.2

$$\text{Low Flow Yield using StreamStats} = \frac{19.2 \text{ ft}^3/\text{sec}}{414 \text{ mi}^2} = 0.046 \frac{\text{ft}^3/\text{sec}}{\text{mi}^2}$$

\* StreamStats Q<sub>7-10</sub> and LFY was not used for modeling.


## StreamStats Report

Region ID:

Workspace ID:

Clicked Point (Latitude, Longitude):

Time:



Parameter Code	Parameter Name	Value	Units
DRNAREA	Drainage Area	414	square miles

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	40.1	ft <sup>3</sup> /s	38	38
30 Day 2 Year Low Flow	53.4	ft <sup>3</sup> /s	33	33
7 Day 10 Year Low Flow	19.2	ft <sup>3</sup> /s	57	57

At confluence with Susquehanna River (6685):

RMI	Elevation (ft)	Drainage Area (mi <sup>2</sup> )
0.0 (203.56 on Susquehanna River)	577.74	9,300

StreamStats Report

Region ID:

PA

Workspace ID:

PA20250909123151246000

Clicked Point (Latitude, Longitude):

41.53436, -75.94623

Time:

2025-09-09 08:32:21 -0400



Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	9300	square miles	4.84	982

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

### WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
		07K	6685	SUSQUEHANNA RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
203.960	Tunk Boro	Pa0020940	0.300	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			3

TRC EVALUATION									
Input appropriate values in A3:A9 and D3:D9									
Source		Reference		AFC Calculations		Reference		CFC Calculations	
TRC	1.3.2.iii			WLA_afc = 1.581		1.3.2.iii		WLA_cfc = 10.535	
PENTOXSD TRG	5.1a			LTAMULT_afc = 0.373		5.1c		LTAMULT_cfc = 0.581	
PENTOXSD TRG	5.1b			LTA_afc= 0.589		5.1d		LTA_cfc = 6.125	
Source									
Effluent Limit Calculations									
PENTOXSD TRG	5.1f				AML MULT = 1.231				
PENTOXSD TRG	5.1g				AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ		
					INST MAX LIMIT (mg/l) = 1.635				
WLA_afc					(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]^(1-FOS/100)				
LTAMULT_afc					EXP((0.5^LN(cvh^2+1))-2.326^LN(cvh^2+1)^0.5)				
LTA_afc					wla_afc^LTAMULT_afc				
WLA_cfc					(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]^(1-FOS/100)				
LTAMULT_cfc					EXP((0.5^LN(cvd^2/no_samples+1))-2.326^LN(cvd^2/no_samples+1)^0.5)				
LTA_cfc					wla_cfc^LTAMULT_cfc				
AML MULT					EXP(2.326^LN((cvd^2/no_samples+1)^0.5)-0.5^LN(cvd^2/no_samples+1))				
AVG MON LIMIT					MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)^AML_MULT)				
INST MAX LIMIT					1.5^((av_mon_limit/AML_MULT)/LTAMULT_afc)				



## Discharge Information

Instructions	Discharge	Stream
--------------	-----------	--------

Facility: Tunkhannock Borough      NPDES Permit No.: PA0020940      Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste      Wastewater Description: Treated Sewage

Design Flow (MGD)*	Hardness (mg/L)*	pH (SU)*	Discharge Characteristics					
			Partial Mix Factors (PMF <sub>c</sub> )				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>100</sub>	Q <sub>50</sub>
0.3	100	7						

Group	Discharge Pollutant	Units	Max Discharge Conc	0.1 left blank		0.5 left blank		0.1 left blank		1 left blank	
				Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	POB	Criteria Mod
1	Total Dissolved Solids (PWS)	mg/L	404								
1	Chloride (PWS)	mg/L	103								
1	Bromide	mg/L	0.48								
1	Sulfate (PWS)	mg/L	30.1								
1	Fluoride (PWS)	mg/L									
2	Total Aluminum	ug/L									
2	Total Antimony	ug/L									
2	Total Arsenic	ug/L									
2	Total Barium	ug/L									
2	Total Beryllium	ug/L									
2	Total Boron	ug/L									
2	Total Cadmium	ug/L									
2	Total Chromium (III)	ug/L									
2	Hexavalent Chromium	ug/L									
2	Total Cobalt	ug/L									
2	Total Copper	mg/L	0.01								
2	Free Cyanide	ug/L									
2	Total Cyanide	ug/L									
2	Dissolved Iron	ug/L									
2	Total Iron	ug/L									
2	Total Lead	mg/L	< 0.005								
2	Total Manganese	ug/L									
2	Total Mercury	ug/L									
2	Total Nickel	ug/L									
2	Total Phenols (Phenolics) (PWS)	ug/L									
2	Total Selenium	ug/L									
2	Total Silver	ug/L									
2	Total Thallium	ug/L									
2	Total Zinc	mg/L	< 0.037								
2	Total Molybdenum	ug/L									
3	Acrolein	ug/L	<								
3	Acrylamide	ug/L	<								
3	Acrylonitrile	ug/L	<								
3	Benzene	ug/L	<								
3	Bromoform	ug/L	<								



## Stream / Surface Water Information

Tunkhannock Borough, NPDES Permit No. PA0020940, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Tunkhannock Creek**

No. Reaches to Model: **1**

Statewide Criteria  
 Great Lakes Criteria  
 ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	028784	203.96	578.26	414			Yes
End of Reach 1	028784	201.95	577.18	9420			Yes

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	203.96	0.045										100	7		
End of Reach 1	201.95	0.045													

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	203.96														
End of Reach 1	201.95														

Wasteload Allocations

AFC

CCT (min): **15**

PMF: **0.122**

Analysis Hardness (mg/l):

**100**

Analysis pH: **7.00**

Pollutants	Stream Conc (mg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	13.439	14.0	82.4	Chem Translator of 0.96 applied
Total Lead	0	0		0	64.581	81.6	480	Chem Translator of 0.791 applied
Total Zinc	0	0		0	117.180	120	705	Chem Translator of 0.978 applied

CFC

CCT (min): **720**

PMF: **0.843**

Analysis Hardness (mg/l):

**100**

Analysis pH: **7.00**

Pollutants	Stream Conc (mg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	8.956	9.33	325	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.517	3.18	111	Chem Translator of 0.791 applied
Total Zinc	0	0		0	118.139	120	4,175	Chem Translator of 0.986 applied

THH

CCT (min): **720**

PMF: **0.843**

Analysis Hardness (mg/l):

**N/A**

Analysis pH: **N/A**

Pollutants	Stream Conc (mg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	

Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL      CCT (min):       PMF:       Analysis Hardness (mg/L):       Analysis pH:

Pollutants	Stream Conc (mg/L)	Stream CV	Trb Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	Report	Report	Report	Report	Report	mg/L	0.053	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target GL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Lead	0.11	mg/L	Discharge Conc < 10% WQBEL
Total Zinc	0.45	mg/L	Discharge Conc < 10% WQBEL



WQM 7.0.pdf

TMS PA0020940.pdf