

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0021695
APS ID 274892
Authorization ID 1405433

Applicant and Facility Information

Applicant Name	<u>Orbisonia & Rockhill Borough Joint Municipal Authority Huntingdon County</u>	Facility Name	<u>Orbisonia Rockhill STP</u>
Applicant Address	<u>843 Elliott Street, PO Box 346 Orbisonia, PA 17243-0346</u>	Facility Address	<u>Croghan Pike/Us 522 Orbisonia, PA 17243-0346</u>
Applicant Contact	<u>Sandra Snyder-Shoop</u>	Facility Contact	<u>Sandra Snyder-Shoop</u>
Applicant Phone	<u>(814) 447-5414</u>	Facility Phone	<u>(814) 447-5414</u>
Client ID	<u>34741</u>	Site ID	<u>252484</u>
Ch 94 Load Status	<u>Projected Hydraulic Overload</u>	Municipality	<u>Orbisonia Borough</u>
Connection Status	<u>No Exceptions Allowed</u>	County	<u>Huntingdon</u>
Date Application Received	<u>August 4, 2022</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 5, 2022</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES Renewal.</u>		

Summary of Review

Skelly & Loy, Inc., on behalf of the Orbisonia & Rockhill Joint Municipal Authority (ORJMA), has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of the NPDES permit. The permit was reissued on January 19, 2018 and became effective on February 1, 2018. The permit will expire on January 31, 2023.

This facility receives 57% of its flow from Orbisonia Borough, 42% from Rockhill Borough, and 1% from Cromwell Township. There are no industrial contributors. The facility has average annual design flow and hydraulic design capacity of 0.183 MGD. The organic design capacity is 327.0 lbs BOD₅/day.

The WQM Part II permit No. 3195402 amendments were issued on June 10, 2009 & September 26, 2017.

Sludge use and disposal description and location(s): N/A due to dispose of at on-site reed beds and solids disposed to landfill.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the proposed permit. Corrected NH₃-N average monthly limit from 19.0 lbs/day to 18.0 lbs/day.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	December 9, 2022
X		<i>Maria D. Bebenek for Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	January 23, 2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.183
Latitude	40° 14' 45.93"	Longitude	-77° 53' 53.52"
Quad Name	Orbisonia	Quad Code	1722
Wastewater Description: Sewage Effluent			
Receiving Waters	Blacklog Creek (CWF)	Stream Code	12797
NHD Com ID	66211533	RMI	1.37 miles
Drainage Area	66.7 mi. ²	Yield (cfs/mi ²)	See comments below
Q ₇₋₁₀ Flow (cfs)	See comments below	Q ₇₋₁₀ Basis	See comments below
Elevation (ft)	612	Slope (ft/ft)	
Watershed No.	12-C	Chapter 93 Class.	CWF & MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Mifflintown Borough Municipal Authority Juniata County		
PWS Waters	Juniata River	Flow at Intake (cfs)	
PWS RMI	37.26 miles	Distance from Outfall (mi)	Approximate 38.0 miles

Changes Since Last Permit Issuance: none

Drainage Area

The discharges are to Blacklog Creek at RMI 1.37 miles. A drainage area upstream of the discharge is estimated to be 66.7 mi.², according to USGS PA StreamStats available at: <https://streamstats.usgs.gov/ss/>.

Streamflow

Streamflow data was collected from the nearest upstream USGS stream gage 01564500 located in Aughwick Creek Three Springs, PA. Q₇₋₁₀ values at this gage are 5.81 cfs respectively for the reporting. The drainage area was found to be 172 mi.². These values were obtained from the latest USGS streamflow report. The drainage area at DP was found to be 66.7 mi.² from USGS StreamStats.

$$Q_{7-10} \text{ runoff rate} = 5.81 \text{ cfs} / 172 \text{ mi.}^2 = 0.03 \text{ cfs/mi.}^2$$

$$Q_{7-10} = 0.03 \text{ cfs/mi.}^2 * 66.7 \text{ mi.}^2 = 2.00 \text{ cfs}$$

Blacklog Creek

25 Pa. Code § 93.9n classifies Blacklog Creek as Cold Water & Migratory Fishes (CWF & MF) surface water. Based on the 2022 Integrated Report, Blacklog Creek, assessment unit ID 20525, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

PWS Intake

The nearest downstream public water supply intake is the Mifflintown Borough Municipal Authority Juniata County on Juniata River. It is approximately 38.0 miles downstream of the discharge. Due to the distance, dilution, and effluent limits the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Orbisonia/Rockhill Municipal Authority - Rockhill STP				
WQM Permit No.		Issuance Date		
3195402 A-1		April 6, 2017		
3195402		June 10, 2009		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Contact Stabilization	Chlorine With Dechlorination	0.183
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.183	327	Projected Hydraulic Overload		Other WWTP

Changes Since Last Permit Issuance: none

Initially the treatment plant served Orbisonia and Rockhill Boroughs. A portion of Cromwell Township and three wastewater treatment plants owned and operated by Southern Huntingdon school district were added to the treatment plant during the last renewal. The application indicated there is no industrial or commercial contributor to this treatment plant. However, there are convenience store average wastewater flow of 0.0011 MGD & retirement home average wastewater flow of 0.0076 MGD.

The treatment facility is a double ditch oxidation secondary treatment with the following train.

Influent passes through a screen to the oxidation ditches if inflow is less than the capacity of the ditches. If flow is more than the oxidation ditch handling capacities, the influent flow is diverted to equalization tanks. After treatment in the ditches, the flow is disinfected and discharged to Blacklog Creek through Outfall 001. The sludge is directed to the sludge holding tank, which is then dewatered, and solids are sent to existing reed beds on site.

The system has the following treatment units:

- One bar screen, one fine screen
- Two Equalization tanks
- Two oxidation ditches
- Proposed double train chlorine contact tanks with dechlorination
- One sludge holding tank
- Four reed beds

The chemicals used sodium hypochlorite for disinfection and sodium bisulfate for dechlorination.

Compliance History	
Summary of DMRs:	The DMRs reported from November 1, 2021 to October 31, 2022 are summarized in the Table below (Pages # 6, 7, & 8).
Summary of Inspections:	<p>10/18/2022: Mr. Clark, DEP's WQS, conducted a compliance evaluation inspection. No violation identified during inspection. Recommendations were kept flow meter calibration records on site and available for inspection, assure the influent sample is kept at about 6 °C during the entire 24-hour composite period, and place a NIST traceable thermometer in sample storage refrigerator. The effluent was clear, and all field test results were within the permit limits.</p> <p>4/27/2022: Mr. Clark, DEP's WQS, conducted a follow-up inspection. No violations identified during inspection. The treatment plant effluent appeared clear with fine solids. All field test results were within the permit limits. The west side oxidation ditch still has an abundance of thick brown foam on the surface. Composite sample dates and times were recorded on the laboratory chain of custody forms. A review of DMRs shows that influent supplementals forms were now included with the monthly reports and a Chesapeake Bay Supplemental Spreadsheet was submitted with the 2020-2021 annual DMR.</p> <p>8/10/2021: Mr. Clark, DEP's WQS, conducted a compliance evaluation inspection. There were violations identified during inspection. Recommendations were submit an influent / Process control supplemental form with monthly DMRs, attach a Chesapeake Bay Annual Spreadsheet to the 2019-2020 report and future quarterly and annual DMRs, be sure to keep effluent and influent samples on ice during the entire 24 hours of compositing, record composite sample on/off times and date in daily log book or bench sheet, check electrical connection to influent sampler to assure unit will not turn off during sampling, and operate scum trough often as possible. Effluent was clear and field test results were within the permit limits.</p> <p>2/26/2020: Mr. Clark, DEP's WQS, conducted a compliance evaluation inspection. No violation identified during inspection. Recommendations were be sure to keep influent samples on ice while compositing, continue with repair of air lines in EQ tank, adjust temperature in effluent compositor, add more details in maintenance and repair log books and print legibly, record composite sample on and off times in daily log book, attach a Chesapeake Bay Annual Spreadsheet to the quarterly eDMRs, and train all employees on use of SCADA system.</p>
Other Comments:	There are three open violations against permittee.

Other Comments:

**NPDES Permit Fact Sheet
Orbisonia Rockhill STP**

NPDES Permit No. PA0021695

The table below summarizes the influent/effluent testing results submitted along with the application.

<i>Influent Testing Results</i>			<i>Effluent Testing Results</i>		
Parameter	Min/Max Value	Average Value	Parameter	Min/Max Value	Average Value
BOD ₅ (mg/L)	424 mg/L	102.1 mg/L	pH (minimum)	6.8 S.U.	
BOD ₅ (lbs/day)	lbs/day	lbs/day	pH (maximum)	7.9 S.U.	
TSS (mg/L)	444 mg/L	82.5 mg/L	D.O (minimum)	5.0 mg/L	6.2 mg/L
TSS (lbs/day)	lbs/day	lbs/day	TRC	0.45 mg/L	0.02 mg/L
TN (mg/L)	21.23 mg/L	21.23 mg/L	Fecal Coliform	9678 No./100mL	37 No./100mL
TN (lbs/day)	lbs/day	lbs/day	CBOD ₅	38.9 mg/L	7.7 mg/L
TP (mg/L)	3.23 mg/L	3.23 mg/L	TSS	204 mg/L	14.7 mg/L
TP (lbs/day)	lbs/day	lbs/day	NH ₃ -N	21.4 mg/L	3.2 mg/L
NH ₃ -N (mg/L)	19.0 mg/L	19.0 mg/L	TN	17.55 mg/L	5.70 mg/L
NH ₃ -N (lbs/day)	lbs/day	lbs/day	TP	5.08 mg/L	3.13 mg/L
TDS (mg/L)	1,990 mg/L	1,990 mg/L	Temp	63.1 F	63.1 F
TDS (lbs/day)	lbs/day	193 lbs/day	TKN	16.35 mg/L	2.49 mg/L
TKN	21.18 mg/L	21.18 mg/L	NO ₂ -N + NO ₃ -N	6.56 mg/L	3.3 mg/L
NO ₂ -N + NO ₃ -N	0.05 mg/L	0.05 mg/L	TDS	340 mg/L	340 mg/L
Fecal Coliform	3255000No./100mL	3255000No./100mL	Chloride	47.0 mg/L	47.0 mg/L
			Bromide	< 0.036 mg/L	< 0.036 mg/L
			Sulfate	47.8 mg/L	47.8 mg/L
			Oil and Grease	< 1.62 mg/L	< 1.62 mg/L
			Total Copper	0.0252 mg/L	0.0134 mg/L
			Total Lead	< 0.00143 mg/L	< 0.00143 mg/L
			Total Zinc	0.0213 mg/L	0.0213 mg/L

Compliance History

DMR Data for Outfall 001 (from November 1, 2021 to October 31, 2022)

Parameter	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21
Flow (MGD) Average Monthly	0.097	0.094	0.092	0.116	0.122	0.194	0.138	0.127	0.172	0.119	0.098	0.107
Flow (MGD) Daily Maximum	0.17	0.188	0.135	0.833	0.279	0.9	0.262	0.173	0.419	0.213	0.144	0.18
pH (S.U.) Minimum	7.0	7.1	7.2	6.6	7.1	7.0	7.0	7.0	7.0	7.2	6.8	7.2
pH (S.U.) Maximum	7.4	7.4	7.4	7.4	7.5	7.5	7.5	7.5	7.6	7.6	7.4	7.5
DO (mg/L) Minimum	6.1	6.0	6.0	6.0	6.4	6.2	6.6	6.2	6.8	6.2	6.8	5.4
TRC (mg/L) Average Monthly	< 0.01	0.01	< 0.01	0.02	0.01	0.02	0.02	0.01	< 0.01	< 0.02	< 0.02	< 0.02
TRC (mg/L) Instantaneous Maximum	0.03	0.02	0.02	0.06	0.02	0.07	0.1	0.04	0.03	0.03	0.09	0.03
CBOD5 (lbs/day) Average Monthly	4.0	< 5.5	< 3.2	< 3.3	3.4	< 16.9	6.6	5.9	< 7.9	< 12.1	< 5.4	< 2.5
CBOD5 (lbs/day) Weekly Average	5.3	8.6	4.9	5.4	4.1	11.0	11.2	8.3	12.9	23.5	11.6	3.5
CBOD5 (mg/L) Average Monthly	6.7	< 8.0	< 5.1	< 4.9	4.6	< 7.8	6.5	6.8	< 8.3	< 15.3	< 7.5	< 3.4
CBOD5 (mg/L) Weekly Average	9.7	13.2	7.8	6.6	6.0	13.4	12.6	9.6	11.9	30.6	17.0	5.1
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	98	79	59	80	91	71	103	87	59	148	90	99
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	191	131	110	105	163	91	162	124	66	329	158	207
BOD5 (mg/L) Raw Sewage Influent Average Monthly	149	116	95	126	131	80	100	98	64	183	111	132
TSS (lbs/day) Average Monthly	< 1.6	3.2	< 1.3	< 2.8	< 1.9	15.1	3.1	< 3.1	< 1.9	9.7	< 1.5	< 1.8
TSS (lbs/day) Raw Sewage Influent Average Monthly	53	47	49	72	60	59	56	57	53	40	47	103

**NPDES Permit Fact Sheet
Orbisonia Rockhill STP**

NPDES Permit No. PA0021695

TSS (lbs/day) Raw Sewage Influent Daily Maximum	137	62	76	100	83	68	77	82	87	53	64	247
TSS (lbs/day) Weekly Average	3.0	4.5	2.0	5.6	3.3	14.7	3.6	5.0	2.6	13.7	1.9	2.4
TSS (mg/L) Average Monthly	< 2.7	4.4	< 2.1	< 4.0	< 2.5	7.6	3.1	< 3.5	< 2.1	12.1	< 2.0	< 2.5
TSS (mg/L) Raw Sewage Influent Average Monthly	90	68	77	113	86	66	57	66	56	48	64	137
TSS (mg/L) Weekly Average	5.2	5.6	2.8	6.8	3.6	18.0	4.0	6.4	3.6	17.6	2.8	3.2
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 2	< 6.0	< 1	< 2	< 2	< 2	< 4	< 5	< 4	< 1	< 15
Fecal Coliform (No./100 ml) Instantaneous Maximum	2.0	4.1	1299.7	2	6.3	4.1	< 4	< 4	12.4	13.5	1	3960
Nitrate-Nitrite (mg/L) Average Quarterly		5.15			< 2.576			9.93			< 2.1	
Nitrate-Nitrite (lbs) Total Quarterly		6.01			4.97			7.70			< 1.5	
Total Nitrogen (mg/L) Average Quarterly		6.15			< 4.59			13.45			< 2.92	
Total Nitrogen (lbs) Total Quarterly		7.2			< 4.09			10.43			< 2.09	
Total Nitrogen (lbs) Total Annual		< 7.1										
Ammonia (lbs/day) Average Monthly	< 0.2	0.4	0.3	0.3	0.4	< 1	< 0.5	< 0.3	0.3	< 3.0	8	0.3
Ammonia (mg/L) Average Monthly	< 0.3	0.6	0.5	0.5	0.5	< 0.4	< 0.5	< 0.3	0.3	< 4.0	0.3	0.4
Ammonia (mg/L) Average Quarterly		5.1			0.655			< 0.500			0.342	
Ammonia (lbs) Total Quarterly		5.95			0.584			< 0.388			0.244	
Ammonia (lbs) Total Annual		< 7										
TKN (mg/L) Average Quarterly		1			2.015			3.520			0.82	
TKN (lbs) Total Quarterly		1.17			2.86			2.73			0.59	
Total Phosphorus (mg/L) Average Quarterly		2.91			2.42			5.32			3.51	

**NPDES Permit Fact Sheet
Orbisonia Rockhill STP**

NPDES Permit No. PA0021695

Total Phosphorus (lbs) Total Quarterly		3.4			3.43			4.13			2.5	
Total Phosphorus (lbs) Total Annual		8.3										
Total Copper (mg/L) Average Monthly	0.00526	0.0109	< 0.00386	0.00456	0.00523	0.0072	0.0166	0.0175	0.0135	0.0114	0.0155	0.0122
Total Copper (mg/L) Daily Maximum	0.00526	0.0109	< 0.00386	0.00456	0.00523	0.0072	0.0166	0.0175	0.0135	0.0114	0.0155	0.0122

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.183</u>
Latitude <u>40° 14' 45.94"</u>	Longitude <u>-77° 53' 53.52"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃-N calculations were based on the Department’s Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

- * Discharge pH 7.0 (Default)
- * Discharge Temperature 20°C (Default)
- * Stream pH 7.0 (Default)
- * Stream Temperature 20°C (Default)
- * Background NH₃-N 0 mg/L (Assumed since no nearby upstream WWTPs)

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 20.03 mg/L NH₃-N as a monthly average (AML) and 40.06 mg/L NH₃-N instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects. The existing limits of 12.0 mg/L AML & 25.0 mg/L IMAX were more stringent and will remain in the proposed permit. Recent DMRs and inspection reports indicate that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\text{Average monthly mass limit: } 12.0 \text{ mg/L} \times 0.183 \text{ MGD} \times 8.34 = 18.3 \text{ (18.0) lbs/day}$$

CBOD₅:

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit (AML) of 25.0 mg/L, 40.0 mg/L AWL, & 50.0 mg/L IMAX will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has typically been achieving concentrations below this limit. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 25.0 \text{ mg/L} \times 0.183 \text{ MGD} \times 8.34 = 38.16 \text{ (38.0) lbs/day} \\ \text{Average weekly mass limit: } & 40.0 \text{ mg/L} \times 0.183 \text{ MGD} \times 8.34 = 61.05 \text{ (61.0) lbs/day} \end{aligned}$$

Dissolved Oxygen (D.O.):

The D.O. goal is 6.0 mg/L. However, a minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP’s current Standard Operating Procedure (SOP) No. BCW-PMT-033, version 1.9 revised March 22, 2021, and has been applied to other point source dischargers throughout the state.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 1.9 revised March 22, 2021, a routine monitoring for E. Coli will be included in the permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included in the permit to be consistent with the recommendation from this SOP.

Total Suspended Solids (TSS):

The existing limits of 30.0 mg/L average monthly (AML), 45.0 mg/L average weekly (AWL), and 60.0 mg/L instantaneous maximum (IMAX) will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Past DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

Mass based AML (lbs/day): $30.0 \text{ (mg/L)} \times 0.183 \text{ (MG/day)} \times 8.34 \text{ (lbs/MG)} \text{ (L/mg)} = 45.79 \text{ (45.0) lbs/day}$

Mass based AWL (lbs/day): $45.0 \text{ (mg/L)} \times 0.183 \text{ (MG/day)} \times 8.34 \text{ (lbs/MG)} \text{ (L/mg)} = 68.68 \text{ (65.0) lbs/day}$

Total Residual Chlorine (TRC):

The attached computer printout utilizes the equations and calculations as presented in the Department's May 1, 2003 Implementation Guidance for TRC (ID No. 391-2000-015) for developing chlorine limitations. The Guidance References Chapter 92a, Section 92a.48(b)(2) which established standard BAT limit of 0.5 mg/l unless a facility-specific BAT has been developed. The attached printout indicates that an average monthly water quality limit of 0.5 mg/l and instantaneous maximum limit of 1.6 mg/l would be needed to prevent toxicity concerns. Minimum monitoring frequency will be 1/day.

Toxics:

The data was analyzed based on the guidelines found in DEP's Water Quality Toxics Management Strategy (Document No. 361-0100-003) and DEP's SOP No. BPNPSM-PMT-033. Spreadsheet results are attached to this fact sheet. The Toxics Management Spreadsheet uses the following logic:

- a. Establish average monthly and IMAX limits in the draft permit where the maximum reported concentration exceeds 50% of the WQBEL.
- b. For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- c. For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10%-50% of the WQBEL.

Pollutant testing results on the current renewal application were reviewed in comparison with DEP's Toxic Management Spreadsheet, version 1.3, March 2021, output recommends a routine monitoring requirement for Total Copper (Cu). Therefore, monitoring requirements for this parameter is remain in the proposed permit.

Total Phosphorus:

The discharge is into a stream segment of Blacklog Creek. DEP's Phosphorus guidance ⁽¹⁾ mentions that "(a) Phosphorus controls for waste discharges to streams shall be established, under subsection (b) whenever the Department determines that instream phosphorus, alone or in combination with other pollutants or instream conditions, contribute to impairment of designated uses as defined in Chapter 93 (relating to water quality standards). No determination made under this subsection shall constitute a final Department action with respect to any person until a specific treatment or control requirement is imposed under subsection (b)." Since Blacklog Creek or Juniata Sub-basin doesn't have instream Phosphorus related impairment, local Phosphorus limit is not necessary now.

Total Dissolved Solids (TDS):

TDS and its associated solids including Bromide, Chloride, and Sulfate have become statewide pollutants of concern. The requirement to monitor these pollutants must be considered under the criteria specified in 25 Pa. Code § 95.10 and the following January 23, 2014 DEP Central Office Directive:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

- Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.

- Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.
- Where the concentration of 1,4-dioxane (CAS 123-91-1) in a discharge exceeds 10 µg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for 1,4-dioxane. Discharges of 0.1 MGD or less should monitor and report for 1,4-dioxane if the concentration of 1,4-dioxane in the discharge exceeds 100 µg/L.

The sample result shows that effluent contains a maximum TDS concentration level of 340.0 mg/L and maximum load of 340.0 mg/L (0.183 x 340 x 8.34 = 518.91 lbs/day) and Bromide of < Detection Level. Thus, no monitoring and reporting or limit requirement is needed now. This justification will be re-evaluated in the next permit renewal.

Stormwater:

There is no known stormwater outfall associated with this facility.

Chesapeake Bay Strategy:

According to DEP's Chesapeake Bay Phase II Watershed Implementation Plan (WIP) Wastewater Supplement, this facility is considered a phase 5 non-significant sewage discharger with design flow less than 0.2 MGD but greater than 0.002 MGD. In general, DEP will issue permits for all phase 5 facilities with monitoring and reporting for Total Nitrogen (TN) and Total Phosphorus (TP) throughout the permit term at a frequency no less than annually. Furthermore, DEP's SOP No. BPNPSM-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 gpd. At this time, the Department is not requiring a total maximum annual nitrogen or phosphorus loading cap. Ammonia-Nitrogen, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, TN, and TP monitoring is already included in the existing permit and will remain in the proposed renewal.

The Chesapeake Bay parameters monitoring frequency for this facility will match that of the conventional pollutants monitoring frequency of one sample per quarter.

Anti-Degradation (93.4):

The effluent limits for this discharge have been developed to ensure that the existing in-stream water used and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

303d Listed Streams:

The discharge is not located on a 303d listed stream segment.

- * Discharge pH 7.0 (Default)
- * Discharge Temperature 20°C (Default)
- * Stream pH 7.0 (Default)
- * Stream Temperature 20°C (Default)
- * Background NH₃-N 0 mg/L (Assumed since no nearby upstream WWTPs)

The following two nodes were used in modeling:

Node 1: Outfall 001 at Blacklog Creek (12797)
 Elevation: 612 ft (USGS)
 Drainage Area: 66.7 mi² (USGS StreamStats)
 River Mile Index: 1.37 (PA DEP eMapPA)
 Low Flow Yield: 0.03 cfs/mi²
 Discharge Flow: 0.183 MGD

Node 2: At the confluence with UNT Blacklog Creek (12798)
 Elevation: 598 ft (USGS)
 Drainage Area: 71.9 mi² (USGS StreamStats)
 River Mile Index: 0.456 (PA DEP eMapPA)
 Low Flow Yield: 0.03 cfs/mi²
 Discharge Flow: 0.00 MGD

The screenshot displays the USGS StreamStats web application interface. On the left is a navigation sidebar with options like 'SELECT A STATE / REGION' (Pennsylvania), 'IDENTIFY & STUDY AREA' (Basin Delineated), and 'BUILD A REPORT'. The main content area is divided into two sections:

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	14.44	percent
DRNAREA	Area that drains to a point on a stream	66.7	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.36	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	66.7	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	1.36	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	14.44	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PII: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	10.6	ft ³ /s	38	38
30 Day 2 Year Low Flow	13.5	ft ³ /s	33	33
7 Day 10 Year Low Flow	5.78	ft ³ /s	51	51
30 Day 10 Year Low Flow	7.41	ft ³ /s	46	46
90 Day 10 Year Low Flow	10.8	ft ³ /s	36	36

Low-Flow Statistics Citations

The right side of the screenshot shows a map view of the study area with a 'Layers' panel on the right. The map displays a river network and surrounding terrain. A notification at the bottom right states: 'Displaying simplified Basin. See FAQ for more information.'

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	4.39	percent
DRNAREA	Area that drains to a point on a stream	172	square miles
PRECIP	Mean Annual Precipitation	38	inches
ROCKDEP	Depth to rock	4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.15	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	172	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	38	inches	35	50.4
STRDEN	Stream Density	2.15	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4	feet	3.32	5.65
CARBON	Percent Carbonate	4.39	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PI: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	12.7	ft ³ /s	38	38
30 Day 2 Year Low Flow	17.6	ft ³ /s	33	33
7 Day 10 Year Low Flow	5.81	ft ³ /s	51	51
30 Day 10 Year Low Flow	8.27	ft ³ /s	46	46
90 Day 10 Year Low Flow	13.5	ft ³ /s	36	36

Low-Flow Statistics Citations

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	14.67	percent
DRNAREA	Area that drains to a point on a stream	71.9	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.38	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	71.9	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	1.38	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	14.67	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PI: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	11.4	ft ³ /s	38	38
30 Day 2 Year Low Flow	14.5	ft ³ /s	33	33
7 Day 10 Year Low Flow	6.24	ft ³ /s	51	51
30 Day 10 Year Low Flow	7.99	ft ³ /s	46	46
90 Day 10 Year Low Flow	11.6	ft ³ /s	36	36

Low-Flow Statistics Citations

Analysis Results WQM 7.0

Hydrodynamics | NH3-N Allocations | D.O. Allocations | D.O. Simulation | **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
1.37	Orbisonia	PA0021695	0.1830

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	20.03	40.06	
Dissolved Oxygen			5

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin		Stream Code		Stream Name			
12C		12797		BLACKLOG CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
1.370	Orbisonia	PA0021695	0.183	CBOD5	25		
				NH3-N	20.03	40.06	
				Dissolved Oxygen			5

Monday, December 5, 2022 | Version 1.1 | Page 1 of 1

Page: 1 of 1 | No Filter

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin		Stream Code		Stream Name					
12C		12797		BLACKLOG CREEK					
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.370	Orbisonia	16.76	50	16.76	50	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.370	Orbisonia	1.89	20.03	1.89	20.03	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
1.370	Orbisonia	25	25	20.03	20.03	5	5	0	0

Monday, December 5, 2022 | Version 1.1 | Page 1 of 1

Page: 1 of 1 | No Filter

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name
12C	12797	BLACKLOG CREEK

RM	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
1.370	0.183	20.000	7.000

Reach Width (ft)	Reach Depth (ft)	Reach W/D Ratio	Reach Velocity (ft/s)
28.273	0.638	44.300	0.127

Reach CBOD5 (mg/L)	Reach Kd (1/day)	Reach NH3-N (mg/L)	Reach Kn (1/day)
4.85	0.038	2.48	0.700

Reach DO (mg/L)	Reach Kd (1/day)	Kd Equation	Reach DO Goal (mg/L)
7.941	3.489	Tavgdou	6

Reach Travel Time (days)	Subreach Results			
0.441	Travel Time (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.044	4.67	2.41	7.46
	0.098	4.50	2.33	7.16
	0.152	4.34	2.26	6.92
	0.177	4.18	2.19	6.73
	0.221	4.03	2.13	6.58
	0.265	3.89	2.06	6.47
	0.309	3.74	2.00	6.39
	0.353	3.61	1.94	6.34
	0.397	3.48	1.88	6.31
	0.441	3.35	1.82	6.30

Monday, December 5, 2022 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows
WLA Method	EMPR	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Baseload Technology <input checked="" type="checkbox"/>
D.O. Goal	6	

Monday, December 5, 2022 Version 1.1 Page 1 of 1

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name
12C	12797	BLACKLOG CREEK

RM	Stream Flow (cfs)	PWS Flow (cfs)	Net Stream Flow (cfs)	Disc Flow (cfs)	Reach Flow (cfs)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trv Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
1370	2.00	0.00	2.00	.2631	0.002290	.638	28.27	44.3	0.13	0.441	20.00	7.00
Q1-10 Flow												
1370	1.28	0.00	1.28	.2631	0.002290	NA	NA	NA	0.10	0.546	20.00	7.00
Q30-10 Flow												
1370	2.72	0.00	2.72	.2631	0.002290	NA	NA	NA	0.15	0.378	20.00	7.00

Monday, December 5, 2022 Version 1.1 Page 1 of 1

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RM	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply PC
12C	12797	BLACKLOG CREEK	1.370	61200	66.70	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (dam)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trv Time (days)	Rch Velocity (ft/s)	W/D Ratio	Rch Width (ft)	Rch Depth (ft)	Trib Temp (°C)	Stream pH	Stream Temp (°C)
Q7-10	0.00	0.00	0.00	0.00	0.0	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10	0.00	0.00	0.00	0.00	0.00	0.0	0.00	0.00	20.00	7.00	0.00
Q30-10	0.00	0.00	0.00	0.00	0.00	0.0	0.00	0.00	20.00	7.00	0.00

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Orbisonia	PA0021695	0.1830	0.1830	0.1830	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Rule Cost (10days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Monday, December 5, 2022 Version 1.1 Page 1 of 2

rptGeneral
— □ ×

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Dis/soe Area (sq ft)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
12C	12797	BLACKLOG CREEK	0.468	598.00	7190	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (dsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.030	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q35-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Orbisonia	PA0021695	0.0000	0.0000	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Monday, December 5, 2022
Version 1.1
Page 2 of 2

Page: 14
◀ 2
▶ ▶ ▶ ▶
🗑️ No Filter

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
2	= Q stream (cfs)	0.5	= CV Daily	
0.183	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 2.273		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.847		5.1d
		WLA_cfc = 2.208		
		LTAMULT_cfc = 0.581		
		LTA_cfc = 1.284		
Source		Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019/Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs/Qd)] \cdot (1-FOS/100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2+1)) - 2.326 \cdot LN(cvh^2+1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011/Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs/Qd)] \cdot (1-FOS/100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2/no_samples+1)) - 2.326 \cdot LN(cvd^2/no_samples+1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2/no_samples+1)^{0.5}) - 0.5 \cdot LN(cvd^2/no_samples+1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	$1.5 \cdot ((av_mon_limit/AML_MULT)/LTAMULT_afc)$			

Toxic Data:

Facility's design flow: 0.183 MGD

pH: 7.35 S.U. (average from Max/Min Data from renewal application, page 6, submitted in August 2022)

Hardness: 100 mg/l (Default)



Discharge Information

Instructions Discharge Stream

Facility: Orbisonia & Rockhill JMA NPDES Permit No.: PA0021695 Outfall No.: 001
 Evaluation Type: Custom / Additives Wastewater Description: Blacklog Creek

Discharge Characteristics								
Design Flow (MGD) 0.183	Hardness (mg/l)* 100	pH (SU)* 7.35	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q _{7.10}	Q _h

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod
Total Copper	mg/L	0.0252								
Total Lead	mg/L	< 0.00143								
Total Zinc	mg/L	0.0213								



Stream / Surface Water Information

Orbisonia & Rockhill JMA, NPDES Permit No. PA0021695, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: Blacklog Creek No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	012797	1.37	612	66.7			Yes
End of Reach 1	012797	0.456	598	71.9			Yes

Q_{7.10}

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	1.37	0.03										100	7		
End of Reach 1	0.456	0.03													

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	1.37														
End of Reach 1	0.456														



Model Results

Orbisonia & Rockhill JMA, NPDES Permit No. PA0021695, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): 15

PMF: 0.700

Analysis Hardness (mg/l): 100

Analysis pH: 7.04

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	13.439	14.0	83.3	Chem Translator of 0.96 applied
Total Lead	0	0		0	64.581	81.6	486	Chem Translator of 0.791 applied
Total Zinc	0	0		0	117.180	120	713	Chem Translator of 0.978 applied

CFC

CCT (min): 30.620

PMF: 1

Analysis Hardness (mg/l): 100

Analysis pH: 7.03

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	8.956	9.33	75.3	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.517	3.18	25.7	Chem Translator of 0.791 applied
Total Zinc	0	0		0	118.139	120	967	Chem Translator of 0.986 applied

THH

CCT (min): 30.620

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL

CCT (min): 11.623

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Copper	0	0		0	N/A	N/A	N/A	

Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements



No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits			Units	Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day) Report	MDL (lbs/day) Report	AML Report	MDL Report	IMAX Report				
Total Copper			Report	Report	Report	mg/L	0.053	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).


Pollutants	Governing WQBEL	Units	Comments
Total Lead	25.7	µg/L	Discharge Conc ≤ 10% WQBEL
Total Zinc	457	µg/L	Discharge Conc ≤ 10% WQBEL



- Area I - Orbisonia Borough, Developable lots W or W/O infrastructure
- Area II - Rockhill Borough, Developable lots W or W/O infrastructure
- Area III - Cromwell Township, Remainder of Sandy Ridge Development W/O infrastructure
- Area IV - Cromwell Township, Rt. 522 South area W/ or W/O Sewage problems
- Area V - Cromwell Township, former Bollinger property W/O infrastructure
- Area VI - Pine Tree Village and Pogue

Source: U.S.G.S. 7.5' Quadrangle - Butler Knob and Orbisonia, Pennsylvania

SKELLY and LOY, Inc.	April 2010	Figure 1
Orbisonia-Rockhill Joint Municipal Authority		
EXISTING AND PROPOSED SERVICE AREAS		
Orbisonia and Rockhill Boroughs, and Cromwell Township Huntingdon County, Pennsylvania		
Job No: R09-0001	Scale: 1" = 2500'	



Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD ₅	38.0	61.0	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	45.0	65.0	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Ammonia	19	XXX	XXX	12.0	XXX	25	1/week	24-Hr Composite
Total Copper	XXX	XXX	XXX	Report	Report Daily Max	XXX	1/month	24-Hr Composite

Existing Effluent Limitations and Monitoring Requirements

Chesapeake Bay Requirement.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report Total Qrtly	Report	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	24-Hr Composite
Kjeldahl--N	Report Total Qrtly	XXX	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	24-Hr Composite
Nitrate-Nitrite as N	Report Total Qrtly	XXX	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	24-Hr Composite
Total Nitrogen	Report Total Qrtly	Report	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	Calculation
Total Phosphorus	Report Total Qrtly	Report	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	24-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD ₅	38.0	61.0 Wkly Avg	XXX	25.0	40.0	50.0	1/week	24-Hr Composite
BOD ₅ Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	45.0	65.0 Wkly Avg.	XXX	30.0	45.0	60.0	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia	18.0	XXX	XXX	12.0	XXX	25.0	1/week	24-Hr Composite
Total Copper	XXX	XXX	XXX	Report	Report Daily Max	XXX	1/month	24-Hr Composite

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report Total Qrtly	Report	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	24-Hr Composite
Kjeldahl--N	Report Total Qrtly	XXX	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	24-Hr Composite
Nitrate-Nitrite as N	Report Total Qrtly	XXX	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	24-Hr Composite
Total Nitrogen	Report Total Qrtly	Report	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	Calculation
Total Phosphorus	Report Total Qrtly	Report	XXX	Report Avg. Quarterly	XXX	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input checked="" type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: No. BCW-PMT-033, version 1.9, revised March 22, 2021
<input type="checkbox"/>	Other: [redacted]