



Application Type Renewal
Facility Type Municipal
Major / Minor Minor

Application No. PA0021881
APS ID 1134220
Authorization ID 1521548

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Applicant and Facility Information

Applicant Name	Westfield Borough Tioga County	Facility Name	Westfield Borough Sewer System STP
Applicant Address	429 E Main Street Westfield, PA 16950-1610	Facility Address	1488 Broughton Road Westfield, PA 16950
Applicant Contact	Roger Watkins	Facility Contact	Donald Wescott
Applicant Phone	(814) 367-2632	Facility Phone	(814) 367-5835
Client ID	63260	Site ID	255822
Ch 94 Load Status	Not Overloaded	Municipality	Westfield Borough
Connection Status	No Limitations	County	Tioga
Date Application Received	March 31, 2025	EPA Waived?	No
Date Application Accepted	April 2, 2025	If No, Reason	Significant CB Discharge
Purpose of Application	Renewal of a NPDES Permit		

Summary of Review

The subject facility is a minor Publicly Owned Treatment Works (POTW) serving Westfield Borough and neighboring portions of Westfield Township in Tioga County.

Sludge use and disposal description and location(s): The facility's dewatered sludge is disposed by landfill. Per the application 26.2 dry tons were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		 Keith C. Allison / Project Manager	September 25, 2025
✓		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	September 29, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.46
Latitude	41° 55' 30.06"	Longitude	-77° 31' 16.37"
Quad Name	Potter Brook	Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Cowanesque River (WWF)	Stream Code	30995
NHD Com ID	57350897	RMI	27.6
Drainage Area	96.8 mi ²	Yield (cfs/mi ²)	0.01325
Q ₇₋₁₀ Flow (cfs)	1.28	Q ₇₋₁₀ Basis	USGS Gage 01518862, Cowanesque River @ Westfield (1985-2008)
Elevation (ft)	1311	Slope (ft/ft)	0.00174
Watershed No.	4-A	Chapter 93 Class.	WWF
Existing Use	N/A	Existing Use Qualifier	N/A
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Impaired		
Cause(s) of Impairment	Pathogens, Siltation, and Flow Modification,		
Source(s) of Impairment	Source Unknown, Agriculture, Removal of Riparian Vegetation, and Urban Runoff		
TMDL Status	Pending	Name	
Nearest Downstream Public Water Supply Intake	PA-NY State Line		
PWS Waters	Cowanesque River	Distance from Outfall (mi)	~27

Changes Since Last Permit Issuance: None. The above stream and drainage characteristics determined for previous reviews remain adequate.

Other Comments:

The facility is not expected to be a significant contributor to the above-listed impairments to the Cowanesque River. The facility's TSS averages below 10 mg/L and it consistently meets its Fecal Coliform limitations.

No downstream water supply is expected to be affected by the discharge at this time with the limitations and monitoring proposed. The Department considers the PA/NY state line to be the closest water supply due to no closer intakes.

Treatment Facility Summary				
Treatment Facility Name: Westfield Borough WWTP				
WQM Permit No.	Issuance Date	Permit Coverage:		
5986401	9/26/88	Upgrade to original plant with inclusion of experimental Submerged Fixed Film Reactor (SFFR)		
5986401 A-1	4/25/19	Plant upgrades		
5986401 A-2	12/14/22	Dechlorination		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Oxidation Ditch	Hypochlorite	0.46
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.46	539	Not Overloaded	Dewatering	Land Application

Changes Since Last Permit Issuance: The upgrades under WQM Permit No. 5986401 A-1 and 5986401 A-2 were completed in 2022 were completed in 2022.

Other Comments: The treatment facilities as permitted under WQM Permit 5986401 A-1 consists of mechanical screen and a manually cleaned bar, a new headworks structure, aerated grit removal system, an influent duplex pump station with a 6' diameter wet well and two (2) 7.5 HP submersible pumps, an oxidation ditch, two (2) 52,873-gallon circular clarifiers, the existing treatment tanks will be converted into two (2) aerobic sludge digestion tanks by installing coarse bubble diffusers, positive displacement blowers, and peristaltic pumps, three (3) chemical feed systems peristaltic-type metering pumps, a new chlorine dosing pump, the existing clarifiers will be converted to chlorine contact tanks with the installation of baffles, dechlorination, and a post aeration system consisting of two (2) centrifugal blowers, fine bubble diffusers, and a post aeration tank.

Industrial Users
The facility has no industrial users.

Hauled-In-Waste
The facility receives no hauled in wastes.

Compliance History

DMR Data for Outfall 001 (from August 1, 2024 to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.150	0.294	0.340	0.239	0.234	0.169	0.133	0.143	0.113	0.124	0.144	0.413
Flow (MGD) Daily Maximum	0.232	0.524	0.693	0.344	0.393	0.384	0.158	0.222	0.151	0.186	0.185	1.87
pH (S.U.) Instantaneous Minimum	7.2	6.8	6.8	6.3	6.2	6.8	6.9	6.7	6.9	6.9	6.9	6.6
pH (S.U.) Instantaneous Maximum	7.8	8.0	7.8	7.6	7.9	7.8	8.2	8.3	8.4	8.3	8.2	8.1
DO (mg/L) Instantaneous Minimum	8.10	6.91	6.74	6.95	8.24	8.92	7.97	8.27	8.34	8.34	8.33	7.38
TRC (mg/L) Average Monthly	0.18	0.17	0.13	0.10	0.18	0.15	0.17	0.16	0.10	0.10	0.19	0.17
TRC (mg/L) Instantaneous Maximum	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
CBOD5 (lbs/day) Average Monthly	< 4.0	< 7.0	< 9.1	< 5.3	< 2.3	4.1	2.7	3.2	< 2.7	< 1.9	< 2.0	< 10.4
CBOD5 (lbs/day) Weekly Average	< 4.76	< 12.61	< 15.56	7.51	4.6	4.89	3.47	5.24	5.35	3.7	2.39	21.14
CBOD5 (mg/L) Average Monthly	< 3.00	< 3.0	< 3.0	< 2.5	3.2	3.4	2.6	2.7	< 3.4	< 1.8	< 1.7	< 3.3
CBOD5 (mg/L) Weekly Average	< 3.00	< 3.0	< 3.0	3.0	8.73	3.7	3.3	4.8	6.9	2.7	2.2	< 4.0
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	128	139	241	94	131	104	143	95	65	87	57	132
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	235	233	4.4	160	189	109	223	138	93	124	84	259
BOD5 (mg/L) Raw Sewage Influent Average Monthly	92	63	85	43	75	79	137	79	76	84	50	54
TSS (lbs/day) Average Monthly	< 5.0	< 9.0	< 12.1	< 3.7	< 4.0	< 5.4	< 4.5	< 5.0	< 3.3	< 4.0	< 4.9	23.5
TSS (lbs/day) Raw Sewage Influent Average Monthly	55	94	89	165	87	61	99	80	70	88	68	66

NPDES Permit Fact Sheet
Westfield Borough Sewer System STP

NPDES Permit No. PA0021881

TSS (lbs/day) Raw Sewage Influent Daily Maximum	90	177	135	261	145	71	201	121	120	133	83	78
TSS (lbs/day) Weekly Average	< 6.34	< 16.8	< 20.75	11.38	< 7.5	< 6.44	4.92	5.84	3.8	5.4	6.0	33.38
TSS (mg/L) Average Monthly	< 4.0	< 4.2	< 4.0	< 4.3	< 4.0	< 4.5	< 4.3	< 4.2	< 4.0	< 4.0	< 4.2	7.5
TSS (mg/L) Raw Sewage Influent Average Monthly	43	42	30	76	49	53	96	65	85	90	58	26
TSS (mg/L) Weekly Average	< 4.0	5.0	< 4.0	5.0	< 10.91	6.0	5.0	5.0	< 4.0	4.0	5.0	13.0
Fecal Coliform (No./100 ml) Geometric Mean	5	6	18	< 1.0	4.0	4.4	< 1.2	< 1.0	< 1.0	< 1.2	< 1.0	< 4
Fecal Coliform (No./100 ml) Instantaneous Maximum	23.8	10.9	26.2	2.0	17.1	17.1	2.0	2.0	1.0	2.0	2.0	13.5
Nitrate-Nitrite (mg/L) Average Monthly	14.8	9.0	9.6	9.2	4.9	7.6	12.2	5.4	5.5	6.3	6.6	8.5
Nitrate-Nitrite (lbs) Total Monthly	458.4	590.8	880	540.2	314.1	258.7	406.5	210.4	144.2	193.2	230.8	784.3
Total Nitrogen (mg/L) Average Monthly	< 14.4	< 10.4	< 10.6	< 11.80	< 6.4	< 8.8	< 13.6	< 6.9	< 7.6	< 7.7	< 7.6	< 10.1
Total Nitrogen (lbs) Total Monthly	< 536.5	697.5	< 975.8	< 697.80	< 402.8	< 304.5	< 453.6	< 267.2	< 196.3	< 236.1	< 267.2	< 959.2
Ammonia (lbs/day) Average Monthly	< 0.13	< 0.26	< 0.30	< 0.21	< 0.31	< 0.13	< 0.10	< 0.11	< 0.10	< 0.10	< 0.20	< 0.39
Ammonia (lbs/day) Weekly Average	< 0.2	< 0.4	< 0.5	< 0.3	1.2	< 0.2	< 0.1	< 0.2	< 0.10	0.10	0.8	0.7
Ammonia (mg/L) Average Monthly	< 0.10	< 0.11	< 0.10	< 0.10	< 0.13	< 0.10	< 0.1	< 0.1	< 0.11	< 0.10	< 0.17	< 0.12
Ammonia (mg/L) Weekly Average	0.11	0.20	< 0.10	< 0.10	0.38	< 0.1	< 0.10	< 0.10	0.13	0.11	0.64	0.20
Ammonia (lbs) Total Monthly	< 3.9	< 7.6	< 9.6	< 5.9	< 9.4	< 3.7	< 3.3	< 3.9	< 2.7	< 3.2	< 6.1	< 11.3
TKN (mg/L) Average Monthly	< 2.0	< 1.4	< 1.0	< 2.6	< 1.4	< 1.2	< 1.4	< 1.5	< 2.1	< 1.4	< 1.0	< 1.6
TKN (lbs) Total Monthly	< 78.1	< 106.7	< 95.8	< 157.6	< 88.7	< 45.8	< 47.2	< 56.9	< 52.1	< 42.9	< 36.4	< 175
Total Phosphorus (lbs/day) Average Monthly	0.58	0.64	0.71	0.41	0.3	0.21	0.15	0.21	0.15	0.22	< 0.24	1.28

NPDES Permit Fact Sheet
Westfield Borough Sewer System STP

NPDES Permit No. PA0021881

Total Phosphorus (lbs/day) Weekly Average	0.9	1.4	1.3	1.6	1.1	0.4	0.2	0.5	0.3	0.3	0.4	1.6
Total Phosphorus (mg/L) Average Monthly	0.477	0.281	0.23	0.232	0.15	0.165	0.135	0.16	0.18	0.22	< 0.22	0.43
Total Phosphorus (mg/L) Weekly Average	0.58	0.34	0.29	0.99	0.48	0.33	0.17	0.25	0.40	0.27	0.28	0.80
Total Phosphorus (lbs) Total Monthly	18.1	19.7	22.5	12.6	9.9	5.8	4.4	6.5	4.7	6.8	< 7.7	39.3

Compliance History

Compliance History	
Summary of Inspections:	The most recent inspection by the Department of the facility on May 7, 2025 identified no violations.
Other Comments:	There are no open violations in eFACTS for Westfield Borough, Tioga County.

Existing Effluent Limitations and Monitoring Requirements								
Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.27	XXX	0.88	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - May 31	41	62	XXX	20	30	40	1/week	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) Jun 1 - Oct 31	21	31	XXX	10	15	20	1/week	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Suspended Solids	62	93	XXX	30	45	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX Geo Mean	2000 XXX	10000	1/week	Grab	
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX Geo Mean	200 XXX	1000	1/week	Grab	
Ammonia-Nitrogen Nov 1 - May 31	19	27	XXX	9.0	13.5	18	2/week	8-Hr Composite
Ammonia-Nitrogen Jun 1 - Oct 31	6.0	9.0	XXX	3.0	4.5	6	2/week	8-Hr Composite
Total Phosphorus	4.1	6.2	XXX	2.0	3.0	4	2/week	8-Hr Composite

Existing Effluent Limitations and Monitoring Requirements – Chesapeake Bay								
Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Net Total Nitrogen	XXX	8402	XXX	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	1120	XXX	XXX	XXX	XXX	1/year	Calculation

Development of Effluent Limitations

Outfall No. 001
Latitude 41° 55' 28.90"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.46
Longitude -77° 31' 17.75"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and are included in the existing permit except for more stringent water quality-based CBOD₅ and TRC limits.

Water Quality-Based Limitations

DO, CBOD5 and NH₃-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. The discharge has existing water quality-based limitations for CBOD₅ and NH₃-N as noted on the previous page. WQM7.0 modeling was performed (see Attachment B) for the discharge to the Cowanesque River and showed that a more stringent ammonia limitation is required beyond the existing limits from 3.0 mg/L to 2.6 mg/L. This more stringent limitation is due to changes to the Department's NH₃-N criteria since the previous review. Based on the existing data listed above this limit is achievable. The Department applies a multiplier of x3 for the winter (November through May) limitations.

The exiting mass loading limitations for ammonia-nitrogen, CBOD5, and TSS, Total Phosphorus were based an actual average flow of 0.247 MGD per the Fact Sheet and Addendum for the 2010 NPDES renewal. The loading limitations that would result from the permitted annual average flow of 0.46 MGD (as is typical Department practice for sewage treatment discharges) would result in higher (less stringent) loadings than the current limitations, including for the new NH₃-N limit. The existing achievable loading limits will remain pursuant to Best Professional Judgment.

Total Residual Chlorine

The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. The attached results of the TRC spreadsheet (see Attachment C) show that the existing limit of 0.27 mg/l is adequate to protect the receiving stream.

Water Quality Toxics Management

No "Reasonable Potential Analysis" was performed to determine additional parameters with the reasonable potential to violate water quality standards for this minor STP discharge with no industrial influent.

Chesapeake Bay/Nutrient Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania in order to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. BAJSA is considered a Phase 3, Significant Chesapeake Bay discharger. Nutrient cap loads have previously been established for this facility pursuant to the Phase III Watershed Implementation Plan.

The discharge's cap loadings as well as the actual Total Nitrogen and Total Phosphorus loadings for the past two cycle years are listed in the table below.

Nutrient	Total Nitrogen (lbs)	Total Phosphorus (lbs)
Nutrient Cap Loads for PA0020567	8,402	1,120
10/1/22 – 9/30/23 Net Loadings	< 5,654	118
10/1/22 – 9/30/23 Total Mass Load	< 5,654	118
10/1/23 – 9/30/24 Net Loadings	< 6,408	< 234
10/1/23 – 9/30/24 Total Mass Load	< 6,048	< 234

E. Coli Monitoring

Quarterly E. Coli monitoring will be included in the draft permit consistent with recent changes to Chapter 93 of the Department's regulations and Departmental policy.

Best Professional Judgment (BPJ) Limitations

Comments: The exiting mass loading limitations for TSS, CBOD₅, NH₃-N, and TP are being kept pursuant to BPJ as noted above. No additional BPJ limitations are necessary at this time beyond the technology and water quality-based limitations noted above.

Anti-Backsliding

No proposed technology or BPJ-based limitations have been made less stringent consistent with the Anti-degradation requirements of The Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.27	XXX	0.88	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - May 31	41	62	XXX	20	30	40	1/week	8-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) Jun 1 - Oct 31	21	31	XXX	10	15	20	1/week	8-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Suspended Solids	62	93	XXX	30	45	60	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Ammonia-Nitrogen Nov 1 - May 31	19	27	XXX	8.0	12.1	16.0	2/week	8-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia-Nitrogen Jun 1 - Oct 31	6.0	9.0	XXX	2.6	4.0	5.3	2/week	8-Hr Composite
Total Phosphorus	4.1	6.2	XXX	2.0	3.0	4	2/week	8-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab

Compliance Sampling Location: Outfall 001

Other Comments: E. Coli monitoring is new as mentioned above. Ammonia-Nitrogen concentration limitations have changed as mentioned above.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Net Total Nitrogen	XXX	8402	XXX	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	1120	XXX	XXX	XXX	XXX	1/year	Calculation


Compliance Sampling Location: Outfall 001

Other Comments: None

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Attachments:

- Discharge Location Map
- WQM7.0 Model
- TRC Model



Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	30995	COWANESQUE RIVER	27.600	1311.00	96.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	Stream pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.013	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Westfield Boro	PA0021881	0.4600	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		10.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		3.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
04A	30995	COWANESQUE RIVER	26.400	1300.00	100.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	Stream pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.013	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000			
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
04A			30995			COWANESQUE RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
27.600	1.28	0.00	1.28	.7116	0.00174	.654	29.45	45.05	0.10	0.708	21.78	7.00
Q1-10 Flow												
27.600	0.82	0.00	0.82	.7116	0.00174	NA	NA	NA	0.09	0.821	22.32	7.00
Q30-10 Flow												
27.600	1.74	0.00	1.74	.7116	0.00174	NA	NA	NA	0.12	0.630	21.45	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
04A	30995	COWANESQUE RIVER		
<u>RMI</u> 27.600	Total Discharge Flow (mgd) 0.460		<u>Analysis Temperature (°C)</u> 21.784	<u>Analysis pH</u> 7.000
<u>Reach Width (ft)</u> 29.450	<u>Reach Depth (ft)</u> 0.654		<u>Reach WDRatio</u> 45.048	<u>Reach Velocity (fps)</u> 0.104
<u>Reach CBOD5 (mg/L)</u> 4.85	<u>Reach Kc (1/days)</u> 0.910		<u>Reach NH3-N (mg/L)</u> 0.96	<u>Reach Kn (1/days)</u> 0.803
<u>Reach DO (mg/L)</u> 6.372	<u>Reach Kr (1/days)</u> 1.783		<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 5
<u>Reach Travel Time (days)</u> 0.708		Subreach Results		
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.071	4.53	0.91	5.98
	0.142	4.22	0.86	5.68
	0.212	3.94	0.81	5.45
	0.283	3.67	0.76	5.29
	0.354	3.42	0.72	5.18
	0.425	3.19	0.68	5.12
	0.496	2.98	0.64	5.10
	0.566	2.78	0.61	5.11
	0.637	2.59	0.57	5.15
	0.708	2.41	0.54	5.21

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
04A	30995	COWANESQUE RIVER

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	27.600 Westfield Boro	13.83	6	13.83	6	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	27.600 Westfield Boro	1.72	3	1.72	3	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	27.60 Westfield Boro	10	10	2.69	2.69	3	3	0	0

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
04A		30995	COWANESQUE RIVER				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
27.600	Westfield Boro	PA0021881	0.460	CBOD5	10		
				NH3-N	2.69	5.38	
				Dissolved Oxygen			3

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.593		1.3.2.iii	WLA_cfc = 0.570
PENTOXSD TRG	5.1a		LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b		LTA_afc = 0.221	5.1d	LTA_cfc = 0.332
Effluent Limit Calculations					
PENTOXSD TRG	5.1f		AML MULT = 1.231		
PENTOXSD TRG	5.1g		AVG MON LIMIT (mg/l) = 0.272	AFC	
			INST MAX LIMIT (mg/l) = 0.889		
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_afc		$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$			
LTA_afc		wla_afc*LTAMULT_afc			
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_cfc		$\text{EXP}((0.5*\text{LN}(cvd^2/no_samples+1))-2.326*\text{LN}(cvd^2/no_samples+1)^0.5)$			
LTA_cfc		wla_cfc*LTAMULT_cfc			
AML MULT		$\text{EXP}(2.326*\text{LN}(cvd^2/no_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no_samples+1))$			
AVG MON LIMIT		$\text{MIN}(\text{BAT_BPJ},\text{MIN}(\text{LTA_afc},\text{LTA_cfc})*\text{AML_MULT})$			
INST MAX LIMIT		$1.5*((\text{av_mon_limit}/\text{AML_MULT})/\text{LTAMULT_afc})$			