

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0022195
 APS ID 1102131
 Authorization ID 1464033

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|--|
| Applicant Name | <u>Catawissa Borough Columbia County</u> | Facility Name | <u>Catawissa Borough STP</u> |
| Applicant Address | <u>307 Main Street</u> <u>Catawissa, PA 17820-1315</u> | Facility Address | <u>S First Street</u> <u>Catawissa, PA 17820-0044</u> |
| Applicant Contact | <u>Connie Cole</u> | Facility Contact | <u>Bob Dunkleburger</u> |
| Applicant Phone | <u>(570) 356-2561</u> | Facility Phone | <u>(570) 355-2561</u> |
| Client ID | <u>65143</u> | Site ID | <u>257479</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Catawissa Borough</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Columbia</u> |
| Date Application Received | <u>November 28, 2023</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>December 12, 2023</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>Renewal of a NPDES Permit</u> | | |

Summary of Review



The subject facility is a minor Publicly Owned Treatment Works (POTW) serving Catawissa Borough in Columbia County.

A map of the discharge location is attached (Attachment A).

Sludge use and disposal description and location(s): The facility's dewatered sludge is sent to other WWTPs for further processing.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|---|--------------|
| ✓ | |  Keith C. Allison / Project Manager | May 22, 2024 |
| ✓ | |  Nicholas W. Hartranft, P.E. / Environmental Engineer Manager | May 23, 2024 |

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|-------------------------------------|------------------------------|--|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>0.2</u> |
| Latitude | <u>40° 57' 3.55"</u> | Longitude | <u>-76° 27' 58.27"</u> |
| Quad Name | <u>Catawissa, PA</u> | Quad Code | <u>1134</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |
| Receiving Waters | <u>Catawissa Creek (TSF)</u> | Stream Code | <u>27529</u> |
| NHD Com ID | <u>65641537</u> | RMI | <u>0.06</u> |
| Drainage Area | <u>153 mi²</u> | Yield (cfs/mi ²) | <u>0.335</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>51.2</u> | Q ₇₋₁₀ Basis | <u>Streamgage No. 01468500, Schuylkill River @Pandingville, PA</u> |
| Elevation (ft) | <u>447</u> | Slope (ft/ft) | <u>0.00032</u> |
| Watershed No. | <u>5-E</u> | Chapter 93 Class. | <u>TSF</u> |
| Existing Use | <u>N/A</u> | Existing Use Qualifier | <u>N/A</u> |
| Exceptions to Use | <u>None</u> | Exceptions to Criteria | <u>None</u> |
| Assessment Status | <u>Impaired</u> | | |
| Cause(s) of Impairment | <u>METALS</u> | | |
| Source(s) of Impairment | <u>ACID MINE DRAINAGE</u> | | |
| TMDL Status | <u>Final</u> | Name | <u>Catawissa Creek</u> |
| Nearest Downstream Public Water Supply Intake | <u>Danville Municipal Authority</u> | | |
| PWS Waters | <u>Susquehanna River</u> | Flow at Intake (cfs) | <u>1,130</u> |
| PWS RMI | <u>138.06</u> | Distance from Outfall (mi) | <u>7</u> |

Changes Since Last Permit Issuance: The above stream and drainage characteristics were determined for a previous review and remain adequate except for an updated flow yield and stream flow.

Other Comments: This discharge is not affecting the above-listed impairment by AMD metals in Catawissa Creek and is not identified as a contributor to the impairment in the TMDL. The impairment to Catawissa Creek is due to mine drainage. The permittee provided monitoring results for Total Aluminum, Total Iron, and Total Manganese - the metals typically associated with AMD impairment. The results for all three are below their respective instream criteria and therefore, the discharge is not expected to be contributing to the impairment and no additional monitoring will be required at this time related to these impairments.

The discharge is not expected to affect any downstream water supply at this time with the limitations and monitoring proposed.

| Treatment Facility Summary | | | | |
|--|---|--|----------------------------|-------------------------------|
| Treatment Facility Name: Borough of Catawissa | | | | |
| WQM Permit No. | Issuance Date | Permit For: | | |
| 1987406 | A-3 – 2/14/20 A-2 – 7/2/15 T-1 – 6/21/94 Original – 8/20/87_ | Replacement of air piping, diffusers, valves, and clarifier skimmers Change from gas to liquid chlorination Transfer | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Extended Aeration | Hypochlorite | 0.2 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.2 | 340 | Not Overloaded | Dewatering | Other WWTP |

Changes Since Last Permit Issuance: The improvements under WQM Permit No. 1987406 A-3 have been made.

Other Comments: The facilities as permitted under WQM Permit No. 1987406 A-3 consists of two comminutors, a manual bar screen, two aeration tanks, two clarifiers, two chlorine contact tanks with sodium hypochlorite disinfection, and an aerated sludge holding tank.

| Industrial Users |
|---|
| The facility does not have any significant industrial users. The industrial users identified in the application include: <ul style="list-style-type: none"> • Catawissa Bottling (<75 GPD) • Mellick Aqua Feed (<75 GPD) • Catawissa Monument (<75 GPD) |

| Hauled-In-Waste |
|--|
| Per the application, the facility has not received any hauled-in wastes over the past three years and the permittee does not anticipate receiving any over the next permit term. |

Compliance History

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)

| Parameter | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 | SEP-23 | AUG-23 | JUL-23 | JUN-23 | MAY-23 | APR-23 |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.1270 | 0.0740 | 0.1210 | 0.1000 | 0.0670 | 0.0750 | 0.0700 | 0.0730 | 0.0680 | 0.0540 | 0.0920 | 0.0470 |
| Flow (MGD) Daily Maximum | 0.2910 | 0.1180 | 0.3610 | 0.3840 | 0.1450 | 0.1420 | 0.1580 | 0.1550 | 0.1620 | 0.0780 | 0.4590 | 0.1160 |
| pH (S.U.) Instantaneous Minimum | 6.4 | 6.4 | 6.4 | 6.3 | 6.3 | 6.2 | 6.6 | 6.6 | 6.6 | 6.3 | 6.5 | 6.3 |
| pH (S.U.) Instantaneous Maximum | 6.8 | 6.9 | 6.9 | 6.9 | 6.9 | 7.0 | 7.1 | 7.0 | 7.1 | 7.1 | 7.1 | 7.1 |
| DO (mg/L) Instantaneous Minimum | 7.0 | 8.2 | 7.6 | 5.0 | 5 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5.0 | 5 |
| TRC (mg/L) Average Monthly | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.20 | 0.20 | 0.20 | 0.10 | 0.20 | 0.10 |
| TRC (mg/L) Instantaneous Maximum | 0.50 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.40 | 0.20 | 0.20 | 0.30 | 0.20 | 0.20 |
| CBOD5 (lbs/day) Average Monthly | < 7 | < 3 | < 5 | < 8 | < 3 | < 4 | < 3 | < 4 | < 3 | < 3 | < 7 | < 2 |
| CBOD5 (lbs/day) Weekly Average | < 11 | < 4 | < 9 | < 19 | < 4 | < 5 | < 5 | < 6 | < 4 | < 4 | < 19 | < 3 |
| CBOD5 (mg/L) Average Monthly | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.78 | < 6.0 |
| CBOD5 (mg/L) Weekly Average | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | < 6.0 | 9.88 | < 6.0 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 170 | 154 | 249 | 198 | 324 | 195 | 138 | 174 | 226 | 236 | 147 | 78 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 197 | 282 | 317 | 302 | 632 | 329 | 259 | 257 | 396 | 515 | 266 | 189 |
| TSS (lbs/day) Average Monthly | 18 | < 6 | 11 | < 51 | < 6 | < 4 | < 5 | < 4 | 4 | < 3 | < 6 | 3 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 235 | 99 | 248 | 191 | 197 | 131 | 101 | 141 | 191 | 54 | 207 | 108 |

**NPDES Permit Fact Sheet
Catawissa Borough Sanitary Sewer STP**

NPDES Permit No. PA0022195

| | | | | | | | | | | | | |
|--|--------|--------|-------|--------|--------|-------|--------|--------|------|-------|--------|-------|
| TSS (lbs/day) Weekly Average | 29 | 10 | 21 | 184 | 13 | 5 | 8 | 7 | 5 | 3 | < 16 | 4 |
| TSS (mg/L) Average Monthly | 16.0 | < 11.7 | 11.3 | < 21.3 | < 11.8 | < 6.4 | < 8.3 | < 6.4 | 7.1 | < 5.1 | < 6.4 | 7.3 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 257 | 177 | 325 | 268 | 378 | 227 | 179 | 208 | 326 | 310 | 215 | 312 |
| TSS (mg/L) Weekly Average | 19.5 | 16.7 | 16.3 | 57.5 | 26.1 | 7.2 | 11.1 | 10.2 | 8.0 | 5.4 | 9.0 | 9.0 |
| Fecal Coliform (No./100 ml) Geometric Mean | < 12 | < 1 | < 1 | < 2 | < 1 | < 1 | < 6 | < 1 | < 1 | < 1 | < 5 | < 1 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 2419.6 | 1.0 | 1 | 24.9 | 2 | < 1 | 1299.7 | 1 | < 1 | 2 | 2419.6 | < 1 |
| Total Nitrogen (lbs/day) Average Monthly | 13 | 11 | 13 | 16 | 6 | 6 | 8 | 583 | 5 | 3 | 8 | 5 |
| Total Nitrogen (mg/L) Average Monthly | 8.88 | 17.32 | 25.03 | 26.61 | 10.24 | 12.31 | 12.95 | 592.91 | 9.92 | 7.36 | 12.74 | 26.01 |
| Ammonia (lbs/day) Average Monthly | 4 | 0.3 | < 0.1 | 0.2 | 0.4 | 0.1 | 1 | 2 | 2 | 1 | 1 | 0.1 |
| Ammonia (mg/L) Average Monthly | 2.44 | 0.44 | < 0.2 | 0.338 | 0.579 | 0.295 | 2.32 | 2.41 | 3.47 | 2.4 | 1.84 | 0.726 |
| Total Phosphorus (lbs/day) Average Monthly | 4 | 2 | 2 | 2 | 1 | 2 | 3 | 4 | 2 | 1 | 1 | 0.8 |
| Total Phosphorus (mg/L) Average Monthly | 2.67 | 3.17 | 3.84 | 3.7 | 1.65 | 3.54 | 4.56 | 4.55 | 4.97 | 3.48 | 2.33 | 4.18 |
| Total Copper (lbs/day) Daily Maximum | | | | 0.007 | | | | | | | | |
| Total Copper (mg/L) Daily Maximum | | | | 0.0347 | | | | | | | | |

Compliance History

Effluent Violations for Outfall 001, from: April 1, 2023 To: March 31, 2024

| Parameter | Date | SBC | DMR Value | Units | Limit Value | Units |
|----------------|----------|----------|-----------|------------|-------------|------------|
| TSS | 12/31/23 | Avg Mo | < 51 | lbs/day | 50 | lbs/day |
| TSS | 12/31/23 | Wkly Avg | 184 | lbs/day | 75 | lbs/day |
| TSS | 12/31/23 | Wkly Avg | 57.5 | mg/L | 45.0 | mg/L |
| Fecal Coliform | 05/31/23 | IMAX | 2419.6 | No./100 ml | 1000 | No./100 ml |
| Fecal Coliform | 09/30/23 | IMAX | 1299.7 | No./100 ml | 1000 | No./100 ml |

Compliance History

| | |
|--------------------------------|---|
| Summary of Inspections: | The facility has been inspected at least annually over the past permit term. The most recent inspection on January 25, 2023 identified a DMR violation but no operational violations at the time of inspection. |
| Other Comments: | A query in WMS found no open violations in eFACTS for Catawissa Borough. |

Existing Effluent Limitations and Monitoring Requirements

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------------|-----------------------|--------------------|---------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Metered |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | Report Inst Min | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD5 | 41 | 65 | XXX | 25.0 | 40.0 | 50 | 1/week | 8-Hr Composite |
| BOD5 Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| TSS | 50 | 75 | XXX | 30.0 | 45.0 | 60 | 1/week | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 1/week | Grab |
| Total Nitrogen | Report | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| Ammonia | Report | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| Total Phosphorus | Report | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| Total Copper | XXX | Report Daily Max | XXX | XXX | Report Daily Max | XXX | 1/year | Grab |

Development of Effluent Limitations

| | |
|--|--|
| Outfall No. <u>001</u> Latitude <u>40° 57' 5.40"</u> Wastewater Description: <u>Sewage Effluent</u> | Design Flow (MGD) <u>0.2</u> Longitude <u>-76° 27' 56.50"</u> |
|--|--|

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments: The above limitations are applicable and are included in the existing permit.

Water Quality-Based Limitations

DO, CBOD₅ and NH₃-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. WQM7.0 modeling was performed (see Attachment B) for the discharge to the Catawissa Creek and showed that no limitations are necessary for these parameters beyond the technology-based secondary treatment limits listed above.

Total Residual Chlorine

The Department uses a modeling spreadsheet to analyze the toxicity of a discharge's TRC in a receiving stream, accounting for available dilution. The attached results of the TRC spreadsheet (see Attachment C) show that the technology-based limit of 0.5 mg/l is adequate to protect the receiving stream.

Water Quality Toxics Management

A "Reasonable Potential Analysis" was performed to determine additional parameters with the reasonable potential to violate water quality standards (see the Toxics Management Spreadsheet, Attachment D). The Toxics Management Spreadsheet (TMS) is a mass-balance water quality analysis model that includes consideration for mixing and other factors to determine recommended water quality-based effluent limits. The model incorporates the water quality criteria of 25 Pa.Code §93.

The TMS recommended that the existing monitoring for Total Copper continue and thus is will remain at the existing annual frequency.

| Pollutant | Highest Sample Results (µg/L) | WQBEL (µg/L) | TMS Result |
|--------------|-------------------------------|--------------|------------------------|
| Total Copper | 77 | 200 | Monitoring Recommended |

Chesapeake Bay/Nutrient Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania in order to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. Catawissa Borough is considered a Phase 4, Non-Significant Chesapeake Bay discharger and thus has received no nutrient cap loads pursuant to the Phase III Watershed Implementation Plan. Monitoring performed over the past permit term for Total Nitrogen and Total Phosphorus has averaged 30.8 mg/L and 3.9 mg/L, respectively. Monthly monitoring will continue consistent with the Phase III WIP for this Phase 4 discharge.

Best Professional Judgment (BPJ) Limitations

Comments: No additional BPJ limitations are necessary at this time beyond the technology and water quality-based limitations noted above.

Anti-Backsliding

No proposed limitations have been made less stringent consistent with the Anti-degradation requirements of The Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------------|-----------------------|--------------------|---------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Metered |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | Report Inst Min | XXX | XXX | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD5 | 41 | 65 | XXX | 25.0 | 40.0 | 50 | 1/week | 8-Hr Composite |
| BOD5 Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| TSS | 50 | 75 | XXX | 30.0 | 45.0 | 60 | 1/week | 8-Hr Composite |
| TSS Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 1/week | 8-Hr Composite |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | 10000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 1/week | Grab |
| Total Nitrogen | Report | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| Ammonia | Report | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| Total Phosphorus | Report | XXX | XXX | Report | XXX | XXX | 1/month | 8-Hr Composite |
| Total Copper | XXX | Report Daily Max | XXX | XXX | Report Daily Max | XXX | 1/year | Grab |

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|----------------------|-------------------------------------|-------------------|-----------------------|--------------------|---------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | Report Daily Max | XXX | 1/quarter | Grab |


Compliance Sampling Location: Outfall 001

Other Comments: E. coli monitoring is new consistent with recent changes to Chapter 93 of the Department's regulations and current Department policy.

| Tools and References Used to Develop Permit | |
|---|--|
| <input checked="" type="checkbox"/> | WQM for Windows Model (see Attachment B) |
| <input type="checkbox"/> | Toxics Management Spreadsheet (see Attachment) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment C) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment) |
| <input checked="" type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input checked="" type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98. |
| <input checked="" type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 386-2000-002, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97. |
| <input checked="" type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97. |
| <input checked="" type="checkbox"/> | Implementation Guidance Design Conditions, 386-2000-007, 9/97. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99. |
| <input checked="" type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008. |
| <input checked="" type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input checked="" type="checkbox"/> | Design Stream Flows, 386-2000-003, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97. |
| <input checked="" type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input type="checkbox"/> | SOP: |
| <input type="checkbox"/> | Other: |

Attachments:

- A. Discharge Location Map
- B. WQM7.0
- C. TRC Model
- D. Toxics Management Spreadsheet



Google Earth



Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-----------------|--------------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 05E | 27529 | CATAWISSA CREEK | 0.060 | 447.00 | 152.81 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | Tributary pH | Stream Temp (°C) | Stream pH |
|---------------|--------------|-----------------|-------------------|----------------------|--------------------|----------|----------------|----------------|---------------------|--------------|------------------|-----------|
| | Q7-10 | 0.335 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Catawissa Boro | PA0022195 | 0.2000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|-----------------|--------------|-------------------|--------------------------|------------------|-------------------------|-------------------------------------|
| 05E | 27529 | CATAWISSA CREEK | 0.000 | 446.90 | 152.82 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|---------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | pH | (°C) | pH |
| Q7-10 | 0.335 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------|---------------|-----------------------------|------------------------------|---------------------------|----------------|-------------------|---------|
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|---------------------|---------------------|-----------------------|-----------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | | <u>Stream Name</u> | | | | | | |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|------------------------|--------------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 05E | | 27529 | | | | CATAWISSA CREEK | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 0.060 | 51.19 | 0.00 | 51.19 | .3094 | 0.00032 | .973 | 105.42 | 108.39 | 0.50 | 0.007 | 20.03 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 0.060 | 32.76 | 0.00 | 32.76 | .3094 | 0.00032 | NA | NA | NA | 0.39 | 0.009 | 20.05 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 0.060 | 69.62 | 0.00 | 69.62 | .3094 | 0.00032 | NA | NA | NA | 0.60 | 0.006 | 20.02 | 7.00 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------|-----------------------------|--|
| 05E | 27529 | CATAWISSA CREEK | | | |
| <hr/> | | | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> | |
| 0.060 | 0.200 | 20.030 | | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> | |
| 105.416 | 0.973 | 108.393 | | 0.502 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> | |
| 2.14 | 0.105 | 0.15 | | 0.702 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> | |
| 8.211 | 0.741 | Tsivoglou | | 6 | |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | | |
| 0.007 | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) | |
| | 0.001 | 2.14 | 0.15 | 8.21 | |
| | 0.001 | 2.14 | 0.15 | 8.21 | |
| | 0.002 | 2.14 | 0.15 | 8.21 | |
| | 0.003 | 2.14 | 0.15 | 8.21 | |
| | 0.004 | 2.14 | 0.15 | 8.21 | |
| | 0.004 | 2.14 | 0.15 | 8.21 | |
| | 0.005 | 2.14 | 0.15 | 8.21 | |
| | 0.006 | 2.14 | 0.15 | 8.21 | |
| | 0.007 | 2.14 | 0.15 | 8.21 | |
| | 0.007 | 2.14 | 0.15 | 8.21 | |
| <hr/> | | | | | |

WQM 7.0 Wasteload Allocations

| | | |
|------------------|--------------------|--------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 05E | 27529 | CATAWISSA CREEK |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 0.060 | Catawissa Boro | 16.7 | 50 | 16.7 | 50 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|-------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 0.060 | Catawissa Boro | 1.88 | 25 | 1.88 | 25 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|------|----------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 0.06 | Catawissa Boro | 25 | 25 | 25 | 25 | 3 | 3 | 0 | 0 |

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|------------------|--------------------|--------------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 05E | 27529 | CATAWISSA CREEK | | | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 0.060 | Catawissa Boro | PA0022195 | 0.200 | CBOD5 | 25 | | |
| | | | | NH3-N | 25 | 50 | |
| | | | | Dissolved Oxygen | | | 3 |

| TRC EVALUATION | | | | | |
|---|---|-------------------------------|-----|--------------------------------------|---------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | | | |
| 51.2 | = Q stream (cfs) | | 0.5 | = CV Daily | |
| 0.2 | = Q discharge (MGD) | | 0.5 | = CV Hourly | |
| 30 | = no. samples | | 1 | = AFC_Partial Mix Factor | |
| 0.3 | = Chlorine Demand of Stream | | 1 | = CFC_Partial Mix Factor | |
| 0 | = Chlorine Demand of Discharge | | 15 | = AFC_Criteria Compliance Time (min) | |
| 0.5 | = BAT/BPJ Value | | 720 | = CFC_Criteria Compliance Time (min) | |
| 0 | = % Factor of Safety (FOS) | | | =Decay Coefficient (K) | |
| Source | Reference | AFC Calculations | | Reference | CFC Calculations |
| TRC | 1.3.2.iii | WLA_afc = 52.808 | | 1.3.2.iii | WLA_cfc = 51.476 |
| PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | | 5.1c | LTAMULT_cfc = 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc = 19.677 | | 5.1d | LTA_cfc = 29.926 |
| Source | Effluent Limit Calculations | | | | |
| PENTOXSD TRG | 5.1f | AML_MULT = 1.231 | | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | | BAT/BPJ | |
| | | INST MAX LIMIT (mg/l) = 1.635 | | | |
| WLA_afc | $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | | |
| LTAMULT_afc | $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$ | | | | |
| LTA_afc | wla_afc * LTAMULT_afc | | | | |
| WLA_cfc | $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$ | | | | |
| LTAMULT_cfc | $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$ | | | | |
| LTA_cfc | wla_cfc * LTAMULT_cfc | | | | |
| AML_MULT | $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$ | | | | |
| AVG MON LIMIT | MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT) | | | | |
| INST MAX LIMIT | $1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$ | | | | |

Discharge Information

Instructions

Discharge

Stream

Facility: Catawissa Borough

NPDES Permit No.: PA002195

Outfall No.: 001

Evaluation Type Custom / Additives

Wastewater Description: POTW

| Discharge Characteristics | | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|-----|--------------------------|----------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) | |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ | Q _h |
| 0.2 | 100 | 7 | | | | | | |

| Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | | 1 if left blank | |
|---------------------|-------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----|-----------------|-------------|
| | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteria Mod | Chem Transl |
| Total Copper | mg/L | 0.0304 | | | | | | | | | |
| Total Lead | mg/L | 0.00205 | | | | | | | | | |
| Total Zinc | mg/L | 0.0523 | | | | | | | | | |
| Total Aluminum | mg/L | 0.158 | | | | | | | | | |
| Total Iron | mg/L | 0.253 | | | | | | | | | |
| Total Manganese | mg/L | 0.015 | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |
| | | | | | | | | | | | |

Stream / Surface Water Information

Catawissa Borough, NPDES Permit No. PA002195, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Catawissa Creek**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|-------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 027529 | 0.06 | 447 | 152.81 | | | Yes |
| End of Reach 1 | 027529 | 0.001 | 446.9 | 152.82 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 0.06 | 0.335 | | | | | | | | | | 100 | 7 | | |
| End of Reach 1 | 0.001 | 0.335 | | | | | | | | | | | | | |

Q_h

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|----------|----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness | pH | Hardness | pH |
| Point of Discharge | 0.06 | | | | | | | | | | | | | | |
| End of Reach 1 | 0.001 | | | | | | | | | | | | | | |

Model Results

Catawissa Borough, NPDES Permit No. PA002195, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Q₇₋₁₀

| RMI | Stream Flow (cfs) | PWS Withdrawal (cfs) | Net Stream Flow (cfs) | Discharge Analysis Flow (cfs) | Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Travel Time (days) | Complete Mix Time (min) |
|-------|-------------------|----------------------|-----------------------|-------------------------------|---------------|------------|------------|-----------|----------------|--------------------|-------------------------|
| 0.06 | 51.19 | | 51.19 | 0.309 | 0.00032 | 0.972 | 105.345 | 108.381 | 0.503 | 0.007 | 875.337 |
| 0.001 | 51.19 | | 51.1947 | | | | | | | | |

Q_h

| RMI | Stream Flow (cfs) | PWS Withdrawal (cfs) | Net Stream Flow (cfs) | Discharge Analysis Flow (cfs) | Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Travel Time (days) | Complete Mix Time (min) |
|-------|-------------------|----------------------|-----------------------|-------------------------------|---------------|------------|------------|-----------|----------------|--------------------|-------------------------|
| 0.06 | 231.65 | | 231.65 | 0.309 | 0.00032 | 1.885 | 105.345 | 55.895 | 1.168 | 0.003 | 327.249 |
| 0.001 | 231.66 | | 231.66 | | | | | | | | |

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|-----------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Copper | 0 | 0 | | 0 | 13.439 | 14.0 | 317 | Chem Translator of 0.96 applied |
| Total Lead | 0 | 0 | | 0 | 64.581 | 81.6 | 1,850 | Chem Translator of 0.791 applied |
| Total Zinc | 0 | 0 | | 0 | 117.180 | 120 | 2,715 | Chem Translator of 0.978 applied |
| Total Aluminum | 0 | 0 | | 0 | 750 | 750 | 16,994 | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|--------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Copper | 0 | 0 | | 0 | 8.956 | 9.33 | 1,409 | Chem Translator of 0.96 applied |
| Total Lead | 0 | 0 | | 0 | 2.517 | 3.18 | 481 | Chem Translator of 0.791 applied |

| | | | | | | | | |
|-----------------|---|---|--|---|---------|-------|---------|----------------------------------|
| Total Zinc | 0 | 0 | | 0 | 118.139 | 120 | 18,099 | Chem Translator of 0.986 applied |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | 1,500 | 1,500 | 249,680 | WQC = 30 day average; PMF = 1 |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|-----------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | 1,000 | 1,000 | 151,056 | |

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|-----------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Aluminum | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Iron | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Manganese | 0 | 0 | | 0 | N/A | N/A | N/A | |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|--------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Copper | Report | Report | Report | Report | Report | mg/L | 0.2 | AFC | Discharge Conc > 10% WQBEL (no RP) |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|----------------|-----------------|-------|----------------------------|
| Total Lead | 481 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Zinc | 1.74 | mg/L | Discharge Conc ≤ 10% WQBEL |
| Total Aluminum | 10,893 | µg/L | Discharge Conc ≤ 10% WQBEL |

| | | | |
|-----------------|---------|------|----------------------------|
| Total Iron | 249,680 | µg/L | Discharge Conc ≤ 10% WQBEL |
| Total Manganese | 151,056 | µg/L | Discharge Conc ≤ 10% WQBEL |