

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0023141  
APS ID 1076348  
Authorization ID 1418729

**Applicant and Facility Information**

Applicant Name	<u>Hastings Area Sewer Authority</u>	Facility Name	<u>Hastings Municipal Authority</u>
Applicant Address	<u>207-1 5th Avenue</u> <u>Hastings, PA 16646-0559</u>	Facility Address	<u>133 Pine Road</u> <u>Hastings, PA 16646-0559</u>
Applicant Contact	<u>Melanie Zearfoss</u>	Facility Contact	<u>Chuck Ishman</u>
Applicant Phone	<u>(814) 247-8619</u>	Facility Phone	<u>814-247-8619</u>
Client ID	<u>334486</u>	Site ID	<u>261471</u>
Ch 94 Load Status	<u>Projected Organic Overload</u>	Municipality	<u>Hastings Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Cambria</u>
Date Application Received	<u>November 17, 2022</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u></u>	If No, Reason	<u>DEP Discretion</u>
Purpose of Application	<u>Renewal of NPDES Permit</u>		

**Summary of Review**

The applicant has applied for the renewal of NPDES Permit PA0023141. The previous permit was issued on June 1, 2018 and expired on May 31, 2023.

Sewage from this plant is treated with screening and grit removal, flow equalization tank, aeration tank, clarifier, aerobic digester and UV light disinfection.



The applicant is currently enrolled in and will continue to use eDMR.

The Act 14 Municipal Notification letter was provided dated August 16, 2022 and no comments were received.

Below is a summary of changes made to this permit:

- *E. Coli* monitoring was imposed
- Copper and lead limits were imposed
- CBOD<sub>5</sub> limits became more stringent
- Summer Ammonia-Nitrogen limits became more stringent
- Monitoring frequencies for several parameters have been updated to comply with DEP guidance and Table 6-3 of the Department's "Technical Guidance for the Development and Specification of Effluent Limitations"
- Mass loading limits for CBOD<sub>5</sub>, Ammonia-nitrogen, and TSS have been rounded to comply with DEP guidance. They are slightly more stringent than the previous cycle.

Sludge use and disposal description and location(s): Laurel Highlands Landfill, Cambria County

Approve	Deny	Signatures	Date
X		 Jordan Coldsmith / Environmental Engineering Specialist	August 29, 2023
X		 Mahbuba Iasmin, Ph.D. / Environmental Engineering Manager	September 21, 2023

**Summary of Review**

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.6</u>
Latitude	<u>40° 40' 18.17"</u>	Longitude	<u>-78° 42' 12.56"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Brubaker Run (CWF)</u>	Stream Code	<u>26858</u>
NHD Com ID	<u>61837043</u>	RMI	<u>3.88</u>
Drainage Area	<u>4.2</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.05</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.221</u>	Q <sub>7-10</sub> Basis	<u>USGS StreamStat</u>
Elevation (ft)	<u>1968</u>	Slope (ft/ft)	_____
Watershed No.	<u>8-B</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>METALS, SILTATION</u>		
Source(s) of Impairment	<u>ACID MINE DRAINAGE, REMOVAL OF RIPARIAN VEGETATION</u>		
TMDL Status	<u>Final</u>	Name	<u>Chest Creek Sediment TMDL</u>
Background/Ambient Data	Data Source		
pH (SU)	_____	_____	
Temperature (°F)	_____	_____	
Hardness (mg/L)	_____	_____	
Other:	_____	_____	
Nearest Downstream Public Water Supply Intake	<u>Shawville Power Plant</u>		
PWS Waters	<u>West Branch Susquehanna River</u>	Flow at Intake (cfs)	_____
PWS RMI	_____	Distance from Outfall (mi)	<u>65.68</u>

Changes Since Last Permit Issuance: None

Other Comments:

**Chest Creek Watershed Sediment TMDL**

A TMDL for the Chest Creek Watershed was approved by the EPA on July 29, 2011 for the control of excessive siltation. In accordance with 40 CFR § 122.44(d)(1)(vii)(B), when developing WQBELs, the permitting authority shall ensure that effluent limits developed to protect a narrative water quality criterion, a numeric water quality criterion, or both, are consistent with the assumptions and requirements of any available wasteload allocation (WLA) for the discharge prepared by the State and approved by the EPA pursuant to 40 CFR § 130.7. The Chest Creek Watershed Sediment TMDL was prepared for sediment-impaired segments of the Chest Creek Watershed. The NPDES permit PA0023141 was originally issued in 1998 and the receiving water for Hasting WWTP is located in a sediment-impaired segment of Chest Creek, Hastings WWTP was not assigned with a wasteload allocation in the 2011 Final TMDL document. Therefore, the application of standard TBELs for TSS at Hastings WWTP is considered sufficient to ensure that the facility would not adversely impact the stream impairment.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Hastings Municipal Authority				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
567S001 A-1		October 4, 1999		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Tertiary	Extended Air Treatment	UV	0.285
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.6	680	Projected Organic Overload	Aerobic Digestion	Drying Bed

Changes Since Last Permit Issuance: None

Other Comments: The HMA WWTP plant headworks consist of screening and grit removal. A 201,000 gallon flow equalization tank is provided to dampen flows. The tank is also used as a side line equalization storage basin.

The HMA WWTP consists of two parallel process trains. Each train consists of the following:

- A 150,800 gallon aeration tank with fine bubble diffusers
- A 88,000 gallon final clarifier
- A 83,000 gallon aerobic digester

Disinfection is provided with ultraviolet light.

Digested sludge is transferred to one of three wedge wire sludge drying beds.

Two post aeration tanks are also provided.

**Compliance History**

**Operations Compliance Check Summary Report**

**Facility:** Hastings WWTP

**NPDES Permit No.:** PA0023141

**Compliance Review Period:** 3/2018 – 3/2023

**Inspection Summary:**

INSPI ID	INSPECTED DATE	INSPI TYPE	AGENCY	INSPECTION RESULT DESC
3484992	12/01/2022	Chapter 94 Inspection	PA Dept of Environmental Protection	No Violations Noted
<a href="#">3328070</a>	01/24/2022	Follow-up Inspection	PA Dept of Environmental Protection	No Violations Noted
<a href="#">2947129</a>	10/08/2019	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted
2890713	05/17/2019	Chapter 94 Inspection	PA Dept of Environmental Protection	No Violations Noted
<a href="#">2858328</a>	01/20/2019	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted

**Violation Summary:**

No violations

**Open Violations by Client ID:**

No open violations for Client ID 334486

**Enforcement Summary:**

No enforcements

**DMR Violation Summary:**

START	END	<del>NON-COMPLIANCE</del>	PARAMETER	SAMPLE	PERMIT	UNITS	CODE
10/01/2020	09/30/2021	Load 2 Effluent Violation	Total Phosphorus (Total Load, <del>lbs</del> )	1853	1481	<del>lbs</del>	Total Annual
08/01/2019	08/31/2019	Concentration 1 Effluent Violation	Ammonia-Nitrogen	< 2.0955	2.0	mg/L	Average Monthly
05/01/2019	05/31/2019	Concentration 1 Effluent Violation	Ammonia-Nitrogen	< 3.262	2.0	mg/L	Average Monthly

08/01/2018	08/31/2018	Concentration 3 Effluent Violation	Fecal Coliform	3265.8	1000	No./100 ml	Instantaneous Maximum
------------	------------	---------------------------------------	----------------	--------	------	---------------	--------------------------

**Compliance Status:**

In compliance. I believe the exceedance for Total Annual Phosphorous to be an error. I've contacted CO about it.

**Completed by:** John Murphy

**Completed date:** 3/10/2023

Compliance History

DMR Data for Outfall 001 (from July 1, 2022 to June 30, 2023)

Parameter	JUN-23	MAY-23	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22
Flow (MGD) Average Monthly	0.116	0.116	0.112	0.173	0.145	0.1888	0.135	0.121	0.109	0.133	0.114	0.11
Flow (MGD) Daily Maximum	0.174	0.209	0.181	0.41	0.245	0.624	0.275	0.19	0.220	0.255	0.315	0.258
pH (S.U.) Instantaneous Minimum	6.73	6.73	6.83	6.37	6.77	6.84	7.02	7.0	7.0	7.02	7.02	7.1
pH (S.U.) Instantaneous Maximum	7.06	6.95	7.2	6.97	7.03	7.08	7.22	7.63	7.33	7.35	7.87	7.41
DO (mg/L) Instantaneous Minimum	6.18	6.56	7.06	7.01	7.02	6.18	7.15	6.13	6.44	6.02	6.02	7.92
CBOD5 (lbs/day) Average Monthly	< 3.0	< 4.6	< 3.5	< 5.7	< 3.7	< 6.3	< 4.9	< 3.8	< 10.6	< 8.7	< 3.8	< 2.6
CBOD5 (lbs/day) Weekly Average	4.1	7.7	< 4.5	11.8	< 3.9	< 10.3	11.3	6.3	33.5	16.5	9.3	< 2.9
CBOD5 (mg/L) Average Monthly	< 3.1	< 4.3	< 3.7	< 4.4	< 3.0	< 3.3	< 3.4	< 4.0	< 11.4	< 7.1	< 3.4	< 3.0
CBOD5 (mg/L) Weekly Average	4.0	8.0	5.0	10.0	< 3.0	4.0	5.0	6.0	37.0	13.0	7.0	< 3.0
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	156	235	177	256	237	280	200	246	151	151	218	139
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	197	390	246	501	323	546	340	528	224	208	354	163
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	173	240	197	172	205	140	150	264	160	138	204	167
TSS (lbs/day) Average Monthly	< 3.8	< 4.7	4.9	< 5.9	3.4	4.7	< 4.5	< 5.0	< 3.5	7.7	5.0	< 2.2

**NPDES Permit Fact Sheet  
Hastings Municipal Authority**

**NPDES Permit No. PA0023141**

TSS (lbs/day) Raw Sewage Influent   Average Monthly	60	65	53	64	73	82	63	46	45	50	90	56
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	88	97	85	114	86	116	104	55	65	91	129	86
TSS (lbs/day) Weekly Average	6.2	9.5	6.0	12.4	4.7	6.3	7.3	8.4	8.5	13.5	7.1	4.8
TSS (mg/L) Average Monthly	< 4.0	< 5.0	5.0	< 4.0	3.0	3.0	< 3.0	< 5.0	< 4.0	6.0	5.0	< 3.0
TSS (mg/L) Raw Sewage Influent   Average Monthly	66	72	55	43	63	43	51	47	48	46	89	68
TSS (mg/L) Weekly Average	8.0	9.0	7.0	7.0	4.0	4.0	5.0	8.0	8.0	10.0	6.0	5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 67	< 6	188	7	< 1	< 2.0	< 1	< 3	< 1	< 3	< 1	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	913.9	593.8	866.4	98.7	< 1	5.2	3.1	139.6	1	23.8	2	< 1
UV Transmittance (%) Daily Minimum	100	100	100	100	115	115	115	115.0	115	115	115	115
Nitrate-Nitrite (mg/L) Average Monthly	< 32.84	< 31.81	< 22.68	< 17.29	< 19.69	< 16.155	< 22.31	< 21.88	< 26.86	< 21.896	< 18.87	< 18.648
Nitrate-Nitrite (lbs) Total Monthly	< 943	< 1043	< 601	< 733	< 638	< 916	< 815	< 636	< 786	< 801	< 557	< 504
Total Nitrogen (mg/L) Average Monthly	< 33.34	< 32.31	< 23.82	< 17.79	< 20.27	< 16.652	< 22.81	< 22.38	< 27.36	< 22.33	< 19.42	< 19.148
Total Nitrogen (lbs) Effluent Net   Total Monthly	< 958	< 1059	< 633	< 754	< 657	< 944	< 833	< 651	< 801	< 818	< 575	< 518
Total Nitrogen (lbs) Effluent Net   Total Annual										8070		
Total Nitrogen (lbs) Total Annual										8070		
Ammonia (lbs/day) Average Monthly	< 0.1	< 0.1	< 0.2	< 0.1	< 0.1	< 0.2	< 0.1	< 0.1	< 0.07	< 0.2	< 0.1	< 0.1



**NPDES Permit Fact Sheet  
Hastings Municipal Authority**

**NPDES Permit No. PA0023141**

Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.172	< 0.1	< 0.1	0.1	< 0.1	< 0.1	< 0.0738	< 0.1328	< 0.145	< 0.113
Ammonia (lbs) Total Monthly	< 3	< 3	< 5.0	< 4	< 3.0	< 6.0	< 4	< 3	< 2	< 5.0	< 4.0	< 0.1
Ammonia (lbs) Total Annual										< 57		
TKN (mg/L) Average Monthly	< 0.5	< 0.5	< 1.14	< 0.5	< 0.6	< 0.6	< 0.5	< 0.5	< 0.5	< 0.4321	0.6	< 0.5
TKN (lbs) Total Monthly	< 15	< 17	< 32	< 21	< 19	< 31	< 18	< 15	< 15	< 17	< 0.6	< 14
Total Phosphorus (mg/L) Average Monthly	6.12	6.04	4.28	2.99	3.31	2.89	2.84	4.01	4.18	4.5	4.24	4.82
Total Phosphorus (lbs) Effluent Net   Total Monthly	174	190	115	125	108	161	102	111	122	166	120	132
Total Phosphorus (lbs) Total Monthly	174	190	115	125	108	161	102	111	122	166	120	132
Total Phosphorus (lbs) Effluent Net   Total Annual										1391		
Total Phosphorus (lbs) Total Annual										1391		
Total Copper (mg/L) Average Quarterly	0.0127			< 0.01000			0.0203			0.0131		

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.6</u>
<b>Latitude</b> <u>40° 40' 19.00"</u>	<b>Longitude</b> <u>-78° 42' 13.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

The discharge was evaluated using WQM7.0 to determine the CBOD<sub>5</sub>, ammonia nitrogen, and dissolved oxygen parameters. The model results show slightly more restrictive limits for CBOD<sub>5</sub> and for summer ammonia-nitrogen Limits. The Limits evaluated for winter ammonia-nitrogen and DO are less restrictive than limits previously imposed.

To comply with anti-backsliding regulations, the previous, more restrictive limits for winter ammonia-nitrogen and DO, will again be imposed for the facility.

Parameter	Limit (mg/l)	SBC	Model
CBOD <sub>5</sub> (Nov 1 – Apr 30)	23	Average Monthly	WQM7.0
CBOD <sub>5</sub> (May 1 – Oct 31)	17	Average Monthly	WQM7.0
Dissolved Oxygen	6.0	Minimum	WQAM63
Ammonia Nitrogen (Nov 1 – Apr 30)	2.0	Average Monthly	WQAM63
Ammonia Nitrogen (May 1 – Oct 31)	4.0	Average Monthly	WQM7.0

Based off of the current submitted DMRs, the facility is capable of meeting these new restrictive limits. Therefore, the facility will not receive a compliance schedule for these limits.

**Toxics Modeling**

Per DEP SOP “Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants in NPDES Permits for Existing Dischargers” (SOP No. BCW-PMT-037), the Toxics Management Spreadsheet (TMS) will be run for all pollutants for which sampling data is available. All sewage facilities with a design flow of greater than or equal to 0.1 MGD are required to provide effluent samples for: pH, TRC, fecal coliform, CBOD<sub>5</sub> or BOD<sub>5</sub>, TSS, NH<sub>3</sub>-N, Total N, Total P, DO, temperature, TKN, NO<sub>2</sub>-N + NO<sub>3</sub>-N, TDS, Chloride, Bromide, Sulfate, oil and grease, and any applicable TMDL parameters. The TMS spreadsheet was run for the applicable parameters of TDS, Chloride, Bromide, Sulfate, Total Copper, Total Lead, and Total Zinc. Reasonable Potential was found for several of these parameters therefore additional WQBELs will be included in the permit. The Full TMS results can be found in Attachment D.

Parameter	Limit (mg/l)	SBC	Model
Total Copper	0.014	Average Monthly	TMS
Total Lead	0.005	Average Monthly	TMS
Total Zinc	Report	Average Monthly	TMS

The limits for Total Copper and Total Lead are new for this permit cycle. The facility was given a pre-draft permit survey and conducted 10 weeks of testing to show that they are capable of the more restrictive limits. The facility was able to meet the new limits for total lead; therefore, the new total lead limits will be effective immediately. For total copper a compliance schedule of two year will be given. Additionally, the permittee will be required to complete a TRE Workplan and a corrosion control feasibility study. These requirements are detailed under part C in the NPDES permit

**Anti-Backsliding**

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA’s anti-backsliding regulation 40 CFR 122.44 (I) Reissued permits. (1) Except as provided in paragraph (I)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

**Mass Loading Limitations**

Per Department SOP “Establishing Effluent Limitations for Individual Sewage Permits” (BCW-PMT-033), mass loading limits will be established for POTWs for CBOD<sub>5</sub>, TSS, ammonia nitrogen. Average monthly mass loading limits will be established for CBOD<sub>5</sub>, TSS, and ammonia nitrogen. Average weekly mass loading limits will be established for CBOD<sub>5</sub> and TSS. Mass loading limits will be calculated according to the formula below:

$$\begin{aligned} & \text{average annual design flow (MGD)} \times \text{concentration limit} \left( \frac{mg}{L} \right) \times 8.34 \text{ (conversion factor)} \\ & = \text{mass loading limit} \left( \frac{lbs}{day} \right) \end{aligned}$$

Please note that the hydraulic capacity of the facility is used for the average annual design flow number for the purposes of the calculations

The following mass loading limitations were calculated:

Parameter	Average Monthly (lbs/day)	Average Weekly (lbs/day)
CBOD <sub>5</sub> (Nov 1 – Apr 30)	115.09	172.63
CBOD <sub>5</sub> (May 1 – Oct 31)	85.06	127.6
TSS	150.12	225.18
Ammonia Nitrogen (May 1 – Oct 31)	20.01	-
Ammonia Nitrogen (Nov 1 – Apr 30)	10.0	-

**Influent Monitoring**

Per Department SOP “New and Reissuance Sewage Individual NPDES Permit Applications” (BCW-PMT-002), POTWs with design flows greater than 2,000 GPD, influent BOD<sub>5</sub> and TSS monitoring will again be included in the permit. The influent monitoring will be established with the same frequency and sample type as the effluent sampling.

**Chesapeake Bay**

Hastings WWTP is considered a Phase 3 discharger by the Chesapeake Bay Watershed Implementation Plan and all effluent limits were to be established in the permit by October 2016. Hastings WWTP has been assigned a Cap Load for TN and TP in the Phase 3 Watershed Implementation Plan Wastewater Supplement (rev. July 29, 2022) to the Chesapeake Bay Watershed Implementation Plan. The cap load for Total Nitrogen is set at 10,959 lbs/year. The cap load for Total Phosphorus is set at 1,461 lbs/year. Cap Loads for TN and TP are implemented in NPDES permits by the establishment of Annual Net Mass Load limits. No TN Offsets were incorporated into the TN Cap loads, and therefore, no Offsets will need to be removed. To comply with the Cap Loads, annual reporting of the load for total nitrogen and total phosphorus will be imposed. Total Nitrogen is the sum of Total Kjeldahl Nitrogen and Nitrate-Nitrite as N so monitoring for Total Kjeldahl Nitrogen and Nitrate-Nitrite as N will also be imposed. In addition, Hastings WWTP will be required to monitor and report both the concentration and the load for TN and TP. The monitoring frequency for Total Nitrogen and Total Phosphorus will be 2/week according to the Chesapeake Bay Phase 3 WIP Wastewater Supplement.

**Additional Considerations**

Sewage discharges will include monitoring, at a minimum, for *E. coli*, in new and reissued permits, with a monitoring frequency of 1/quarter for design flows  $\geq 0.05$  and  $< 1$  MGD.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Department's "Technical Guidance for the Development and Specification of Effluent Limitations".

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Average Monthly	Weekly Average	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5 Nov 1 - Apr 30	115.1	172.6	23.0	34.5	XXX	46	1/week	8-Hr Composite
CBOD5 May 1 - Oct 31	85.1	127.6	17.0	25.5	XXX	34	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	Report	XXX	XXX	XXX	1/week	8-Hr Composite
TSS	150.12	225.18	30.0	45.0	XXX	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	Report	XXX	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Recorded
Ammonia-Nitrogen Nov 1 - Apr 30	20.01	XXX	4.0	XXX	XXX	8	2/week	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	10.0	XXX	2.0	XXX	XXX	4	2/week	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Average Monthly	Weekly Average	Daily Maximum	Instant. Maximum		
Total Lead	0.025	0.035 Daily Max	0.005	XXX	0.007	0.012	1/week	24-Hr Composite
Total Zinc	Report	Report Daily Max	Report	XXX	XXX	XXX	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: N/A

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Two Years After Permit Effective Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Copper	Report	Report	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: N/A

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Two Years After Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Copper	0.068	102 Daily Max	XXX	0.014	20.3 Daily Max	20.3	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: N/A



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Nitrate-Nitrite as N	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/week	24-Hr Composite
Total Nitrogen	Report Annl Avg	Report Annl Avg	XXX	Report Annl Avg	XXX	XXX	2/week	24-Hr Composite
Net Total Nitrogen	XXX	10959 Total Annual	XXX	XXX	XXX	XXX	1/month	Calculation
Ammonia	XXX	Report Total Annual	XXX	XXX	XXX	XXX	1/week	24-Hr Composite
TKN	Report Annl Avg	XXX	XXX	Report Annl Avg	XXX	XXX	1/week	24-Hr Composite
Total Phosphorus	Report Annl Avg	Report Annl Avg	XXX	Report Annl Avg	XXX	XXX	2/week	24-Hr Composite
Net Total Phosphorus	XXX	1461 Total Annual	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location: Outfall 001

Other Comments: N/A

**ATTACHMENT A:**  
**USGS STREAMSTATS**


## StreamStats Report

**Region ID:** PA

**Workspace ID:** PA20230223143854989000

**Clicked Point (Latitude, Longitude):** 40.67172, -78.70348

**Time:** 2023-02-23 09:39:15 -0500



 Collapse All

### Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	4.2	square miles

Parameter Code	Parameter Description	Value	Unit
ELEV	Mean Basin Elevation	1968	feet
PRECIP	Mean Annual Precipitation	43	inches

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	4.2	square miles	2.33	1720
ELEV	Mean Basin Elevation	1968	feet	898	2700
PRECIP	Mean Annual Precipitation	43	inches	38.7	47.9

Low-Flow Statistics Flow Report [Low Flow Region 3]

PII: Prediction Interval-Lower, PIU: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	0.519	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	0.739	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	0.221	ft <sup>3</sup> /s	54	54
30 Day 10 Year Low Flow	0.302	ft <sup>3</sup> /s	49	49
90 Day 10 Year Low Flow	0.448	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

Stuckey, M.H.,2006, *Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams*: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

**ATTACHMENT B:**  
**WQM MODELING RESULTS (SUMMER)**

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
08B	26858	BRUBAKER RUN	3.880	1968.00	4.20	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
Q7-10	0.100	0.22	0.00	0.000	0.000	10.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Hastings WTP	PA0023141	0.6000	0.0000	0.0000	0.000	20.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	9.01	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Hydrodynamic Outputs

**SWP Basin**      **Stream Code**      **Stream Name**  
**08B**              **26858**              **BRUBAKER RUN**

RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
3.880	0.22	0.00	0.22	.9282	0.00499	.514	13.5	26.27	0.17	1.428	20.00	7.00
<b>Q1-10 Flow</b>												
3.880	0.14	0.00	0.14	.9282	0.00499	NA	NA	NA	0.16	1.487	20.00	7.00
<b>Q30-10 Flow</b>												
3.880	0.30	0.00	0.30	.9282	0.00499	NA	NA	NA	0.17	1.376	20.00	7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
08B	26858	BRUBAKER RUN

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.880	Hastings WTP	16.76	19.31	16.76	19.31	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.880	Hastings WTP	1.89	2.5	1.89	2.5	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
3.88	Hastings WTP	17.62	17.62	2.5	2.5	6	6	0	0

## WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
08B	26858	BRUBAKER RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
3.880	0.600	20.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
13.502	0.514	26.270	0.166	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
14.62	0.995	2.02	0.700	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
6.579	7.855	Tsivoglou	6	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
1.428	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.143	12.68	1.83	6.07
	0.286	11.00	1.65	6.19
	0.428	9.54	1.49	6.47
	0.571	8.28	1.35	6.77
	0.714	7.18	1.22	7.05
	0.857	6.23	1.11	7.31
	1.000	5.41	1.00	7.54
	1.143	4.69	0.91	7.73
	1.285	4.07	0.82	7.91
	1.428	3.53	0.74	8.06

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
08B	26858	BRUBAKER RUN					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.880	Hastings WTP	PA0023141	0.600	CBOD5	17.62		
				NH3-N	2.5	5	
				Dissolved Oxygen			6



**ATTACHMENT C:**  
**WQM MODELING RESULTS (WINTER)**

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
08B	26858	BRUBAKER RUN	<b>3.880</b>	1968.00	4.20	0.00000	0.00	<input checked="" type="checkbox"/>

#### Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.200	0.22	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

#### Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Hastings WTP	PA0023141	0.6000	0.0000	0.0000	0.000	15.00	7.00

#### Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	12.51	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

## WQM 7.0 Hydrodynamic Outputs

**SWP Basin**      **Stream Code**      **Stream Name**  
**08B**              **26858**              **BRUBAKER RUN**

RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
-----	-------------------	----------------	-----------------------	--------------------------	---------------------	------------	------------	-----------	----------------	------------------------	--------------------	-------------

#### Q7-10 Flow

3.880    0.22    0.00    0.22    .9282    0.00499    .514    13.5    26.27    0.17    1.428    13.08    7.00

#### Q1-10 Flow

3.880    0.14    0.00    0.14    .9282    0.00499    NA    NA    NA    0.16    1.487    13.68    7.00

#### Q30-10 Flow

3.880    0.30    0.00    0.30    .9282    0.00499    NA    NA    NA    0.17    1.376    12.55    7.00

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

## WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
08B	26858	BRUBAKER RUN

### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.880	Hastings WTP	24.1	27.78	24.1	27.78	0	0

### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
3.880	Hastings WTP	3.05	4.04	3.05	4.04	0	0

### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
3.88	Hastings WTP	23.13	23.13	4.04	4.04	5	5	0	0

## WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
08B	26858	BRUBAKER RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
3.880	0.600	13.077		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
13.502	0.514	26.270		0.166
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
19.07	1.327	3.26		0.411
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
6.444	6.665	Tsivoglou		6
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
1.428	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.143	16.61	3.08	6.05
	0.286	14.47	2.90	6.23
	0.428	12.61	2.73	6.60
	0.571	10.98	2.58	6.99
	0.714	9.57	2.43	7.37
	0.857	8.34	2.29	7.72
	1.000	7.26	2.16	8.03
	1.143	6.33	2.04	8.30
	1.285	5.51	1.92	8.54
	1.428	4.80	1.81	8.76

## WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>		<u>Stream Name</u>				
08B	26858		BRUBAKER RUN				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
3.880	Hastings WTP	PA0023141	0.600	CBOD5	23.13		
				NH3-N	4.04	8.08	
				Dissolved Oxygen			5

**ATTACHMENT D:**  
**TMS RESULTS**



Group 3	Carbon Tetrachloride	µg/L	<																		
	Chlorobenzene	µg/L																			
	Chlorodibromomethane	µg/L	<																		
	Chloroethane	µg/L	<																		
	2-Chloroethyl Vinyl Ether	µg/L	<																		
	Chloroform	µg/L	<																		
	Dichlorobromomethane	µg/L	<																		
	1,1-Dichloroethane	µg/L	<																		
	1,2-Dichloroethane	µg/L	<																		
	1,1-Dichloroethylene	µg/L	<																		
	1,2-Dichloropropane	µg/L	<																		
	1,3-Dichloropropylene	µg/L	<																		
	1,4-Dioxane	µg/L	<																		
	Ethylbenzene	µg/L	<																		
	Methyl Bromide	µg/L	<																		
	Methyl Chloride	µg/L	<																		
	Methylene Chloride	µg/L	<																		
	1,1,2,2-Tetrachloroethane	µg/L	<																		
	Tetrachloroethylene	µg/L	<																		
	Toluene	µg/L	<																		
	1,2-trans-Dichloroethylene	µg/L	<																		
1,1,1-Trichloroethane	µg/L	<																			
1,1,2-Trichloroethane	µg/L	<																			
Trichloroethylene	µg/L	<																			
Vinyl Chloride	µg/L	<																			
Group 4	2-Chlorophenol	µg/L	<																		
	2,4-Dichlorophenol	µg/L	<																		
	2,4-Dimethylphenol	µg/L	<																		
	4,6-Dinitro-o-Cresol	µg/L	<																		
	2,4-Dinitrophenol	µg/L	<																		
	2-Nitrophenol	µg/L	<																		
	4-Nitrophenol	µg/L	<																		
	p-Chloro-m-Cresol	µg/L	<																		
	Pentachlorophenol	µg/L	<																		
	Phenol	µg/L	<																		
	2,4,6-Trichlorophenol	µg/L	<																		
Group 5	Acenaphthene	µg/L	<																		
	Acenaphthylene	µg/L	<																		
	Anthracene	µg/L	<																		
	Benzidine	µg/L	<																		
	Benzo(a)Anthracene	µg/L	<																		
	Benzo(a)Pyrene	µg/L	<																		
	3,4-Benzofluoranthene	µg/L	<																		
	Benzo(ghi)Perylene	µg/L	<																		
	Benzo(k)Fluoranthene	µg/L	<																		
	Bis(2-Chloroethoxy)Methane	µg/L	<																		
	Bis(2-Chloroethyl)Ether	µg/L	<																		
	Bis(2-Chloroisopropyl)Ether	µg/L	<																		
	Bis(2-Ethylhexyl)Phthalate	µg/L	<																		
	4-Bromophenyl Phenyl Ether	µg/L	<																		
	Butyl Benzyl Phthalate	µg/L	<																		
	2-Chloronaphthalene	µg/L	<																		
	4-Chlorophenyl Phenyl Ether	µg/L	<																		
	Chrysene	µg/L	<																		
	Dibenzo(a,h)Anthracene	µg/L	<																		
	1,2-Dichlorobenzene	µg/L	<																		
	1,3-Dichlorobenzene	µg/L	<																		
	1,4-Dichlorobenzene	µg/L	<																		
	3,3-Dichlorobenzidine	µg/L	<																		
Diethyl Phthalate	µg/L	<																			
Dimethyl Phthalate	µg/L	<																			
Di-n-Butyl Phthalate	µg/L	<																			
2,4-Dinitrotoluene	µg/L	<																			

	2,6-Dinitrotoluene	µg/L	<																	
	Di-n-Octyl Phthalate	µg/L	<																	
	1,2-Diphenylhydrazine	µg/L	<																	
	Fluoranthene	µg/L	<																	
	Fluorene	µg/L	<																	
	Hexachlorobenzene	µg/L	<																	
	Hexachlorobutadiene	µg/L	<																	
	Hexachlorocyclopentadiene	µg/L	<																	
	Hexachloroethane	µg/L	<																	
	Indeno(1,2,3-cd)Pyrene	µg/L	<																	
	Isophorone	µg/L	<																	
	Naphthalene	µg/L	<																	
	Nitrobenzene	µg/L	<																	
	n-Nitrosodimethylamine	µg/L	<																	
	n-Nitrosodi-n-Propylamine	µg/L	<																	
	n-Nitrosodiphenylamine	µg/L	<																	
	Phenanthrene	µg/L	<																	
	Pyrene	µg/L	<																	
	1,2,4-Trichlorobenzene	µg/L	<																	
Group 6	Aldrin	µg/L	<																	
	alpha-BHC	µg/L	<																	
	beta-BHC	µg/L	<																	
	gamma-BHC	µg/L	<																	
	delta BHC	µg/L	<																	
	Chlordane	µg/L	<																	
	4,4-DDT	µg/L	<																	
	4,4-DDE	µg/L	<																	
	4,4-DDD	µg/L	<																	
	Dieldrin	µg/L	<																	
	alpha-Endosulfan	µg/L	<																	
	beta-Endosulfan	µg/L	<																	
	Endosulfan Sulfate	µg/L	<																	
	Endrin	µg/L	<																	
	Endrin Aldehyde	µg/L	<																	
	Heptachlor	µg/L	<																	
	Heptachlor Epoxide	µg/L	<																	
	PCB-1016	µg/L	<																	
	PCB-1221	µg/L	<																	
	PCB-1232	µg/L	<																	
	PCB-1242	µg/L	<																	
	PCB-1248	µg/L	<																	
PCB-1254	µg/L	<																		
PCB-1260	µg/L	<																		
PCBs, Total	µg/L	<																		
Toxaphene	µg/L	<																		
2,3,7,8-TCDD	ng/L	<																		
Group 7	Gross Alpha	pCi/L																		
	Total Beta	pCi/L	<																	
	Radium 226/228	pCi/L	<																	
	Total Strontium	µg/L	<																	
	Total Uranium	µg/L	<																	
	Osmotic Pressure	mOs/kg																		





### Stream / Surface Water Information

Hastings WTP, NPDES Permit No. PA0023141, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: Brubaker Run

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	026858	3.88	1968	4.2			Yes
End of Reach 1	026858	0.01	1866	12.8			Yes

Q<sub>7-10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	3.88	0.1										100	7		
End of Reach 1	0.01	0.1													

Q<sub>h</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	3.88														
End of Reach 1	0.01														



Toxic Management Spreadsheet  
Version 1.3, March 2021

Model Results

Hastings WTP, NPDES Permit No. PA0023141, Outfall 001

Instructions Results RETURN TO INPUTS SAVE AS PDF PRINT All Inputs Results Limits

Hydrodynamics

Q<sub>1-10</sub>

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mlx Time (min)
3.88	0.42		0.42	0.928	0.005	0.526	14.155	26.914	0.181	1.306	0.989
0.01	1.28		1.28								

Q<sub>A</sub>

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mlx Time (min)
3.88	3.48		3.48	0.928	0.005	0.886	14.155	15.979	0.352	0.673	2.906
0.01	9.219		9.22								

Wasteload Allocations

AFC OCT (min): 0.989 PMF: 1 Analysis Hardness (mg/l): 100 Analysis pH: 6.47

Pollutants	Stream Conc	Stream CV	Trio Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	1,089	
Total Copper	0	0		0	13.439	14.0	20.3	Chem Translator of 0.96 applied
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	64.581	81.6	119	Chem Translator of 0.791 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	117.180	120	174	Chem Translator of 0.978 applied

CFC OCT (min): 0.989 PMF: 1 Analysis Hardness (mg/l): 100 Analysis pH: 6.47

Pollutants	Stream Conc (µg/L)	Stream CV	Trio Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	8.956	9.33	13.6	Chem Translator of 0.96 applied
Total Iron	0	0		0	1,500	1,500	2,179	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.517	3.18	4.62	Chem Translator of 0.791 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	118.139	120	174	Chem Translator of 0.986 applied

THH OCT (min): 0.989 PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trio Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	1,452	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL OCT (min): 2.906 PMF: 1 Analysis Hardness (mg/l): N/A Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trio Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	

Total Lead	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	N/A	N/A	N/A

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: **4**

Pollutants	Mass Limits		Concentration Limits			Units	Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX				
Total Copper	0.068	102	0.014	20.3	20.3	mg/L	0.014	CFC	Discharge Conc $\approx$ 50% WQBEL (RP)
Total Lead	0.023	0.036	0.005	0.007	0.012	mg/L	0.005	CFC	Discharge Conc $\approx$ 50% WQBEL (RP)
Total Zinc	Report	Report	Report	Report	Report	mg/L	0.12	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Aluminum	0.75	mg/L	Discharge Conc $\approx$ 10% WQBEL
Total Iron	2.18	mg/L	Discharge Conc $\approx$ 10% WQBEL
Total Manganese	1.45	mg/L	Discharge Conc $\approx$ 10% WQBEL

**ATTACHMENT E:**  
**PREDRAFT SURVEY RESULTS**

Cu  
Pb

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
PRE-DRAFT PERMIT SURVEY FOR TOXIC POLLUTANTS**

Permittee Name: Hastings Area Sewer Authority Permit No.: PA0023141

Pollutant(s) identified by DEP that may require WQBELs: Copper (Total), Lead (Total)

Is the permittee aware of the source(s) of the pollutant(s)?  Yes  No  Suspected

If Yes or Suspected, describe the known or suspected source(s) of pollutant(s) in the effluent.

Has the permittee completed any studies in the past to control or treat the pollutant(s)?  Yes  No

If Yes, describe prior studies and results:

Does the permittee believe it can achieve the proposed WQBELs now?  Yes  No  Uncertain

If No, describe the activities, upgrades or process changes that would be necessary to achieve the WQBELs, if known.

Estimated date by which the permittee could achieve the proposed WQBELs: \_\_\_\_\_  Uncertain

Will the permittee conduct additional sampling for the pollutant(s) to supplement the application?  Yes  No

Check the appropriate box(es) below to indicate site-specific data that have been collected by the permittee in the past. If any of these data have not been submitted to DEP, please attach to this survey.

<input type="checkbox"/> Discharge pollutant concentration coefficient(s) of variability	Year(s) Studied:
<input type="checkbox"/> Discharge and background Total Hardness concentrations (metals)	Year(s) Studied:
<input type="checkbox"/> Background / ambient pollutant concentrations	Year(s) Studied:
<input type="checkbox"/> Chemical translator(s) (metals)	Year(s) Studied:
<input type="checkbox"/> Slope and width of receiving waters	Year(s) Studied:
<input type="checkbox"/> Velocity of receiving waters at design conditions	Year(s) Studied:
<input type="checkbox"/> Acute and/or chronic partial mix factors (mixing at design conditions)	Year(s) Studied:
<input type="checkbox"/> Volatilization rates (highly volatile organics)	Year(s) Studied:
<input type="checkbox"/> Site-specific criteria (e.g., Water Effect Ratio or related study)	Year(s) Studied:

Please submit this survey to the DEP regional office that is reviewing the permit application within 30 days of receipt.

**Hasting Area Sewer Authority PWSID #PA0023141**

	Sample Date	Copper (ug/L)	Copper (mg/L)		Lead (ug/L)	Q	Lead (mg/L)
1.	4/20/2023	10.5	0.0105		0.361		0.000361
2.	4/27/2023	3.0	0.0030		0.082		0.000082
3.	5/4/2023	12.7	0.0127		0.280		0.000280
4.	5/11/2023	13.0	0.0130		0.232		0.000232
5.	5/18/2023	17.1	0.0171		0.323		0.000323
6.	5/25/2023	15.4	0.0154		0.840		0.000840
7.	6/1/2023	18.4	0.0184		1.430		0.001430
8.	6/8/2023	14.4	0.0144		0.169		0.000169
9.	6/15/2023	15.3	0.0153		0.236		0.000236
10.	6/22/2023	14.9	0.0149		0.205		0.000205
	Average	13.5	0.0135		0.4158		0.0004158

**Note:** Lab Reporting Limit (RL) for Copper (Cu) = 0.0001 mg/L  
and Lead (Pb) = 0.0025 mg/L.

Sample: Effluent UV Channel

Project Manager: Mike McCluskey

Study Duration: 1 sample/week x 10 weeks

Sampler: Jared Hay (InnoH2O Solutions)