



Application Type

Renewal

Facility Type

Non-Municipal

Major / Minor

Minor

Application No.

PA0023434

APS ID

1122452

Authorization ID

1500898

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Applicant and Facility Information

Applicant Name	PA American Water Co.	Facility Name	Koppel Borough
Applicant Address	852 Wesley Drive	Facility Address	5001 5th Avenue Rt 351
	Mechanicsburg, PA 17055-4436		Koppel, PA 16136-1129
Applicant Contact	Li An	Facility Contact	Michelle Cavallo
Applicant Phone	(724) 743-3131	Facility Phone	724-255-6640
Client ID	87712	Site ID	257788
Ch 94 Load Status	Not Overloaded	Municipality	Koppel Borough
Connection Status	No Limitations	County	Beaver
Date Application Received	September 23, 2024	EPA Waived?	Yes
Date Application Accepted	September 30, 2024	If No, Reason	
Purpose of Application	Renewal of NPDES Permit		

Summary of Review

The applicant has applied for the renewal of NPDES Permit PA0023434. The previous permit was issued on November 1, 2021 and will expire on March 31, 2025.

Sewage from this plant is treated with Muffin Monster and Bypass Bar Screen, Two ICEAS SBR basins, Aerated Sludge Digester, and UV Disinfection.

A flow rerate was approved on July 11, 2024 under WQM 0474418 A-5 that approved the annual average design flow of 0.31 MGD and a design hydraulic capacity of 0.31 MGD with a design organic capacity of 408 lbs/day.

Monitoring frequencies for the proposed effluent limits have been updated to comply with Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Department's "Technical Guidance for the Development and Specification of Effluent Limitations".

The applicant is currently enrolled in and will continue to use eDMR.

The Notification letters were provided dated August 13, 2024 and no comments were received.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-

Approve	Deny	Signatures	Date
X		 Jordan Coldsmith / Environmental Engineering Specialist	January 7, 2025
X		 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	January 24, 2025

Summary of Review

day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

Outfall No.	001	Design Flow (MGD)	.31
Latitude	40° 50' 22.93"	Longitude	-80° 18' 54.50"
Quad Name	Beaver Falls	Quad Code	40080G3
Wastewater Description: Sewage Effluent			
Receiving Waters	Beaver River (WWF)	Stream Code	33953
NHD Com ID	123918307	RMI	11.2
Drainage Area		Yield (cfs/mi ²)	
Q ₇₋₁₀ Flow (cfs)		Q ₇₋₁₀ Basis	
Elevation (ft)		Slope (ft/ft)	
Watershed No.	20-B	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	CAUSE UNKNOWN, POLYCHLORINATED BIPHENYLS (PCBS)		
Source(s) of Impairment	SOURCE UNKNOWN, SOURCE UNKNOWN		
TMDL Status	Name _____		
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake		Beaver Falls Muni Auth	
PWS Waters	Beaver River (WWF)	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	5.68

Changes Since Last Permit Issuance: None

Other Comments: N/A

Treatment Facility Summary				
Treatment Facility Name: Koppel Borough WWTP				
WQM Permit No.	Issuance Date			
0474418	11/04/1974			
0474418 A-1	03/12/2002			
0474418 A-2	11/01/2014			
0474418 A-3	03/30/2020			
0474418 A-4	03/20/2024			
0474418 A-5	07/11/2024			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	UV	0.31
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.31	408	Not Overloaded		

Changes Since Last Permit Issuance:

Other Comments: The treatment process consists of;

- Muffin Monster and Bypass Bar Screen
- Two ICEAS SBR basins
- Aerated Sludge Digester
- UV Disinfection

Compliance History

Operations Compliance Check Summary Report

Facility: KOPPEL BORO WWTP

NPDES Permit No.: PA0023434

Compliance Review Period: 1/1/20-1/16/25

Inspection Summary:

INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC	INSPECTION COMMENT
05/22/2023	Compliance Evaluation	PA Dept of Environmental Protection	Violation(s) Noted	
06/22/2021	Administrative/File Review	PA Dept of Environmental Protection	Administratively Closed	Review of eDMR Non-Compliance data for routine monitoring
05/04/2021	Administrative/File Review	PA Dept of Environmental Protection	No Violations Noted	Compliance assistance regarding usage of FF NODI Code vs GG NODI Code for eDMR reporting of TRC while awaiting NPDES amendment
04/30/2021	Routine/Partial Inspection	PA Dept of Environmental Protection	No Violations Noted	
02/22/2021	Administrative/File Review	PA Dept of Environmental Protection	Violation(s) Noted	
08/12/2020	Routine/Partial Inspection	PA Dept of Environmental Protection	No Violations Noted	

Violation Summary:

VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC
05/22/2023	92A.44	NPDES - Violation of effluent limits in Part A of permit
02/22/2021	92A.44	NPDES - Violation of effluent limits in Part A of permit

Open Violations by Client ID:

No open violations for Client ID 87712 for Clean Water Program or within Southwest Region, but the following open violations exist at other facilities in Southeast, South Central, and Northeast Regions.

INSP PROGRAM	PROGRAM SPECIFIC ID	INSP ID	VIOLATION ID	VIOLATION DATE	VIOLATION CODE	VIOLATION	INSP REGION
Air Quality	25-1008096-5	3850104	8204416	10/10/2024	127.444	Construction, Modification, Reactivation and Operation of Sources, Operating Permit Requirements, Compliance requirements. A person may not cause or permit the operation of a source subject to this article unless the source and air cleaning devices identified in the application for the plan approval and operating permit and the plan approval issued to the source are operated and maintained in accordance with specifications in the application and conditions in the plan approval and operating permit issued by the Department. A person may not cause or permit the operation of an air contamination source subject to this chapter in a manner inconsistent with good operating practices.	NERO
Storage Tanks	15-35902	3899999	8213605	11/20/2024	245.612(D)	Failure to meet aboveground storage tank secondary and/or emergency containment requirements	SERO
WPC NPDES	PA0026492	3830416	8201850	08/21/2024	92A.44	NPDES - Violation of effluent limits in Part A of permit	NERO
WPC NPDES	PA0026492	3830416	8201851	08/21/2024	92A.61(C)	NPDES - Failure to monitor pollutants as required by the NPDES permit	NERO
WPC NPDES	PA0026492	3830416	8201852	08/21/2024	92A.47(C)	NPDES - Illegal discharge to waters of the Commonwealth from a sanitary sewer overflow (SSO)	NERO
WPC NPDES	PA0026492	3831748	8201290	08/21/2024	92A.44	NPDES - Violation of effluent limits in Part A of permit	NERO
WPC NPDES	PA0026492	3831748	8201291	08/21/2024	92A.61(C)	NPDES - Failure to monitor pollutants as required by the NPDES permit	NERO
WPC NPDES	PA0026492	3831748	8201292	08/21/2024	92A.47(C)	NPDES - Illegal discharge to waters of the Commonwealth from a sanitary sewer overflow (SSO)	NERO

WPC NPDES	PA0026972	3848782	8204100	07/23/2024	CSL201	CSL - Unauthorized, unpermitted discharge of sewage to waters of the Commonwealth	SCRO
WPC State Water Pollution Control	WQG02460510	3605646	8156718	08/21/2023	92A.47(C)	NPDES - Illegal discharge to waters of the Commonwealth from a sanitary sewer overflow (SSO)	SERO

Enforcement Summary:

ENF TYPE	ENF TYPE DESC	EXECUTED DATE	VIOLATIONS		AMOUNT RECEIVED	ENF FINAL STATUS	ENF CLOSED DATE
NOV	Notice of Violation	07/28/2023	92A.44			Comply/Closed	09/07/2023
CACP	Consent Assessment of Civil Penalty	05/10/2021	92A.44		\$3,600.00	Comply/Closed	05/26/2021
NOV	Notice of Violation	02/22/2021	92A.44			Comply/Closed	12/31/2021

Effluent Violation Summary:

MON PD	Parameter	Reported Value	Permit Limit	Unit	Stat Base Code	Facility Comments
Sep-24	Fecal Coliform	1204	1000	No./100 ml	Instantaneous Maximum	The fecal coliform sample from 9-17-2024 exceeded the permitted instantaneous maximum level. This occurred due to fouling inside UV Train 2's reactor. The manufacturer's recommendation is to switch the UV trains every 6-8 weeks, but going forward the UV trains will be switched and cleaned monthly to ensure we mitigate any fouling before it becomes an issue.
Aug-20	Total Residual Chlorine (TRC)	1.99	1.6	mg/L	Instantaneous Maximum	See attached non-compliance form.

Compliance Status: Facility is generally in compliance with its ongoing CAP and the NPDES permit. There are no pending enforcement actions at this time.

Completed by: Amanda Illar **Completed date:** 1/16/25

Compliance History

DMR Data for Outfall 001 (from December 1, 2023 to November 30, 2024)

Parameter	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23
Flow (MGD) Average Monthly	0.097	0.07	0.089	0.118	0.128	0.11	0.144	0.301	0.155	0.098	0.170	0.097
Flow (MGD) Daily Maximum	0.195	0.132	0.116	0.199	0.343	0.169	0.255	1.158	0.347	0.142	0.511	0.278
pH (S.U.) Instantaneous Minimum	7.02	6.85	7.11	7.13	7.02	6.9	6.94	6.95	6.9	6.9	6.8	6.9
pH (S.U.) Instantaneous Maximum	7.33	7.51	7.42	7.35	7.36	7.64	7.34	7.8	7.2	7.1	7.4	7.28
DO (mg/L) Instantaneous Minimum	4.45	5.01	4.44	4.39	4.37	4.25	4.42	4.3	4.5	4.3	4.5	4.8
TRC (mg/L) Average Monthly	GG											
TRC (mg/L) Instantaneous Maximum	GG											
CBOD5 (lbs/day) Average Monthly	< 2.8	< 2.0	< 2.3	< 3.2	< 3.5	< 3.1	< 3.4	< 7.3	< 4.7	< 2.4	< 4.6	< 2.1
CBOD5 (lbs/day) Weekly Average	< 4.9	< 3.3	< 2.5	< 4.0	< 5.4	< 4.0	< 3.9	< 19.9	< 8.7	< 2.8	< 10.5	< 2.6
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3	< 3.0
CBOD5 (mg/L) Weekly Average	< 3.0	< 3.0	3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
BOD5 (mg/L) Raw Sewage Influent Average Monthly	107	188	76	65	54	108	110	86	79	146	90	163
TSS (lbs/day) Average Monthly	< 3.7	< 2.0	< 2.3	< 3.2	< 5.3	< 3.1	< 3.4	< 7.3	< 4.7	< 2.4	< 5.6	< 2.1
TSS (lbs/day) Weekly Average	6.4	< 3.3	< 2.5	< 4.0	14.3	< 4.0	< 3.9	< 19.9	< 8.7	< 2.8	< 10.5	< 2.6
TSS (mg/L) Average Monthly	< 4.0	< 3.0	< 3.0	< 3.0	< 4.0	< 3.0	< 3.0	< 3.0	< 3	< 3	< 4	< 3.0

NPDES Permit Fact Sheet
Koppel Borough

NPDES Permit No. PA0023434

TSS (mg/L) Raw Sewage Influent Average Monthly	402	717	119	184	163	442	242	122	151	427	315	417
TSS (mg/L) Weekly Average	7.0	< 3.0	< 3.0	< 3.0	8.0	< 3.0	< 3.0	< 3.0	< 3	< 3	5	< 3.0
Fecal Coliform (No./100 ml) Geometric Mean	< 6	< 3.0	72	< 13	< 1	< 4	< 1	< 2	< 2	< 3	< 3	2
Fecal Coliform (No./100 ml) Instantaneous Maximum	1414	11	1204	240	4	191	2	2	4	15	10	5
UV Intensity (μw/cm ²) Daily Minimum	59.32	163.3	42.3	86.4	260.5	116.2	287.9	20.1	25.4	134	2.7	3.7
Total Nitrogen (mg/L) Daily Maximum												2.00
Ammonia (mg/L) Average Monthly	< 0.17	< 0.16	< 0.51	< 0.1	< 0.13	< 0.1	< 0.13	0.19	0.19	0.25	< 0.31	< 0.14
Total Phosphorus (mg/L) Daily Maximum												0.83

Compliance History

Effluent Violations for Outfall 001, from: January 1, 2024 To: November 30, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	09/30/24	IMAX	1204	No./100 ml	1000	No./100 ml

Summary of Inspections: [REDACTED]

Other Comments: [REDACTED]

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 50' 22.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .31
Longitude -80° 18' 56.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

The discharge was evaluated using WQM7.0 to determine the CBOD₅, ammonia nitrogen, and dissolved oxygen parameters. The model results showed that the limits for CBOD₅ and dissolved oxygen will not change.

Parameter	Limit (mg/l)	SBC	Model
CBOD ₅	25	Average Monthly	WQM7.0
	50	IMAX	
Dissolved Oxygen	4	Minimum	WQM7.0
Ammonia Nitrogen	25	Average Monthly	WQM7.0
	50	IMAX	

Per Department SOP "Establishing Effluent Limitations for Individual Sewage Permits" (BCW-PMT-033), For existing discharges, if WQM modeling results for summer indicates that an average monthly limit of 25 mg/L is acceptable, the application manager will generally establish a year-round monitoring requirement for ammonia-nitrogen, at a minimum. A seasonal multiplier of 3 times the summertime average monthly limit should be established for the winter period.

A weekly monitoring frequency for Ammonia-Nitrogen will again be imposed.

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit

(unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

Mass Loading Limitations

Per Department SOP "Establishing Effluent Limitations for Individual Sewage Permits" (BCW-PMT-033), mass loading limits will be established for POTWs for CBOD₅, TSS, ammonia nitrogen. Average monthly mass loading limits will be established for CBOD₅, TSS, and ammonia nitrogen. Average weekly mass loading limits will be established for CBOD₅ and TSS. Mass loading limits will be calculated according to the formula below:

$$\begin{aligned} \text{average annual design flow (MGD)} \times \text{concentration limit } \left(\frac{\text{mg}}{\text{L}} \right) \times 8.34 \text{ (conversion factor)} \\ = \text{mass loading limit } \left(\frac{\text{lbs}}{\text{day}} \right) \end{aligned}$$

The following mass loading limitations were calculated:

Parameter	Average Monthly (lbs/day)	Average Weekly (lbs/day)
CBOD ₅	64.64	96.95
TSS	77.56	116.34
Ammonia Nitrogen	N/A	N/A

Influent Monitoring

Per Department SOP "New and Reissuance Sewage Individual NPDES Permit Applications" (BCW-PMT-002), POTWs with design flows greater than 2,000 GPD, influent BOD₅ and TSS monitoring will again be included in the permit. The influent monitoring will be established with the same frequency and sample type as the effluent sampling.

Additional Considerations

Sewage discharges will include monitoring, at a minimum, for *E. coli*, in new and reissued permits, with a monitoring frequency of 1/quarter for design flows ≥ 0.05 and < 1 MGD.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Department's "Technical Guidance for the Development and Specification of Effluent Limitations".

An annual sampling frequency for total phosphorus and total nitrogen will again be imposed per 25 PA Code §92a.61.

Per Department SOP "New and Reissuance Sewage Individual NPDES Permit Applications" (BCW-PMT-002) Where ultraviolet (UV) disinfection is used, TRC limits are not applicable, but the limits table(s) in Part A will generally contain, at a minimum, routine monitoring of UV transmittance (%), UV dosage ($\mu\text{Ws}/\text{cm}^2$ or mWs/cm^2 or $\text{mJoules}/\text{cm}^2$) or UV intensity ($\mu\text{W}/\text{cm}^2$ or mW/cm^2) at the same monitoring frequency that would be used for TRC.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	64.6	97.0	XXX	25	37.5	50	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	77.6	116.3	XXX	30	45	60	1/week	8-Hr Composite
TSS Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Intensity (μ w/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Daily Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia-Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite

Compliance Sampling Location: Outfall 001

Other Comments: N/A



Attachment 1 Summer WQM7 Results



Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC		
					(ft)	(sq mi)	(ft/ft)	(mgd)				
20B	33953	BEAVER RIVER			11.200	1128.00	3090.00	0.00000	0.00	<input checked="" type="checkbox"/>		
Stream Data												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)		
Q7-10	0.200	640.00	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00		
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							
Discharge Data												
				Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)		
Koppel Boro		PA0023434			0.3100	0.0000	0.0000	0.000	20.00	7.00		
Parameter Data												
				Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
				CBOD5	25.00	2.00	0.00	1.50				
				Dissolved Oxygen	4.00	8.24	0.00	0.00				
				NH3-N	25.00	0.00	0.00	0.70				

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
20B	33953	BEAVER RIVER										
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)	(fps)	(ft/s)	(days)	(°C)	
Q7-10 Flow												
11.200	640.00	0.00	640.00	.4796	0.00019	1.162	492.34	423.77	1.12	0.055	25.00	7.00
Q1-10 Flow												
11.200	409.60	0.00	409.60	.4796	0.00019	NA	NA	NA	0.87	0.070	24.99	7.00
Q30-10 Flow												
11.200	870.40	0.00	870.40	.4796	0.00019	NA	NA	NA	1.33	0.046	25.00	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20B	33953	BEAVER RIVER

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.200 Koppel Boro		11.08	50	11.08	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.200 Koppel Boro		1.37	25	1.37	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
11.20 Koppel Boro		25	25	25	25	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20B	33953	BEAVER RIVER		
<u>RMI</u>		<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
11.200		0.310	24.996	7.000
<u>Reach Width (ft)</u>		<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
492.336		1.162	423.772	1.120
<u>Reach CBOD5 (mg/L)</u>		<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.02		0.013	0.02	1.028
<u>Reach DO (mg/L)</u>		<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.240		1.114	Tsivoglou	5
<u>Reach Travel Time (days)</u>	0.055	<u>Subreach Results</u>		
		TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)
				D.O. (mg/L)
		0.005	2.02	0.02
		0.011	2.02	0.02
		0.016	2.02	0.02
		0.022	2.02	0.02
		0.027	2.02	0.02
		0.033	2.02	0.02
		0.038	2.02	0.02
		0.044	2.02	0.02
		0.049	2.02	0.02
		0.055	2.02	0.02
				7.54

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20B	33953	BEAVER RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
11.200	Koppel Boro	PA0023434	0.310	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4



Attachment 2 Winter WQM Inputs & Results



Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20B	33953	BEAVER RIVER	11.200	1128.00	3090.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.400	640.00	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

		Discharge Data					
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Koppel Boro	PA0023434	0.3100	0.0000	0.0000	0.000	15.00	7.00
Parameter Data							
Parameter Name		Disc Conc	Trib Conc	Stream Conc	Fate Coef		
		(mg/L)	(mg/L)	(mg/L)	(1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	12.51	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code				Stream Name						
20B		33953				BEAVER RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)		(cfs)		(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
11.200	640.00	0.00	640.00	.4796	0.00019	1.162	492.34	423.77	1.12	0.055	5.01	7.00
Q1-10 Flow												
11.200	409.60	0.00	409.60	.4796	0.00019	NA	NA	NA	0.87	0.070	5.01	7.00
Q30-10 Flow												
11.200	870.40	0.00	870.40	.4796	0.00019	NA	NA	NA	1.33	0.046	5.01	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name					
		20B	33953	BEAVER RIVER			

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.200	Koppel Boro	24.1	50	24.1	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
11.200	Koppel Boro	4.36	25	4.36	25	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
11.20	Koppel Boro	25	25	25	25	4	4	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20B	33953	BEAVER RIVER		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
11.200	0.310	5.007	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
492.336	1.162	423.772	1.120	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.02	0.014	0.02	0.221	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
12.504	0.693	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.055	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.005	2.02	0.02	11.45
	0.011	2.02	0.02	11.45
	0.016	2.02	0.02	11.45
	0.022	2.02	0.02	11.45
	0.027	2.02	0.02	11.45
	0.033	2.02	0.02	11.45
	0.038	2.02	0.02	11.45
	0.044	2.02	0.02	11.45
	0.049	2.02	0.02	11.45
	0.055	2.02	0.02	11.45

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20B	33953	BEAVER RIVER		
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter
11.200	Koppel Boro	PA0023434	0.310	CBOD5
				NH3-N
				Dissolved Oxygen
				25
				25
				50
				4



Attachment 3 Upstream StreamStat




StreamStats Report

Region ID: PA

Workspace ID: PA20250108204513977000

Clicked Point (Latitude, Longitude): 40.83971, -80.31525

Time: 2025-01-08 15:45:40 -0500



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	3090	square miles
ELEV	Mean Basin Elevation	1128	feet

➤ Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	3090	square miles	2.26	1400
ELEV	Mean Basin Elevation	1128	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	252	ft^3/s
30 Day 2 Year Low Flow	333	ft^3/s
7 Day 10 Year Low Flow	160	ft^3/s
30 Day 10 Year Low Flow	186	ft^3/s
90 Day 10 Year Low Flow	254	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.
(<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply



Attachment 4 Downstream StreamStat



StreamStats Report

Region ID: PA

Workspace ID: PA20250108205027613000

Clicked Point (Latitude, Longitude): 40.82612, -80.31195

Time: 2025-01-08 15:50:51 -0500



[Collapse All](#)

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	3090	square miles
ELEV	Mean Basin Elevation	1128	feet

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	3090	square miles	2.26	1400
ELEV	Mean Basin Elevation	1128	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	252	ft^3/s
30 Day 2 Year Low Flow	333	ft^3/s
7 Day 10 Year Low Flow	160	ft^3/s
30 Day 10 Year Low Flow	186	ft^3/s
90 Day 10 Year Low Flow	254	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.25.0

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1