

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0023442  
APS ID 276360  
Authorization ID 1387727

**Applicant and Facility Information**

Applicant Name	<u>Wrightsville Borough Municipal Authority York County</u>	Facility Name	<u>Wrightsville STP</u>
Applicant Address	<u>601 Water Street</u> <u>Wrightsville, PA 17368-1646</u>	Facility Address	<u>723 Water Street</u> <u>Wrightsville, PA 17368-1648</u>
Applicant Contact	<u>Brian Lyle</u>	Facility Contact	<u>Brian Lyle</u>
Applicant Phone	<u>(717) 252-2768</u>	Facility Phone	<u>(717) 252-2768</u>
Client ID	<u>74724</u>	Site ID	<u>451705</u>
Ch 94 Load Status	<u>Existing Organic Overload</u>	Municipality	<u>Wrightsville Borough</u>
Connection Status	<u>No Exceptions Allowed</u>	County	<u>York</u>
Date Application Received	<u>March 4, 2022</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>March 17, 2022</u>	If No, Reason	<u>Significant CB Discharge</u>
Purpose of Application	<u>NPDES permit renewal.</u>		

**Summary of Review**

C.S. Davidson, Inc., on behalf of the Wrightsville Borough Municipal Authority (WBMA), applied to the Pennsylvania Department of Environmental Protection (DEP) for renewal and issuance of the NPDES permit. This permit renewal application was received on March 4, 2022. The permit was reissued on August 3, 2017 and became effective on August 1, 2018. The permit expired on August 31, 2022. The terms and conditions of the permit have been administratively extended.

The WQM Part II permit No. 6707406 was issued on 7/30/2007, and 6707406 A-1 amendment was issued on 3/10/2023. WQM Sewer Extension & Pumping Station No. 6702403 was issued on 6/4/2003. WQM Pump Station No. 6721404 was issued on 12/28/2021 to construction of a new pumping station.

Based on the WQM Part II Permit No. 6707406 A-1, the average annual design flow is 0.40 MGD; and hydraulic design capacity is increased from 0.4 MGD to 0.65 MGD) and the organic loading capacity is also increased from 864 lbs. BOD<sub>5</sub>/day to 1,464 lbs. BOD<sub>5</sub>/day. The renewal application indicated the WBMA currently serves Wrightsville Borough (80%) and Hellam Township (20%).

Sludge use and disposal description and location(s): N/A because sludge hauling is by Republic Service to Modern Landfill.

Changes from the previous permit: The E. Coli. monitoring and report requirements will add to the proposed permit. The hydraulic capacity flow changed from 0.4 MGD to 0.650 MGD. Organic capacity changed from 680 lbs/day to 1,464 lbs/day.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	June 23, 2023
X		Maria D. Bebenek for Daniel W. Martin Daniel W. Martin, P.E. / Environmental Engineer Manager	July 18, 2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.4
Latitude	40° 1' 12.21"	Longitude	-76° 31' 13.37"
Quad Name	Columbia West	Quad Code	1833
Wastewater Description: Sewage Effluent			
Receiving Waters	Susquehanna River (WWF)	Stream Code	06685
NHD Com ID		RMI	27.396 miles
Drainage Area	~ 26,000 sq.mi	Yield (cfs/mi <sup>2</sup> )	0.13
Q <sub>7-10</sub> Flow (cfs)	~ 3,210	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	236.30	Slope (ft/ft)	
Watershed No.	7-1	Chapter 93 Class.	WWF
Existing Use	none	Existing Use Qualifier	
Exceptions to Use	none	Exceptions to Criteria	
Assessment Status	Impaired (see comments below)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Red Lion Municipal Authority		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	20.896 miles	Distance from Outfall (mi)	Approximate 6.5 miles

Changes Since Last Permit Issuance:

**Drainage Area**

The discharge is to Susquehanna River at RMI 27.396 miles. A drainage area upstream of the discharge is estimated to be 26,000 sq.mi, according to the USGS PA Stream Stats (<http://water.usgs.gov/osw/streamstats/pennsylvania.html>).

**Streamflow**

The USGS PA Stream Stats also produces a Q<sub>7-10</sub> of 3,340 cfs at the discharge. This is a reasonable value as the USGS stream gauging station No. 01576000 just upstream of the discharge has a Q<sub>7-10</sub> of 3,300 cfs.

$$\begin{aligned}
 Q_{7-10} &= 3340 \text{ cfs} \\
 \text{Low Flow Yield} &= 3340 \text{ cfs} / 26000 \text{ mi.}^2 = 0.13 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 3340 \text{ cfs} = 4,542 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 3340 \text{ cfs} = 2,138 \text{ cfs}
 \end{aligned}$$

**Susquehanna River**

According to the latest DEP water quality integrated report (formerly 303(d) list), Susquehanna River in the vicinity of the discharge is impaired for aquatic life use due to metals from unknown source(s). It is also impaired for recreational use due to pathogens from unknown source(s). A Total Maximum Daily Load (TMDL) is not yet developed for the lower Susquehanna River basin. Although no TMDL has been taken into consideration during this review, all permit requirements will be developed to ensure that the discharge will not contribute to the existing impairment nor cause additional impairment to the river.

**Public Water Supply Intake**

The WBMA's water supply intake is located about 0.8 miles upstream of the discharge. As a result, the intake is not expected to be impacted by the discharge. The nearest downstream water supply intake is the Red Lion Municipal Authority on the Susquehanna River located approximately 6.5 miles downstream of the discharge. Considering dilution and nature of the discharge, the discharge is not expected to significantly impact this water supply intake. Additionally, Red Lion Municipal Authority considers Susquehanna River as a "tertiary" water source and utilizes this intake only during drought conditions.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Wrightsville STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6707406		7/30/2007		
6707406 A-1		3/10/2023		
6702403		6/4/2003		
6721404		12/28/2021		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage			Ultraviolet	0.4
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.65	1,464	Existing Organic Overload		

Changes Since Last Permit Issuance:

Other Comments: The WQM Part II No. 6707406 A-1 was issued on March 10, 2023 to upgrade and rerate the existing STP as follows.

- The hydraulic capacity is increasing from 0.4 MGD to 0.65 MGD;
- The organic design capacity is increasing from 834 lbs BOD<sub>5</sub>/day to 1,464 lbs BOD<sub>5</sub>/day;
- Replace the influent low meter recorder with a unit that can document inflow rates of up to 1.635 MGD;
- Administrative removal of the non-existent grit chamber from the WQM permit;
- Operation changes to the plant's existing Sequencing Batch Reactors (SBRs);
- Addition of one additional fine bubble diffuser rack to each SBR to facilitate higher organic loading; and
- Addition of one 30 HP positive-displacement blower to supply air to the proposed fine bubble diffusers

Per DEP's most recent visit to the treatment plant on June 24, 2019, the treatment plant consists of:

1. Influent channel
2. Fine screen
3. Influent Pump Station
4. Two SBRs
5. Clear well
6. UV system
7. Two Digesters
8. Centrifuge

An aerobic digester and centrifuge are available for solids handling. Sludge generated from this facility will be land applied.

Chemical used:

Poly-aluminum Chloride and Ferric Chloride are used for coagulation. Soda Ash is used for alkalinity control.

Industrial/Commercial Users:

The permit application indicated there are no commercial or industrial contributors to the treatment plant.

Biosolids:

The total sewage sludge /biosolids production within the facility for the previous year was 72.608 dry tons.

Compliance History	
<b>Summary of DMRs:</b>	A summary of the past 12-month DMR is presented on the pages 6, 7, & 8.
<b>Summary of Inspections:</b>	<p>06/24/2019: Mr. Randecker, DEP Water Quality Specialist, conducted a compliance evaluation inspection. There were no violations identified during inspection. Recommendations were to maintain secondary thermometers in influent and effluent composite samplers and replace expired Chlorine standards. The field test results were within the permit limits.</p> <p>1/13/2020: Mr. Shawn Fassi, DEP Environmental trainee, conducted an administrative review of Chesapeake Bay nutrient calculations for Compliance Year 2018-2019. With some minor issues, reports and data generally appeared to be properly calculated and accurate. There were no violations identified during inspection.</p>
<b>Other Comments:</b>	There is one open violation against the facility or the permittee on safe Drinking Water dated 2/22/2023 due to failure of a Public Water System to obtain a permit.

Other Comments:

**NPDES Permit Fact Sheet  
Wrightsville STP**

**NPDES Permit No. PA0023442**

The table below summarizes the influent/effluent testing results submitted along with the application.

<i>Influent Testing Results</i>			<i>Effluent Testing Results</i>		
<b>Parameter</b>	<b>Min/Max Value</b>	<b>Average Value</b>	<b>Parameter</b>	<b>Min/Max Value</b>	<b>Average Value</b>
BOD <sub>5</sub> (mg/L)	269 mg/L	200 mg/L	pH (minimum)	6.8 S.U.	
BOD <sub>5</sub> (lbs/day)	947 lbs/day	644 lbs/day	pH (maximum)	8.0 S.U.	
TSS (mg/L)	262 mg/L	194 mg/L	D.O (minimum)	6.9 mg/L	8.27 mg/L
TSS (lbs/day)	947 lbs/day	481 lbs/day	TRC	mg/L	mg/L
TN (mg/L)	mg/L	29 mg/L	Fecal Coliform	194 No./100mL	1.49 No./100 mL
TN (lbs/day)	lbs/day	78 lbs/day	CBOD <sub>5</sub>	4 mg/L	3.09 mg/L
TP (mg/L)	mg/L	5.5 mg/L	TSS	8 mg/L	3.61 mg/L
TP (lbs/day)	lbs/day	15.0 lbs/day	NH <sub>3</sub> -N	1.5 mg/L	0.22 mg/L
NH <sub>3</sub> -N (mg/L)	mg/L	21.0 mg/L	TN	6.98 mg/L	3.57 mg/L
NH <sub>3</sub> -N (lbs/day)	lbs/day	56.0 lbs/day	TP	0.8 mg/L	0.42 mg/L
TDS (mg/L)	mg/L	348 mg/L	Temp	F	56 F
TDS (lbs/day)	lbs/day	932 lbs/day	TKN	2.73 mg/L	0.98 mg/L
TKN	mg/L	28 mg/L	NO <sub>2</sub> -N + NO <sub>3</sub> -N	6.4 mg/L	2.75 mg/L
NO <sub>2</sub> -N + NO <sub>3</sub> -N	mg/L	0.91 mg/L	TDS	294 mg/L	294 mg/L
			Chloride	65 mg/L	65 mg/L
			Bromide	< 0.2mg/L	< 0.2mg/L
			Sulfate	38 mg/L	38 mg/L
			Oil and Grease	< 5 mg/L	< 5 mg/L
			Total Copper	0.017 mg/L	0.017 mg/L
			Total Lead	< 0.001 mg/L	< 0.001 mg/L
			Total Zinc	0.053 mg/L	0.053 mg/L

Compliance History

DMR Data for Outfall 001 (from May 1, 2022 to April 30, 2023)

Parameter	APR-23	MAR-23	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22
Flow (MGD) Average Monthly	0.315	0.347	0.318	0.321	0.330	0.320	0.333	0.333	0.340	0.331	0.323	0.354
Flow (MGD) Daily Maximum	0.407	0.437	0.413	0.387	0.441	0.364	0.394	0.383	0.389	0.389	0.360	0.484
pH (S.U.) Minimum	7.0	7.0	7.1	7.0	6.8	6.8	7.0	7.0	6.9	6.9	6.9	6.8
pH (S.U.) IMAX	7.3	7.5	7.3	7.4	7.3	7.6	7.4	7.5	7.6	7.4	7.2	7.3
DO (mg/L) Minimum	9.1	9.1	10.1	10.3	9.2	8.0	8.0	7.1	6.8	7.2	7.4	8.2
CBOD5 (lbs/day) Average Monthly	< 6	< 7	< 6	7	< 7	< 7	< 7	< 7	< 7	< 7	< 6	< 7
CBOD5 (lbs/day) Weekly Average	< 7	< 7	< 8	7	< 7	< 7	< 7	< 7	< 7	< 8	< 7	< 8
CBOD5 (mg/L) Average Monthly	< 2.4	< 2.4	< 2.4	2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4	< 2.4
CBOD5 (mg/L) Weekly Average	< 2.4	< 2.4	< 2.4	2.4	< 2.4	< 2.4	< 2.4	2.4	< 2.4	< 2.4	2.4	< 2.4
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	784	537	635	509	408	509	470	594	631	689	704	621
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	1503	694	903	750	598	586	525	953	750	762	1166	741
BOD5 (mg/L) Raw Sewage Influent Average Monthly	333	202	275	181	159	188	169	230	219	235	260	214
TSS (lbs/day) Average Monthly	5	7	6	5	3	5	6	6	9	8	7	10
TSS (lbs/day) Raw Sewage Influent Average Monthly	898	674	739	632	424	696	590	635	968	1031	825	721
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	1622	925	1506	796	623	778	722	677	1284	1165	935	841
TSS (lbs/day) Weekly Average	5	16	10	9	3	8	11	9	22	16	11	20
TSS (mg/L) Average Monthly	2.0	2.6	2.0	1.8	1.0	2.0	2.0	2.0	3.25	2.8	2.6	3.8

**NPDES Permit Fact Sheet  
Wrightsville STP**

**NPDES Permit No. PA0023442**

TSS (mg/L) Raw Sewage Influent   Average Monthly	382	252	323	226	170	257	225	248	336	355	306	250
TSS (mg/L) Weekly Average	2.0	6.0	3.0	3.0	2.0	3.0	4.0	3.0	8.0	5.0	4.0	8.0
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 1	< 1.0	< 1	< 1	< 1	< 1	< 1	1	< 2	< 1
Fecal Coliform (CFU/100 ml) IMAX	< 1	2.0	< 1.0	3.0	1	3.0	2.0	2	2.0	2	6	3.0
UV Intensity (mW/cm²) Minimum	1.5	2.0	2.0	1.6	2.0	2.3	2.2	1.9	1.8	1.9	2.1	2.5
Nitrate-Nitrite (mg/L) Average Monthly	< 2.5	< 2.5	< 2.5	< 2.9	< 2.5	< 2.46	< 2.8	< 2.3	< 2.0	< 1.8	< 1.75	< 2.6
Nitrate-Nitrite (lbs) Total Monthly	< 188	< 219	< 179	< 241	< 206	< 199	< 232	< 192	178	< 160	< 141	< 224
Total Nitrogen (mg/L) Average Monthly	< 3.62	< 3.8	< 4.6	< 4.7	< 3.93	< 3.38	< 3.35	< 2.9	2.57	< 2.4	< 2.33	< 3.6
Total Nitrogen (lbs) Effluent Net   Total Monthly	< 273	< 332	< 331	< 396	< 322	< 272	< 282	< 242	< 225	208	188	< 311
Total Nitrogen (lbs) Total Monthly	< 273	< 332	< 331	< 396	< 322	< 272	282	< 242	225	208	< 188	< 311
Total Nitrogen (lbs) Effluent Net   Total Annual								3191				
Total Nitrogen (lbs) Total Annual								3191				
Ammonia (lbs/day) Average Monthly	< 0.3	< 0.4	< 0.6	< 0.6	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.5
Ammonia (mg/L) Average Monthly	< 0.1	< 0.15	< 0.21	< 0.22	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.16
Ammonia (lbs) Total Monthly	< 8	< 13	< 16	< 19	< 8	8	< 8	< 8	< 9	9	< 8	< 14
Ammonia (lbs) Total Annual								137				
TKN (mg/L) Average Monthly	1.12	1.3	2.1	1.8	1.4	< 0.91	< 0.6	< 0.6	< 0.54	< 0.55	< 0.58	1.0
TKN (lbs) Total Monthly	85	113	151	155	115	< 73	< 51	< 51	< 47	< 49	< 44	116
Total Phosphorus (lbs/day) Average Monthly	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3	2.0	0.6	0.7	0.9	0.7

**NPDES Permit Fact Sheet**

**NPDES Permit No. PA0023442**

**Wrightsville STP**

Total Phosphorus (mg/L) Average Monthly	< 0.13	< 0.1	< 0.1	< 0.1	< 0.1	< 0.11	< 0.11	0.21	0.21	0.25	0.35	0.25
Total Phosphorus (lbs) Effluent Net   Total Monthly	< 10	< 9	< 7	< 9	< 9	< 9	< 9	54	19	23	28	22
Total Phosphorus (lbs) Effluent Net   Total Annual	< 10	< 9	< 7	< 9	< 9	< 9	< 9	< 54	19	23	28	22
Total Phosphorus (lbs) Effluent Net   Total Annual								186				
Total Phosphorus (lbs) Total Annual								186				



**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.4</u>
<b>Latitude</b> <u>40° 1' 12.21"</u>	<b>Longitude</b> <u>-76° 31' 13.37"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Total Residual Chlorine is not applied.

**Water Quality-Based Limitations**

**Ammonia (NH<sub>3</sub>-N):**

NH<sub>3</sub>-N calculations were based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH<sub>3</sub>-N criteria used in the attached computer model of the stream:

- \* Discharge pH                    7.0                    (Default per 391-2000-007)
- \* Discharge Temperature    20°C                    (Default per 391-2000-007)
- \* Stream pH                        7.0                    (Default per 391-2000-006)
- \* Stream Temperature        25°C                    (Default for WWF per 391-2000-003)
- \* Background NH<sub>3</sub>-N            0 mg/L                    (Assumed since no nearby upstream WWTPs)

Regarding NH<sub>3</sub>-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 25.0 mg/L NH<sub>3</sub>-N as a monthly average (AML) and 50.0 mg/L NH<sub>3</sub>-N instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects. Recent DMR data show that the plant is discharging NH<sub>3</sub>-N well below 25.0 mg/l year-round. Therefore, no NH<sub>3</sub>-N limits are proposed in the proposed permit. However, the minimum monitoring frequency report average monthly concentration and mass average monthly will remain the same as 2/week.

**Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>):**

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit (AML) of 25.0 mg/L, 40.0 mg/L average weekly limit (AWL), & 50.0 mg/L IMAX will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has typically been achieving concentrations below this limit. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 25.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 83.4 \text{ lbs/day} \\ \text{Average weekly mass limit: } & 40.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 133.4 \text{ lbs/day} \end{aligned}$$

The average monthly and average weekly mass loadings were calculated as 83.4 lbs/day and 133.4 lbs/day respectively. These values are rounded down to 80.0 lbs/day and 130.0 lbs/day, respectively. The minimum monitoring frequency will remain the same as 1/week.

**Dissolved Oxygen (D.O.):**

The D.O. goal is 6.0 mg/L. However, a minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BPNPSM-PMT-033 and has been applied to other point source dischargers throughout the state.

**pH:**

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

**Fecal Coliform:**

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

**E. Coli:**

As recommended by DEP's SOP No. BCW-PMT-033, version 1.9 revised March 22, 2021, a routine monitoring for E. Coli will be included in the permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/quarter will be included in the permit to be consistent with the recommendation from this SOP.

**Total Suspended Solids (TSS):**

The existing technology-based limits of 30.0 mg/L average monthly, 45.0 mg/L weekly average, and 60.0 mg/L IMAX will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 30.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 100.08 \text{ lbs/day} \\ \text{Average weekly mass limit: } & 45.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 150.12 \text{ lbs/day} \end{aligned}$$

The average monthly and weekly average mass loadings will be rounded down to 100.0 lbs/day and 150.0 lbs/day, respectively.

**Toxics:**

The data was analyzed based on the guidelines found in DEP's Water Quality Toxics Management Strategy (Document No. 361-0100-003) and DEP's SOP No. BPNPSM-PMT-033. Spreadsheet results are attached to this fact sheet. The Toxics Management Spreadsheet uses the following logic:

- a. Establish average monthly and IMAX limits in the draft permit where the maximum reported concentration exceeds 50% of the WQBEL.
- b. For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- c. For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10%-50% of the WQBEL.

Pollutant testing results on the current (2022) application were reviewed in comparison with DEP's Toxic Management Spreadsheet, version 1.4, May 2023, output recommends no routine monitoring requirements. Therefore, no monitoring requirements are added in the proposed permit.

**UV:**

The UV system monitor and report the UV light intensity (mW/cm<sup>2</sup>) will remain in the proposed permit.

**Chesapeake Bay:**

In the Phase 3 WIP Wastewater Supplement revised on July 29, 2022, Table 5 of this document shows that Wrightsville Borough Municipal Authority has been allocated 7,306 lbs/year of TN and 974 lbs/year of TP.

**NPDES Permit Fact Sheet  
Wrightsville STP**

**NPDES Permit No. PA0023442**

Phase 3 WIP Wastewater Supplement  
Revised, July 29, 2022

NPDES Permit No.	Phase	Facility	Latest Permit Issuance Date	Permit Expiration Date	Cap Load Compliance Start Date	TN Cap Load (lbs/yr)	TN Offsets Included in Cap Load (lbs/yr)	TP Cap Load (lbs/yr)	TN Delivery Ratio	TP Delivery Ratio
PA0023442	3	Wrightsville Borough Municipal Authority	8/3/2017	8/31/2022	10/1/2011	7,306	0	974	0.805	0.387
PA0023531	1	Danville Municipal Authority	2/26/2021	2/28/2026	10/1/2011	66,118	-	8,816	0.802	0.459
PA0023558	3	Ashland Borough	4/23/2012	4/30/2017	10/1/2013	23,744	-	3,166	0.793	0.458
PA0023736	3	Tri-Boro Municipal Authority	7/13/2021	7/31/2026	10/1/2013	9,132	-	1,218	0.515	0.372
PA0023744	1	Northeastern York County Sewer Authority	7/12/2022	7/31/2027	10/1/2010	33,485	-	4,627	0.836	0.486
PA0024040	1	Highspire Borough	2/24/2022	2/28/2027	10/1/2010	36,529	-	4,871	0.830	0.503
PA0024139	3	Cumberland Township Municipal Authority (North)	11/13/2019	11/30/2024	10/1/2013	9,132	-	1,218	0.563	0.720
PA0024147	3	Cumberland Township Municipal Authority (South)	11/13/2019	11/30/2024	10/1/2013	11,872	-	1,583	0.681	0.720
PA0024384	2	North Middleton Township Authority	5/10/2022	5/31/2027	10/1/2012	16,895	-	2,253	0.748	0.444
PA0024406	2	Mt. Carmel Municipal Sewage Authority	10/25/2017	10/31/2022	10/1/2010	41,095	-	5,479	0.792	0.517
PA0024431	1	Dillsburg Borough Authority	12/29/2021	12/31/2026	10/1/2011	27,945	-	3,726	0.635	0.408
PA0024708	3	Union Township	5/11/2022	5/31/2027	10/1/2012	11,872	-	1,583	0.705	0.416
PA0024759	3	Cumwensville Municipal Authority	5/8/2018	5/31/2023	10/1/2014	13,698	-	1,826	0.630	0.386
PA0024902	3	Upper Allen Township	8/6/2020	10/31/2022	10/1/2012	20,091	-	2,679	0.682	0.410
PA0025381	3	Saxton Borough Municipal Authority	8/17/2017	8/31/2022	10/1/2011	7,306	-	974	0.641	0.200
PA0025933	1	Lock Haven Borough	9/16/2016	9/30/2021	10/1/2011	68,492	-	9,132	0.772	0.428
PA0026051	1	Chambersburg Borough	6/27/2022	6/30/2027	10/1/2012	124,199	-	16,560	0.997	0.742
PA0026077	1	Carlisle Borough	10/13/2017	10/31/2022	10/1/2008	127,852	-	17,047	0.748	0.444
PA0026107	1	Wyoming Valley Sewer Authority	2/4/2008	2/28/2013	10/1/2010	584,467	-	77,929	0.813	0.512
PA0026191	1	Huntingdon Borough	2/16/2017	2/28/2022	10/1/2011	73,058	-	9,741	0.796	0.373
PA0026239	1	University Area Joint Authority	9/11/2019	9/30/2024	10/1/2010	164,381	-	21,918	0.641	0.323

- 8 -

These cap loads calculated based on the design flow of 0.4 MGD with TN concentration of 6.0 mg/L and TP concentration of 0.8 mg/L will remain in the draft permit. As specified in DEP’s Wastewater Supplement to the Phase 3 WIP, the upgrade project will not result in any increase in cap loads. Accordingly, these cap loads will still be in effect following the upgrade.

This approach, consistent with the Chesapeake Bay TMDL, was based on the actual performance data previously evaluated by the Department. Since the permittee is easily capable of achieving compliance with these loads, the Department determines that no “compliance schedule” for the requirements associated with the Chesapeake Bay Strategy is necessary. Accordingly, the Chesapeake Bay nutrient existing limitations and monitoring requirements will remain in the proposed permit.

**Total Phosphorus:**

For Total Phosphorus (TP), the current NPDES permit requires the permittee to comply with average monthly and instantaneous maximum (IMAX) limits of 2.0 mg/L and 4.0 mg/L, respectively. These limits were previously established based upon the fact that the loading from this facility likely exceeds the minimum 0.25% contribution requirement per DEP’s technical guidance no. 391-2000-018. Total Phosphorus (TP) is still a parameter of concern for all sewage treatment facilities in the Chesapeake Bay watershed and these limits are still necessary to protect both local receiving water and Chesapeake Bay watershed. The relaxation or removal of these limits is also prohibited by EPA’s anti-backsliding regulation found in 40 CFR § 122.44(l)(1).

$$2.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 6.672 \text{ lbs/day} + (6.672 \times 0.25\%) = 8.34 \text{ lbs/day} (8.0 \text{ lbs/day})$$

**Additional Considerations**

*Flow Monitoring*

Flow monitoring is recommended by the permit guidance and is also required by 25 Pa. Code §§ 92a.27 and 92a.61.

*Influent Monitoring*

As a result of negotiation with EPA, influent monitoring of TSS and BOD<sub>5</sub> are required for any POTWs; therefore, influent sampling of BOD<sub>5</sub> and TSS will be included in the draft permit. A 24-hr composite sample type will be required to be consistent with the proposed sampling frequency for TSS and CBOD<sub>5</sub> in the effluent.

*Total Dissolved Solids (TDS)*

Total Dissolved Solids and its major constituents including Bromide, Chloride, and Sulfate have become statewide pollutants of concern and threats to DEP’s mission to prevent violations of water quality standards. The requirement to monitor these pollutants is necessary under the following DEP Central Office directive:

*For point source discharges and upon issuance or reissuance of an individual NPDES permit:*

- *Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.*
- *Where the concentration of bromide in a discharge exceeds 1.0 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.*

The facility has no record of monitoring these pollutants. However, the application shows a maximum influent concentration of 348.0 mg/L for TDS. The effluent concentration is not expected to exceed 1,000 mg/L. No monitoring is necessary.

**Stormwater Outfalls:**

There are no stormwater outfalls associated with this WWTP.

**303d Listed Streams:**

The discharge from this facility is to Juniata River which is assessed as attaining its designated uses.

**Antidegradation (93.4):**

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

**Class A Wild Trout Fisheries:**

No Class A Wild Trout Fisheries are impacted by this discharge.

**WQM 7.0:**

The following data were used in the attached computer model (WQM 7.0) of the stream:

- Discharge pH 7.0 (Default per 391-2000-007)
- Discharge Temperature 20°C (Default per 391-2000-013)
- Stream pH 7.0 (Default per 392-2000-013)
- Stream Temperature 25°C (Default per 392-2000-013)

The following two nodes were used in modeling:

Node 1: Outfall 001 to Susquehanna River (06685)  
Elevation: 236.30 ft (USGS National Map Viewer)  
Drainage Area: 26,000 mi<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 27.396 (PA DEP eMapPA)  
Low Flow Yield: 0.13 cfs/mi<sup>2</sup>  
Discharge Flow: 0.4 MGD

Node 2: At 06685 confluence with Canadochly Creek  
Elevation: 226.71 ft (USGS National Map Viewer)  
Drainage Area: 26,100 mi<sup>2</sup> (USGS PA StreamStats)  
River Mile Index: 23.765 (PA DEP eMapPA)  
Low Flow Yield: 0.13 cfs/mi<sup>2</sup>  
Discharge Flow: 0.0 MGD

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	8.1356	degrees
CARBON	Percentage of area of carbonate rock	6.68	percent
DRNAREA	Area that drains to a point on a stream	26000	square miles
ELEV	Mean Basin Elevation	1328	feet
FOREST	Percentage of area covered by forest	67.7622	percent
GLACIATED	Percentage of basin area that was historically covered by glaciers	45.3718	percent
PRECIP	Mean Annual Precipitation	40	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.76	miles per square mile
URBAN	Percentage of basin with urban development	2.8921	percent


> Low-Flow Statistics

Low-Flow Statistics Parameters [3.9 Percent (1020 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26000	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	8.1356	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.5	feet	4.13	5.21
URBAN	Percent Urban	2.8921	percent	0	89

Low-Flow Statistics Parameters [42.5 Percent (11100 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26000	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	40	inches	35	50.4
STRDEN	Stream Density	1.76	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	6.68	percent	0	99



> Low-Flow Statistics

Low-Flow Statistics Parameters [3.8 Percent (982 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26000	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	8.1397	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.5	feet	4.13	5.21
URBAN	Percent Urban	2.8813	percent	0	89

Low-Flow Statistics Parameters [42.6 Percent (11100 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26000	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	40	inches	35	50.4
STRDEN	Stream Density	1.76	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	6.64	percent	0	99

Low-Flow Statistics Parameters [6.2 Percent (1610 square miles) Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26000	square miles	2.33	1720
ELEV	Mean Basin Elevation	1329	feet	898	2700
PRECIP	Mean Annual Precipitation	40	inches	38.7	47.9

Low-Flow Statistics Parameters [47.3 Percent (12300 square miles) Low Flow Region 5]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26000	square miles	4.84	982
PRECIP	Mean Annual Precipitation	40	inches	33.1	47.1
GLACIATED	Percent of Glaciation	45.4321	percent	0	100
FOREST	Percent Forest	67.8129	percent	41	100

Low-Flow Statistics Disclaimers [3.8 Percent (982 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [3.8 Percent (982 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	9290	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	10300	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	7270	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	7650	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	8160	ft <sup>3</sup> /s

Low-Flow Statistics Disclaimers [42.6 Percent (11100 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [42.6 Percent (11100 square miles) Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	5970	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	7050	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	4460	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	5250	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	6520	ft <sup>3</sup> /s

Low-Flow Statistics Disclaimers [6.2 Percent (1610 square miles) Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [6.2 Percent (1610 square miles) Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	2410	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	2980	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	1450	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	1810	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	2480	ft <sup>3</sup> /s

Low-Flow Statistics Disclaimers [47.3 Percent (12300 square miles) Low Flow Region 5]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [47.3 Percent (12300 square miles) Low Flow Region 5]

Statistic	Value	Unit
7 Day 2 Year Low Flow	3530	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	4460	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	2270	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	2980	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	3840	ft <sup>3</sup> /s

Low-Flow Statistics Flow Report [Area-Averaged]

Statistic	Value	Unit
7 Day 2 Year Low Flow	4710	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	5680	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	3340	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	4050	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	5050	ft <sup>3</sup> /s

*Low-Flow Statistics Citations*

[Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.](#)

USGS StreamStats

SELECT A STATE / REGION  
Pennsylvania

IDENTIFY A STUDY  
Basin Delineated

SELECT SCENARIO

**BUILD A REPORT** Report Builder

Step 1: You can modify computed basin characteristics here, then select the type of reports you wish to generate. Then click "Build Report" button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS Accessibility FOIA Privacy Policy & Notices

StreamStats Report

Region ID: PA  
 Workspace ID: PA20230621132409946000  
 Clicked Point (Latitude, Longitude): 39.97179, -76.47746  
 Time: 2023-06-21 09:24:49 -0400

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	8.1326	degrees
CARBON	Percentage of area of carbonate rock	6.73	percent
DRNAREA	Area that drains to a point on a stream	26100	square miles
ELEV	Mean Basin Elevation	1328	feet
FOREST	Percentage of area covered by forest	67.7183	percent
GLACIATED	Percentage of basin area that was historically covered by glaciers	45.3343	percent
PRECIP	Mean Annual Precipitation	40	inches
ROCKDEP	Depth to rock	4.5	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	1.75	miles per square mile
URBAN	Percentage of basin with urban development	2.8987	percent

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Displaying simplified Basin. See FAQ for more information.

Low-Flow Statistics

Low-Flow Statistics Parameters [4.0 Percent (1040 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26100	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	8.1326	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.5	feet	4.13	5.21
URBAN	Percent Urban	2.8987	percent	0	89

Low-Flow Statistics Parameters [42.5 Percent (11100 square miles) Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26100	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	40	inches	35	50.4
STRDEN	Stream Density	1.75	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4.5	feet	3.32	5.65
CARBON	Percent Carbonate	6.73	percent	0	99

Low-Flow Statistics Parameters [6.2 Percent (1610 square miles) Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26100	square miles	2.33	1720
ELEV	Mean Basin Elevation	1328	feet	898	2700
PRECIP	Mean Annual Precipitation	40	inches	38.7	47.9

Low-Flow Statistics Parameters [47.2 Percent (12300 square miles) Low Flow Region 5]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	26100	square miles	4.84	982
PRECIP	Mean Annual Precipitation	40	inches	33.1	47.1
GLACIATED	Percent of Glaciation	45.3343	percent	0	100
FOREST	Percent Forest	67.7183	percent	41	100

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Displaying simplified Basin. See FAQ for more information.

USGS StreamStats

SELECT A STATE / REGION  
Pennsylvania

IDENTIFY A STUDY AREA  
Basin Delineator

SELECT SCENARIO

**BUILD A REPORT** Report Builder

Step 1: You can modify computed basin characteristics here, then select the type of reports you wish to generate. Then click "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS  
Accessibility FOIA Privacy Policy & Notices

Low-Flow Statistics Disclaimers [4.0 Percent (1040 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [4.0 Percent (1040 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	9320	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	10400	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	7290	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	7670	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	8190	ft <sup>3</sup> /s

Low-Flow Statistics Disclaimers [42.5 Percent (11100 square miles) Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [42.5 Percent (11100 square miles) Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	6030	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	7120	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	4510	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	5310	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	6590	ft <sup>3</sup> /s

Low-Flow Statistics Disclaimers [6.2 Percent (1610 square miles) Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [6.2 Percent (1610 square miles) Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	2420	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	2990	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	1460	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	1810	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	2490	ft <sup>3</sup> /s

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Displaying simplified Basin. See FAQ for more information.

USGS StreamStats

SELECT A STATE / REGION  
Pennsylvania

IDENTIFY A STUDY AREA  
Basin Delineator

SELECT SCENARIO

**BUILD A REPORT** Report Builder

Step 1: You can modify computed basin characteristics here, then select the type of reports you wish to generate. Then click "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Open Report

POWERED BY WIM

USGS Home Contact USGS Search USGS  
Accessibility FOIA Privacy Policy & Notices

Low-Flow Statistics Disclaimers [6.2 Percent (1610 square miles) Low Flow Region 3]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [6.2 Percent (1610 square miles) Low Flow Region 3]

Statistic	Value	Unit
7 Day 2 Year Low Flow	2420	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	2990	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	1460	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	1810	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	2490	ft <sup>3</sup> /s

Low-Flow Statistics Disclaimers [47.2 Percent (12300 square miles) Low Flow Region 5]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [47.2 Percent (12300 square miles) Low Flow Region 5]

Statistic	Value	Unit
7 Day 2 Year Low Flow	3540	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	4470	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	2270	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	2980	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	3840	ft <sup>3</sup> /s

Low-Flow Statistics Flow Report [Area-Averaged]

Statistic	Value	Unit
7 Day 2 Year Low Flow	4750	ft <sup>3</sup> /s
30 Day 2 Year Low Flow	5730	ft <sup>3</sup> /s
7 Day 10 Year Low Flow	3370	ft <sup>3</sup> /s
30 Day 10 Year Low Flow	4080	ft <sup>3</sup> /s
90 Day 10 Year Low Flow	5090	ft <sup>3</sup> /s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Displaying simplified Basin. See FAQ for more information.



Analysis Results WQM 7.0

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | Effluent Limitations

RMI: 27.40 | Discharge Name: Wrightsville MA | Permit Number: PA0023442 | Disc Flow (mgd): 0.4000

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	25	50	
Dissolved Oxygen			5

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

rptEffLimits

**WQM 7.0 Effluent Limits**

SWP Basin	Stream Code	Stream Name	RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Avg. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
07K	6695	SUSQUEHANNA RIVER	27.398	Wrightsville MA	PA0023442	0.4000	CBOD5	25		
							NH3-N	25	50	
							Dissolved Oxygen			5

Thursday, June 22, 2023 | Version 1.1 | Page 1 of 1

rpt\_WLA

**WQM 7.0 Wasteload Allocations**

SWP Basin	Stream Code	Stream Name	RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
07K	6695	SUSQUEHANNA RIVER	27.398	Wrightsville MA	11.07	30	11.07	30	0	0

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
27.398	Wrightsville MA	1.37	25	1.37	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
27.40	Wrightsville MA	25	25	25	25	5	5	0	0

Thursday, June 22, 2023 | Version 1.1 | Page 1 of 1

rptDOSim

### WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name	
07K	9995	SUSQUEHANNA RIVER	
Flow	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
27.396	04.00	24.500	7.000
Reach Width (ft)	Reach Depth (ft)	Reach Velocity (ft/s)	Reach Slope (ft/ft)
2335.425	08.72	343.40 13	2.170
Reach CSODs (mgd)	Reach K <sub>1</sub> (1/day)	Reach NPK-N (mg/L)	Reach K <sub>2</sub> (1/day)
2.00	0.010	0.00	1.000
Reach DO (mg/L)	Reach K <sub>2</sub> (1/day)	K <sub>2</sub> Equivalents	Reach DO Goal (mg/L)
8.242	3.723	Subsidiary	8
Reach Travel Time (days)	Subreach Results		
0.102	Travel Time (days)	CSODs (mg/L)	NPK-N (mg/L)
		DO (mg/L)	
	0.010	2.00	0.00
	0.020	2.00	0.00
	0.031	2.00	0.00
	0.041	2.00	0.00
	0.051	2.00	0.00
	0.061	2.00	0.00
	0.071	2.00	0.00
	0.081	2.00	0.00
	0.092	2.00	0.00
	0.102	2.00	0.00

Thursday, June 22, 2023      Version 1.1      Page 1 of 1

Page: 1/1      No Filter

rptModelSpecs

### WQM 7.0 Modeling Specifications

Parameters	Units	Use Inputted Q1-10 and Q25-10 Flows
WLA Method	EMPR	<input type="checkbox"/>
Q1-10/Q1-10 Ratio	0.84	<input type="checkbox"/>
Q25-10/Q1-10 Ratio	1.36	<input type="checkbox"/>
D.O. Saturation	90.00%	<input checked="" type="checkbox"/>
D.O. Goal	8	<input type="checkbox"/>

Thursday, June 22, 2023      Version 1.1      Page 1 of 1

Page: 1/1      No Filter

rptHydro

### WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
07K	9995	SUSQUEHANNA RIVER										
RM	Stream Flow With (cfs)	FWS Stream Flow (cfs)	Disc. Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (ft/s)	Reach Time (days)	Analysis Temp (°C)	Analysis pH	
<b>Q7-10 Flow</b>	27.396	3380.00	0.00	8188	0.00260	812	2308.45	343.401	2.18	0.102	25.00	7.00
<b>Q1-10 Flow</b>	27.396	2163.20	0.00	2163.20	0.00260	NA	NA	NA	1.70	0.131	25.00	7.00
<b>Q25-10 Flow</b>	27.396	4598.20	0.00	4598.20	0.00260	NA	NA	NA	2.59	0.086	25.00	7.00

Thursday, June 22, 2023      Version 1.1      Page 1 of 1

Page: 1/1      No Filter

rptGeneral

### Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	Flow	Elevation (ft)	Drainage Area (acres)	Slope (ft/ft)	W/L Ratio	Apply
07K	9995	SUSQUEHANNA RIVER	27.396	236.30	28100.00	0.00000	0.00	<input checked="" type="checkbox"/>

Design Cond.	LFY (cfs)	Inb Flow (cfs)	Stream Flow (cfs)	Rich Flow (cfs)	Rich Velocity (ft/s)	W/D Ratio	Rich Depth (ft)	Rich Temp (°C)	Inb pH	Stream Temp (°C)	Stream pH
Q7-10	0.130	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q1-10	0.00	0.00	0.000	0.000							
Q25-10	0.00	0.00	0.000	0.000							

Name	Permit Number	Discharge Data		Disc. Temp (°C)	Disc. pH	
		Disc. Flow (mgd)	Disc. Flow (mgd)			
Wrightsville MA	PA0023442	0.4000	0.4000	0.4000	25.00	7.00

Parameter Name	Parameter Data		Reach Factor	Reach Goal
	Disc. Conc (mg/L)	Inb Conc (mg/L)		
CSODs	25.00	2.00	0.00	1.50
Observed Oxygen	5.00	8.24	0.00	0.00
NPK-N	25.00	0.00	0.00	0.70

Thursday, June 22, 2023      Version 1.1      Page 1 of 2

Page: 1/1      No Filter

rptGeneral

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sqmi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply F.C.
07K	0685	SUSQUEHANNA RIVER	23.765	236.71	26100.00	0.00000	0.00	<input checked="" type="checkbox"/>

Design Cond.	LFY (cfs/m)	Inb Flow (cfs)	Stream Flow (cfs)	Rch Tss Time (days)	Rch Velocity (ft/s)	WD (ft)	Rch Width (ft)	Rch Depth (ft)	Effluent Temp (°C)	pH	Stream Temp (°C)
Q1-10	0.130	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q2-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reaction Factor	Disc Temp (°C)	Disc pH
Wrightsville MA	PA0023442	0.0000	0.0000	0.0000	0.000	20.00	7.00

Parameter Name	Disc Conc (mg/L)	Inb Conc (mg/L)	Stream Conc (mg/L)	Fila Coef (1/days)
CO2O5	2.500	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
PHOS-N	2.500	0.00	0.00	0.70

Thursday, June 22, 2023      Version 1.1      Page 2 of 2

Page: 14    2    No Filter

**Toxic:**

The following data were used in the attached computer model DEP's Toxic Management Spreadsheet, version 1.4, May 2023 of the stream:

- Discharge pH                                    7.0                    (Default)
- Discharge Hardness                         100                   (Default)
- Stream pH                                       7.0                    (Default)
- Stream Hardness                              100                   (Default)

The following two nodes were used in modeling:

Node 1:                Outfall 001 to Susquehanna River (06685)  
 Elevation:             236.30 ft (USGS National Map Viewer)  
 Drainage Area:        26,000 mi<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index:     27.396 (PA DEP eMapPA)  
 Low Flow Yield:       0.13 cfs/mi<sup>2</sup>  
 Discharge Flow:      0.4 MGD

Node 2:                At 06685 confluence with Canadochly Creek  
 Elevation:             226.71 ft (USGS National Map Viewer)  
 Drainage Area:        26,100 mi<sup>2</sup> (USGS PA StreamStats)  
 River Mile Index:     23.765 (PA DEP eMapPA)  
 Low Flow Yield:       0.13 cfs/mi<sup>2</sup>  
 Discharge Flow:      0.0 MGD



Water Management System/Plant  
Version 1.4, May 2004

Discharge Information

Introduction Discharge Stream

Facility: Wrightsville Borough MA, York County NPDES Permit No: PA0023442 Outfall No: 001  
 Evaluation Type: Custom / Additive Wastewater Description: Susquehanna River

Design Flow	Hardness (mg/L)	pH (BOT)	Pollutant Mitigation Factors (PMFs)				Complete MTD Times (min)	
			APC	CPC	TSS	CRL	Q <sub>100</sub>	Q <sub>5</sub>
0.4	100	7						

Discharge Pollutant	Units	Max Discharge Conc.	1 Year Flow		2 Year Flow		3 Year Flow		4 Year Flow		Critical a Mod.	Class. (Transf.)
			T/D Conc.	Stream Conc.	Daily CV	Hourly CV	Stream in CV	Fate Coeff.	POB	POB		
Total Copper	mg/L	0.017										
Total Lead	mg/L	0.021										
Total Zinc	mg/L	0.020										



Water Management System/Plant  
Version 1.4, May 2004

Stream / Surface Water Information

Wrightsville Borough MA, York County, NPDES Permit No. PA0023442, Outfall 001

Introduction Discharge Stream

Receiving Surface Water Name: Susquehanna River No. Reaches to Model: 1  
 Statewide Criteria  
 Great Lakes Criteria  
 ORSANCO Criteria

Location	Stream Code	RM	Wetland (ft)	DA (mi <sup>2</sup> )	Slope (ft)	PWS Wetland (MOC)	Apply PWS Criteria*
Point of Discharge	000605	27.548	226.3	25.023			Yes
End of Reach 1	000605	22.765	226.71	25.120			Yes

Location	RM	LPT (days)	Flow (cfs)		W/D Ratio	W/DH (ft)	Depth (ft)	W/Depth (ft)	Stream Time (hours)	Tributary	Stream		Analysis
			Stream	Tributary							Hardness (pH)	Hardness (pH)	
Point of Discharge	27.548	0.12									100	7	
End of Reach 1	22.765	0.12											

Location	RM	LPT (days)	Flow (cfs)		W/D Ratio	W/DH (ft)	Depth (ft)	W/Depth (ft)	Stream Time (hours)	Tributary	Stream		Analysis
			Stream	Tributary							Hardness (pH)	Hardness (pH)	
Point of Discharge	27.548												
End of Reach 1	22.765												

NPDES Permit Fact Sheet  
Wrightsville STP

NPDES Permit No. PA0023442



Water Management Consultant  
Version 1.0 (10/2018)

Model Results

Wrightsville Borough PA, York County NPDES Permit No. PA0023442, Outfall 001

RETURN TO INPUTS    SAVE AS PDF    PRINT     All     Results     Limits

All Parameters

Wastewater Allocation

AFO    OCT (mg)     PMP:     Analysis Hardness (mg/l)     Analysis pH:

Products	Conc	Stream	TRC Conc	Peak	WQI	WQI CQ	WQA (ug/L)	Comments
Total Copper	0	0	0	0	0	0	0	Clear: Threshold of 0.10 Applied
Total Lead	0	0	0	0	0	0	0	Clear: Threshold of 0.10 Applied
Total Zinc	0	0	0	0	0	0	0	Clear: Threshold of 0.20 Applied

CFC    OCT (mg)     PMP:     Analysis Hardness (mg/l)     Analysis pH:

Products	Conc	Stream	TRC Conc	Peak	WQI	WQI CQ	WQA (ug/L)	Comments
Total Copper	0	0	0	0	0	0	0	Clear: Threshold of 0.10 Applied
Total Lead	0	0	0	0	0	0	0	Clear: Threshold of 0.10 Applied
Total Zinc	0	0	0	0	0	0	0	Clear: Threshold of 0.20 Applied

TMR    OCT (mg)     PMP:     Analysis Hardness (mg/l)     Analysis pH:

Products	Conc	Stream	TRC Conc	Peak	WQI	WQI CQ	WQA (ug/L)	Comments
Total Copper	0	0	0	0	0	0	0	Clear: Threshold of 0.10 Applied
Total Lead	0	0	0	0	0	0	0	Clear: Threshold of 0.10 Applied
Total Zinc	0	0	0	0	0	0	0	Clear: Threshold of 0.20 Applied

CRF    OCT (mg)     PMP:     Analysis Hardness (mg/l)     Analysis pH:

Products	Conc	Stream	TRC Conc	Peak	WQI	WQI CQ	WQA (ug/L)	Comments
Total Copper	0	0	0	0	0	0	0	Clear: Threshold of 0.10 Applied
Total Lead	0	0	0	0	0	0	0	Clear: Threshold of 0.10 Applied
Total Zinc	0	0	0	0	0	0	0	Clear: Threshold of 0.20 Applied

Model Results    4/22/2018    Page 3

Product	Conc	Stream	TRC Conc	Peak	WQI	WQI CQ	WQA (ug/L)	Comments
Total Lead	0	0	0	0	0	0	0	Clear: Threshold of 0.10 Applied
Total Zinc	0	0	0	0	0	0	0	Clear: Threshold of 0.20 Applied

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:


Products	AME (Monthly)		MCA (Quarterly)		MAX (Annual)		Limits	Coverages (WQBEL)	Comments
	AME	MCA	AME	MCA	MAX				

Other Problems without Limits or Monitoring

The following products do not require effluent limits or monitoring (exceeds water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than threshold for monitoring, or the product was not detected since sufficiently sensitive analytical method was used (e.g., < Target CL))

Products	Monitoring	Limits	Comments
Total Copper	0.10	0.10	Discharge Conc < 10% WQBEL
Total Lead	0.10	0.10	Discharge Conc < 10% WQBEL
Total Zinc	0.20	0.20	Discharge Conc < 10% WQBEL

Model Results    4/22/2018    Page 4



**Existing Effluent Limitations and Monitoring Requirements**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD <sub>5</sub>	80	130	XXX	25.0	40.0	50	1/week	24-Hr Composite
BOD <sub>5</sub> Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	100	150	XXX	30.0	45.0	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Ammonia	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Phosphorus	8.0	XXX	XXX	2.0	XXX	4	2/week	24-Hr Composite

**Existing Effluent Limitations and Monitoring Requirements**

Chesapeake Bay Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia --N	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Nitrogen (lbs) Effluent Net	Report	7,306	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus (lbs) Effluent Net	Report	974	XXX	XXX	XXX	XXX	1/month	Calculation

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Recorded
CBOD5	80.0	130.0	XXX	25.0	40.0	50.0	1/week	24-Hr Composite
BOD5	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	100.0	150.0	XXX	30.0	45.0	60.0	1/week	24-Hr Composite
Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Phosphorus	8.0	XXX	XXX	2.0	XXX	4.0	2/week	24-Hr Composite

Compliance Sampling Location:     

Other Comments:



<b>Proposed Effluent Limitations and Monitoring Requirements</b>
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia --N	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Nitrogen (lbs) Effluent Net	Report	7,306	XXX	XXX	XXX	XXX	1/month	Calculation
Total Phosphorus (lbs) Effluent Net	Report	974	XXX	XXX	XXX	XXX	1/month	Calculation

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [redacted]