

Application Type Renewal  
 Facility Type Sewage  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
SECOND DRAFT**

Application No. PA0024015  
 APS ID 629655  
 Authorization ID 1212483

**Applicant and Facility Information**

Applicant Name	<u>Cressona Borough Authority</u>	Facility Name	<u>Cressona Borough Sewer Treatment Plant</u>
Applicant Address	<u>58 South Sillyman Street</u> <u>Cressona, PA 17929-1117</u>	Facility Address	<u>58 South Sillyman Street Rear</u> <u>Cressona, PA 17929</u>
Applicant Contact	<u>Gail M. Buffington, Authority Manager</u>	Facility Contact	<u>Scott Lutz, Chief Operator</u>
Applicant Phone	<u>(570) 385-0185</u>	Facility Phone	<u>(570) 385-1155</u>
Client ID	<u>78409</u>	Site ID	<u>543303</u>
SIC Code	<u>4952</u>	Municipality	<u>Cressona Borough</u>
SIC Description	<u>Trans. &amp; Utilities - Sewerage Systems</u>	County	<u>Schuylkill</u>
Date Published in PA Bulletin	<u>September 14, 2019</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>October 14, 2019</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Application for a renewal of an NPDES permit for discharge of treated sewage</u>		

**Internal Review and Recommendations**

Public notice was published in the PA Bulletin on September 14, 2019.

No comments were received during the 30-day comment period.

A second draft is being issued because an IMAX limitation for Ammonia-Nitrogen was mistakenly omitted from the first draft of the NPDES permit. A stricter summertime limitation of 13.8 mg/L was added for the first draft of this permit. An IMAX limitation of 27.6 mg/L for Ammonia-Nitrogen has now been added in this second draft. The wintertime monitoring/reporting will remain. No other limitations or frequencies were changed in this permit.

The "Requirements for Total Residual Chlorine (TRC)" condition was also removed from Part C of the permit because the proposed limits are technology-based (not water-quality based). Therefore, this condition would not be applicable to the permit.

Approve	Return	Deny	Signatures	Date
X			/s/ Allison Seyfried / Environmental Engineering Specialist	November 8, 2019
X			/s/ Amy M. Bellanca, P.E. / Environmental Engineer Manager	November 8, 2019