

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0024023
APS ID 816483
Authorization ID 1244605

Applicant and Facility Information

Applicant Name	<u>Bernville Borough Berks County</u>	Facility Name	<u>Bernville Borough STP</u>
Applicant Address	<u>PO Box 40</u> <u>Bernville, PA 19506-0040</u>	Facility Address	<u>State Road 183 near Garfield Street</u> <u>Bernville, PA 19506</u>
Applicant Contact	<u>Danny Strunk</u>	Facility Contact	<u>Mike Kreiser</u>
Applicant Phone	<u>(610) 488-1591</u>	Facility Phone	<u>(717) 933-7076</u>
Client ID	<u>95172</u>	Site ID	<u>257959</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Bernville Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Berks</u>
Date Application Received	<u>August 28, 2018</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>September 17, 2018</u>	If No, Reason	<u></u>
Purpose of Application	<u>This is an application request for NPDES renewal.</u>		

Approve	Deny	Signatures	Date
X		Nicholas Hong, P.E. / Environmental Engineer Nick Hong (via electronic signature)	March 17, 2021
X		Daniel W. Martin, P.E. / Environmental Engineer Manager /s/ Maria Bebenek for Dan Martin	March 21, 2021
X		Maria D. Bebenek, P.E. / Environmental Program Manager /s/	March 21, 2021

Summary of Review

The application submitted by the applicant requests a NPDES renewal permit for the Bernville Borough WWTP located at State Road 183 near Garfield Street, Bernville, PA in Berks County, municipality of Bernville. The existing permit became effective on March 1, 2014 and expired on February 28, 2019. The application for renewal was received by DEP Southcentral Regional Office (SCRO) on August 28, 2018.

The purpose of this Fact Sheet is to present the basis of information used for establishing the proposed NPDES permit effluent limitations. The Fact Sheet includes a description of the facility, a description of the facility's receiving waters, a description of the facility's receiving waters attainment/non-attainment assessment status, and a description of any changes to the proposed monitoring/sampling frequency. Section 6 provides the justification for the proposed NPDES effluent limits derived from technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), total maximum daily loading (TMDL), antidegradation, anti-backsliding, and/or whole effluent toxicity (WET). A brief summary of the outlined descriptions has been included in the Summary of Review section.

The subject facility is a 0.285 MGD (average annual design) treatment facility. The applicant does not anticipate any proposed upgrades to the treatment facility in the next five years. The NPDES application has been processed as a Minor Sewage Facility (Level 2) due to the type of sewage and the design flow rate for the facility. The applicant disclosed the Act 14 requirement to Berks County Planning Commission and Bernville Borough Planning Commission and the notice was received by the parties on August 13, 2018 and August 20, 2018. A planning approval letter was not necessary as the facility is neither new or expanding.

Utilizing the DEP's web-based Emap-PA information system, the receiving waters has been determined to be Northkill Creek. The sequence of receiving streams that the Northkill Creek discharges into are the Tulpehocken Creek, the Schuylkill River, the Delaware River which eventually drains into the Delaware Bay. The receiving water has protected water usage for warm water fishes (WWF) and migratory fishes (MF). No Class A Wild Trout fisheries are impacted by this discharge. The absence of high quality and/or exceptional value surface waters removes the need for an additional evaluation of anti-degradation requirements.

The Northkill Creek is a Category 2 and 5 stream listed in the 2020 Integrated List of All Waters (formerly 303d Listed Streams). This stream is an attaining stream that supports fish consumption and potable water supply. The receiving waters is also impaired for aquatic life and recreational uses. The receiving waters is not subject to a total maximum daily load (TMDL) plan to improve water quality in the subject facility's watershed.

The existing permit and proposed permit differ as follows:

- **Due to DRBC regulations, TDS shall have a limit of 1,000 mg/l and be monitored on a 1x/quarter basis.**

Sludge use and disposal description and location(s): Sewage sludge is disposed at Lehigh County Authority

The proposed permit will expire five (5) years from the effective date.

Based on the review in this report, it is recommended that the permit be drafted. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Any additional information or public review of documents associated with the discharge or facility may be available at PA DEP Southcentral Regional Office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file review, contact the SCRO File Review Coordinator at 717.705.4700.

1.0 Applicant

1.1 General Information

This fact sheet summarizes PA Department of Environmental Protection's review for the NPDES renewal for the following subject facility.

Facility Name: Bernville Borough

NPDES Permit # PA0024023

Physical Address: State Road 183 near Garfield Street
Bernville, PA 19506

Mailing Address: PO Box 40
Bernville, PA 19506

Contact: Mike Kreiser
President/Operator
Select Environmental Solutions
Selectenvironmental@gmail.com

Consultant: Mary Peters
Project Manager
Entech Engineering, Inc.
mpeters@entecheng.com

1.2 Permit History

Description of Facility

The Fact Sheet prepared on October 31, 2013 erroneously stated that the flow rate was corrected from a maximum monthly flow of 0.45 MGD to 0.285 MGD.

A letter from DEP dated for January 18, 2007 rescinded the WQM Part II permit No 0698407 Amendment 05-1 due to execution of a Consent Order and Agreement. The letter reinstated the WQM Part II permit No 0698407 issued on March 8, 1999. The annual hydraulic capacity is 0.285 MGD and the monthly maximum hydraulic capacity is 0.45 MGD. This was confirmed with a telephone call with Mary Peters of Entech Engineering in March 2021.

Permit submittal included the following information.

- NPDES Application
- Influent Sample Data
- Effluent Sample Data

2.0 Treatment Facility Summary

2.1.1 Site location

The physical address for the facility is State Road 183 near Garfield Street, Bernville, PA 19506. A topographical and an aerial photograph of the facility are depicted as Figure 1 and Figure 2.

Figure 1: Topographical map of the subject facility





Figure 2: Aerial Photograph of the subject facility



2.1.2 Sources of Wastewater/Stormwater

The facility received wastewater contributions from the following municipalities.

Bernville Borough 90%
Penn Township 10%

The facility reported no industrial/commercial users and no hauled in wastes.

2.2 Description of Wastewater Treatment Process

The subject facility is a 0.285 MGD average annual design flow facility. The hydraulic design flow is 0.45 MGD. The subject facility treats wastewater using a raw sewage grinder, an influent pump(s), bar screen, ferric chloride feed system, a sequencing batch reactor(s), a sludge digester (sludge holding tank), a post-equalization tank, and a two channel uv system prior to discharge through the outfall. The facility is being evaluated for flow, pH, dissolved oxygen, UV transmittance, CBOD5, TSS, fecal coliform, ammonia-nitrogen, total phosphorus, and total dissolved solids. The existing permits limits for the facility is summarized in Section 2.4.

The treatment process is summarized in the table.

Treatment Facility Summary				
Treatment Facility Name: Bernville STP				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Phosphorus Reduction	Sequencing Batch Reactor	Ultraviolet	0.285
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.45	288	Not Overloaded		Other WWTP

2.3 Facility Outfall Information

The facility has the following outfall information for wastewater.

Outfall No. 001 Design Flow (MGD) .285
 Latitude 40° 25' 46.00" Longitude -76° 6' 44.09"
 Wastewater Description: Sewage Effluent

The subject facility outfall is within the vicinity of another sewage/wastewater outfall. The outfall is the North Heidelberg STP (PA0033766) which is about 0.25 miles upstream from the subject facility. The design flow rate for the facility is 0.1 MGD.

2.3.1 Operational Considerations- Chemical Additives

Chemical additives are chemical products introduced into a waste stream that is used for cleaning, disinfecting, or maintenance and which may be detected in effluent discharged to waters of the Commonwealth. Chemicals excluded are those used for neutralization of waste streams, the production of goods, and treatment of wastewater.

The subject facility utilizes the following chemicals as part of their treatment process.

- Ferric chloride for precipitating phosphorus
- Polymer for coagulating suspended solids
- Microbes for decomposing organic matter

2.4 Existing NPDES Permits Limits

The existing NPDES permit limits are summarized in the table.

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. A. For Outfall 001, Latitude 40° 25' 46.00", Longitude 76° 6' 44.08", River Mile Index 0.26, Stream Code 01902

Receiving Waters: Northkill Creek

Type of Effluent: Treated municipal wastewater

1. The permittee is authorized to discharge during the period from March 1, 2014 through February 28, 2019.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
CBOD5	59	95 Wkly Avg	XXX	25	40	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids	71	106 Wkly Avg	XXX	30	45	60	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (CFU/100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab

Outfall 001, Continued (from March 1, 2014 through February 28, 2019)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia-Nitrogen	47	XXX	XXX	20	XXX	40	1/week	24-Hr Composite
Total Phosphorus	2.38	XXX	XXX	1.0	XXX	2.0	1/week	24-Hr Composite
Total Dissolved Solids	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

3.0 Facility NPDES Compliance History

3.1 Summary of Inspections

A summary of the most recent inspections during the existing permit review cycle is as follows.

The DEP inspector noted the following during the inspection.

05/06/2014: There was nothing significant to report

12/01/2016: The collection system was recently televised and spot repairs were made.

02/13/2019: There was nothing significant to report

3.2 Summary of DMR Data

A review of approximately 1-year of DMR data shows that the monthly average flow data for the facility below the design capacity of the treatment system. The maximum average flow data for the DMR reviewed was 0.3485 MGD in December 2020. The design capacity of the treatment system is 0.45 MGD.

The off-site laboratory used for the analysis of the parameters was Suburban Testing Labs located at 1037F MacArthur Road, Reading, PA 19605..

**NPDES Permit Fact Sheet
Bernville Borough STP**

NPDES Permit No. PA0024023

DMR Data for Outfall 001 (from January 1, 2020 to December 31, 2020)

Parameter	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20	MAR-20	FEB-20	JAN-20
Flow (MGD) Average Monthly	0.3485	0.2002	0.1457	0.1543	0.3256	0.1642	0.2618	0.285	0.3233	0.2732	0.3054	0.3071
Flow (MGD) Daily Maximum	1.2096	0.3915	0.3099	0.2418	0.9587	0.2632	0.563	0.6556	0.5056	0.5344	0.4543	0.6418
pH (S.U.) Minimum	6.87	6.82	6.84	6.94	6.81	6.88	6.93	6.85	6.88	6.85	6.9	6.75
pH (S.U.) Maximum	7.1	7.14	7.19	7.23	7.34	7.25	7.26	7.19	7.22	7.2	7.23	7.27
DO (mg/L) Minimum	6.52	6.83	6.79	7.07	7.33	6.53	6.73	6.71	7.51	7.3	7.0	7.74
CBOD5 (lbs/day) Average Monthly	< 5	< 3	< 2	< 3	< 7	3	< 4	< 5	< 6	< 5	< 5	< 5
CBOD5 (lbs/day) Weekly Average	< 7	< 4	< 3	< 3	< 16	4	< 5	< 6	< 8	< 6	< 6	8
CBOD5 (mg/L) Average Monthly	< 2	< 2	< 2	< 2.1	< 2.1	2.5	< 2.3	< 2.1	< 2	< 2	< 2	< 2.1
CBOD5 (mg/L) Weekly Average	< 2	< 2	< 2	2.3	2.3	3	2.4	2.2	< 2	2.1	< 2	2.3
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	267	129	146	176	153	154	129	117	180	194	150	307
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	395	139	207	235	235	198	187	145	329	374	167	763
BOD5 (mg/L) Raw Sewage Influent Average Monthly	98.7	85.1	129	139.9	56.2	117.7	69.1	52.9	57.6	83.3	60.3	108.5
TSS (lbs/day) Average Monthly	16	5	2	3	8	3	< 3	< 3	< 4	< 3	< 3	< 5
TSS (lbs/day) Raw Sewage Influent Average Monthly	407	262	175	194	165	169	173	115	259	204	207	457
TSS (lbs/day) Raw Sewage Influent Daily Maximum	882	438	270	261	176	332	319	186	536	305	230	627
TSS (lbs/day) Weekly Average	36	9	3	4	19	4	4	4	5	4	4	11

**NPDES Permit Fact Sheet
Bernville Borough STP**

NPDES Permit No. PA0024023

TSS (mg/L) Average Monthly	3.7	3.2	2	2.2	2.2	2.1	< 1.5	< 1.1	< 1.3	< 1.2	< 1.1	< 1.9
TSS (mg/L) Raw Sewage Influent Average Monthly	143	167	152	155	68	131.6	94	52	83	89	82.4	201
TSS (mg/L) Weekly Average	7	5.6	2.3	3.2	2.7	2.6	1.8	1.2	1.5	1.5	1.2	3.1
Total Dissolved Solids (mg/L) Average Monthly	260			232			278			234		
Fecal Coliform (CFU/100 ml) Geometric Mean	< 1	< 1	< 1	< 1	< 5	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	1	2	2	< 1	208	< 1	< 1	1	1	< 1	< 1	< 1
UV Transmittance (%) Minimum	82.1	75.9	85.1	84.9	79.6	85.2	86.5	88.4	91.2	89.1	84.3	87
Ammonia (lbs/day) Average Monthly	< 0.3	< 0.2	< 0.1	< 0.1	< 0.4	< 0.1	< 0.2	< 0.2	< 0.3	< 0.2	< 0.3	< 0.3
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.11	< 0.1	< 0.1	< 0.1
Total Phosphorus (lbs/day) Average Monthly	< 1.00	0.70	0.70	0.70	2.00	0.60	0.90	1.00	1.00	0.80	1.00	0.90
Total Phosphorus (mg/L) Average Monthly	< 0.37	0.43	0.6	0.53	0.47	0.42	0.45	0.41	0.42	0.36	0.4	0.4

3.3 Non-Compliance

3.3.1 Non-Compliance- NPDES Effluent

A summary of the non-compliance to the permit limits for the existing permit cycle is as follows.

From the DMR data beginning in March 1, 2014 to February 13, 2021, the table summarizes observed effluent non-compliances.

**Summary of Effluent Non-Compliance with NPDES Permit Limits
Beginning March 1, 2014 and Ending February 13, 2021**

DATE	PARAMETER	SAMPLE VALUE	CONDITION	PERMIT VALUE	MEASURE	STATISTICAL BASE CODE
08/21/2017	Carbonaceous Biochemical Oxygen Demand (CBOD5)	109	>	95	lbs/day	Weekly Average

3.3.2 Non-Compliance- Enforcement Actions

A summary of the non-compliance enforcement actions for the current permit cycle is as follows:

Beginning in March 1, 2014 to February 13, 2021, there were no observed enforcement actions.

3.4 Summary of Biosolids Disposal

A summary of the biosolids disposed of from the facility is as follows.

2020			
Sewage Sludge / Biosolids Production Information			
Hauled Off-Site			
Date (YEAR)	Gallons	% Solids	Dry Tons
January	22400	2.3	2.148
February			
March	22400	2.2	2.055
April			
May	22400	2.8	2615
June			
July	22400	5.4	5.044
August			
September	22400	3.4	3.176
October			
November	2240	1.4	1.308
December			
Notes:			
Sewage Sludge/Biosolids disposed at Lehigh County authority WWTP			

3.5 Open Violations

No open violations existed as of March 2021.

4.0 Receiving Waters and Water Supply Information Detail Summary

4.1 Receiving Waters

The receiving waters has been determined to be Northkill Creek. The sequence of receiving streams that the Northkill Creek discharges into are the Tulpehocken Creek, the Schuylkill River, the Delaware River which eventually drains into the Delaware Bay.

4.2 Public Water Supply (PWS) Intake

The closest PWS to the subject facility is Western Berks Water Authority (PWS ID #3060066) located approximately 9 miles downstream of the subject facility on the Tulpehocken Creek. Based upon the distance and the flow rate of the facility, the PWS should not be impacted.

4.3 Class A Wild Trout Streams

Class A Wild Trout Streams are waters that support a population of naturally produced trout of sufficient size and abundance to support long-term and rewarding sport fishery. DEP classifies these waters as high-quality coldwater fisheries.

The information obtained from EMAP suggests that no Class A Wild Trout Fishery will be impacted by this discharge.

4.4 2020 Integrated List of All Waters (303d Listed Streams):

Section 303(d) of the Clean Water Act requires States to list all impaired surface waters not supporting uses even after appropriate and required water pollution control technologies have been applied. The 303(d) list includes the reason for impairment which may be one or more point sources (i.e. industrial or sewage discharges) or non-point sources (i.e. abandoned mine lands or agricultural runoff and the pollutant causing the impairment such as metals, pH, mercury or siltation).

States or the U.S. Environmental Protection Agency (EPA) must determine the conditions that would return the water to a condition that meets water quality standards. As a follow-up to listing, the state or EPA must develop a Total Maximum Daily Load (TMDL) for each waterbody on the list. A TMDL identifies allowable pollutant loads to a waterbody from both point and non-point sources that will prevent a violation of water quality standards. A TMDL also includes a margin of safety to ensure protection of the water.

The water quality status of Pennsylvania's waters uses a five-part categorization (lists) of waters per their attainment use status. The categories represent varying levels of attainment, ranging from Category 1, where all designated water uses are met to Category 5 where impairment by pollutants requires a TMDL for water quality protection.

The receiving waters is listed in the 2020 Pennsylvania Integrated Water Quality Monitoring and Assessment Report as a Category 2 and 5 waterbody. The surface waters is an attaining stream that supports fish consumption and potable water supply. The receiving stream is also impaired for aquatic life and recreational uses due to pathogens from an unknown source. The designated use has been classified as protected waters for warm water fishes (WWF) and migratory fishes (MF).

4.5 Low Flow Stream Conditions

Water quality modeling estimates are based upon conservative data inputs. The data are typically estimated using either a stream gauge or through USGS web based StreamStats program. The NPDES effluent limits are based upon the combined flows from both the stream and the facility discharge.

A conservative approach to estimate the impact of the facility discharge using values which minimize the total combined volume of the stream and the facility discharge. The volumetric flow rate for the stream is based upon the seven-day, 10-year low flow (Q710) which is the lowest estimated flow rate of the stream during a 7 consecutive day period that occurs once in 10 -year time period. The facility discharge is based upon a known design capacity of the subject facility.

The closest WQN station to the subject facility is the Tulpehocken Creek station (WQN117). This WQN station is located approximately 13 miles downstream of the subject facility.

The closest gauge station to the subject facility is the Tulpehocken Creek at Blue Marsh Damsite near Reading station (USGS station number 1470960). This gauge station is located approximately 9 miles downstream of the subject facility.

The low flow yield and the Q710 for the subject facility was estimated as shown below.

Gauge Station Data		
USGS Station Number	1470960	
Station Name	Tulpehocken Creek at Blue Marsh Damsite near Reading	
Q710	38.2	ft ³ /sec
Drainage Area (DA)	175	mi ²
Calculations		
The low flow yield of the gauge station is:		
Low Flow Yield (LFY) = Q710 / DA		
LFY = (38.2 ft ³ /sec / 175 mi ²)		
LFY =	0.2183	ft ³ /sec/mi ²
The low flow at the subject site is based upon the DA of		
	42	mi ²
Q710 = (LFY@gauge station)(DA@Subject Site)		
Q710 = (0.2183 ft ³ /sec/mi ²)(42 mi ²)		
Q710 =	9.168	ft ³ /sec

4.6 Summary of Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.285</u>
Latitude	<u>40° 25' 41.67"</u>	Longitude	<u>-76° 6' 48.96"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			

Receiving Waters	<u>Northkill Creek</u>	Stream Code	<u>1902</u>
NHD Com ID	<u>25962314</u>	RMI	<u>0.17</u>
Drainage Area	<u>42</u>	Yield (cfs/mi ²)	<u>0.2183</u>
Q ₇₋₁₀ Flow (cfs)	<u>9.168</u>	Q ₇₋₁₀ Basis	<u>StreamStats/StreamGauge</u>
Elevation (ft)	<u>289</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>3-C</u>	Chapter 93 Class.	<u>WWF, MF</u>
Existing Use	<u>Same as Chapter 93 class</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>

Assessment Status	<u>Attaining Use(s) supports fish consumption/potable water supply. Impaired for aquatic life/recreational uses</u>		
Cause(s) of Impairment	<u>Pathogen</u>		
Source(s) of Impairment	<u>Unknown source</u>		
TMDL Status	<u>Not applicable</u>	Name	<u></u>

Background/Ambient Data		Data Source	
pH (SU)	<u>7.59</u>	Median July to Sept	<u></u>
Temperature (°C)	<u>20.0</u>	Median July to Sept	<u></u>
Hardness (mg/L)	<u>154</u>	Median historical	<u></u>
Other:	<u></u>		<u></u>

Nearest Downstream Public Water Supply Intake	<u>Western Berks Water Authority</u>		
PWS Waters	<u>Tulpehocken Creek</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u>5.95</u>	Distance from Outfall (mi)	<u>9</u>

5.0: Overview of Presiding Water Quality Standards

5.1 General

There are at least six (6) different policies which determines the effluent performance limits for the NPDES permit. The policies are technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), antidegradation, total maximum daily loading (TMDL), anti-backsliding, and whole effluent toxicity (WET) The effluent performance limitations enforced are the selected permit limits that is most protective to the designated use of the receiving waters. An overview of each of the policies that are applicable to the subject facility has been presented in Section 6.

5.2.1 Technology-Based Limitations

TBEL treatment requirements under section 301(b) of the Act represent the minimum level of control that must be imposed in a permit issued under section 402 of the Act (40 CFR 125.3). Available TBEL requirements for the state of Pennsylvania are itemized in PA Code 25, Chapter 92a.47.

The presiding sources for the basis for the effluent limitations are governed by either federal or state regulation. The reference sources for each of the parameters is itemized in the tables. The following technology-based limitations apply, subject to water quality analysis and best professional judgement (BPJ) where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

5.2.2 Mass Based Limits

For publicly owned treatment works (POTW), mass loadings are calculated based upon design flow rate of the facility and the permit limit concentration. The generalized calculation for mass loadings is shown below:

$$Quantity \left(\frac{lb}{day} \right) = (MGD)(Concentration)(8.34)$$

5.3 Water Quality-Based Limitations

WQBEL are based on the need to attain or maintain the water quality criteria and to assure protection of designated and existing uses (PA Code 25, Chapter 92a.2). The subject facility that is typically enforced is the more stringent limit of either the TBEL or the WQBEL.

Determination of WQBEL is calculated by spreadsheet analysis or by a computer modeling program developed by DEP. DEP permit engineers utilize the following computing programs for WQBEL permit limitations: (1) MS Excel worksheet for Total Residual Chlorine (TRC); (2) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1.0 (WQM Model) and (3) PENTOXSD using DEP Toxics Management Spreadsheet for Toxics pollutants.

5.3.1 Water Quality Modeling 7.0

The WQM Model is a computer model that is used to determine NPDES discharge effluent limitations for Carbonaceous BOD (CBOD5), Ammonia Nitrogen (NH₃-N), and Dissolved Oxygen (DO) for single and multiple point source discharges scenarios. WQM Model is a complete-mix model which means that the discharge flow and the stream flow are assumed to instantly and completely mixed at the discharge node.

WQM recommends effluent limits for DO, CBOD5, and NH₃-N in mg/l for the discharge(s) in the simulation.

Four types of limits may be recommended. The limits are

- (a) a minimum concentration for DO in the discharge as 30-day average;
- (b) a 30-day average concentration for CBOD5 in the discharge;
- (c) a 30-day average concentration for the NH₃-N in the discharge;
- (d) 24-hour average concentration for NH₃-N in the discharge.

The WQM Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

The input values utilized for the modeling are summarized in the table which can be found in Attachment B.

The applicable WQM Effluent Limit Type are discussed in Section 6 under the corresponding parameter which is either DO, CBOD, or ammonia-nitrogen.

5.3.2 Toxics Modeling

Effluent sampling results are required for total copper, total lead, and total zinc if the facility receives industrial or commercial wastewater contributions. The facility reported that they do not have industrial or commercial wastewater contributions.

The facility is not subject to toxics modeling.

5.3.3 Whole Effluent Toxicity (WET)

The facility is not subject to WET.

5.4 Total Maximum Daily Loading (TMDL)

5.4.1 TMDL

The goal of the Clean Water Act (CWA), which governs water pollution, is to ensure that all of the Nation's waters are clean and healthy enough to support aquatic life and recreation. To achieve this goal, the CWA created programs designed to regulate and reduce the amount of pollution entering United States waters. Section 303(d) of the CWA requires states to assess their waterbodies to identify those not meeting water quality standards. If a waterbody is not meeting standards, it is listed as impaired and reported to the U.S. Environmental Protection Agency. The state then develops a plan to clean up the impaired waterbody. This plan includes the development of a Total Maximum Daily Load (TMDL) for the pollutant(s) that were found to be the cause of the water quality violations. A Total Maximum Daily Load (TMDL) calculates the maximum amount of a specific pollutant that a waterbody can receive and still meet water quality standards.

Pennsylvania has committed to restoring all impaired waters by developing TMDLs and TMDL alternatives for all impaired waterbodies. The TMDL serves as the starting point or planning tool for restoring water quality.

5.4.1.1 Local TMDL

The subject facility does not discharge into a local TMDL.

5.5 Anti-Degradation Requirement

Chapter 93.4a of the PA regulations requires that surface water of the Commonwealth of Pennsylvania may not be degraded below levels that protect the existing uses. The regulations specifically state that *Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected*. Antidegradation requirements are implemented through DEP's guidance manual entitled Water Quality Antidegradation Implementation Guidance (Document #391-0300-02).

The policy requires DEP to protect the existing uses of all surface waters and the existing quality of High Quality (HQ) and Exceptional Value (EV) Waters. Existing uses are protected when DEP makes a final decision on any permit or approval for an activity that may affect a protected use. Existing uses are protected based upon DEP's evaluation of the best available information (which satisfies DEP protocols and Quality Assurance/Quality Control (QA/QC) procedures) that indicates the protected use of the waterbody.

For a new, additional, or increased point source discharge to an HQ or EV water, the person proposing the discharge is required to utilize a nondischarge alternative that is cost-effective and environmentally sound when compared with the cost of the proposed discharge. If a nondischarge alternative is not cost-effective and environmentally sound, the person must use the best available combination of treatment, pollution prevention, and wastewater reuse technologies and assure that any discharge is nondegrading. In the case of HQ waters, DEP may find that after satisfaction of intergovernmental coordination and public participation requirements lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In addition, DEP will assure that cost-effective and reasonable best management practices for nonpoint source control in HQ and EV waters are achieved.

The subject facility's discharge will be to a non-special protection waters and the permit conditions are imposed to protect existing instream water quality and uses. Neither HQ waters or EV waters is impacted by this discharge.

5.6 Anti-Backsliding

Anti-backsliding is a federal regulation which prohibits a permit from being renewed, reissued, or modified containing effluent limitations which are less stringent than the comparable effluent limitations in the previous permit (40 CFR 122.1.1 and 40 CFR 122.1.2). A review of the existing permit limitations with the proposed permit limitations confirm that the facility is consistent with anti-backsliding requirements. The facility has proposed effluent limitations that are as stringent as the existing permit.

6.0 NPDES Parameter Details

The basis for the proposed sampling and their monitoring frequency that will appear in the permit for each individual parameter are itemized in this Section. The final limits are the more stringent of technology based effluent treatment (TBEL) requirements, water quality based (WQBEL) limits, TMDL, antidegradation, anti-degradation, or WET.

The reader will find in this section:

- a) a justification of recommended permit monitoring requirements and limitations for each parameter in the proposed NPDES permit;
- b) a summary of changes from the existing NPDES permit to the proposed permit; and
- c) a summary of the proposed NPDES effluent limits.

6.1 Recommended Monitoring Requirements and Effluent Limitations

A summary of the recommended monitoring requirements and effluent limitations are itemized in the tables. The tables are categorized by (a) Conventional Pollutants and Disinfection, (b) Nitrogen Species and Phosphorus, and (c) Toxics

For WQM modeling, the North Heidelberg and Bernville were modelled together. No changes from the existing permit to the proposed permit were observed when modeling for CBOD and ammonia-nitrogen.

6.1.1 Conventional Pollutants and Disinfection

Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection Bernville Borough; PA0024023			
Parameter	Permit Limitation Required by ¹ :	Recommendation	
pH (S.U.)	TBEL	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-3).
		Effluent Limit:	Effluent limits may range from pH = 6.0 to 9.0
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 95.2(1).
Dissolved Oxygen	BPJ	Monitoring:	The monitoring frequency shall be daily as a grab sample (Table 6-3).
		Effluent Limit:	Effluent limits shall be greater than 5.0 mg/l.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by best professional judgement.
CBOD	TBEL	Monitoring:	The monitoring frequency shall be 1x/wk as an 24-hr composite sample (Table 6-3).
		Effluent Limit:	Effluent limits shall not exceed 59 lbs/day and 25 mg/l as an average monthly.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). WQM modeling indicates that the TBEL is more stringent than the WQBEL. Thus, the permit limit is confined to TBEL.
TSS	TBEL	Monitoring:	The monitoring frequency shall be 1x/wk as a 24-hr composite sample (Table 6-3).
		Effluent Limit:	Effluent limits shall not exceed 71 lbs/day and 30 mg/l as an average monthly.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). While there is no WQM modeling for this parameter, the permit limit for TSS is generally assigned similar effluent limits as CBOD or BOD. Since the TBEL is more stringent than TBEL, TBEL will apply.
UV disinfection	SOP	Monitoring:	The monitoring frequency is 1/day. The facility will be required to recording the UV transmittance.
		Effluent Limit:	No effluent limitations
		Rationale:	Consistent with the SOP- Establishing Effluent Limitations for Individual Sewage Permits (Revised January 10, 2019), the facility will be required to have routine monitoring for UV transmittance, UV dosage, or UV intensity.
Fecal Coliform	TBEL	Monitoring:	The monitoring frequency shall be 1x/wk as a grab sample (Table 6-3).
		Effluent Limit:	Summer effluent limits shall not exceed 200 No./100 mL as a geometric mean. Winter effluent limits shall not exceed 2000 No./100 mL as a geometric mean.
		Rationale:	The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(4) and 92a.47(a)(5).

Notes:

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.285 MGD.
- 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017

6.1.2 Nitrogen Species and Phosphorus

Summary of Proposed NPDES Parameter Details for Nitrogen Species and Phosphorus		
Bernville Borough; PA0024023		
Parameter	Permit Limitation Required by ¹ :	Recommendation
Ammonia-Nitrogen	DRBC Limit	Monitoring: The monitoring frequency shall be 1x/wk as a 24-hr composite sample
		Effluent Limit: Effluent limits shall not exceed 47 lbs/day and 20 mg/l as an average monthly.
		Rationale: Due to the Delaware River Basin, a limit for ammonia-nitrogen is required consistent with the DRBC Administrative Manual- Part III Water Quality Regulations (18 CFR Section 410). Article 4.30.5 requires an average monthly limit of 20 mg/l for ammonia nitrogen.
Total Phosphorus	Anti-backsliding	Monitoring: The monitoring frequency shall be 1x/wk as a 24-hr composite sample
		Effluent Limit: Effluent limits shall not exceed 2.38 lbs/day and 1.0 mg/l as an average monthly.
		Rationale: Consistent with the Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams (391-2000-018) since the discharge is located upstream of the Blue Marsh Reservoir, the existing total phosphorus limit of 1.0 will remain in the permit as the limit is also applied to other facilities located upstream of the reservoir. Due to anti-backsliding regulations, the current phosphorus limit shall continue to the proposed permit.

Notes:

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.285 MGD.
- 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017

6.1.3 Toxics

Summary of Proposed NPDES Parameter Details for Toxics		
Bernville Borough; PA0024023		
Parameter	Permit Limitation Required by ¹ :	Recommendation
TDS	DRBC Limit	Monitoring: The monitoring frequency shall be 1x/quarter as a 24-hr composite sample
		Effluent Limit: Effluent limits shall not exceed 1,000 mg/l as an average monthly.
		Rationale: Due to the Delaware River Basin, the DRBC Administrative Manual- Part III Water Quality Regulations (18 CFR Part 410 Article 3.10.4.D.2) requires that TDS shall not exceed 1,000 mg/l. as an average monthly limit. Based upon DMR from January 2020 to December 2020, the facility is meeting the 1,000 mg/l limit. The monitoring shall continue to the proposed permit. Per DRBC, a limit shall be enforced.
Notes:		

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.285 MGD.
- 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017

6.2 Summary of Changes From Existing Permit to Proposed Permit

A summary of how the proposed NPDES permit differs from the existing NPDES permit is summarized as follows.

Changes in Permit Monitoring or Effluent Quality		
Parameter	Existing Permit	Draft Permit
TDS	Monitoring is required 1x/quarter	Due to DRBC regulations, a limit of 1,000 mg/l is required. Monitoring shall continue at 1x/quarter.

6.3.1 Summary of Proposed NPDES Effluent Limits

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

The proposed NPDES effluent limitations are summarized in the table below.

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. A. For Outfall 001, Latitude 40° 25' 46.00", Longitude 76° 6' 44.09", River Mile Index 0.45, Stream Code 1902

Receiving Waters: Tulpehocken Creek (WWF)

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from Permit Effective Date through Permit Expiration Date.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average Report Daily Max	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	59	95	XXX	25	40	50	1/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Suspended Solids	71	106	XXX	30	45	60	1/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Dissolved Solids	XXX	XXX	XXX	1000.0 Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
Ultraviolet light transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured

Outfall001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia-Nitrogen	47	XXX	XXX	20	XXX	40	1/week	24-Hr Composite
Total Phosphorus	2.38	XXX	XXX	1.0	XXX	2	1/week	24-Hr Composite

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

6.3.2 Summary of Proposed Permit Part C Conditions

The subject facility has the following Part C conditions.

- SBR Batch Discharge Condition
- DRBC May Have Other Requirements
- Hauled-in Waste Restrictions
- Solids Management for Non-Lagoon Treatment Systems

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: <i>New and Reissuance Sewage Individual NPDES Applications, rev October 11, 2013</i>
<input type="checkbox"/>	Other: [redacted]

Attachment A

Stream Stats/Gauge Data

10 Selected Streamflow Statistics for Streamgauge Locations in and near Pennsylvania

Table 1. List of U.S. Geological Survey streamgauge locations in and near Pennsylvania with updated streamflow statistics.—Continued

[Latitude and Longitude in decimal degrees; mi², square miles]

Streamgauge number	Streamgauge name	Latitude	Longitude	Drainage area (mi ²)	Regulated ¹
01465780	Poquessing Creek above Byberry Creek at Phila., Pa.	40.070	-74.975	13.2	N
01465798	Poquessing Creek at Grant Ave. at Philadelphia, Pa.	40.057	-74.985	21.4	N
01465850	South Branch Rancocas Creek at Vincentown, N.J.	39.94	-74.763	64.5	N
01466500	McDonalds Branch in Byrne State Forest, N.J.	39.885	-74.505	2.35	N
01467000	North Branch Rancocas Creek at Pemberton, N.J.	39.97	-74.684	118	N
01467042	Pennypack Creek at Pine Road, at Philadelphia, Pa.	40.090	-75.069	37.9	N
01467048	Pennypack Creek at Lower Rhawn St Bdg, Phila., Pa.	40.050	-75.033	49.8	N
01467050	Wooden Bridge Run at Philadelphia, Pa.	40.055	-75.022	3.35	N
01467081	South Branch Pennsauken Creek at Cherry Hill, N.J.	39.942	-75.001	8.98	N
01467086	Tacony Creek ab Adams Avenue, Philadelphia, Pa.	40.047	-75.111	16.7	N
01467087	Frankford Creek at Castor Ave, Philadelphia, Pa.	40.016	-75.097	30.4	N
01467089	Frankford Creek at Torresdale Ave., Phila., Pa.	40.007	-75.092	33.8	N
01467150	Cooper River at Haddonfield, N.J.	39.903	-75.021	17.0	N
01467500	Schuylkill River at Pottsville, Pa.	40.684	-76.186	53.4	N
01468500	Schuylkill River at Landingville, Pa.	40.629	-76.125	133	N
01469500	Little Schuylkill River at Tamaqua, Pa.	40.807	-75.972	42.9	N
01470500	Schuylkill River at Berne, Pa.	40.523	-75.998	355	N
01470756	Maiden Creek at Virginville, Pa.	40.514	-75.883	159	N
01470779	Tulpehocken Creek near Bernville, Pa.	40.413	-76.172	66.5	N
01470853	Furnace Creek at Robesonia, Pa.	40.340	-76.143	4.18	N
01470960	Tulpehocken Creek at Blue Marsh Damsite near Reading, Pa.	40.371	-76.025	175	Y
01471000	Tulpehocken Creek near Reading, Pa.	40.369	-75.979	211	Y
01471510	Schuylkill River at Reading, Pa.	40.335	-75.936	880	Y
01471875	Manatawny Creek near Spangsville, Pa.	40.340	-75.742	56.9	N
01471980	Manatawny Creek near Pottstown, Pa.	40.273	-75.680	85.5	N
01472000	Schuylkill River at Pottstown, Pa.	40.242	-75.652	1,147	Y
01472157	French Creek near Phoenixville, Pa.	40.151	-75.601	59.1	N
01472174	Pickering Creek near Chester Springs, Pa.	40.090	-75.630	5.98	N
01472198	Perkiomen Creek at East Greenville, Pa.	40.394	-75.515	38.0	N
01472199	West Branch Perkiomen Creek at Hillegass, Pa.	40.374	-75.522	23.0	N
01472500	Perkiomen Creek near Frederick, Pa.	40.275	-75.455	152	N
01472620	East Branch Perkiomen Creek near Dublin, Pa.	40.404	-75.234	4.05	LF
01472810	East Branch Perkiomen Creek near Schwenksville, Pa.	40.259	-75.429	58.7	LF
01473000	Perkiomen Creek at Graterford, Pa.	40.230	-75.452	279	LF
01473120	Skipack Creek near Collegeville, Pa.	40.165	-75.433	53.7	N
01473169	Valley Creek at Pa. Turnpike Br near Valley Forge, Pa.	40.079	-75.461	20.8	N
01473500	Schuylkill River at Norristown, Pa.	40.111	-75.347	1,760	N
01473900	Wissahickon Creek at Fort Washington, Pa.	40.124	-75.220	40.8	N
01473950	Wissahickon Creek at Bells Mill Rd, Phila., Pa.	40.080	-75.226	53.6	N
01473980	Wissahickon Creek at Livezey Lane, Phila., Pa.	40.050	-75.214	59.2	N
01474000	Wissahickon Creek at Mouth, Philadelphia, Pa.	40.015	-75.207	64.0	N
01474500	Schuylkill River at Philadelphia, Pa.	39.968	-75.189	1,893	N
01475000	Mantua Creek at Pitman, N.J.	39.737	-75.113	6.05	N
01475300	Darby Creek at Waterloo Mills near Devon, Pa.	40.023	-75.422	5.15	N
01475510	Darby Creek near Darby, Pa.	39.929	-75.272	37.4	N

22 Selected Streamflow Statistics for Streamgage Locations in and near Pennsylvania

Table 2. Selected low-flow statistics for streamgage locations in and near Pennsylvania.—Continued

[ft³/s; cubic feet per second; —, statistic not computed; <, less than]

Streamgage number	Period of record used in analysis ¹	Number of years used in analysis	1-day, 10-year (ft ³ /s)	7-day, 10-year (ft ³ /s)	7-day, 2-year (ft ³ /s)	30-day, 10-year (ft ³ /s)	30-day, 2-year (ft ³ /s)	90-day, 10-year (ft ³ /s)
01453000	¹ 1904–1927	18	237	312	447	378	546	472
01454700	1968–2005	38	471	510	745	600	902	760
01455500	1930–2008	52	0	.4	7.8	—	—	6.0
01457000	1905–2008	89	40.6	45.6	70.5	52.2	81.7	62.5
01459500	² 1975–2008	34	1.9	2.1	4.1	2.9	7.1	5.7
01459500	¹ 1937–1973	37	.4	.9	2.1	1.3	3.6	2.9
01463500	1914–2008	95	1,540	1,720	2,700	1,960	3,120	2,430
01463620	1974–2008	19	2.4	2.7	7.6	4.8	10.6	8.6
01464000	1925–2008	84	9.4	14.2	25.7	18.7	34.2	29.3
01464500	1942–2008	65	16.4	18.9	34.0	24.4	42.3	37.3
01464645	1987–2008	22	3.3	3.6	12.3	4.4	13.6	5.4
01464720	1992–2008	17	3.0	3.6	5.8	4.5	7.3	6.2
01465000	1886–1934	28	—	3.4	10.1	4.9	15.0	12.9
01465500	1936–2008	73	9.0	12.7	26.4	17.3	37.4	28.6
01465770	1966–1982	16	.3	.4	1.2	.8	1.7	1.7
01465798	1967–2008	42	1.0	1.2	3.6	3.0	6.8	7.9
01465850	1963–2008	19	5.2	8.5	13.2	12.1	19.5	17.1
01466500	1955–2008	54	.8	.8	1.1	.9	1.2	.9
01467000	1923–2008	86	26.2	34.2	51.8	41.6	63.2	53.2
01467042	1966–1981	16	8.6	9.3	16.8	11.3	21.5	17.0
01467048	1967–2008	42	10.7	12.1	18.9	16.6	27.2	26.6
01467050	1967–1981	15	.3	.4	.8	.7	1.3	1.6
01467081	1969–2008	38	2.4	2.9	4.1	3.9	6.0	6.3
01467086	1967–1988	23	3.3	4.4	6.9	6.6	9.9	10.4
01467087	1984–2008	25	1.6	2.1	6.1	4.8	10.1	12.0
01467089	1968–1982	15	4.8	6.6	9.6	10.3	16.0	20.1
01467150	1965–2008	44	3.9	5.4	10.1	7.3	13.2	11.5
01467500	1945–1969	25	14.6	17.2	24.5	19.8	28.5	23.4
01468500	1949–2008	40	40.8	44.5	70.6	52.1	82.4	65.0
01469500	1921–2008	88	4.8	5.5	10.9	7.3	14.4	10.1
01470500	1949–2008	60	69.2	82.3	137	102	164	133
01470756	1974–1995	22	14.8	16.7	30.5	23.4	43.9	35.5
01470779	1976–2008	33	21.9	24.6	39.3	29.4	45.2	34.8
01470853	1984–2005	22	.2	.4	1.2	.8	1.6	1.1
01470960	² 1980–2008	29	29.4	31.8	52.4	47.0	74.7	66.3
01470960	¹ 1967–1978	12	32.7	38.2	74.0	47.6	88.3	59.5
01471000	² 1980–2008	29	36.9	43.4	69.4	58.9	93.9	81.0
01471000	¹ 1952–1978	27	41.8	47.6	77.1	55.3	91.2	68.6
01471510	² 1980–2008	29	222	244	347	274	422	340
01471510	¹ 1916–1930	10	142	173	279	206	337	245
01471875	1995–2008	14	10.9	11.8	21.2	14.1	25.3	19.0
01471980	1976–2004	29	16.5	17.8	29.2	21.7	34.9	29.7
01472000	² 1980–2008	29	276	301	432	349	527	453
01472000	¹ 1929–1978	50	228	258	411	298	486	374
01472157	1970–2008	39	9.5	10.2	17.2	12.5	21.8	17.0

Attachment B

Modeling Input Values

WQM 7.0 Modeling Output Values