

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0024091
 APS ID 1128757
 Authorization ID 1512125

Applicant and Facility Information

Applicant Name	Millville Borough	Facility Name	Millville Borough Sewer System STP
Applicant Address	PO Box 30	Facility Address	136 Morehead Avenue
	Millville, PA 17846-0030		Millville, PA 17846
Applicant Contact	Don Keefer	Facility Contact	Michael Woolcock
Applicant Phone	(570) 458-5709	Facility Phone	(570) 458-6208
Client ID	87618	Site ID	246312
Ch 94 Load Status	Not Overloaded	Municipality	Millville Borough
Connection Status	No Limitations	County	Columbia
Date Application Received	January 10, 2025	EPA Waived?	Yes
Date Application Accepted	January 15, 2025	If No, Reason	
Purpose of Application	Renewal of a NPDES Permit		



Summary of Review

The subject facility is a Publicly Owned Treatment Works (POTW) serving Millville Borough and neighboring portions of Greenwood Township and White Pines Landfill in Pine Township all in Columbia County.

Sludge use and disposal description and location(s): The facility's digested sludge is disposed by landfill. Per the application 14.21 dry tons were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		 Keith C. Allison / Project Manager	September 15, 2025
✓		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	September 15, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.3</u>
Latitude	<u>41° 6' 47.89"</u>	Longitude	<u>-76° 31' 38.34"</u>
Quad Name	<u>Millville, PA</u>	Quad Code	
Wastewater Description:	<u>Sewage Effluent</u>		
Receiving Waters	<u>Little Fishing Creek (CWF)</u>	Stream Code	<u>27657</u>
NHD Com ID	<u>65638943</u>	RMI	<u>8.4</u>
Drainage Area	<u>42.1 mi²</u>	Yield (cfs/mi ²)	<u>0.0504</u>
Q ₇₋₁₀ Flow (cfs)	<u>2.1</u>	Q ₇₋₁₀ Basis	<u>USGS Gage 01552500, Muncy Creek near Sonestown (1942-2008)</u>
Elevation (ft)	<u>605</u>	Slope (ft/ft)	<u>0.003</u>
Watershed No.	<u>5-C</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>N/A</u>	Existing Use Qualifier	<u>N/A</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Impaired</u>	Name _____	
Cause(s) of Impairment	<u>PATHOGENS</u>	Distance from Outfall (mi) _____	
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>	Approx. 9	
TMDL Status	<u>Not Developed</u>		
Nearest Downstream Public Water Supply Intake	<u>Suez Water PA @ Bloomsburg</u>		
PWS Waters	<u>Fishing Creek</u>		

Comments:

The discharge is not expected to be contributing to the impairment to Little Fishing Creek from Pathogens. The permittee generally meets its fecal coliform limitations which are identical to the prior Fecal Coliform criteria from Chapter 93 of the Department's regulations.

The discharge is not expected to affect any downstream water supply at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
Treatment Facility Name: Millville Borough				
WQM Permit No.	Issuance Date	Permit For:		
1900405	A-2 – 2/6/25 A-1 – 5/28/19 Original – 1/23/01	Replacement of Grinder unit with spiral sieve screen Addition of step feed system to existing STP Construction of new STP		
1906401	6/15/06 5/28/19	Hydraulic Rerate from 0.25 to 0.3 MGD Incorporation of Step Feed process		
1909402	11/16/09	Transfer of Sewer Extensions		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Activated Sludge	Ultraviolet	0.3
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.3	800	Not Overloaded	Anaerobic Digestion	Combination of methods

Changes Since Last Permit Issuance: WQM 1900405 Amendment No. 2 was issued on February 6, 2025.

Other Comments: The existing treatment facility, as permitted under WQM Permit Nos. 1900405 and 1906401 consists of a septic receiving station, bar screen and comminutor, influent pump station, vortex grit removal chamber, primary clarifier, single stage nitrification-denitrification biological treatment, secondary clarifiers, UV disinfection, cascade aeration, aerobic digestion, belt filter press.

Compliance History

DMR Data for Outfall 001 (from August 1, 2024 to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.177	0.217	0.264	0.162	0.165	0.156	0.135	0.169	0.131	0.136	0.130	0.192
Flow (MGD) Daily Maximum	0.356	0.501	0.514	0.305	0.431	0.282	0.216	0.304	0.285	0.225	0.154	0.385
pH (S.U.) Instantaneous Minimum	6.6	6.5	6.5	6.5	6.5	6.1	6.0	6.1	6.1	6.2	6.2	6.5
pH (S.U.) Instantaneous Maximum	7.1	6.9	7.0	6.9	6.9	7.1	6.7	6.8	6.6	7.2	7.0	7.0
DO (mg/L) Instantaneous Minimum	10.9	10.2	10.9	10.4	10.1	9.7	10.3	10.1	10.2	10.1	10.2	10.6
CBOD5 (lbs/day) Average Monthly	< 5	5	7	7	7	18	< 3	3.6	< 2	3.5	2.4	4
CBOD5 (lbs/day) Weekly Average	7	10	10	11	10	44	4	7.0	< 2	6.5	3.4	6
CBOD5 (mg/L) Average Monthly	< 3	3	< 3	5	6	15	< 3	< 3	< 2	4	2.1	3
CBOD5 (mg/L) Weekly Average	4	5	4	7	9	39	4	7	2	6	2.3	3
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	234	339	332	216	176	323.2	210	229.7	209.6	240	267.3	659
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	366	714	609	364	245.2	381.2	259	271	364.3	451	349	1277
BOD5 (mg/L) Raw Sewage Influent Average Monthly	187	177	199	194	117	236	205	187	189	235	240	346
TSS (lbs/day) Average Monthly	27	15	33	30	15	21	6	15.1	11	22	12	12
TSS (lbs/day) Raw Sewage Influent Average Monthly	275	356	219	153.5	149.5	432.7	346	302.3	315.6	303.3	467	1912
TSS (lbs/day) Raw Sewage Influent Daily Maximum	330	745	290	171	237.2	799.8	610	699.8	348.7	441	1080	5767

NPDES Permit Fact Sheet
Millville Borough Sewer System STP

NPDES Permit No. PA0024091

TSS (lbs/day) Weekly Average	42	23	51	47	55	34	7	28.3	15	36	16	16
TSS (mg/L) Average Monthly	18	10	13	22	19	17	6	11	12	23	10.3	9
TSS (mg/L) Raw Sewage Influent Average Monthly	201	183	247	126	101	361	379	246	322	308	459	1189
TSS (mg/L) Weekly Average	21	15	22	30	30	30	7	19	16	36	15	12
Total Dissolved Solids (mg/L) Average Quarterly		832			946			1530			2960	
Fecal Coliform (No./100 ml) Average Monthly	2	4	34	< 5	100.3	126	4	4	< 1	62	32	9
Fecal Coliform (No./100 ml) Instantaneous Maximum	4	9	2419	32	248	2419.5	9.6	14.8	2	770.1	235.9	248
UV Intensity (mW/cm ²) Instantaneous Minimum	3.2	4.3	2.7	2.2	1.5	0.86	1.9	2.1	1.2	1.3	1.5	1.7
Total Nitrogen (mg/L) Average Monthly	5.9	4.55	3.06	13.2	18.8	33	21	22	36	66	37	9
Ammonia (lbs/day) Average Monthly	< 0.1	0.4	< 0.1	2	6	9	< 1	1.46	0.1	< 0.6	0.16	2
Ammonia (lbs/day) Weekly Average	0.2	0.9	1	6	9	20	2	4.12	0.2	< 0.9	0.37	5
Ammonia (mg/L) Average Monthly	< 0.1	0.21	< 0.6	< 2	5	11	< 1	1	0.129	< 1	< 0.151	2.0
Ammonia (mg/L) Weekly Average	< 0.1	0.44	1	6	8	23	2	3	0.144	< 1	< 0.256	5.0
Total Phosphorus (mg/L) Average Monthly	0.44	0.031	0.42	0.33	9	12	6	5	4	5.2	2	0.2
Total Copper (mg/L) Average Monthly	0.017	0.023	0.011	0.018	0.014	0.014	0.005	0.025	0.030	0.040	0.018	< 0.010
Total Copper (mg/L) Daily Maximum	0.035	0.031	0.018	0.023	0.021	0.024	0.008	0.033	0.051	0.056	0.022	< 0.020
Sulfate (mg/L) Average Quarterly		146			127			267			439	
Total Zinc (mg/L) Average Monthly	0.051	0.058	0.033	0.047	0.026	0.046	0.049	0.145	0.1	0.1	0.068	0.05
Total Zinc (mg/L) Daily Maximum	0.059	0.096	0.039	0.064	0.027	0.066	0.062	0.269	0.144	0.14	0.075	0.07

NPDES Permit Fact Sheet
Millville Borough Sewer System STP

NPDES Permit No. PA0024091

1,4-Dioxane (mg/L) Average Quarterly		0.343			< 50			< 50			< 50	
Chloride (mg/L) Average Quarterly		332			355			727			12500	
Bromide (mg/L) Average Quarterly		< 1			1.02			1.74			3.3	

Compliance History

Effluent Violations for Outfall 001, from: August 1, 2024 to July 31, 2025

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
CBOD5	02/28/25	Avg Mo	15	mg/L	13	mg/L
CBOD5	02/28/25	Wkly Avg	39	mg/L	20	mg/L
Ammonia	02/28/25	Wkly Avg	23	mg/L	18	mg/L
Fecal Coliform	05/31/25	IMAX	2419	No./100 ml	1000	No./100 ml

Compliance History, Cont'd

Summary of Inspections:	The most recent inspection of the facility by the Department on July 16, 2025 identified eDMR discharge violations but no operational violations at the time of inspection.
Other Comments:	A WMS query found the open violations in eFACTS as listed in the attached table for Millville Borough. See Attachment B.

Existing Effluent Limitations and Monitoring Requirements

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0	XXX	XXX	XXX	1/week	Grab
CBOD5	33	50	XXX	13	20	26	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	75	113	XXX	30	45	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Dissolved Solids	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	1/week	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Metered
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Ammonia Nov 1 - May 31	30	45	XXX	12	18	24	1/week	24-Hr Composite
Ammonia Jun 1 - Oct 31	10	15	XXX	4.0	6.0	8	1/week	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Copper	XXX	XXX	XXX	0.052	0.081 Daily Max	XXX	1/week	24-Hr Composite
Sulfate	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Zinc	XXX	XXX	XXX	0.2	0.3 Daily Max	0.5	1/week	24-Hr Composite
1,4-Dioxane	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Chloride	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Bromide	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.3
 Latitude 41° 6' 46.90" Longitude -76° 31' 40.10"
 Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)

Comments: The above limits are applicable and are included in the existing permit besides a more stringent exiting water quality-based limit for CBOD₅ as noted below.

Water Quality-Based Limitations

DO, CBOD₅ and NH₃-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. The discharge has existing limits water quality-based limits for CBOD₅, NH₃-N, and DO as listed on the previous page. WQM7.0 modeling was performed (see Attachment B) for the discharge to the Little Fishing Creek and showed that no limitations are necessary for these parameters beyond the existing limitations.

Water Quality Toxics Management

A "Reasonable Potential Analysis" was performed to determine additional parameters with the reasonable potential to violate water quality standards (see the Toxics Management Spreadsheet, Attachment D). The Toxics Management Spreadsheet (TMS) is a mass-balance water quality analysis model that includes consideration for mixing and other factors to determine recommended water quality-based effluent limits. The model incorporates the water quality criteria of 25 Pa. Code §93.

The TMS recommended that Total Copper and Total Zinc limitations as well as Chloride monitoring continue and thus will remain. The limit for Total Copper is more stringent while the Total Zinc limit is less stringent. Chloride monitoring will now be monthly rather than quarterly.

Pollutant	Long-Term Average (µg/L)	Actual Maximum (µg/L)	Existing Limitation (µg/L)	WQBEL (µg/L)	TMS Recommendation
Total Copper	0.021	0.084	0.052	0.045	Limitation
Total Zinc	0.056	0.30	0.2	0.39	Limitation
Chloride	1667	12,500	Reporting	10,078	Reporting

In addition, due to the receipt of flows from the landfill and the downstream water supply intake the existing monitoring for 1-4-Dioxane, Bromide, Chloride, and Sulfates will continue.

Chesapeake Bay/Nutrient Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania in order to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. Catawissa Borough is considered a Phase 4, Non-Significant Chesapeake Bay discharger and thus has received no nutrient cap loads pursuant to the Phase III Watershed Implementation Plan. Monitoring performed over the past permit term for Total Nitrogen and Total Phosphorus has averaged 23.9 mg/L and 3.2 mg/L, respectively. Monthly monitoring will continue consistent with the Phase III WIP for this Phase 4 discharge.

E. Coli Monitoring

Consistent with recent changes to Chapter 93 of the Department's regulations quarterly E. Coli monitoring will be included in the draft permit.

Best Professional Judgment (BPJ) Limitations

Comments: No additional BPJ limitations are necessary at this time beyond the technology and water quality-based limitations noted above.

Anti-Backsliding

No proposed limitations have been made less stringent consistent with the Anti-degradation requirements of The Clean Water Act and 40 CFR 122.44(l) except for a less stringent water-quality based limitation for Total Zinc.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	6.0	XXX	XXX	XXX	1/week	Grab
CBOD5	33	50	XXX	13	20	26	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	75	113	XXX	30	45	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Total Dissolved Solids	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	1/week	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Metered
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Ammonia Nov 1 - May 31	30	45	XXX	12	18	24	1/week	24-Hr Composite
Ammonia Jun 1 - Oct 31	10	15	XXX	4.0	6.0	8	1/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Total Copper	0.11	0.18 Daily Max	XXX	0.045	0.071 Daily Max	0.11	1/week	24-Hr Composite
Sulfate	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Zinc	0.97	1.51 Daily Max	XXX	0.39	0.61 Daily Max	0.97	1/week	24-Hr Composite
1,4-Dioxane	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Chloride	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/month	24-Hr Composite
Bromide	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
E. Coli (No./100 ml)	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/quarter	Grab


Compliance Sampling Location: Outfall 001

Other Comments: Limitations have been modified for Total Copper and Total Zinc. Chloride monitoring is now monthly rather than quarterly, and E. Coli monitoring is new.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment C)
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment D)
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input checked="" type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP:
<input type="checkbox"/>	Other:

Attachments:

- Discharge Location Map
- Open Violations List
- WQM7.0 Model
- Toxics Management Spreadsheet



Open Violations for Millville Borough

CLIENT	FACILITY	PF KIND	INSP PROGRAM	PROGRAM	VIOLATION	VIOLATION
				SPECIFIC ID		
MILLVILLE BORO	MILLVILLE MUNI WATER AUTH	Water Purveyor	Water Planning and Conservation	101484-001	11/30/2023	Reporting for all water withdrawals and 110.301 usage
MILLVILLE BORO	MILLVILLE MUNI WATER AUTH	Water Purveyor	Water Planning and Conservation	101484-001	11/20/2024	Reporting for all water withdrawals and 110.301 usage
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	3/25/2025 B6A	OTHER VIOLATIONS DEEMED TO BE SIGNIFICANT DEFICIENCIES FAILURE OF A CWS TO DEVELOP AND/OR UPDATE AN EMERGENCY RESPONSE PLAN
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	3/25/2025 D6E	FAILURE TO OPERATE AND MAINTAIN THE WATER SYSTEM FAILURE TO SUBMIT AN ANNUAL SOURCE WATER PROTECTION PROGRAM UPDATE FORM
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	3/25/2025 D2J	FAILURE TO PREPARE AND/OR MAINTAIN A SYSTEM MAP
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	3/25/2025 D6D	FAILURE OF A CWS TO PERFORM A SYSTEM EVALUATION ANNUALLY
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	3/25/2025 C8A	FAILURE TO IMPLEMENT A FILTER BED EVALUATION PROGRAM
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	3/25/2025 C3E	FAILURE TO COMPLY WITH A PERMIT CONDITION
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	3/25/2025 C7	FAILURE OF A COMMUNITY WATER SYSTEM TO DEVELOP AND/OR UPDATE AN OPERATION AND MAINTENANCE PLAN
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	3/25/2025 D6A	FAILURE OF A COMMUNITY WATER SYSTEM TO PREPARE AND/OR MAINTAIN A MONTHLY OPERATING REPORT
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	8/18/2025 D4A	CHRONIC FAILURE TO REPORT FAILURE TO PROVIDE RECORDS OR DATA REQUESTED BY THE DEPARTMENT OR ALLOW THE DEPARTMENT TO CONDUCT
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	8/18/2025 D10	CHRONIC FAILURE TO REPORT
MILLVILLE BORO	MILLVILLE MUNICIPAL AUTHORITY	Community	Safe Drinking Water	4190017	8/20/2025 B6C	CHRONIC FAILURE TO REPORT

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05C	27657	LITTLE FISHING CREEK	8.400	605.00	42.10	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	Stream pH	Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.050	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Millville Boro	PA0024091	0.3000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		13.00	2.00	0.00	1.50		
Dissolved Oxygen		6.00	8.24	0.00	0.00		
NH3-N		4.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05C	27657	LITTLE FISHING CREEK	6.800	580.00	50.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.050	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	8.24	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
05C			27657			LITTLE FISHING CREEK						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
8.400	2.12	0.00	2.12	.4641	0.00296	.629	27.35	43.52	0.15	0.650	20.90	7.00
Q1-10 Flow												
8.400	1.36	0.00	1.36	.4641	0.00296	NA	NA	NA	0.12	0.791	21.27	7.00
Q30-10 Flow												
8.400	2.89	0.00	2.89	.4641	0.00296	NA	NA	NA	0.17	0.562	20.69	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
05C	27657	LITTLE FISHING CREEK		
<u>RMI</u> 8.400	Total Discharge Flow (mgd) 0.300	Analysis Temperature (°C) 20.897	Analysis pH 7.000	
<u>Reach Width (ft)</u> 27.354	<u>Reach Depth (ft)</u> 0.629	<u>Reach WDRatio</u> 43.516	<u>Reach Velocity (fps)</u> 0.150	
<u>Reach CBOD5 (mg/L)</u> 3.97	<u>Reach Kc (1/days)</u> 0.693	<u>Reach NH3-N (mg/L)</u> 0.72	<u>Reach Kn (1/days)</u> 0.750	
<u>Reach DO (mg/L)</u> 7.840	<u>Reach Kr (1/days)</u> 4.320	<u>Kr Equation</u> Tsivoglou	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.650	Subreach Results			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.065	3.79	0.68	7.75
	0.130	3.62	0.65	7.70
	0.195	3.45	0.62	7.68
	0.260	3.29	0.59	7.68
	0.325	3.14	0.56	7.70
	0.390	3.00	0.54	7.72
	0.455	2.86	0.51	7.76
	0.520	2.73	0.49	7.80
	0.585	2.60	0.46	7.84
	0.650	2.49	0.44	7.88

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
05C	27657	LITTLE FISHING CREEK

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	8.400 Millville Boro	15.08	8	15.08	8	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	8.400 Millville Boro	1.8	4	1.8	4	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	8.40 Millville Boro	13	13	4	4	6	6	0	0

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
05C	27657	LITTLE FISHING CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
8.400	Millville Boro	PA0024091	0.300	CBOD5	13		
				NH3-N	4	8	
				Dissolved Oxygen			6

Discharge Information

Instructions **Discharge** **Stream**

Facility: **Millville Borough** NPDES Permit No.: **PA0020491** Outfall No.: **001**

Evaluation Type: **Custom / Additives** Wastewater Description: **Sewage Effluent**

Discharge Characteristics							
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀
0.3	100	7					

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank		1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Sulfate (PWS)	mg/L	287									
1,4-Dioxane	µg/L	< 3									
Chloride (PWS)	mg/L	1730									
Bromide	mg/L	365									
Total Copper	mg/L	0.06									
Total Zinc	mg/L	0.51									

Stream / Surface Water Information

Millville Borough, NPDES Permit No. PA0020491, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Little Fishing Creek**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	027657	8.4	605	42.1			Yes
End of Reach 1	027657	3	470	362		5	Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	8.4	0.0504										100	7		
End of Reach 1	3	0.0504													

Q_h

Location	RMI	LFY (cfs/mi ²)	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	8.4														
End of Reach 1	3														

Model Results

Millville Borough, NPDES Permit No. PA0020491, Outfall 001

[Instructions](#)

[Results](#)

[RETURN TO INPUTS](#)

[SAVE AS PDF](#)

[PRINT](#)

All

Inputs

Results

Limits

Hydrodynamics

Q₇₋₁₀

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
8.4	2.12		2.12	0.464	0.005	0.624	26.491	42.439	0.156	2.11	19.084
3	18.24	7.735	10.5098								

Q_h

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
8.4	14.34		14.34	0.464	0.005	1.345	26.491	19.695	0.415	0.794	8.408
3	94.021	7.735	86.29								

Wasteload Allocations

AFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	13.439	14.0	70.7	Chem Translator of 0.96 applied
Total Zinc	0	0		0	117.180	120	605	Chem Translator of 0.978 applied

CFC

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	8.956	9.33	52.0	Chem Translator of 0.96 applied
Total Zinc	0	0		0	118.139	120	668	Chem Translator of 0.986 applied

THH

CCT (min): 19.084

THH PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

PWS PMF: 1

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Sulfate (PWS)	0	0		0	250,000	250,000	10,078,054	WQC applied at RMI 3 with a design stream flow of 18.2448 cfs
Chloride (PWS)	0	0		0	250,000	250,000	10,078,054	WQC applied at RMI 3 with a design stream flow of 18.2448 cfs
Total Copper	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

 CRL

CCT (min): 8.408

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

 Recommended WQBELs & Monitoring RequirementsNo. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Chloride (PWS)	Report	Report	Report	Report	Report	mg/L	10,078	THH-PWS	Discharge Conc > 10% WQBEL (no RP)
Total Copper	0.11	0.18	0.045	0.071	0.11	mg/L	0.045	AFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Zinc	0.97	1.51	0.39	0.61	0.97	mg/L	0.39	AFC	Discharge Conc ≥ 50% WQBEL (RP)

 Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Sulfate (PWS)	10,078	mg/L	Discharge Conc ≤ 10% WQBEL
1,4-Dioxane	N/A	N/A	No WQS
Bromide	N/A	N/A	No WQS