

Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0024392  
APS ID 1021100  
Authorization ID 1322756

**Applicant and Facility Information**

Applicant Name	<u>Rouseville Borough</u>	Facility Name	<u>Rouseville Borough STP</u>
Applicant Address	<u>P.O. Box 317</u> <u>Rouseville, PA 16344-0317</u>	Facility Address	<u>Route 8 South, Main Street</u> <u>Rouseville, PA 16344</u>
Applicant Contact	<u>Joe Dengel Administrator</u>	Facility Contact	<u>Joe Dengel</u>
Applicant Phone	<u>(814) 677-3056</u>	Facility Phone	<u>(814) 677-3056</u>
Client ID	<u>75173</u>	Site ID	<u>533136</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Cornplanter Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Venango</u>
Date Application Received	<u>July 31, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 13, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for an existing discharge of treated municipal sewage.</u>		

**Summary of Review**

This is a municipal POTW treated domestic wastewater from Rouseville Borough, Venango County.

This facility discharges to Oil Creek, which is known to contain threatened and endangered mussel species. A summary of threatened and endangered mussel species concerns and considerations is included on Page 9 of this Fact Sheet.

There are currently no open violations listed in EFACTS for this permittee (5/09/2023). [5/16/2023 CWY](#)

Sludge use and disposal description and location(s): Sludge is hauled offsite and disposed of at the Franklin WWTP.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Adam J. Pesek Adam J. Pesek, E.I.T. / Project Manager	May 9, 2023
X		Chad W. Yurismic Chad W. Yurismic, P.E. / Environmental Engineer Manager	5/16/2023

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.24</u>
Latitude	<u>41° 27' 37"</u>	Longitude	<u>-79° 41' 24"</u>
Quad Name	<u>Oil City</u>	Quad Code	<u>0708</u>
Wastewater Description: <u>Sewage Effluent</u>			

Receiving Waters	<u>Oil Creek</u>	Stream Code	<u>54128</u>
NHD Com ID	<u>100475857</u>	RMI	<u>2.62</u>
Drainage Area	<u>314</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.10</u>
Q <sub>7-10</sub> Flow (cfs)	<u>31.5</u>	Q <sub>7-10</sub> Basis	<u>USGS #03020500 ('34-'08)</u>
Elevation (ft)	<u>1.002</u>	Slope (ft/ft)	<u>0.00421</u>
Watershed No.	<u>16-E</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>

Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>MERCURY</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u>Pending</u>	Name	<u></u>

Background/Ambient Data		Data Source	
pH (SU)	<u>7.55</u>	WQN 868	<u></u>
Temperature (°C)	<u>25</u>	Default	<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other: NH <sub>3</sub> -N	<u>0.026</u>	WQN 868	<u></u>
Other: CBOD <sub>5</sub>	<u>1.1</u>	WQN 868	<u></u>

Nearest Downstream Public Water Supply Intake	<u>Aqua Pennsylvania, Inc. – Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1450</u>
PWS RMI	<u>90</u>	Distance from Outfall (mi)	<u>40</u>

Changes Since Last Permit Issuance:

Other Comments:

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Rouseville Borough STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
6102401		4/01/2002		
6110402		3/09/2011		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary With Ammonia Reduction	Sequencing Batch Reactor	Hypochlorite	0.24
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
0.24	454	Not Overloaded	Aerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: A permit amendment application for WQM permit No. 6110402 was submitted on 3/14/2023 for obtaining and incorporating a portable septage receiving station at the facility.

Other Comments:

Compliance History	
<b>Summary of Inspections:</b>	Last site inspection was conducted on 4/28/2021. The inspection report noted the Borough was working on a GIS map of the collection system and working on and I/I maintenance schedule. Smoke testing and line jetting were also being performed. The report also noted that the effluent actuator was not working in SBR 1, which should be fixed as well as cleaning out the chlorine contact tanks.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from March 1, 2022 to February 28, 2023)

Parameter	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22
Flow (MGD) Average Monthly	0.137	0.142	0.0021	0.0	0.017	0.090	0.058	0.078	0.089	0.179	0.193	0.203
Flow (MGD) Daily Maximum	0.351	0.478	0.047	0.0	0.078	0.338	0.105	0.123	0.184	0.541	0.344	0.692
pH (S.U.) Minimum	6.2	6.5	6.3	6.5	6.6	6.6	6.7	6.6	6.5	6.5	6.7	6.7
pH (S.U.) Maximum	6.9	7.1	7.6	7.0	7.1	7.1	7.2	7.2	7.1	7.0	7.1	8.5
DO (mg/L) Minimum	6.6	4.9	4.9	4.2	4.3	4.6	4.4	4.2	5.1	5.4	7.8	8.5
TRC (mg/L) Average Monthly	0.13	0.35	0.3	0.37	0.35	0.21	0.17	0.21	0.28	0.27	0.22	0.4
TRC (mg/L) Instantaneous Maximum	0.3	1.3	0.97	1.03	1.46	0.45	0.28	0.35	1.0	0.94	0.49	2.0
CBOD5 (lbs/day) Average Monthly	5	6	1	48	3	7	8	4	6	10	14	16
CBOD5 (lbs/day) Weekly Average	5	9	2	49	6	9	10	8	9	13	19	47
CBOD5 (mg/L) Average Monthly	4	4	3	8	10	8	15	6	10	8	7	7
CBOD5 (mg/L) Weekly Average	6	8	5	13	12	14	18	18	20	12	8	11
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	75	17	10	382	12	30	21	< 19	30	45	118	60
BOD5 (lbs/day) Raw Sewage Influent   Daily Maximum	180	42	19	430	25	68	28	< 30	37	63	235	139
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	48.9	16.1	74.9	50.3	48.4	26	37	< 28	45	35	64	32
TSS (lbs/day) Average Monthly	11	40	1	58	2	10	5	6	10	11	29	62

**NPDES Permit Fact Sheet  
Rouseville Borough STP**

**NPDES Permit No. PA0024392**

TSS (lbs/day) Raw Sewage Influent   Average Monthly	77	48	1	525	38	46	43	29	66	57	134	68
TSS (lbs/day) Raw Sewage Influent   Daily Maximum	123	71	2	751	38	90	60	47	100	82	243	109
TSS (lbs/day) Weekly Average	8	98	2	75	5	25	7	13	20	18	55	219
TSS (mg/L) Average Monthly	7	25	7	11	7	8	8	11	19	7	14	23
TSS (mg/L) Raw Sewage Influent   Average Monthly	63	40	7	95	87	44	73	41	95	52	75	48
TSS (mg/L) Weekly Average	9	67	11	13	9	10	12	28	42	9	22	38
Fecal Coliform (CFU/100 ml) Geometric Mean	10	10	10	26	49	239	63	710	19	53	318	1457
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	10	10	10	703	5900	7000	390	93000	126	6727	1100	27000
Total Nitrogen (lbs/day) Average Quarterly			1			2			2			14
Total Nitrogen (mg/L) Average Quarterly			3.13			0.354			2.31			9.2
Ammonia (lbs/day) Average Monthly	0.4	0.1	0.0008	7	0.4	0.3	0.06	< 0.1	1	0.10	0.2	51.05
Ammonia (mg/L) Average Monthly	0.2	0.1	0.5	0.8	0.8	0.354	0.1	< 0.2	2.0	0.10	0.14	1.05
Total Phosphorus (lbs/day) Average Quarterly			0.06			0.06			0.1			0.4
Total Phosphorus (mg/L) Average Quarterly			0.16			0.1			0.17			0.28

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>0.24</u>
<b>Latitude</b> <u>41° 27' 37.00"</u>	<b>Longitude</b> <u>-79° 41' 24.00"</u>
<b>Wastewater Description:</b> <u>Treated domestic sewage</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX	-	92a.61

Comments: Monitoring for E. coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
N/A			

Comments: No WQBELs were calculated as a result of WQM modeling.

**Best Professional Judgment (BPJ) Limitations**

Comments: Monitoring for influent BOD<sub>5</sub> and influent TSS is placed in the permit in accordance with the Department's SOP entitled "New and Reissuance Individual Sewage NPDES Permit Applications."

A minimum D.O. limit of 4.0 mg/l, an IMAX TRC limit of 1.6 mg/l, and monitoring for ammonia nitrogen, total nitrogen, and total phosphorus are placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Discharges."

**Mercury Impairment**

The receiving stream reach is impaired for total mercury. Due to this impairment, an evaluation of the effluent was conducted to determine if monitoring was necessary in the renewed permit. Below is effluent sampling results from the renewal application that was used for the evaluation.

Unit	Most stringent criteria	Sample 1	Sample 2	Sample 3
ug/l	0.05	0.0021	0.0027	0.0035

As can be seen from the table, all three effluent results were well below the most stringent WQ criterion for total mercury. Therefore, the Department has no reason to believe that this discharge is contributing to the impairment. No monitoring will be placed in the proposed renewed permit for total mercury.

5/20/2023

6/4/2023

**Anti-Backsliding**

N/A



This segment of Oil Creek is known to also contain federal and state listed threatened and endangered mussel species. Due to the Outfall 001 discharging directly to Oil Creek, potential impacts to endangered mussel species were evaluated.

The USFWS has indicated in comment letters and email correspondence on other NPDES permits, that to protect threatened and endangered mussel species, wastewater discharges containing ammonia-nitrogen (NH<sub>3</sub>-N), chloride (Cl<sup>-</sup>) dissolved nickel, dissolved zinc, and total copper where mussels or their habitat exist, can be no more than 1.9 mg/l, 78 mg/l, 7.3 µg/l, 13.18 µg/l, and 10 µg/l respectively. Therefore, the Department has considered all of these parameters in this evaluation.

The calculated site-specific criteria based on WQN Station 868 stream background pH data and default temperature for a WWF (pH of 7.55 and temperature of 25) results in NH<sub>3</sub>-N criteria of 0.965 mg/l.

The Department conducted a mussel survey on Oil Creek on June 11, 12 & 14, 2018, including in the vicinity and adjacent to this discharge. The findings of that survey were that no live mussels were collected within 200 meters below the discharge. One northern riffleshell was found on the right descending bank between 200 and 250 meters downstream of the discharge during the survey.

A summary of the sampling data for ammonia-nitrogen (NH<sub>3</sub>-N) and chloride (Cl<sup>-</sup>) are based on three samples at Outfall 001 for the 2020 renewal application, and one sample of total copper, dissolved nickel and dissolved zinc based from water chemistry data of this discharge provided in a Department Memo "Results of Water Chemistry Collections at National Pollution Discharge Elimination System (NPDES) Discharges – Freshwater Mussel Toxicity Study Allegheny River, Shenango River and French Creek Watersheds," dated March 6, 2023 as follows:

PARAMETER	UNITS	Outfall 001			Comments
		Max	Avg. Value	No. Samples	
NH <sub>3</sub> -N	mg/l	4.85	0.639	17	Renewal Application
NH <sub>3</sub> -N (additional)	mg/l	9.73	0.508		eDMR average monthly data from August 2020 to March 2023.
Chloride	mg/l	108	101.5	3	Renewal Application
Dissolved Nickel	µg/l	<8.0		1	
Dissolved Zinc	µg/l	26.1		1	
Total Copper	µg/l	4.51		1	

As can be seen from the sampling above, the total copper effluent concentration is below protective levels for threatened and endangered mussels.

The attached Mussel Impact Evaluation Sheet was used to determine the area of river that will be required to assimilate the maximum reported effluent concentrations of ammonia nitrogen, chloride, nickel, zinc, and copper to achieve pollutant concentrations that at or below the USFWS criteria in the river. The spreadsheet determined all parameters besides ammonia nitrogen had a calculated area of impact of less than one square meters. Using the maximum discharge concentration reported on the renewal application, the spreadsheet calculated an area of impact of up to 6.11 square meters due to ammonia nitrogen in low flow scenario.

Based on the fact that the closest known mussels downstream are over 200 meters downstream, there are no perceived impacts to threatened and endangered mussels due to this discharge. Additionally, please note that although the maximum concentration reported for ammonia nitrogen has a significant calculated area of impact, it should be noted that the long-term average concentration being discharged is below the site-specific criterion of 0.965 mg/l for protection of mussels.

Ammonia nitrogen will continue to be monitored in the renewed NPDES Permit. No additional requirements are recommended at this time due to threatened and endangered mussels in Oil Creek.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	50	80	XXX	25	40	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	60	90	XXX	30	45	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Ammonia	Report	XXX	XXX	Report	XXX	XXX	2/month	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date )

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location: Outfall 001 (after disinfection)

Other Comments:

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54128	OIL CREEK	2.620	1022.00	314.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	31.50	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.55	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Rouseville Boro	PA0024392	0.2400	0.0000	0.0000	0.000	20.00	6.80

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	1.10	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.03	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16E	54128	OIL CREEK	1.180	990.00	316.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.55	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16E		54128				OIL CREEK						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
2.620	31.50	0.00	31.50	.3713	0.00421	.927	84.65	91.34	0.41	0.217	24.94	7.53
<b>Q1-10 Flow</b>												
2.620	20.16	0.00	20.16	.3713	0.00421	NA	NA	NA	0.32	0.277	24.91	7.52
<b>Q30-10 Flow</b>												
2.620	42.84	0.00	42.84	.3713	0.00421	NA	NA	NA	0.48	0.183	24.96	7.53

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

**SWP Basin**      **Stream Code**                      **Stream Name**  
16E                      54128    OIL CREEK

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.620	Rouseville Boro	6.01	50	6.01	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.620	Rouseville Boro	.98	25	.98	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.62	Rouseville Boro	25	25	25	25	4	4	0	0



**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16E	54128	OIL CREEK		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.620	0.240	24.942	7.527	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
84.651	0.927	91.337	0.406	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
1.38	0.270	0.32	1.024	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.499	8.967	Tsivoglou	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.217	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.022	1.37	0.31	7.54
	0.043	1.36	0.31	7.54
	0.065	1.35	0.30	7.54
	0.087	1.34	0.29	7.54
	0.108	1.33	0.29	7.54
	0.130	1.32	0.28	7.54
	0.152	1.31	0.27	7.54
	0.173	1.30	0.27	7.54
	0.195	1.29	0.26	7.54
	0.217	1.28	0.26	7.54

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16E		54128		OIL CREEK			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.620	Rouseville Boro	PA0024392	0.240	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

1A	B	C	D	E	F	G
2	<b>TRC EVALUATION</b>					
3	Input appropriate values in B4:B8 and E4:E7					
4	31.5	= Q stream (cfs)		0.5	= CV Daily	
5	0.24	= Q discharge (MGD)		0.5	= CV Hourly	
6	30	= no. samples		0.24	= AFC_Partial Mix Factor	
7	0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
8	0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
9	0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
	0	= % Factor of Safety (FOS)		0	= Decay Coefficient (K)	
10	Source	Reference	AFC Calculations		Reference	CFC Calculations
11	TRC	1.3.2.iii	WLA_afc = 6.514		1.3.2.iii	WLA_cfc = 26.397
12	PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
13	PENTOXSD TRG	5.1b	LTA_afc = 2.427		5.1d	LTA_cfc = 15.346
14						
15	Source	Effluent Limit Calculations				
16	PENTOXSD TRG	5.1f	AML_MULT = 1.231			
17	PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.500		BAT/BPJ	
18			INST_MAX_LIMIT (mg/l) = 1.635			
	WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
	LTA_afc	wla_afc * LTAMULT_afc				
	WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
	LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
	LTA_cfc	wla_cfc * LTAMULT_cfc				
	AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
	AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
	INST_MAX_LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

**Rouseville Borough STP**

Cornplanter Township, Venango County  
PA0024392

Discharge pH

Outfall 001

<u>Date</u>	<u>pH min</u>	<u>pH max</u>	<u>10<sup>-pH min</sup></u>	<u>10<sup>-pH max</sup></u>	<u>&amp; pH max)</u>	<u>-Log (Ave pH)</u>
Jul-20	6.9	7.2	1.26E-07	6.31E-08	9.45E-08	<b>7.0</b>
Aug-20	6.8	7.2	1.58E-07	6.31E-08	1.11E-07	<b>7.0</b>
Sep-20	6.7	7.1	2E-07	7.94E-08	1.39E-07	<b>6.9</b>
Jul-21	6.6	6.9	2.51E-07	1.26E-07	1.89E-07	<b>6.7</b>
Aug-21	6.6	6.9	2.51E-07	1.26E-07	1.89E-07	<b>6.7</b>
Sep-21	6.5	7.0	3.16E-07	1E-07	2.08E-07	<b>6.7</b>
Jul-22	6.6	7.2	2.51E-07	6.31E-08	1.57E-07	<b>6.8</b>
Aug-22	6.7	7.2	2E-07	6.31E-08	1.31E-07	<b>6.9</b>
Sep-22	6.6	7.1	2.51E-07	7.94E-08	1.65E-07	<b>6.8</b>
					Median:	<b>6.8</b>

Outfall 001

Facility:	Rouseville Boro STP		
Permit Number:	PA0024392	Effective:	Expiration:
Outfall No:	001		
Location:	Cornplanter Township, Venango County		
Discharge to:	Oil Creek		
Site Specific Mussel Survey Completed:	No		
Discharge and Stream Characteristics		Comments	
Q <sub>S</sub>	Stream Flow	20 MGD / 31.5 cfs	
Q <sub>D</sub>	Discharge Flow	0.24 MGD / 0.37139 cfs	
C <sub>S(Cl)</sub>	Instream chloride Concentration	16.77 mg/L	9/12/2017 sample at WQN #868
C <sub>E(Cl)</sub>	Discharge chloride (existing)	108 mg/L	Maximum value from 2020 NPDES Renewal Application
C <sub>P(Cl)</sub>	Discharge chloride (proposed)	108 mg/L	Maximum value from 2020 NPDES Renewal Application
C <sub>S(Ni)</sub>	Instream nickel Concentration	2 µg/L	Average of three instream samples taken on 8/8, 8/19, and 8/29/2022 (< 0.002, < 0.002, and 0.002 mg/L) in Plum Boro, Allegheny County.
C <sub>E(Ni)</sub>	Discharge nickel (existing)	8 µg/L	Fall 2022 discharge sample collected by the Department
C <sub>P(Ni)</sub>	Discharge nickel (proposed)	8 µg/L	Fall 2022 discharge sample collected by the Department
C <sub>S(Zn)</sub>	Instream zinc Concentration	5 µg/L	9/12/2017 sample on the Allegheny River above Oil City (<5 ug/l)
C <sub>E(Zn)</sub>	Discharge zinc (existing)	26.1 µg/L	Fall 2022 discharge sample collected by the Department
Zn <sub>P(Zn)</sub>	Discharge zinc (proposed)	26.1 µg/L	Fall 2022 discharge sample collected by the Department
C <sub>S(Cu)</sub>	Instream copper Concentration	4 µg/L	9/12/2017 sample at WQN #868
C <sub>E(Cu)</sub>	Discharge copper (existing)	4.51 µg/L	Fall 2022 discharge sample collected by the Department
Zn <sub>P(Cu)</sub>	Discharge copper (proposed)	4.51 µg/L	Fall 2022 discharge sample collected by the Department
C <sub>S(NH3-N)</sub>	Instream NH <sup>3</sup> -N	0.026 mg/L	WQN #868
C <sub>E(NH3-N)</sub>	Discharge NH <sup>3</sup> -N (existing)	9.73 mg/L	Maximum value from 2020 NPDES Renewal Application
C <sub>P(NH3-N)</sub>	Discharge NH <sup>3</sup> -N (proposed)	9.73 mg/L	Maximum value from 2020 NPDES Renewal Application
pH <sub>S</sub>	Instream pH	7.55 S.U.	WQN #868
T <sub>S</sub>	Instream Temp.	25 °C	Default value for a WWF
C <sub>C(NH3-N)</sub>	Ammonia criteria	0.965 mg/L	From ammonia criteria comparison spreadsheet -using Instream pH and Temp
C <sub>C(Cl)</sub>	Chloride criteria	78 mg/L	USFWS criteria
C <sub>C(Ni)</sub>	Nickel criteria	7.3 µg/L	USFWS criteria
C <sub>C(Zn)</sub>	Zinc criteria	13.18 µg/L	USFWS criteria
C <sub>C(Cu)</sub>	Copper criteria	10 µg/L	USFWS criteria
W <sub>S</sub>	Stream width	30.5 meters	Google Earth (Approximate)

**Ammonia Criteria Calculations:**

pH <sub>S</sub>	7.55 S.U.	(Default value is 7.0)
T <sub>S</sub>	25 °C	(Default value is 20 °C for a CWF and 25 °C for a WWF)
<b>Acute Criteria</b>		
	METHOD and UNITS	CRITERIA
	Old CMC (mg TAN/L) =	3.839
	EPA 2013 CMC (mg TAN/L) =	5.654
		Oncorhynchus present * formula on pg. 41 (plateaus at 15.7 C)
		Oncorhynchus absent * formula on pg. 42 (plateaus at 10.2 C)
<b>Chronic Criteria</b>		
	METHOD and UNITS	CRITERIA
	Old CMC (mg TAN/L) =	0.978
	C <sub>C(NH3-N)</sub> EPA 2013 CMC (mg TAN/L) =	0.965
		* formula on pg. 46 (plateaus at 7 C)

**Endangered Mussel Species Impact Area Calculations:**

**Existing Area of Impact**

N/A - No Site Specific Mussel Survey Completed for this Discharger

Approximate Area of Impact Determined from Survey =	N/A m <sup>2</sup>	(Enter N/A if no site specific survey has been completed)
Existing Mussel Density within Area of Impact =		
Rabbitsfoot ( <i>Quadrula cylindrica</i> )		per m <sup>2</sup>
Northern Riffleshell ( <i>Epioblasma torulosa rangiana</i> )		per m <sup>2</sup>
Rayed Bean ( <i>Villosa fabalis</i> )		per m <sup>2</sup>
Clubshell ( <i>Pleurobema clava</i> )		per m <sup>2</sup>
Sheepnose ( <i>Plethobasus cyphus</i> )		per m <sup>2</sup>
Snuffbox ( <i>Epioblasma triquetra</i> )		per m <sup>2</sup>
TOTAL		0 per m <sup>2</sup>

**Method 1 - Utilizing Site Specific Mussel Survey Information**

N/A - No Site Specific Mussel Survey Completed for this Discharger

This method utilizes a simple comparison of the size of the existing area of impact as determined from a site specific mussel survey and the chlorides in the existing discharge compared to the chlorides in the proposed discharge after the facility upgrades treatment technologies. This method is only applicable to where the stream impairment is caused by TDS and/or chlorides as the plume has been delineated through conductivity measurements.

A. Area of Impact Determined from Survey:	N/A	m <sup>2</sup>
B. Chlorides in Existing Discharge:		108 mg/L
C. Chlorides in Proposed Discharge after Treatment Facility Upgrade:		108 mg/L
D. Approximate Area of Impact after Treatment Facility Upgrades:		N/A m <sup>2</sup>

A/B = D/C      Therefore, D = (A\*C)/B

Outfall 001

Facility:	Rouseville Boro STP		
Permit Number:	PA0024392	Effective:	Expiration:
Outfall No:	001		
Location:	Cornplanter Township, Venango County		
Discharge to:	Oil Creek		
Site Specific Mussel Survey Completed:	No		

Endangered Mussel Species Impact Area Calculations: (continued...)

Method 2 - Mass Balance Relationship of Loading and Assimilative Capacity of Stream

Chloride (Cl <sup>-</sup> )	$L_{S(Cl)} = \text{Available Chloride Loading in Stream} = C_{Cl(Cl)} - C_{S(Cl)} \times Q_3(\text{MGD}) \times 8.34 =$	10,213 lbs/Day
	$L_{D-MAX(Cl)} = \text{Current Maximum Discharge Chloride Loading exceeding criteria} = (C_{E(Cl)} - C_{E(CL)}) \times Q_3(\text{MGD}) \times 8.34 =$	60 lbs/Day
	$\%E_{(Cl)} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(Cl)} / L_{S(Cl)} =$	1% of Stream Capacity
	$L_{D(Cl)} = \text{Proposed Discharge Cl}^- \text{ Loading exceeding criteria after Treatment Facility Upgrades} = (C_{P(Cl)} - C_{P(Cl)}) \times Q_3(\text{MGD}) \times 8.34 =$	60.048 lbs/Day
	$\%P_{(Cl)} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(Cl)} / L_{S(Cl)} =$	0.59% of Stream Capacity
	$\text{Proposed Area of Impact due to Chloride} * = (\%P_{(Cl)} \times W_s)^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	0.02 m <sup>2</sup>
Nickel (Ni)	$L_{S(Ni)} = \text{Available Nickel Loading in Stream} = C_{Cl(Ni)} - C_{S(Ni)} \times Q_3(\text{MGD}) \times 8.34 =$	884 lbs/Day
	$L_{D-MAX(Ni)} = \text{Current Maximum Discharge Nickel Loading exceeding criteria} = (C_{E(Ni)} - C_{E(Ni)}) \times Q_3(\text{MGD}) \times 8.34 =$	1 lbs/Day
	$\%E_{(Ni)} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(Ni)} / L_{S(Ni)} =$	0% of Stream Capacity
	$L_{D(Ni)} = \text{Proposed Discharge Ni Loading exceeding criteria after Treatment Facility Upgrades} = (C_{P(Ni)} - C_{P(Ni)}) \times Q_3(\text{MGD}) \times 8.34 =$	1.40112 lbs/Day
	$\%P_{(Ni)} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(Ni)} / L_{S(Ni)} =$	0.16% of Stream Capacity
	$\text{Proposed Area of Impact due to Nickel} * = (\%P_{(Ni)} \times W_s)^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	0.00 m <sup>2</sup>
Zinc (Zn)	$L_{S(Zn)} = \text{Available Zinc Loading in Stream} = C_{Cl(Zn)} - C_{S(Zn)} \times Q_3(\text{MGD}) \times 8.34 =$	1,364 lbs/Day
	$L_{D-MAX(Zn)} = \text{Current Maximum Discharge Zinc Loading exceeding criteria} = (C_{E(Zn)} - C_{E(Zn)}) \times Q_3(\text{MGD}) \times 8.34 =$	26 lbs/Day
	$\%E_{(Zn)} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(Zn)} / L_{S(Zn)} =$	2% of Stream Capacity
	$L_{D(Zn)} = \text{Proposed Discharge Zn Loading exceeding criteria after Treatment Facility Upgrades} = (C_{P(Zn)} - C_{P(Zn)}) \times Q_3(\text{MGD}) \times 8.34 =$	25.860672 lbs/Day
	$\%P_{(Zn)} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(Zn)} / L_{S(Zn)} =$	1.90% of Stream Capacity
	$\text{Proposed Area of Impact due to Zinc} * = (\%P_{(Zn)} \times W_s)^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	0.17 m <sup>2</sup>
Copper (Cu)	$L_{S(Cu)} = \text{Available Copper Loading in Stream} = C_{Cl(Cu)} - C_{S(Cu)} \times Q_3(\text{MGD}) \times 8.34 =$	1,001 lbs/Day
	$L_{D-MAX(Cu)} = \text{Current Maximum Discharge Copper Loading exceeding criteria} = (C_{E(Cu)} - C_{E(Cu)}) \times Q_3(\text{MGD}) \times 8.34 =$	-11 lbs/Day
	$\%E_{(Cu)} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(Cu)} / L_{S(Cu)} =$	0% of Stream Capacity
	$L_{D(Cu)} = \text{Proposed Discharge Cu Loading exceeding criteria after Treatment Facility Upgrades} = (C_{P(Cu)} - C_{P(Cu)}) \times Q_3(\text{MGD}) \times 8.34 =$	-10.988784 lbs/Day
	$\%P_{(Cu)} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(Cu)} / L_{S(Cu)} =$	-1.10% of Stream Capacity
	$\text{Proposed Area of Impact due to Copper} * = (\%P_{(Cu)} \times W_s)^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	0.06 m <sup>2</sup>
Ammonia-Nitrogen (NH3-N)	$L_{S(NH3-N)} = \text{Available NH3-N Loading in Stream} = C_{Cl(NH3-N)} - C_{S(NH3-N)} \times Q_3(\text{MGD}) \times 8.34 =$	157 lbs/Day
	$L_{D-MAX(NH3-N)} = \text{Current Maximum Discharge NH3-N Loading} = C_{E(NH3-N)} \times Q_3(\text{MGD}) \times 8.34 =$	19 lbs/Day
	$\%E_{(NH3-N)} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(NH3-N)} / L_{S(NH3-N)} =$	12% of Stream Capacity
	$L_{D(NH3-N)} = \text{Proposed Discharge NH3-N Loading after Treatment Facility Upgrades} = C_{P(NH3-N)} - C_{Cl(NH3-N)} \times Q_3(\text{MGD}) \times 8.34 =$	18 lbs/Day
	$\%P_{(NH3-N)} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(NH3-N)} / L_{S(NH3-N)} =$	11.46% of Stream Capacity
	$\text{Proposed Area of Impact due to NH3-N} * = (\%P_{(NH3-N)} \times W_s)^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	6.11 m <sup>2</sup>

Outfall 001

Facility:	Rouseville Boro STP		
Permit Number:	PA0024392	Effective:	Expiration:
Outfall No:	001		
Location:	Cornplanter Township, Venango County		
Discharge to:	Oil Creek		
Site Specific Mussel Survey Completed:	No		

Endangered Mussel Species Impact Area Calculations: (continued...)

Method 3 - Mass Balance Relationship of Stream Flow, Proposed Effluent Quality, and Mussel Protection Criteria

Chloride (Cl)	$Q_{A(Cl)}C_{S(Cl)} + Q_0C_{P(Cl)} = Q_T C_{C(Cl)}$		
	$Q_{A(Cl)} = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$		
	$Q_T = Q_S + Q_0 \text{ (cfs)}$		
	$Q_{A(Cl)}C_{S(Cl)} + Q_0C_{P(Cl)} = (Q_0+Q_S)C_{C(Cl)}$		
	SOLVING FOR $Q_{A(Cl)} = [(Q_0C_{P(Cl)} / C_{C(Cl)}) - Q_0] / (1 - C_{S(Cl)} / C_{C(Cl)}) =$	0.18196472 cfs	
	$\%P_{(Cl)} = \text{Percent of Stream Width Required to Assimilate Chlorides to Criteria}$		
	Concentration = $Q_{A(Cl)} / Q_S \text{ (cfs)} =$	0.5777%	
Nickel (Ni)	$Q_{A(Ni)}C_{S(Ni)} + Q_0C_{P(Ni)} = Q_T C_{C(Ni)}$		
	$Q_{A(Ni)} = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$		
	$Q_T = Q_S + Q_0 \text{ (cfs)}$		
	$Q_{A(Ni)}C_{S(Ni)} + Q_0C_{P(Ni)} = (Q_0+Q_S)C_{C(Ni)}$		
	SOLVING FOR $Q_{A(Ni)} = [(Q_0C_{P(Ni)} / C_{C(Ni)}) - Q_0] / (1 - C_{S(Ni)} / C_{C(Ni)}) =$	0.04905151 cfs	
	$\%P_{(Ni)} = \text{Percent of Stream Width Required to Assimilate Nickel to Criteria}$		
	Concentration = $Q_{A(Ni)} / Q_S \text{ (cfs)} =$	0.1557%	
Zinc (Zn)	$Q_{A(Zn)}C_{S(Zn)} + Q_0C_{P(Zn)} = Q_T C_{C(Zn)}$		
	$Q_{A(Zn)} = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$		
	$Q_T = Q_S + Q_0 \text{ (cfs)}$		
	$Q_{A(Zn)}C_{S(Zn)} + Q_0C_{P(Zn)} = (Q_0+Q_S)C_{C(Zn)}$		
	SOLVING FOR $Q_{A(Zn)} = [(Q_0C_{P(Zn)} / C_{C(Zn)}) - Q_0] / (1 - C_{S(Zn)} / C_{C(Zn)}) =$	0.58659643 cfs	
	$\%P_{(Zn)} = \text{Percent of Stream Width Required to Assimilate Zinc to Criteria}$		
	Concentration = $Q_{A(Zn)} / Q_S \text{ (cfs)} =$	1.8622%	
Copper (Cu)	$Q_{A(Cu)}C_{S(Cu)} + Q_0C_{P(Cu)} = Q_T C_{C(Cu)}$		
	$Q_{A(Cu)} = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$		
	$Q_T = Q_S + Q_0 \text{ (cfs)}$		
	$Q_{A(Cu)}C_{S(Cu)} + Q_0C_{P(Cu)} = (Q_0+Q_S)C_{C(Cu)}$		
	SOLVING FOR $Q_{A(Cu)} = [(Q_0C_{P(Cu)} / C_{C(Cu)}) - Q_0] / (1 - C_{S(Cu)} / C_{C(Cu)}) =$	-0.33982185 cfs	
	$\%P_{(Cu)} = \text{Percent of Stream Width Required to Assimilate Copper to Criteria}$		
	Concentration = $Q_{A(Cu)} / Q_S \text{ (cfs)} =$	-1.0788%	
Ammonia-Nitrogen (NH3-N)	$Q_{A(NH3-N)}C_{S(NH3-N)} + Q_0C_{P(NH3-N)} = Q_T C_{C(NH3-N)}$		
	$Q_{A(NH3-N)} = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$		
	$Q_T = Q_S + Q_0 \text{ (cfs)}$		
	$Q_{A(NH3-N)}C_{S(NH3-N)} + Q_0C_{P(NH3-N)} = (Q_0+Q_S)C_{C(NH3-N)}$		
	SOLVING FOR $Q_{A(NH3-N)} = [(Q_0C_{P(NH3-N)} / C_{C(NH3-N)}) - Q_0] / (1 - C_{S(NH3-N)} / C_{C(NH3-N)}) =$	3.466702 cfs	
	$\%P_{(NH3-N)} = \text{Percent of Stream Width Required to Assimilate NH3-N to Criteria}$		
	Concentration = $Q_{A(NH3-N)} / Q_S \text{ (cfs)} =$	11.0054%	
Zinc (Zn)	$W_{I(Zn)} = \text{Proposed Width of Stream required to Assimilate Zinc to Criteria}$		
	Concentration = $W_S \times \%P_{(Zn)}$	0.567974 meters	
	Proposed Area of Impact due to Zinc * = $(W_{I(Zn)})^2 \times 0.5 =$	0.16 m <sup>2</sup>	
	* assuming equal flow across transect and 90° spread at discharge		
	Copper (Cu)	$W_{I(Cu)} = \text{Proposed Width of Stream required to Assimilate Copper to Criteria}$	
		Concentration = $W_S \times \%P_{(Cu)}$	-0.329034 meters
		Proposed Area of Impact due to Copper * = $(W_{I(Cu)})^2 \times 0.5 =$	0.05 m <sup>2</sup>
* assuming equal flow across transect and 90° spread at discharge			
Ammonia-Nitrogen (NH3-N)		$W_{I(NH3-N)} = \text{Proposed Width of Stream required to Assimilate NH3-N to Criteria}$	
		Concentration = $W_S \times \%P_{(NH3-N)}$	3.356648 meters
		Proposed Area of Impact due to NH3-N * = $(W_{I(NH3-N)})^2 \times 0.5 =$	5.63 m <sup>2</sup>
	* assuming equal flow across transect and 90° spread at discharge		