

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0024961
APS ID 211
Authorization ID 1307647

Applicant and Facility Information

Applicant Name	<u>Oley Township Municipal Authority Berks County</u>	Facility Name	<u>Oley Township STP</u>
Applicant Address	<u>1 Rose Virginia Road, PO Box 19 Oley, PA 19547-8605</u>	Facility Address	<u>94 Tollhouse Road Oley, PA 19547</u>
Applicant Contact	<u>Shirley Moyer</u>	Facility Contact	<u>Mike Eshbach</u>
Applicant Phone	<u>(610) 987-3423</u>	Facility Phone	<u>(484) 650-0980</u>
Client ID	<u>69639</u>	Site ID	<u>445562</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Oley Township</u>
Connection Status	<u>No Exceptions Allowed</u>	County	<u>Berks</u>
Date Application Received	<u>February 24, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 6, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>NDPES permit renewal.</u>		

Summary of Review

Spotts, Stevens and McCoy, on behalf of the Oley Township Municipal Authority, has applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The flow design is 0.4 MGD, and hydraulic capacity design is 0.5 MGD. This facility serves the areas of Oley Township (100%). The permit was reissued on October 26, 2015 and became effective on November 1, 2015. The permit expired on October 31, 2020 but the terms and conditions of the permit have been extended since that time.

The first amendment WQM Part II No. 0672403 A-1 was issued on June 26, 1998. The second amendment WQM Part II No. 0672403 09-1 was issued on April 17, 2009. The third amendment WQM Part II No. 067203 12-1 was issued on March 5, 2013. The fourth amendment WQM Part II No. 0672403 A-4 was issued on December 5, 2019.

Sludge use and disposal description and location(s): N/A due to the sludge is hauled away by Jesse Baro, Inc's Services.

This discharge may also be subject to effluent limitations and conditions as developed and required by the Delaware River Basin Commission (DRBC). The DRBC limits may be more stringent. The permittee shall comply with any more stringent effluent limitations or standards contained in their docket, in accordance with 25 Pa. Code § 92a.12(b). Please contact the DRBC for more information at (690) 883-9500.

The last docket was issued on March 12, 2014 and will expire on March 12, 2024 by the Delaware River Basin Commission (DRBC) for this facility: D-2001-036 CP-2. According to the DRBC docket, four municipal wells provide water in the service area. The DRBC will be copied on the draft permit so they will have an opportunity to review and comment.

Changes from the previous permit: Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml. The E. Coli. monitoring and report requirements will add to the proposed permit.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	October 8, 2021
X		<i>Maria D. Bebenek for Daniel W. Martin</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	October 13, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.4
Latitude	40° 22' 30.74"	Longitude	-75° 44' 4.75"
Quad Name	Manatawny	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Manatawny Creek (CWF)	Stream Code	01655
NHD Com ID	25981186	RMI	15.8 miles
Drainage Area	48.6 mi. ²	Yield (cfs/mi ²)	0.3
Q ₇₋₁₀ Flow (cfs)	14.3	Q ₇₋₁₀ Basis	UGSG StreamStats
Elevation (ft)	302	Slope (ft/ft)	
Watershed No.	3-D	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	PA American Water Company at E. Vincent Twp.		
PWS Waters	Schuylkill River	Flow at Intake (cfs)	
PWS RMI	47 miles	Distance from Outfall (mi)	Approximate 24 miles

Changes Since Last Permit Issuance:

Drainage Area

The discharge is to Manatawny Creek at RMI 15.8 miles. A drainage area upstream of the discharge is estimated to be 48.6 mi.², according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

Stream Flow

According to StreamStats, the point of first use has a Q₇₋₁₀ of 14.3 cfs and a drainage area of 48.6 mi.², which results in a Q₇₋₁₀ low flow yield of 0.3 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 14.3 \text{ cfs} \\
 \text{Low Flow Yield} &= 14.3 \text{ cfs} / 48.6 \text{ mi.}^2 = 0.3 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 14.3 \text{ cfs} = 19.45 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 14.3 \text{ cfs} = 9.15 \text{ cfs}
 \end{aligned}$$

The resulting Q₇₋₁₀ dilution ratio is: $Q_{\text{stream}} / Q_{\text{discharge}} = 14.3 \text{ cfs} / [0.4 \text{ MGD} * (1.547 \text{ cfs/MGD})] = 23.1:1$

Manatawny Creek

25 Pa. Code § 93.9f classifies Manatawny Creek as Cold-Water Fishes (CWF) surface water. Based on the 2020 Integrated Report, Manatawny Creek, assessment unit IDs 6002; 19190; & 19191, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply

The nearest downstream public water supply intake is the PA American Water Company at E. Vincent Twp. on Schuylkill river, approximately 24 miles downstream of this discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Oley Township STP				
WQM Permit No.		Issuance Date		
0672403 A-1		6/26/1998		
0672403 09-1		4/17/2009		
0672403 12-1		3/05/2013		
0672403 A-4		12/05/2019		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Sequencing Batch Reactor	Gas Chlorine	0.4
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.5	576	Not Overloaded		Combination of methods

Changes Since Last Permit Issuance: The WQM Part II No. 0672403 A-4 amendment issued on 12/5/2019 as follows.

- Removed the existing grinder and four submersible influent pumps;
- Installed a dry well with three suction lift influent pumps, each with 700 gpm capacity, one as stand-by;
- Variable frequency drives and motors for new pumps and associated fittings, alarms, and controls;
- Added a vertical mechanically-cleaned screen in the influent wet well with guide rails to vertically lift the screen;
- Active ventilation of dry well and controls area and of existing wet well;
- Relocated the influent composite sampler and added an influent meter to the manhole upstream of the influent wet well (Manhole 1).

The WWTP consists:

One Sewage Pump Station, one muffin monster grinder, one influent lift station, two SBR tanks, two aerobic digesters, two chlorine contact tanks, one high flow effluent pump, one volute sludge press, four reed beds, outfall.

Chemical:

Uses Alum (Aluminum Sulfate) for Phosphorus removal and for settling. Uses polymer for sludge thickening. Uses Chlorine for disinfection.

Compliance History	
Summary of DMRs:	The DMRs reported from August 1, 2020 to July 31, 2021 are summarized in the Table below (Pages # 5 & 6).
Summary of Inspections:	<p>8/5/2020: DEP WQS conducted inspection due to Oley Township STP notified the Department of flooding, influent overflow, and failure as a result of receiving over 6" of rainfall on 8/4/2020. There were no violations noted during inspection. Mr. Eshbach stated that the wet well and one digester was pumped yesterday morning by Klines prior to flooding. Stream was almost level with chlorine contact tank which experienced overflow. Composite samples were collected throughout the event.</p> <p>5/31/2019: DEP ECS conducted routine inspection. There were violations noted such as: Final effluent was discolored brown. A high concentration of suspended solids was observed discharging through the chlorine contact tank. Biosolids were observed on the ground outside belt filter press room overhead door. On 5/13/2019 – plant operation log entry "Cl₂ tank overflowed". On 5/14/2019-plant operation log entry "effluent dirty, did not start sampler". Recommend notify the Department when the plant enters storm mode.</p> <p>11/30/2017- DEP ECS conducted a compliance evaluation inspection. There were no violations noted during inspection. There were recommendations such as notify the Department when return line piping is modified, or a pump or treatment unit will be taken offline for an extended period. Field test results were within the permit limits.</p>
Other Comments:	There is currently no open violation associated with the permit.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from August 1, 2020 to July 31, 2021)

Parameter	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20
Flow (MGD) Average Monthly	0.225	0.199	0.183	0.267	0.476	0.331	0.303	0.380	0.211	0.167	0.163	0.291
Flow (MGD) Daily Maximum	0.372	0.243	0.283	0.389	1.078	0.895	0.554	0.999	0.545	0.189	0.185	0.649
pH (S.U.) Minimum	7.2	7.2	7.2	6.8	7.7	7.1	7.0	6.6	6.4	6.7	6.7	7.1
pH (S.U.) Instantaneous Maximum	7.9	8.1	7.9	7.9	6.9	7.8	7.8	7.8	7.9	8.0	8.0	7.8
DO (mg/L) Minimum	5.1	5.2	5.3	5.9	5.2	6.0	5.3	5.4	6.3	7.2	5.5	5.5
TRC (mg/L) Average Monthly	0.2	0.2	0.2	0.3	0.3	0.3	0.4	0.3	0.2	0.4	0.2	0.2
TRC (mg/L) Instantaneous Maximum	0.48	0.52	0.88	0.45	0.54	0.78	0.66	0.77	0.5	0.61	0.6	1.14
CBOD5 (lbs/day) Average Monthly	< 7	5	11	9	< 10	< 7	< 5	< 10	< 3.0	4.0	6	12
CBOD5 (lbs/day) Weekly Average	11	6	33	13	20	13	< 7	15	6	4.0	11	25
CBOD5 (mg/L) Average Monthly	< 4	3	7	4	< 2	< 3	2.0	< 4	< 2.0	3.0	4	4
CBOD5 (mg/L) Weekly Average	6	4	19	5	3	4	3	5.6	3	3.0	6	6
BOD5 (lbs/day) Influent Average Monthly	236	184	198	257	379	540	256	698	338	277	541	413
BOD5 (mg/L) Influent Average Monthly	132	111	131	127	105	175	105	258	214	215	343	179
TSS (lbs/day) Average Monthly	< 10	< 7	< 6	< 8	< 16	< 11	< 9	< 10	< 6	< 5.0	< 6	< 20
TSS (lbs/day) Influent Average Monthly	362	210	227	409	456	502	305	661	453	321	909	912
TSS (lbs/day) Weekly Average	15	7	7	< 10	< 25	< 14	< 14	< 15	< 7	< 6.0	< 10	55
TSS (mg/L) Average Monthly	< 5	< 4	< 4	< 4	< 4	< 4	< 4	< 4	< 4	< 4	< 4	< 7

**NPDES Permit Fact Sheet
Oley Township STP**

NPDES Permit No. PA0024961

TSS (mg/L) Influent Average Monthly	203	< 129	149	217	123	164	126	252	284	249	580	326
TSS (mg/L) Weekly Average	10	< 4	4	< 4	< 4	< 4	< 4	< 4	< 4	< 4	< 4	13
Total Dissolved Solids (lbs/day) Average Monthly		799			926			749			1001	
Total Dissolved Solids (mg/L) Average		420			398			538			566	
Fecal Coliform (CFU/100 ml) Geometric Mean	< 3	< 5	< 4	3	< 1	< 1	< 1	< 1	< 2	4	9	23
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	11	64	22	8	2	< 1	4	1	8	15	186	180
Total Nitrogen (lbs/day) Average Monthly	8	< 7	13	14	19	12	4.28	10	9	5.0	< 8	16
Total Nitrogen (mg/L) Average Monthly	4.2	4.26	8.49	7.26	4.63	4.72	9	3.83	3.53	4.16	< 3.21	5.07
Ammonia (lbs/day) Average Monthly	< 0.2	< 0.3	8	10	5	3	5	4	4	< 0.9	< 6	< 8
Ammonia (mg/L) Average Monthly	< 1	0.18	5	5	1	1	2	2	< 1	< 1	< 1	< 2
Total Phosphorus (lbs/day) Average Monthly	2.3	2.6	1.5	1.0	1.7	2.1	1.7	1.6	3.0	1.2	2.3	1.4
Total Phosphorus (mg/L) Average Monthly	1.3	1.5	1.0	0.5	0.4	0.9	0.8	0.6	0.8	0.9	1.5	0.5

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.4</u>
Latitude <u>40° 22' 30.00"</u>	Longitude <u>-75° 44' 6.00"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments:

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	25°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	20°C	(Default)
*	Background NH ₃ -N	=	0 mg/L	(Default)

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 25.0 mg/L as a monthly average and 50.0 mg/L IMAX are necessary to protect the aquatic life from toxicity effects at the point of discharge. The DRBC Ammonia limit of 20.0 mg/L is therefore imposed, the same as in the previous NPDES permit. Then, the existing limits of 20.0 mg/L monthly average & 40.0 mg/L IMAX are more stringent and will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\text{Average monthly mass limit: } 20.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 66.7 \text{ (67.0) lbs/day}$$

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 25.0 mg/L monthly average (AML), 40.0 mg/L weekly average, and 50.0 mg/L instantaneous maximum (IMAX) will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 25.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 83.4 \text{ (83.0) lbs/day} \\ \text{Average weekly mass limit: } & 40.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 133.4 \text{ (133.0) lbs/day} \end{aligned}$$

pH:
The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

Dissolved Oxygen (D.O.):
A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BPNPSM-PMT-033 and has been applied to other point source dischargers throughout the state.

Fecal Coliform:
The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:
As recommended by DEP's SOP no. BPNPSM-PMT-033, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/week will be included in the permit to be consistent with the recommendation from this SOP.

Total Suspended Solids (TSS):
The existing technology-based limits of 30.0 mg/L average monthly, 45.0 mg/L weekly average, and 60.0 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits. Mass limits are calculated as follows:

$$\begin{aligned} \text{Average monthly mass limit: } & 30.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 100.0 \text{ lbs/day} \\ \text{Average weekly mass limit: } & 45.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 150.1 \text{ (150.0) lbs/day} \end{aligned}$$

Total Phosphorus:
Previous permit had average monthly concentration monitoring requirement 2.0 mg/l and instantaneous maximum limit of 4.0 mg/l. Accordingly, existing TP limits will remain in the proposed permit. See the EPA guidance, Nutrient Criteria Technical Guidance Manual – Rivers and Streams, 07/2000 EPA-822-B-00-002, for more information about nutrient impacts on streams. Mass limits are calculated as follows:

$$\text{Average monthly mass limit: } 2.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 6.7 \text{ lbs/day}$$

Biosolids Management:
Sludge is digested on-site, via an aerobic sludge digester, and removed by a certified hauler.

Additional Considerations

Flow Monitoring
Flow monitoring is recommended by the permit guidance and is also required by 25 Pa. Code §§ 92a.27 and 92a.61.

Influent Monitoring
As a result of negotiation with EPA, influent monitoring of TSS and BOD₅ are required for any POTWs; therefore, influent sampling of BOD₅ and TSS will be included in the draft permit. A 24-hr composite sample type will be required to be consistent with the proposed sampling frequency for TSS and CBOD₅ in the effluent.

Total Dissolved Solids (TDS)
The DRBC regulation [18 CFR Part 410] includes an effluent limit for TDS of 1,000 mg/L, because eight rounds of sampling per the application resulted in an average concentration of 466.0 mg/L for TDS (page 6), the Department contents that there is not a "reasonable potential" for the effluent to exceed this limit and is not imposing a limit. Additionally, State regulations [25 Pa. Code § 95.10] do not require a TDS limit until existing permittees increase their TDS mass load to less than or equal 5,000 lbs/day. Mass limits are calculated as follows:

$$\text{Average monthly mass limit: } 466.0 \text{ mg/L} \times 0.4 \text{ MGD} \times 8.34 = 1,554.6 \text{ lbs/day}$$

The TDS mass load average monthly is 1,554.6 lbs/day and is well below 5,000 lbs/day. Due to DRBC's requirements, then the TDS monitoring and report (1/quarter) requirements will remain in the proposed permit.

Total Nitrogen

Monitoring requirements for Total Nitrogen are being added to all NPDES permits in the State if the permit does not already include them, as authorized by 25 Pa. Code § 92a.61. Controlling nutrients in waterways requires data collection. The existing minimum monitoring and report calculation of monthly for Total Nitrogen permit will be remain in the proposed permit

Toxics

DEP utilizes a Toxics Management Spreadsheet (last modified on March 2021 ver. 1.3) to facilitate calculations necessary for completing a reasonable potential analysis and determining WQBELs for toxic pollutants. The effluent testing information renewal application (page 6) indicates that there are no toxic pollutants of concern.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

Anti-Backsliding

No limits have been included in the renewal permit that are less stringent than in the previous permit.

Antidegradation (Chapter 93.4)

The effluent limits for this discharge have been developed to ensure that existing stream uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High Quality (HQ) or Exceptional Value (EV) waters are impacted by this discharge.

WQM 7.0 Data:

D.O. Goal: 6.0 mg/L

Node 1: Manatawny Creek (01655)

Elevation:	302 ft (USGS National Map Viewer)
Drainage Area:	48.6 mi. ² (USGS PA StreamStats)
River Mile Index:	15.8 (PA DEP eMapPA)
Low Flow Yield:	0.3 cfs/mi. ²
Discharge Flow:	0.4 MGD (NPDES Application)

Node 2: Just before confluence with Furnace Run

Elevation:	287 ft (USGS National Map Viewer)
Drainage Area:	49.9 mi. ² (USGS PA StreamStats)
River Mile Index:	13.9 (PA DEP eMapPA)
Low Flow Yield:	0.3 cfs/mi. ²
Discharge Flow:	0.000 MGD

Map | eFacts Query | Advanced Query

ESRI Streets & Imagery Topographic National Geographic




Locate Latitude and Longitude

Decimal Degrees DD/MM/SS

Latitude: Degrees: Minutes: Seconds:

Longitude:



USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the 'Build Report' button

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

POWERED BY WIM

[USGS Home](#) [Contact USGS](#) [Search USGS](#)
[Accessibility](#) [FOIA](#) [Privacy](#) [Policy & Notices](#)

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	48.6	square miles
BSLOPD	Mean basin slope measured in degrees	6.6066	degrees
ROCKDEP	Depth to rock	5.2	feet
URBAN	Percentage of basin with urban development	1.6025	percent

Low-Flow Statistics Parameters [99.8 Percent (48.4 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	48.6	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.6066	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.2	feet	4.13	5.21
URBAN	Percent Urban	1.6025	percent	0	89

Low-Flow Statistics Disclaimers [99.8 Percent (48.4 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors

Low-Flow Statistics Flow Report [99.8 Percent (48.4 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	23.1	ft ³ /s
30 Day 2 Year Low Flow	25.9	ft ³ /s
7 Day 10 Year Low Flow	14.3	ft ³ /s
30 Day 10 Year Low Flow	15.9	ft ³ /s
90 Day 10 Year Low Flow	19	ft ³ /s

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

USGS StreamStats

SELECT A STATE / REGION
Pennsylvania

IDENTIFY A STUDY AREA
Basin Delineated

SELECT SCENARIOS

BUILD A REPORT Report Built

Step 1: You can modify computed basin characteristics here, then select the types of reports you wish to generate. Then click the "Build Report" button.

Show Basin Characteristics

Select available reports to display:

- Basin Characteristics Report
- Scenario Flow Reports

Continue

POWERED BY WIM

USGS Home Contact USGS Search USGS
Accessibility FOIA Privacy Policy & Notices

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	49.9	square miles
BSLOPD	Mean basin slope measured in degrees	6.5564	degrees
ROCKDEP	Depth to rock	5.2	feet
URBAN	Percentage of basin with urban development	1.5611	percent

Low-Flow Statistics Parameters [99.8 Percent (49.7 square miles) Low Flow Region 1]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	49.9	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	6.5564	degrees	1.7	6.4
ROCKDEP	Depth to Rock	5.2	feet	4.13	5.21
URBAN	Percent Urban	1.5611	percent	0	89

Low-Flow Statistics Disclaimers [99.8 Percent (49.7 square miles) Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [99.8 Percent (49.7 square miles) Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	23.4	ft ³ /s
30 Day 2 Year Low Flow	26.3	ft ³ /s
7 Day 10 Year Low Flow	14.5	ft ³ /s
30 Day 10 Year Low Flow	16.2	ft ³ /s
90 Day 10 Year Low Flow	19.4	ft ³ /s

Report About Help

Layers

- Base Maps
- Application Layers
- National Layers
- PA Map Layers

Hereford

Bally

Baro

New Berlinville

Sassamansville

Boyer town

Displaying simplified Basin. See FAQ for more information.

Analysis Results WQM 7.0

Hydrodynamics NH3-N Allocations D.O. Allocations D.O. Simulation **Effluent Limitations**

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
15.80	Oley Township	PA0024961	0.4000

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	25	50	
Dissolved Oxygen			5

Record: 1 of 1 No Filter Search

Print < Back Next > Archive Cancel

rptEffLimits

WQM 7.0 Effluent Limits

WQP Basin		Stream Code		Stream Name			
03D	1866	MANATAWNY CREEK					
RMI	Name	Permit Number	Disc. Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
15.800	Oley Township	PA0024961	0.400	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			5

Thursday, September 23, 2021 Version 1.1 Page 1 of 1

rpt_WLA

WQM 7.0 Wasteload Allocations

WQP Basin		Stream Code		Stream Name					
03D	1866	MANATAWNY CREEK							
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
15.800	Oley Township	16.33	50	16.33	50	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
15.800	Oley Township	1.87	25	1.87	25	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
15.800	Oley Township	25	25	25	25	5	5	0	0

Thursday, September 23, 2021 Version 1.1 Page 1 of 1

rptDOSim

WQM 7.0 D.O. Simulation

SMP Basin		Stream Code	Stream Name	
03D	1865		MANATAWNY CREEK	
<u>RA</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
15.800	0.400	20.204	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (ft/s)</u>	
52.243	0.794	66.866	0.371	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach K1 (1/day)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach No. T (days)</u>	
294	0.444	1.02	0.711	
<u>Reach DO (mg/L)</u>	<u>Reach K2 (1/day)</u>	<u>K1 Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.111	3.806	Tsivagou	6	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.313	<u>Trav Time</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	0.081	250	1.00	8.07
	0.083	286	0.97	8.04
	0.084	282	0.96	8.01
	0.125	278	0.98	7.99
	0.156	274	0.91	7.97
	0.188	270	0.89	7.96
	0.219	266	0.87	7.96
	0.250	263	0.85	7.95
	0.281	259	0.83	7.95
	0.313	255	0.81	7.95

Thursday, September 23, 2021 Version 1.1 Page 1 of 1

Page: 1 of 1 No Filter

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust K1	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

Thursday, September 23, 2021 Version 1.1 Page 1 of 1

Page: 1 of 1 No Filter

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin		Stream Code			Stream Name									
03D		1886			MANATAWNY CREEK									
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Flow	Reach Slope	Depth	Width	WD Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH		
(cfs)	(cfs)	(cfs)	(cfs)	(cfs)	(%/ft)	(ft)	(ft)		(fps)	(days)	(°C)			
Q7-10 Flow														
15800	14.98	0.00	14.98	.6188	0.00150	.784	52.24	66.67	0.37	0.313	20.20	7.00		
Q1-10 Flow														
15800	9.33	0.00	9.33	.6188	0.00150	NA	NA	NA	0.29	0.367	20.31	7.00		
Q30-10 Flow														
15800	19.83	0.00	19.83	.6188	0.00150	NA	NA	NA	0.44	0.265	20.15	7.00		

Thursday, September 23, 2021 Version 1.1 Page 1 of 1

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
(cfs)	(cfs)	(cfs)	(cfs)	(ft)	(sq mi)	(%/ft)	(mgd)	
03D	1886	MANATAWNY CREEK	15,800	302.00	48.60	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFV	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream Temp	pH
	(cfs)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)	(°C)	
Q7-10	0.300	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10	0.00	0.00	0.000	0.000							
Q30-10	0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	Disc Temp	Disc pH
		(mgd)	(mgd)	(mgd)		(°C)	
Oley Township	PA0024961	0.4000	0.4000	0.4000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc	Trib Conc	Stream Conc	Fate Coef
	(mg/L)	(mg/L)	(mg/L)	(1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Thursday, September 23, 2021 Version 1.1 Page 1 of 2

rptGeneral
— □ ×

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
03D	1655	MANATAWNY CREEK	13.900	287.00	49.90	0.00000	0.00	<input checked="" type="checkbox"/>

Stress Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(ctm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.300	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Oley Township	PA0024961	0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Thursday, September 23, 2021
Version 1.1
Page 2 of 2

Page: 1 2
No Filter

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
14.3	= Q stream (cfs)		0.5	= CV Daily	
0.4	= Q discharge (MGD)		0.5	= CV Hourly	
30	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 7.391		1.3.2.iii	WLA_cfc = 7.198
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 2.754		5.1d	LTA_cfc = 4.185
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST MAX LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	83	133	XXX	25	40	50	1/week	24-Hr Composite
TSS	100	150	XXX	30	45	60	1/week	24-Hr Composite
BOD5 Effluent Net	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Effluent Net	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
Total Dissolved Solids	Report Average	XXX	XXX	Report Average	XXX	XXX	1/quarter	24-Hr Composite
Ammonia	67	XXX	XXX	20	XXX	40	1/week	24-Hr Composite
Total Phosphorus	6.7	XXX	XXX	2.0	XXX	4.0	1/week	24-Hr Composite
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation

Proposed Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	83.0	133.0 Wkly Avg	XXX	25.0	40.0	50.0	1/week	24-Hr Composite
TSS	100.0	150.0 Wkly Avg	XXX	30.0	45.0	60.0	1/week	24-Hr Composite
BOD5 Effluent Net	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS Effluent Net	Report	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	1/week	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/week	Grab
Ammonia	67.0	XXX	XXX	20.0	XXX	40.0	1/week	24-Hr Composite
Total Phosphorus	6.7	XXX	XXX	2.0	XXX	4.0	1/week	24-Hr Composite
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	1/month	Calculation
Total Dissolved Solids	Report Avg Qrtly	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input checked="" type="checkbox"/>	Other: DRBC