

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0025461
APS ID 1012787
Authorization ID 1307955

Applicant and Facility Information

Applicant Name	<u>Vernon Township Sanitary Authority</u>	Facility Name	<u>South Watson Run STP</u>
Applicant Address	<u>16678 McMath Avenue</u> <u>Meadville, PA 16335-6568</u>	Facility Address	<u>9868 S Watson Run Road</u> <u>Meadville, PA 16335-7258</u>
Applicant Contact	<u>Beverly Styborski</u>	Facility Contact	<u>Michael Davidson</u>
Applicant Phone	<u>(814) 337-8126</u>	Facility Phone	<u>(724) 372-3339</u>
Client ID	<u>6757</u>	Site ID	<u>462707</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Vernon Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Crawford</u>
Date Application Received	<u>March 2, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 26, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of an NPDES permit for an existing POTW discharge of treated sewage.</u>		

Summary of Review

Act 14 – Proof of Notification was submitted and received.

South Watson Run STP is currently registered to use the Departments eDMR system for reporting.

There are no open violations for subject client no. 6757 as of 10/5/2021.

Sludge use and disposal description and location(s): Septage must be pumped and hauled off-site by a septage hauler for land application under a general permit authorized by DEP or disposal at an STP.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jon F. Bucha Jonathan F. Bucha / Civil Engineer General	October 12, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	October 14, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.27</u>
Latitude	<u>41° 36' 2.38"</u>	Longitude	<u>-80° 13' 20.32"</u>
Quad Name	<u>Geneva</u>	Quad Code	<u>0604</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Watson Run (WWF)</u>	Stream Code	<u>52289</u>
NHD Com ID	<u>127348905</u>	RMI	<u>1.9</u>
Drainage Area	<u>13.8 mi²</u>	Yield (cfs/mi ²)	<u>0.083 (USGS# 03024000 '72 - '08)</u>
Q ₇₋₁₀ Flow (cfs)	<u>1.15</u>	Q ₇₋₁₀ Basis	<u>Calculated</u>
Elevation (ft)	<u>1074</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>16-D</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.0</u>	Default	
Temperature (°F)	<u>25° C</u>	WWF Default	
Hardness (mg/L)	<u>-</u>	-	
Other:	<u>0.1 mg/L</u>	NH ₃ -N Default	
Nearest Downstream Public Water Supply Intake	<u>Aqua PA Emlenton</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1376</u>
PWS RMI	<u>90</u>	Distance from Outfall (mi)	<u>68</u>

Changes Since Last Permit Issuance: Yield has been updated to reflect the most current USGS data.

Other Comments: This treatment facility is capable of meeting effluent requirements

Treatment Facility Summary				
Treatment Facility Name: Vernon Township - S Watson Run STP				
WQM Permit No.		Issuance Date		
2009402				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Hypochlorite	0.27
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.27	320	Not Overloaded	Aerobic Digestion	

Changes Since Last Permit Issuance: None

Other Comments: Treatment facility consists of a pump station, flow metering with recording, comminution with bypass bar screen, three parallel activated sludge units, clarification, gas chlorine disinfection, and aerated sludge holding tank.

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Average Monthly	0.108	0.143	0.097	0.136	0.108	0.131	0.139	0.172	0.212	0.133	0.094	0.068
pH (S.U.) Minimum	6.9	6.7	6.9	6.6	6.7	6.6	6.9	6.9	6.9	6.9	6.9	6.9
pH (S.U.) Maximum	7.5	7.2	7.5	7.2	7.1	7.0	7.2	7.2	7.3	7.2	7.3	7.2
DO (mg/L) Minimum	6.6	6.6	6.2	4.9	4.8	6.9	8.4	4.2	4.5	4.2	4.2	4.3
TRC (mg/L) Average Monthly	0.3	0.3	0.3	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.2
CBOD5 (lbs/day) Average Monthly	< 3.4	< 10.9	4.3	< 5.3	3.2	5.7	6.2	< 4.1	< 7.8	< 3.7	< 2.7	< 1.8
CBOD5 (lbs/day) Weekly Average	4.4	23.7	6.0	12.9	4.9	10.1	8.3	< 5.8	< 14.2	7.0	< 4.3	2.3
CBOD5 (mg/L) Average Monthly	< 5	< 8	5	< 4	4	5	6	< 3	< 5	< 4	< 3	< 3
CBOD5 (mg/L) Weekly Average	6	10	7	7	6	6	8	< 3	< 12	5	< 3	4
BOD5 (lbs/day) Influent Average Monthly	113	202	139	125	142	143	147	143	192	130	123	84
BOD5 (lbs/day) Influent Weekly Average	188	334	221	200	175	205	183	201	232	268	187	150
BOD5 (mg/L) Influent Average Monthly	132	176	163	114	181	132	153	106	121	124	140	157
BOD5 (mg/L) Influent Weekly Average	148	303	191	164	246	208	173	116	165	191	167	294
TSS (lbs/day) Average Monthly	< 4.2	< 7.5	< 6.0	< 6.5	5.8	9.2	8.4	7.9	< 11.6	< 6.8	6.1	6.6
TSS (lbs/day) Influent Average Monthly	105	89	115	115	104	105	135	99	152	107	86	87

**NPDES Permit Fact Sheet
South Watson Run STP**

NPDES Permit No. PA0025461

TSS (lbs/day) Influent Weekly Average	151	125	169	126	129	163	150	130	243	233	157	173
TSS (lbs/day) Weekly Average	< 6.7	16.1	10.2	10.4	7.3	14.5	15.9	11.6	19.9	14.0	11.4	10.9
TSS (mg/L) Average Monthly	< 5	< 6	< 7	< 6	7	8	8	6	< 7	< 6	7	12
TSS (mg/L) Influent Average Monthly	136	95	145	116	128	90	141	79	93	100	99	163
TSS (mg/L) Influent Weekly Average	218	160	250	170	160	118	158	119	134	166	196	340
TSS (mg/L) Weekly Average	< 5	7	12	6	9	9	15	6	9	10	8	19
Fecal Coliform (CFU/100 ml) Geometric Mean	< 2	< 13	11	12	38	15	8	5	10	6	33	< 18
Total Nitrogen (mg/L) Average Monthly	18.8	17.5	21.7	16.3	19.9	14.7	15.8	10.29	9.85	13.9	19	19.2
Ammonia (lbs/day) Average Monthly	< 0.7	< 1.6	< 0.7	< 0.9	< 0.6	< 0.9	< 0.8	< 1.1	< 1.3	< 0.8	< 0.7	< 0.4
Ammonia (mg/L) Average Monthly	< 0.8	< 1.1	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8	< 0.8
Total Phosphorus (mg/L) Average Monthly	2.7	1.5	2.6	0.84	1.0	0.97	1.3	0.69	0.86	1.0	2.3	1.2

Compliance History

Summary of Inspections: An inspection occurred on 10/8/2020 where no violations were noted.

Summary of eDMRs: Reviewing the past 3 years of eDMR data, this facility has had no effluent exceedances and appears to be operating in good condition.

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	.27
Latitude	41° 36' 2.38"	Longitude	-80° 13' 20.32"
Wastewater Description: Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Total Residual Chlorine	0.4	Average Monthly	TRC_CALC Spreadsheet
Ammonia Nitrogen (May 1 – Oct 31)	4.0	Average Monthly	WQM 7.0
Ammonia Nitrogen (Nov 1 – Apr 30)	12.0	Average Monthly	WQM 7.0
CBOD ₅	15.0	Average Monthly	WQM 7.0
Dissolved Oxygen	4.0	Daily Minimum	WQM 7.0

Comments: Modeling results show that the present limits of 0.3 mg/L and 2.5 mg/L for TRC, and Ammonia Nitrogen, respectively, are more stringent than the Water Quality-Based Limitations required to protect water quality. It is recommended that the current limits be re-imposed to protect the stream. Dissolved Oxygen had a monitoring schedule of 1/week monitoring frequency for a 5-year permit term on the previous renewal to allow for monitoring equipment and install, which will now be daily monitoring.

Best Professional Judgment (BPJ) Limitations

Comments: Total Nitrogen, Total Phosphorus, and E. Coli monitoring is based on Ch. 92a.61 and the Departments SOP for Establishing Effluent Limitations for Individual Sewage Permits (SOP No. BPNPSM-PMT-033). Total Nitrogen and Total Phosphorus monitoring frequency will remain at 1/week, which is in accordance with Table 6-3 from the Permit Writers Manual. E. Coli monitoring is a new addition to this permit renewal and will have a monitoring frequency of 1/quarter. Raw sewage influent monitoring will remain in the permit renewal as recommended by the SOP (No. BPNPSM-PMT-033) for parameters BOD₅ and Total Suspended Solids (TSS), at the same frequency as the effluent.

Anti-Backsliding

Anti-Backsliding considerations do not apply since the effluent limitations are all remaining the same as in the previous permit renewal.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Weekly Average	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	Continuous	Recorded
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.3	XXX	1.3	1/day	Grab
CBOD5	34.0	45.0	20.0	15.0	XXX	30	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report	Report	Report	XXX	XXX	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report	Report	Report	XXX	XXX	1/week	24-Hr Composite
TSS	68.0	101.0	45.0	30.0	XXX	60	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Ammonia-Nitrogen May 1 - Oct 31	5.5	XXX	XXX	2.5	XXX	5.0	1/week	24-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	16.5	XXX	XXX	7.5	XXX	15.0	1/week	24-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Weekly Average	Average Monthly	Maximum	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection.

Attachment A – eMAP Stream Designation



Attachment B – Streamstats Drainage Area (Discharge Point)




Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	13.8	square miles
ELEV	Mean Basin Elevation	1282	feet
PRECIP	Mean Annual Precipitation	44	inches

Attachment C – Streamstats Drainage Area (End of Reach)

Region ID: PA
 Workspace ID: PA20211006171911096000
 Clicked Point (Latitude, Longitude): 41.57731, -80.22422
 Time: 2021-10-06 13:19:32 -0400

PA
 PA20211006171911096000
 41.57731, -80.22422
 2021-10-06 13:19:32 -0400



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	15.1	square miles
ELEV	Mean Basin Elevation	1273	feet
PRECIP	Mean Annual Precipitation	44	inches

Attachment D – WQM 7.0 Modeling

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
16D	52289	WATSON RUN					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.900	South WatsonRun	PA0025461	0.000	CBOD5	13.9		
				NH3-N	4.17	8.34	
				Dissolved Oxygen			4

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
16D	52289	WATSON RUN			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>	
1.900	0.270	23.664		7.025	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>	
20.169	0.572	35.238		0.135	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>	
5.18	0.519	1.19		0.928	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>	
6.594	1.820	Tsivoglou		5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>				
0.857	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)	
	0.086	4.91	1.10	6.13	
	0.171	4.66	1.01	5.78	
	0.257	4.42	0.94	5.52	
	0.343	4.20	0.86	5.34	
	0.429	3.98	0.80	5.23	
	0.514	3.78	0.74	5.17	
	0.600	3.58	0.68	5.16	
	0.686	3.40	0.63	5.17	
	0.771	3.23	0.58	5.22	
	0.857	3.06	0.54	5.29	

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16D	52289	WATSON RUN	1.900	1074.00	13.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.083	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
South WatsonRun	PA0025461	0.0000	0.0000	0.2700	0.000	20.00	7.10

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	7.54	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16D	52289	WATSON RUN	0.001	1061.00	15.10	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.083	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
16D	52289	WATSON RUN										
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH

Q7-10 Flow

1.900 1.15 0.00 1.15 .4177 0.00130 .572 20.17 35.24 0.14 0.857 23.66 7.02

Q1-10 Flow

1.900 0.73 0.00 0.73 .4177 0.00130 NA NA NA 0.11 1.017 23.19 7.03

Q30-10 Flow

1.900 1.56 0.00 1.56 .4177 0.00130 NA NA NA 0.15 0.752 23.94 7.02

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16D	52289	WATSON RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.900	South WatsonRu	7.51	20.52	7.51	20.52	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.900	South WatsonRu	1.43	6.38	1.43	6.38	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.90	South WatsonRun	13.9	13.9	4.17	4.17	4	4	0	0

Attachment E – Discharge pH

South Watson Run STP							
Vernon Township, Crawford County							
PA0025461							
Discharge pH							
Date	pH min	pH max	10 ^{-pH min}	10 ^{-pH max}	& pH max)	-Log (Ave pH)	
Jul-21	6.7	7.2	1.99526E-07	6.3096E-08	1.3131E-07	6.9	
Aug-21	6.9	7.5	1.25893E-07	3.1623E-08	7.8758E-08	7.1	
Jul-20	6.9	7.2	1.25893E-07	6.3096E-08	9.4494E-08	7.0	
Aug-20	7	7.4	0.0000001	3.9811E-08	6.9905E-08	7.2	
Sep-20	6.9	7.2	1.25893E-07	6.3096E-08	9.4494E-08	7.0	
Jul-19	6.9	7.4	1.25893E-07	3.9811E-08	8.2852E-08	7.1	
Aug-19	7.1	7.4	7.94328E-08	3.9811E-08	5.9622E-08	7.2	
Sep-19	7.1	7.3	7.94328E-08	5.0119E-08	6.4776E-08	7.2	
Jul-18	6.7	7.2	1.99526E-07	6.3096E-08	1.3131E-07	6.9	
Aug-18	6.8	7.1	1.58489E-07	7.9433E-08	1.1896E-07	6.9	
						Median:	7.1

Attachment F – TRC CALC Spreadsheet

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
1.15	= Q stream (cfs)	0.5	= CV Daily		
0.27	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BJP Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.897		1.3.2.iii	WLA_cfc = 0.867
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.334		5.1d	LTA_cfc = 0.504
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.412		AFC	
		INST MAX LIMIT (mg/l) = 1.346			
WLA_afc	(.019/e ^{-k*AFC_tc}) + [(AFC_Yc*Qs*.019/Qd*e ^{-k*AFC_tc})]... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_afc	EXP((0.5*LN(cvh ² +1))-2.326*LN(cvh ² +1) ^{0.5})				
LTA_afc	wla_afc*LTAMULT_afc				
WLA_cfc	(.011/e ^{-k*CFC_tc}) + [(CFC_Yc*Qs*.011/Qd*e ^{-k*CFC_tc})]... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_cfc	EXP((0.5*LN(cvd ² /no_samples+1))-2.326*LN(cvd ² /no_samples+1) ^{0.5})				
LTA_cfc	wla_cfc*LTAMULT_cfc				
AML MULT	EXP(2.326*LN((cvd ² /no_samples+1) ^{0.5})-0.5*LN(cvd ² /no_samples+1))				
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)				