

Application Type Renewal  
Facility Type Municipal  
Major / Minor Major

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0025917  
APS ID 990640  
Authorization ID 1268712

**Applicant and Facility Information**

Applicant Name	<u>Chalfont New Britain Township Joint Sewer Authority Bucks County</u>	Facility Name	<u>Chalfont New Britain Township Joint Sewer Authority</u>
Applicant Address	<u>1645 Upper State Road Doylestown, PA 18901-2624</u>	Facility Address	<u>1645 Upper State Road Doylestown, PA 18901-2666</u>
Applicant Contact	<u>John Schmidt</u>	Facility Contact	<u>John Schmidt</u>
Applicant Phone	<u>(215) 345-1225</u>	Facility Phone	<u>(215) 345-1225</u>
Client ID	<u>62143</u>	Site ID	<u>454079</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Doylestown Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Bucks</u>
Date Application Received	<u>March 28, 2019</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u></u>	If No, Reason	<u>Major Facility</u>
Purpose of Application	<u>Permit Renewal.</u>		

**Summary of Review**

The applicant requests approval for the renewal of a National Pollutant Discharge Elimination System (NPDES) permit to discharge an average annual flow of 4.625 MGD to Neshaminy Creek located in Doylestown Township, Bucks County. In 2015, the permit was amended to increase the hydraulic capacity from 6.0 to 7.0 MGD upon permittee's request.

The plant process includes screening, primary settling to remove grit and grease, a split treatment process, final clarifier, and UV disinfection. The split treatment process consists of submersible mixers and an oxidation ditch which is a modified version of activated sludge unit. Denitrification, phosphorus and ammonia removal is achieved in oxidation ditch. Solid wastes generated are processed to final product called biosolids, which are recycled for beneficial uses in community.

Water quality modeling is performed using Department's WQM. The previous monthly average effluent limit for CBOD<sub>5</sub> was 12 mg/l (5/1 – 10/31) and 24 mg/l (11/1 – 4/30). The existing effluent limit for dissolved oxygen limit is 5.0 mg/l (minimum). The current WQM model recommends a CBOD<sub>5</sub> limit of 7-mg/l, based on an NH<sub>3</sub>-N limit of 2.0-mg/l. Therefore, CBOD<sub>5</sub> limits for this renewal has been changed to 7 mg/l (5/1 – 10/31) and 14 mg/l (11/1 – 4/30).

A "Reasonable Potential Analysis" determined Aluminum, Chloride, Copper, Total Dissolved Solids, Zinc, Total Iron and Total Lead are parameters of concern. WQBEL calculated by Pentox recommended that limits be established for Total Aluminum, Total Copper, Total Iron and report only for Total Lead and Total Zinc. TDS is report only in the existing permit and will remain unchanged.

E.Coli report only requirement has been added in the permit as per the revised SOP for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits SOP No. BCW-PMT-033

Current limit for phosphorus, Total Kjeldahl Nitrogen remain unchanged for this renewal.

Approve	Deny	Signatures	Date
X		<i>Vasantha</i> Vasantha Palakurti / Environmental Engineering Specialist	6/3/2021
		Pravin C. Patel, P.E. / Environmental Engineer Manager	

**Summary of Review**

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>4.625</u>
Latitude	<u>40° 17' 18.41"</u>	Longitude	<u>-75° 10' 42.37"</u>
Quad Name	<u></u>	Quad Code	<u>1644</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Neshaminy Creek (TSF, MF)</u>	Stream Code	<u>02484</u>
NHD Com ID	<u>25479308</u>	RMI	<u>37.9300</u>
Drainage Area	<u>61.7</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1</u>
Q <sub>7-10</sub> Flow (cfs)	<u>6.4</u>	Q <sub>7-10</sub> Basis	<u>Previous Permit</u>
Elevation (ft)	<u>220</u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>2-F</u>	Chapter 93 Class.	<u>TSF, MF</u>
Existing Use	<u>None</u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>NUTRIENTS, ORGANIC ENRICHMENT, PATHOGENS, SILTATION</u>		
Source(s) of Impairment	<u>MUNICIPAL POINT SOURCE DISCHARGES, MUNICIPAL POINT SOURCE DISCHARGES, SOURCE UNKNOWN, SOURCE UNKNOWN</u>		
TMDL Status	<u>Final, 04/09/2003 (Nutrient TMDL withdrawn)</u>	Name	<u>Neshaminy Creek</u>

Changes Since Last Permit Issuance: In 2015, the permit was amended to increase the hydraulic capacity from 6.0 to 7.0 MGD upon permittee's request. The design capacity and flow remained the same. There were no other changes to assumptions, flows, etc. since last permit renewal.

Outfall 002: Stormwater runoff from Chalfont New Britain STP property

Treatment Facility Summary				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia And Phosphorus	Oxidation Ditch	Ultraviolet	4.625
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
7	11572	Not Overloaded	Conditioning (Chemical, Heat, Etc.)	Land Application

Compliance History

DMR Data for Outfall 001 (from November 1, 2018 to October 31, 2019)

Parameter	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18
Flow (MGD) Average Monthly	3.16	2.51	2.83	4.45	4.57	6.25	4.69	6.92	5.71	6.66	6.30	7.72
Flow (MGD) Daily Maximum	7.24	3.10	3.90	8.61	7.05	11.87	8.36	13.96	8.99	11.79	13.18	12.31
pH (S.U.) Minimum	7.1	7.4	6.3	6.7	7.1	6.9	7.2	6.9	6.8	6.9	6.9	7.0
pH (S.U.) Maximum	7.8	7.7	7.6	7.6	7.5	7.5	7.6	7.4	7.3	7.3	7.4	7.4
DO (mg/L) Minimum	7.3	7.2	7.8	7.2	8.1	8.0	6.8	8.3	7.7	9.7	9.4	9.5
CBOD5 (lbs/day) Average Monthly	51	58	55	136	81	301	165	325	1099	1028	342	159
CBOD5 (lbs/day) Weekly Average	58	91	71	249	96	621	216	445	2538	2994	687	266
CBOD5 (mg/L) Average Monthly	2.1	2.7	2.2	3.1	2.1	4.9	4.3	5.5	18.5	13	7.1	2.6
CBOD5 (mg/L) Raw Sewage Influent   Average Monthly	183	191	160	131	124	127	166	138	159	130	106	147
CBOD5 (mg/L) Weekly Average	2.2	3.8	2.5	4.4	2.2	7.3	5.3	6.7	38.1	32	15.1	3.8
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	5301	5261	6288	7426	8278	8439	9397	10076	11449	8975	6168	12573
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	221	259	265	192	215	159	260	183	225	168	134	221
TSS (lbs/day) Average Monthly	121	102	165	486	319	2746	630	1896	3686	3093	742	783
TSS (lbs/day) Raw Sewage Influent   Average Monthly	5871	5833	5899	7721	8892	10771	8440	12296	13272	9786	7487	14454

**NPDES Permit Fact Sheet**  
**Chalfont New Britain Township Joint Sewer Authority**

**NPDES Permit No. PA0025917**

TSS (lbs/day) Weekly Average	230	128	197	969	393	5142	1767	3459	8226	8226	2224	1032
TSS (mg/L) Average Monthly	4.8	4.7	6.8	11.5	8.2	38	13	29	62.9	39	16.4	12
TSS (mg/L) Raw Sewage Influent   Average Monthly	240	286	248	209	229	188	227	208	275	190	160	237
TSS (mg/L) Weekly Average	6.6	5.7	7.3	18.1	10.1	74	27	51	90.5	90	49.0	16
Total Dissolved Solids (mg/L) Average Monthly		517			493			460			423	
Fecal Coliform (CFU/100 ml) Geometric Mean	62	35	184	43	19	91	28	8	5	8	19	43
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	326	102	579	649	63	600	687	26	20	15	2420	727
Nitrate-Nitrite (lbs/day) Average Monthly	186	127	56	64	164	117	151	206	84	33	513	296
Nitrate-Nitrite (mg/L) Average Monthly	6.4	6.0	2.4	1.9	4.4	3.7	4.6	4.2	2.2	3.4	9.6	9.9
Ammonia (lbs/day) Average Monthly	17	12	30	152	13	448	506	200	71	47	38	133
Ammonia (mg/L) Average Monthly	0.52	0.65	1.2	3.98	0.32	8.98	13.3	2.7	1.75	0.89	0.88	2.1
TKN (lbs/day) Average Monthly	20	24	68	28	56	603	315	127	197	166	54	30
TKN (mg/L) Average Monthly	1.00	1.10	2.50	1.00	1.50	19.0	9.60	2.60	4.10	2.90	1.00	1.00
Total Phosphorus (lbs/day) Average Monthly	34	24	28	30	19	91	32	59	36	33	38	48
Total Phosphorus (mg/L) Average Monthly	1.07	1.1	1.2	0.84	0.50	1.69	0.68	0.94	0.74	0.51	0.88	0.78
Total Aluminum (mg/L) Average Monthly	< 0.0250	< 0.300	< 0.300	< 0.300	< 0.300	< 0.300	0.300	< 0.300	0.300	< 0.300	< 0.300	0.300
Dissolved Iron (mg/L) Average Monthly	< 0.200	< 0.200	< 0.200	< 0.200	< 0.200	0.338	< 0.200	< 0.200	0.200	< 0.200	< 0.200	< 0.200
Total Iron (mg/L) Average Monthly	< 0.200	0.371	< 0.200	< 0.200	0.256	0.339	< 0.200	< 0.200	0.200	0.475	< 0.200	0.306

**NPDES Permit Fact Sheet**  
**Chalfont New Britain Township Joint Sewer Authority**

**NPDES Permit No. PA0025917**

UV Dosage (mjoules/cm <sup>2</sup> ) Minimum	35338	31269	36308	37269	36781	35159	36519	35152	35235	35599	35871	33961
Chronic WET - Ceriodaphnia Survival (TUc) Daily Maximum		GG			GG			GG			1.0	
Chronic WET - Ceriodaphnia Reproduction (TUc) Daily Maximum		GG			GG			GG			1.0	
Chronic WET - Pimephales Survival (TUc) Daily Maximum		GG			GG			GG			1.0	
Chronic WET - Pimephales Growth (TUc) Daily Maximum		GG			GG			GG			1.0	

**DMR Data for Outfall 002 (from November 1, 2018 to October 31, 2019)**

Parameter	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18
pH (S.U.) Daily Maximum											7.4	
CBOD5 (mg/L) Daily Maximum											3.3	
COD (mg/L) Daily Maximum											< 50	
TSS (mg/L) Daily Maximum											132	
Oil and Grease (mg/L) Daily Maximum											< 0.10	
Fecal Coliform (CFU/100 ml) Daily Maximum											272	
TKN (mg/L) Daily Maximum											< 1.0	
Total Phosphorus (mg/L) Daily Maximum											0.14	
Dissolved Iron (mg/L) Daily Maximum											2.55	

Compliance History

Effluent Violations for Outfall 001, from: December 1, 2018 To: October 31, 2019

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
CBOD5	02/28/19	Avg Mo	1099	lbs/day	926	lbs/day
CBOD5	01/31/19	Avg Mo	1028	lbs/day	926	lbs/day
CBOD5	02/28/19	Wkly Avg	2538	lbs/day	1389	lbs/day
CBOD5	01/31/19	Wkly Avg	2994	lbs/day	1389	lbs/day
CBOD5	02/28/19	Wkly Avg	38.1	mg/L	36	mg/L
TSS	03/31/19	Avg Mo	1896	lbs/day	1157	lbs/day
TSS	02/28/19	Avg Mo	3686	lbs/day	1157	lbs/day
TSS	01/31/19	Avg Mo	3093	lbs/day	1157	lbs/day
TSS	05/31/19	Avg Mo	2746	lbs/day	1157	lbs/day
TSS	01/31/19	Wkly Avg	8226	lbs/day	1736	lbs/day
TSS	04/30/19	Wkly Avg	1767	lbs/day	1736	lbs/day
TSS	05/31/19	Wkly Avg	5142	lbs/day	1736	lbs/day
TSS	12/31/18	Wkly Avg	2224	lbs/day	1736	lbs/day
TSS	02/28/19	Wkly Avg	8226	lbs/day	1736	lbs/day
TSS	03/31/19	Wkly Avg	3459	lbs/day	1736	lbs/day
TSS	05/31/19	Avg Mo	38	mg/L	30	mg/L
TSS	02/28/19	Avg Mo	62.9	mg/L	30	mg/L
TSS	01/31/19	Avg Mo	39	mg/L	30	mg/L

**NPDES Permit Fact Sheet  
Chalfont New Britain Township Joint Sewer Authority**

**NPDES Permit No. PA0025917**

TSS	05/31/19	Wkly Avg	74	mg/L	45	mg/L
TSS	12/31/18	Wkly Avg	49.0	mg/L	45	mg/L
TSS	01/31/19	Wkly Avg	90	mg/L	45	mg/L
TSS	02/28/19	Wkly Avg	90.5	mg/L	45	mg/L
TSS	03/31/19	Wkly Avg	51	mg/L	45	mg/L
Fecal Coliform	12/31/18	IMAX	2420	CFU/100 ml	1000	CFU/100 ml
Ammonia	07/31/19	Avg Mo	152	lbs/day	77	lbs/day
Ammonia	04/30/19	Avg Mo	506	lbs/day	231	lbs/day
Ammonia	05/31/19	Avg Mo	448	lbs/day	77	lbs/day
Ammonia	04/30/19	Avg Mo	13.3	mg/L	6.0	mg/L
Ammonia	05/31/19	Avg Mo	8.98	mg/L	2.0	mg/L
Ammonia	07/31/19	Avg Mo	3.98	mg/L	2.0	mg/L
Total Phosphorus	05/31/19	Avg Mo	91	lbs/day	39	lbs/day
Total Phosphorus	08/31/19	Avg Mo	1.2	mg/L	1.0	mg/L
Total Phosphorus	05/31/19	Avg Mo	1.69	mg/L	1.0	mg/L
Total Phosphorus	08/31/19	Avg Mo	1.2	mg/L	1.0	mg/L
Total Phosphorus	10/31/19	Avg Mo	1.07	mg/L	1.0	mg/L
Total Phosphorus	09/30/19	Avg Mo	1.1	mg/L	1.0	mg/L



**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u> <b>Latitude</b> <u>40° 17' 18.41"</u> <b>Wastewater Description:</b> <u>Sewage Effluent</u>	<b>Design Flow (MGD)</b> <u>4.625</u> <b>Longitude</b> <u>-75° 10' 42.34"</u>
---------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------------------------------------

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

The site-specific design conditions used to develop the water quality based effluent limits (WQBELS) in WQM and TMS modeling are:

Node 1: CNBSTP (from previous WQPR)  
Node 2: PA0051250 - BCWSA - King Street STP (from previous WQPR)  
Temp = 23° C  
pH = 7.0  
D.O. (dissolved oxygen) Goal = 6-mg/l (trout stocking fishery criteria) (Default)  
K(CBOD<sub>5</sub>) = 0.6 (WQM model decay coefficient for advanced secondary treatment effluent)  
K(NH<sub>3</sub>) = 0.7  
Q<sub>7-10</sub> = 6.4-cfs (From previous permit) and 4.3 -cfs (BCWSA - King Street STP – 2012 WQPR)  
Q<sub>d</sub> = 4.625-MGD  
RMI (river mile index) = 37.85 and 31.7 miles  
Elevation = 220 and 198 feet  
Drainage Area = 61.7 and 75.9 mi<sup>2</sup> (USGS online drainage area tool)

**CBOD<sub>5</sub>, NH<sub>3</sub>-N, and Dissolved Oxygen**

Neshaminy Creek is listed as impaired for nutrients, organic enrichment, and low dissolved oxygen. Municipal point sources have been identified as a possible source for the impairment. Therefore, water quality based effluent limits for CBOD<sub>5</sub>, NH<sub>3</sub>-N (ammonia), and Dissolved Oxygen are required. Water quality based effluent limits are based on achieving in-stream dissolved oxygen and ammonia criteria using the Department’s WQM model.

The previous monthly average effluent limit for CBOD<sub>5</sub> was 12 mg/l (5/1 – 10/31) and 24 mg/l (11/1 – 4/30). The existing effluent limit for dissolved oxygen limit is 5.0 mg/l (minimum). The current WQM model recommends a CBOD<sub>5</sub> limit of 7-mg/l, based on an NH<sub>3</sub>-N limit of 2.0-mg/l. Therefore, CBOD<sub>5</sub> limits for this renewal has been changed to 7 mg/l (5/1 – 10/31) and 14 mg/l (11/1 – 4/30).

Phosphorous

Current limit for phosphorus remains unchanged for this renewal. Neshaminy Creek is listed as impaired for nutrients, organic enrichment, and low dissolved oxygen. Municipal point sources have been identified as a possible source for the impairment. Currently there is no nutrient TMDL for Neshaminy.

As per the “previous permit and fact sheet”, the facility previously had a seasonal TP limit of 2.0 mg/l for the period from April 1<sup>st</sup> through October 30<sup>th</sup>. For the NPDES permit renewal of 2009, the facility provided 3 years of discharge data which showed that TP ranged from 0.8 to 2.4 mg/l, with an average of 1.6 mg/l. The flows during the same period averaged 3.9-MGD, which was near the design flow of 4.0-MGD. Based on a concentration of 2.0-mg/l, a daily loading of 66.7 lbs/day would be generated at a design flow of 4.0-MGD. The actual loading was 52.1 lbs/day, with a range from 32.5 to 92.9 lbs/day. Based on an evaluation of the operational capabilities of the facility, CNBTJSA proposed a limit of 50 lbs/day which yielded the following proposed limits:

- 1.50-mg/l at 4.00-MGD
- 1.35-mg/l at 4.44-MGD
- 1.30-mg/l at 4.60-MGD

Since CNBTJSA proposed the design and construction of an expansion to a design flow of 4.6-MGD, the Department recommended a technology-based step reduction of the phosphorus limit (after expansion) to a monthly average limit of 1.0-mg/l. This represents an 80% reduction of influent phosphorus based on modern day conditions. The NPDES permit was later amended for a design flow of 4.625-MGD. Since there was only a 0.5% difference between the two flows, the final monthly average permit limit remained at 1.0-mg/l. Therefore, the monthly average limit for total phosphorus remains 1.0-mg/l.

NO<sub>2</sub>+NO<sub>3</sub> as N

Existing permit has NO<sub>2</sub>+NO<sub>3</sub> effluent limits as: 9.0 mg/l (5/1 – 10/31) and “Report” (11/1 – 6/30) and the current limits are carried over to this permit cycle.

According to the previous permit, all publicly owned sewage treatment plants (POTWs) that discharge to the Neshaminy Creek basin include numerical NO<sub>2</sub>+NO<sub>3</sub> limits designed to protect the Aqua Pennsylvania public water supply (PWS) intake located near Trevoise. The NO<sub>2</sub>+NO<sub>3</sub> limits are based by limiting the sum of the ammonia and NO<sub>2</sub>+NO<sub>3</sub> limits to 11 mg/l, from July 1<sup>st</sup> thru October 31<sup>st</sup>. CNB STP’s permit has a seasonal ammonia limit of 2.0 mg/l, and a NO<sub>2</sub>+NO<sub>3</sub> limit of 9.0 mg/l. NO<sub>2</sub>+NO<sub>3</sub> limits may be extended to additional months in future permits; therefore, a reporting requirement is recommended for the remaining months of the year. The recommended NO<sub>2</sub>+NO<sub>3</sub> effluent limits are: 9.0 mg/l (5/1 – 10/31) and “Report” (11/1 – 6/30).

Total Kjeldahl Nitrogen (TKN)

The recommended TKN effluent limit is “Report” and remains unchanged for this renewal.

Reasonable Potential Analysis - Toxic Pollutants

A review of the reported effluent sample data submitted with the permit application shows that most toxic pollutants were either not detected or were detected below most stringent surface water criteria. For pollutants that were detected above the most stringent criteria, the average concentrations were compared against a WQBEL generated by the Department's PENTOXSD model. The model was run with a Q7-10 flow of 6.4-cfs, background hardness of 141 mg/l and discharge hardness of 272 mg/l. An evaluation of the parameters of further interest shows that no permit limits are required, except as noted: (See page 18 for TMS report)

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Dissolved Solids (PWS)	Report	Report	Report	Report	Report	mg/L	N/A	N/A	Special Monitoring Applies
Chloride (PWS)	Report	Report	Report	Report	Report	mg/L	N/A	N/A	Special Monitoring Applies
Bromide	Report	Report	Report	Report	Report	mg/L	N/A	N/A	Special Monitoring Applies
Sulfate (PWS)	Report	Report	Report	Report	Report	mg/L	N/A	N/A	Special Monitoring Applies
Total Aluminum	35.2	54.9	912	1,423	2,280	µg/L	912	AFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Barium	Report	Report	Report	Report	Report	µg/L	4,552	THH	Discharge Conc > 10% WQBEL (no RP)
Total Copper	0.91	1.42	23.5	36.7	58.8	µg/L	23.5	AFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Iron	110	171	2,845	4,439	7,113	µg/L	2,845	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Lead	Report	Report	Report	Report	Report	µg/L	9.35	CFC	Discharge Conc > 10% WQBEL (no RP)
Total Zinc	Report	Report	Report	Report	Report	µg/L	195	AFC	Discharge Conc > 10% WQBEL (no RP)

Comments:

Total Dissolved Solids: The TDS criterion is applied at nearest downstream PWS intake. Once a quarter monitoring is continued for this renewal to be consistent for TDS monitoring requirement typically added by DRBC. As per the Toxic Management Spreadsheet, Chloride, Bromide and Sulfate are shown as report only, since TDS is <1,000 mg/l, monitoring for other TDS related parameters is not required at this time.

Iron (Fe) / Aluminum (Al): Ferric chloride and alum are commonly used chemicals for phosphate removal. Therefore, a monitoring condition for total iron, dissolved iron, and total aluminum were recommended during previous renewal. The PENTOXSD/Toxic Management model was run to determine the WQBEL for Iron and Aluminum using an in-stream hardness of 141-mg/l and discharge hardness of 272-mg/l. For a permitted flow of 4.625-MGD, the model calculated WQBEL of 2845-ug/l. Since the reported effluent Iron is greater than the WQBEL, permit limit of 2.84 mg/l for monthly average and 4.43 mg/l for daily maximum limit is applied for this renewal. Aluminum limits are established for this renewal. Permit limit of 0.9 mg/l for monthly average and 1.4 mg/l for daily maximum limit is applied for this renewal.

TRC (Total Residual Chlorine): The facility converted to UV (Ultraviolet) disinfection process around 1999. Therefore, there are no permit limits required for TRC or chlorine disinfection byproducts. A Part C permit condition is included in permit, in case chlorine is used for other than disinfection purposes.

Total Lead: For a permitted flow of 4.625-MGD, the level of detection for Lead is greater than 10% WQBEL. Therefore, for this renewal "Report only" has been added to the permit. The data will be reviewed during the next permit renewal to determine if a limit is needed.

Total Zinc: For a permitted flow of 4.625-MGD, the level of detection for Lead is greater than 10% WQBEL. Therefore "Report only" has been added to the permit for this renewal. The data will be reviewed during the next permit renewal to determine if a limit is needed.

Total Copper: The toxic modeling was run to determine the WQBEL for copper using an in-stream hardness of 141-mg/l and discharge hardness of 272-mg/l. For a permitted flow of 4.625-MGD, the model calculated WQBEL of 23.5-ug/l. Since there is not enough data reported in the last permit cycle "Report only" has been included for 58 months. The final WQBELs of 0.0235 mg/l based on the current discharge and facility conditions become effective on the beginning 59th month unless DEP issues an amendment to this permit prior to that date. The permittee shall conduct a TRE in accordance with DEP's Water Quality Toxics Management Strategy, Appendix C, Permittee Guidance for Conducting a Toxics Reduction Evaluation (TRE) (361-0100-003). See permit Part C.III

For Outfall 001,  Acute  Chronic WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other:

The dilution series used for the tests was: 100%, 77%, 53%, 27%, and 13%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 53%.

**Summary of Four Most Recent Test Results**

TST Data Analysis

(NOTE – In lieu of recording information below, the application manager may attach the DEP WET Analysis Spreadsheet).

Test Date	Ceriodaphnia Results (Pass/Fail)		Pimephales Results (Pass/Fail)	
	Survival	Reproduction	Survival	Growth
June 2016	100 %	100 %	100 %	100 %
July 2017	100 %	100 %	92.5 %	100 %
December 2018	100 %	100 %	98 %	100 %
December 2019	100 %	100 %	100 %	100 %

\* A “passing” result is that in which the replicate data for the TIWC is not statistically significant from the control condition. This is exhibited when the calculated t value (“T-Test Result”) is greater than the critical t value. A “failing” result is exhibited when the calculated t value (“T-Test Result”) is less than the critical t value.

**Evaluation of Test Type, IWC and Dilution Series for Renewed Permit**

Acute Partial Mix Factor (PMFa): 1                      Chronic Partial Mix Factor (PMFc): 1

**1. Determine IWC – Acute (IWCa):**

$$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$$

$$[(4.625 \text{ MGD} \times 1.547) / ((6.4 \text{ cfs} \times 1) + (4.625 \text{ MGD} \times 1.547))] \times 100 = \mathbf{52.7\%}$$

Is IWCa < 1%?  YES  NO

**Type of Test for Permit Renewal: Chronic Tests Required**

**2b. Determine Target IWCC**

$$(Q_d \times 1.547) / (Q_{7-10} \times PMFC) + (Q_d \times 1.547)$$

$$[(4.625 \text{ MGD} \times 1.547) / ((6.4 \text{ cfs} \times 1) + (4.625 \text{ MGD} \times 1.547))] \times 100 = \mathbf{53\%}$$

**3. Determine Dilution Series**

*(NOTE – check Attachment C of WET SOP for dilution series based on TIWCa or TIWCc, whichever applies).*

Dilution Series = 100%, 77%, 53%, 27%, and 13%.

**WET Limits**

Has reasonable potential been determined?  YES  NO

Will WET limits be established in the permit?  YES  NO

**Toxicity Limit Calculation**

$$TUc = 1/TIWCc = 1 / (IWCC/1.0) = 1 / 0.53 = \mathbf{1.88 TUc}$$

The chronic toxicity limit for a 4.625-mgd facility is 1.88 TUc, or NOEC = 53%

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Completion of 58<sup>th</sup> Month.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Copper, Total	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Beginning of 59<sup>th</sup> month through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Copper, Total	0.91	1.42	XXX	0.023	0.036	0.058	1/month	24-Hr Composite

**PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	9.0 Max	XXX	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5 Raw Sewage Influent	XXX	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
CBOD5 Nov 1 - Apr 30	540	810	XXX	14	21	28	2/week	24-Hr Composite
CBOD5 May 1 - Oct 31	270	405	XXX	7	10.5	14	2/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS	1157	1736	XXX	30	45	60	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) May 1 – Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/week	Grab
Fecal Coliform (No./100 ml) Oct 1 – Apr 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000*	2/week	Grab
Nitrate-Nitrite Nov 1 - Jun 30	347	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Nitrate-Nitrite Jul 1 - Oct 31	347	XXX	XXX	9.0	XXX	18	2/week	24-Hr Composite

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia Nov 1 - Apr 30	231	XXX	XXX	6.0	XXX	12	2/week	24-Hr Composite
Ammonia May 1 - Oct 31	77	XXX	XXX	2.0	XXX	4	2/week	24-Hr Composite
Total Phosphorus Nov 1 - Mar 31	77	XXX	XXX	2.0	XXX	4	2/week	24-Hr Composite
Total Phosphorus Apr 1 - Oct 31	39	XXX	XXX	1.0	XXX	2	2/week	24-Hr Composite
Total Aluminum	0.0352	0.054	XXX	0.9	1.4	2.2	1/month	24-Hr Composite
Dissolved Iron	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Total Iron	0.11	0.171	XXX	2.84	4.43	7.11	1/month	24-Hr Composite
Total Lead	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Total Zinc	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
TKN	Report	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Total Dissolved Solids	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	24-Hr Composite
UV Dosage (mjoules/cm <sup>2</sup> )	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Chronic WET - Ceriodaphnia Survival (TUc)	XXX	XXX	XXX	XXX	1.9 Daily Max	XXX	See Permit	See Permit
Chronic WET - Ceriodaphnia Reproduction (TUc)	XXX	XXX	XXX	XXX	1.9 Daily Max	XXX	See Permit	See Permit
Chronic WET - Pimephales Survival (TUc)	XXX	XXX	XXX	XXX	1.9 Daily Max	XXX	See Permit	See Permit
Chronic WET - Pimephales Growth (TUc)	XXX	XXX	XXX	XXX	1.9 Daily Max	XXX	See Permit	See Permit



**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 002, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Daily Maximum	Maximum	Instant. Maximum		
pH (S.U.)	XXX	XXX	XXX	Report	XXX	XXX	1/year	Grab
CBOD5	XXX	XXX	XXX	Report	XXX	XXX	1/year	Grab
COD	XXX	XXX	XXX	Report	XXX	XXX	1/year	Grab
TSS	XXX	XXX	XXX	Report	XXX	XXX	1/year	Grab
Oil and Grease	XXX	XXX	XXX	Report	XXX	XXX	1/year	Grab
Fecal Coliform (CFU/100 ml)	XXX	XXX	XXX	Report	XXX	XXX	1/year	Grab
TKN	XXX	XXX	XXX	Report	XXX	XXX	1/year	Grab
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	1/year	Grab
Dissolved Iron	XXX	XXX	XXX	Report	XXX	XXX	1/year	Grab



## Discharge Information

Instructions Discharge Stream

Facility: Chalfont New Britain STP NPDES Permit No.: PA0025917 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Sewage Effluent

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>
4.625	272	7					6.4	

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank	
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
Group 1	Total Dissolved Solids (PWS)	mg/L	808								
	Chloride (PWS)	mg/L	429								
	Bromide	mg/L									
	Sulfate (PWS)	mg/L	30.5								
	Fluoride (PWS)	mg/L									
Group 2	Total Aluminum	µg/L	793								
	Total Antimony	µg/L									
	Total Arsenic	µg/L									
	Total Barium	µg/L	899								
	Total Beryllium	µg/L									
	Total Boron	µg/L	83.1								
	Total Cadmium	µg/L									
	Total Chromium (III)	µg/L									
	Hexavalent Chromium	µg/L									
	Total Cobalt	µg/L									
	Total Copper	µg/L	16								
	Free Available Cyanide	µg/L									
	Total Cyanide	µg/L									
	Dissolved Iron	µg/L									
	Total Iron	µg/L	9170								
	Total Lead	µg/L	4.6								
	Total Manganese	µg/L	168								
	Total Mercury	µg/L									
	Total Nickel	µg/L									
	Total Phenols (Phenolics) (PWS)	µg/L									
Total Selenium	µg/L										
Total Silver	µg/L										
Total Thallium	µg/L										
Total Zinc	µg/L	55									
Total Molybdenum	µg/L	2.9									
Acrolein	µg/L	<									
Acrylamide	µg/L	<									
Acrylonitrile	µg/L	<									
Benzene	µg/L	<									
Bromoform	µg/L	<									







Stream / Surface Water Information

Chalfont New Britain STP, NPDES Permit No. PA0025917, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: \_\_\_\_\_ No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	002484	37.85	220	61.7			Yes
End of Reach 1	002484	31.7	198	75.9			Yes

**Q<sub>7-10</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	37.85	0.104										100	7	141	
End of Reach 1	31.7	0.057													

**Q<sub>h</sub>**

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	37.85														
End of Reach 1	31.7														



## Model Results

Chalfont New Britain STP, NPDES Permit No. PA0025917, Outfall 001

**Instructions** **Results**

[RETURN TO INPUTS](#)

[SAVE AS PDF](#)

[PRINT](#)

All

Inputs

Results

Limits

**Hydrodynamics**

**Q<sub>7-10</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
37.85	6.42		6.42	7.155	0.00068	0.804	54.503	67.762	0.31	1.214	6.4
31.7	7.23		7.2262								

**Q<sub>h</sub>**

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
37.85	37.72		37.72	7.155	0.00068	1.361	54.503	40.037	0.605	0.621	69.585
31.7	41.848		41.85								

**Wasteload Allocations**

**AFC**

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Bromide	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	1,423	
Total Barium	0	0		0	21,000	21,000	39,834	
Total Boron	0	0		0	8,100	8,100	15,364	
Total Copper	0	0		0	18.577	19.4	36.7	Chem Translator of 0.96 applied
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	93.684	126	240	Chem Translator of 0.741 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	156.779	160	304	Chem Translator of 0.978 applied

**CFC**

CCT (min):

PMF:

Analysis Hardness (mg/l):

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Bromide	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	4,100	4,100	7,777	
Total Boron	0	0		0	1,600	1,600	3,035	
Total Copper	0	0		0	12,012	12.5	23.7	Chem Translator of 0.96 applied
Total Iron	0	0		0	1,500	1,500	2,845	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	3,651	4.93	9.35	Chem Translator of 0.741 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	158.062	160	304	Chem Translator of 0.986 applied

**THH**      CCT (min):       PMF:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Bromide	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	2,400	2,400	4,552	
Total Boron	0	0		0	3,100	3,100	5,880	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	1,000	1,000	1,897	
Total Zinc	0	0		0	N/A	N/A	N/A	

**CRL**      CCT (min):       PMF:       Analysis Hardness (mg/l):       Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Bromide	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	

Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

**Recommended WQBELs & Monitoring Requirements**

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Dissolved Solids (PWS)	Report	Report	Report	Report	Report	mg/L	N/A	N/A	Special Monitoring Applies
Chloride (PWS)	Report	Report	Report	Report	Report	mg/L	N/A	N/A	Special Monitoring Applies
Bromide	Report	Report	Report	Report	Report	mg/L	N/A	N/A	Special Monitoring Applies
Sulfate (PWS)	Report	Report	Report	Report	Report	mg/L	N/A	N/A	Special Monitoring Applies
Total Aluminum	35.2	54.9	912	1,423	2,280	µg/L	912	AFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Barium	Report	Report	Report	Report	Report	µg/L	4,552	THH	Discharge Conc > 10% WQBEL (no RP)
Total Copper	0.91	1.42	23.5	36.7	58.8	µg/L	23.5	AFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Iron	110	171	2,845	4,439	7,113	µg/L	2,845	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Lead	Report	Report	Report	Report	Report	µg/L	9.35	CFC	Discharge Conc > 10% WQBEL (no RP)
Total Zinc	Report	Report	Report	Report	Report	µg/L	195	AFC	Discharge Conc > 10% WQBEL (no RP)

**Other Pollutants without Limits or Monitoring**

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., ≤ Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Boron	3,035	µg/L	Discharge Conc ≤ 10% WQBEL
Total Manganese	1,897	µg/L	Discharge Conc ≤ 10% WQBEL
Total Molybdenum	N/A	N/A	No WQS