

Application Type Renewal  
Facility Type Municipal  
Major / Minor Major

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0026646  
APS ID 30164  
Authorization ID 1023729

**Applicant and Facility Information**

Applicant Name	<u>Antietam Valley Municipal Authority Berks County</u>	Facility Name	<u>Antietam Valley STP</u>
Applicant Address	<u>502 Butter Lane Reading, PA 19606-1604</u>	Facility Address	<u>502 Butter Lane Reading, PA 19606-1604</u>
Applicant Contact	<u>Kerry Ustaszewski</u>	Facility Contact	<u>Kerry Ustaszewski</u>
Applicant Phone	<u>(610) 779-0150</u>	Facility Phone	<u>(610) 779-0150</u>
Client ID	<u>77399</u>	Site ID	<u>253991</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Saint Lawrence Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Berks</u>
Date Application Received	<u>April 28, 2014</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>May 23, 2014</u>	If No, Reason	<u>Major Facility</u>
Purpose of Application	<u>NPDES Renewal.</u>		

**Summary of Review**

The Antietam Valley Municipal Authority has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of a NPDES permit for the Antietam Valley STP. The amended permit was last reissued to the Antietam Valley Municipal Authority on December 21, 2009 and became effective on January 1, 2010. The permit was amended on November 29, 2011. The permit expired on December 31, 2014 but the terms and conditions of the permit have been administratively extended since that time.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted and a notice of the draft permit be published in the *Pennsylvania Bulletin* for public comments for 30 days. A file review of documents associated with the discharge or permittee may be available at the PA DEP southcentral regional office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file reviews, contact the SCRO file review coordinator at 717.705.4700.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Aaron Baar / Permits Section	July 22, 2019
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria D. Bebenek, P.E. / Program Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	1.225
Latitude	40° 19' 50.89"	Longitude	-75° 52' 23.26"
Quad Name		Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	Antietam Creek (CWF)	Stream Code	01790
NHD Com ID	25963816	RMI	4.79
Drainage Area	9.98 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.3998
Q <sub>7-10</sub> Flow (cfs)	3.99	Q <sub>7-10</sub> Basis	USGS StreamStats
Elevation (ft)	307.56	Slope (ft/ft)	
Watershed No.	3-C	Chapter 93 Class.	CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	PATHOGENS		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Pottstown		
PWS Waters	Schuylkill River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	~15

**Drainage Area**

The discharge is to a Antietam Creek at RMI 4.79. A drainage area upstream of the discharge is determined to be 9.98 sq.mi. according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

**Stream Flow**

According to StreamStats, this area has a Q<sub>7-10</sub> of 3.99 cfs and a drainage area of 9.98 mi<sup>2</sup>, which results in a LFY of 0.3998 cfs/mi<sup>2</sup>. This information was used to obtain a Q<sub>7-10</sub>, a chronic 30-day (Q<sub>30-10</sub>) and acute (Q<sub>1-10</sub>) exposure stream flows for the discharge point as follows (Guidance No. 391-2000-023).

$$\begin{aligned} \text{LFY} &= 3.99 \text{ cfs}/9.98 \text{ mi}^2 = 0.3998 \text{ cfs/mi}^2 \\ \text{Q}_{7-10} &= 3.99 \text{ cfs} \\ \text{Q}_{30-10} &= 1.36 * 3.99 \text{ cfs} = 5.4264 \text{ cfs} \\ \text{Q}_{1-10} &= 0.64 * 3.99 \text{ cfs} = 2.5536 \text{ cfs} \end{aligned}$$

**Antietam Creek**

25 Pa Code §93.9 classifies Antietam Creek as a CWF waterway. Effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. The discharge is in a stream segment listed not attaining uses (pathogens/source unknown). No local TMDL has been taken into consideration during this review.

*Public Water Supply Intake*

The nearest downstream public water supply intake is the Borough of Pottstown intake located on Schuylkill River approximately 15 miles from the discharge. Considering the distance and nature, the discharge is not expected to significantly affect the water supply.

*Class A Wild Trout Streams*

The receiving stream is not a Class A Wild Trout stream; therefore no Class A Wild Trout Fishery is impacted by this discharge.

<b>Treatment Facility Summary</b>				
<b>Treatment Facility Name:</b> Antietam Valley STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary With Ammonia Reduction	Oxidation Ditch	Gas Chlorine	1.225
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
2.45	2050	Not Overloaded	Anaerobic Digestion	Landfill

The Antietam Valley Municipal Authority owns and operates the sanitary wastewater treatment facility located in Saint Lawrence Borough, Berks County. The facility serves portions of Mount Penn Borough, Lower Alsace Township, Exeter Township, Saint Lawrence Borough and the City of Reading. Wastes are residential in nature, and all sewer systems are 100% separated. Having an annual average design flow of 1.225 mgd and a hydraulic design capacity of 2.45 MGD, this facility includes a headworks featuring grinding, fine screening, comminution and grit removal. Flow from the headworks is split between two systems. System 1 consists of two primary clarifiers, four aeration tanks, two secondary clarifiers and one anaerobic primary digester. System 2 consists of two aeration tanks, one secondary clarifier and an aerobic digester. Flows from System 1 and System 2 then flow into two oxidation tanks, secondary clarification, chlorine disinfection system, dichlorination system and the outfall (Outfall 001). No other chemicals are declared in the application.

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	A summary of past DMR data is presented on the next page.
<b>Summary of Inspections:</b>	There are no inspection reports available in the File Room at the time this report was drafted.

Other Comments: A file review revealed that there is one Clean Water open violation associated with this facility - Unauthorized, unpermitted discharge of sewage to waters of the Commonwealth (6/20/2019).

Compliance History

DMR Data for Outfall 001 (from June 1, 2018 to May 31, 2019)

Parameter	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18	OCT-18	SEP-18	AUG-18	JUL-18	JUN-18
Flow (MGD) Average Monthly	1.421	1.03	1.412	1.357	1.512	1.51	1.972	1.028	2.143	2.263	1.066	0.901
Flow (MGD) Daily Maximum	2.987	1.588	3.307	2.116	3.69	2.744	3.335	1.445	6.058	5.936	2.892	2.366
pH (S.U.) Minimum	6.7	6.8	6.6	6.8	6.8	6.7	6.7	6.9	6.7	6.9	7.0	7.0
pH (S.U.) Maximum	7.2	7.1	7.2	7.1	7.4	7.1	7.1	7.2	7.2	7.3	7.3	7.5
DO (mg/L) Minimum	6.7	7.1	5.9	7.1	7.2	7.6	7.7	6.4	5.9	6.5	6.6	6.6
TRC (mg/L) Average Monthly	0.06	0.04	0.04	0.06	0.08	0.07	0.08	0.06	< 0.06	< 0.07	0.04	0.03
TRC (mg/L) Instantaneous Maximum	0.16	0.15	0.10	0.13	0.15	0.13	0.13	0.12	0.13	0.26	0.16	0.09
CBOD5 (lbs/day) Average Monthly	< 30	< 18	< 26	< 22	< 30	< 25	< 33	< 18	< 51	< 64	< 21	< 19
CBOD5 (lbs/day) Weekly Average	< 43	< 25	< 30	< 27	< 50	< 32	< 44	< 25	142	< 101	< 38	< 34
CBOD5 (mg/L) Average Monthly	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2
CBOD5 (mg/L) Weekly Average	< 2	< 2	< 2	< 2	3	< 2	< 2	< 2	3	< 3	3	< 2
BOD5 (lbs/day) Raw Sewage Influent   Average Monthly	1763	1445	1549	1621	1453	1435	1248	1411	1586	2035	1407	1648
BOD5 (mg/L) Raw Sewage Influent   Average Monthly	123	165	128	149	118	122	80	165	166	84	178	205
TSS (lbs/day) Average Monthly	< 30	< 21	< 16	< 16	< 17	< 34	< 25	< 19	< 54	< 73	< 17	< 24
TSS (lbs/day) Raw Sewage Influent   Average Monthly	1417	966	1323	1680	1736	1079	1933	1455	2017	1516	1487	1872

**NPDES Permit Fact Sheet  
Antietam Valley STP**

**NPDES Permit No. PA0026646**

TSS (lbs/day) Weekly Average	63	< 49	< 27	27	31	52	43	< 58	136	< 136	31	74
TSS (mg/L) Average Monthly	< 2	< 2	< 1	< 1	< 1	< 3	< 2	< 2	< 3	< 2	< 2	< 2
TSS (mg/L) Raw Sewage Influent   Average Monthly	101	107	113	147	136	90	115	166	191	76	186	238
TSS (mg/L) Weekly Average	4	< 6	< 2	3	2	5	2	< 5	3	< 4	4	4
Total Dissolved Solids (lbs/day) Average Monthly			4230			3837			2583			3060
Total Dissolved Solids (mg/L) Average Monthly			437			405			432			442
Fecal Coliform (CFU/100 ml) Geometric Mean	90	57	17	71	36	57	40	34	22	34	20	25
Ammonia (lbs/day) Average Monthly	< 1	< 0.9	< 3	< 1	< 6	< 1	< 2	< 0.9	< 3	< 5	< 2	< 0.9
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.17	< 0.1	< 0.29	< 0.1	< 0.11	< 0.1	< 0.11	< 0.16	< 0.14	< 0.1

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.21	XXX	0.68	1/day	Grab
CBOD5	255	383	XXX	25.0	40.0	50	2/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS	306	460	XXX	30.0	45.0	60	2/week	24-Hr Composite
Total Dissolved Solids	XXX	Report Daily Max	XXX	1,000	XXX	XXX	1/quarter	24-Hr Composite
Ammonia Nov 1 - Apr 30	77.0	XXX	XXX	7.5	XXX	15	2/week	24-Hr Composite
Ammonia May 1 - Oct 31	26.0	XXX	XXX	2.5	XXX	5	2/week	24-Hr Composite

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) 1.225  
 Latitude 40° 19' 50.88" Longitude -75° 52' 24.13"  
 Wastewater Description: Sewage Effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to water quality analysis and BPJ where applicable.

**Water Quality-Based Limitations**

*CBOD<sub>5</sub>, NH<sub>3</sub>-N and Dissolved Oxygen (DO)*

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD<sub>5</sub>, NH<sub>3</sub>-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. The model was utilized and the model output indicated that existing WQBELs of 25 mg/L for CBOD<sub>5</sub> and 2.5 mg/L for ammonia (summer) are still appropriate.

The monitoring frequency and sample type for NH<sub>3</sub>-N, CBOD<sub>5</sub> and DO are proposed to remain unchanged.

*Toxics*

PADEP's Toxic Screening Analysis (Version 2.6) was used to identify water quality pollutants of concern. Initial results from the effluent data in the application resulted in scores of parameters being identified as candidates for PENTOXSD modeling due to high detection criteria used by the testing lab. Three extra samples were requested to verify results; TDS, Chloride, Total Copper, Free Available Cyanide, Total Lead, Total Phenols, Chloroform and Dichlorobromomethane were still identified as candidates for PENTOXSD modeling based on the results of the extra sampling. These parameters were evaluated using PENTOXSD (Version 2.0d). The PENTOXSD output indicated that a WQBEL for Copper is recommended. Monitoring is also recommended for Free Available Cyanide, Chloroform and Dichlorobromomethane.

Given the limited data set provided, the reviewer recommends 1/week monitoring of Total Copper, Free Available Cyanide, Chloroform and Dichlorobromomethane in order to best determine during the next permit renewal whether any limits are warranted.



*Total Residual Chlorine*

Total Residual Chlorine (TRC) effluent levels must be regulated in accordance with 25 Pa Code §92a.48(b). DEP's TRC\_CALC worksheet was utilized to determine if the existing limits of 0.21 mg/L (average monthly) and 0.68 mg/L (instantaneous maximum) are still appropriate. The model was utilized, and the model output indicated that existing limits are still appropriate.

**Best Professional Judgment (BPJ) Limitations**

*Dissolved Oxygen*

A minimum of 5.0 mg/L for DO is an existing effluent limit and will remain unchanged in the draft permit as recommended by DEP's SOP. This requirement has also been assigned to other sewage facilities in the region. 5.0 mg/L is taken directly from 25 Pa. Code § 93.7(a) and it is also determined to be appropriate according to water quality modeling.

*Total Phosphorus & Total Nitrogen*

DEP's SOP no. BPNPSM-PMT-033 recommends monitoring requirements for Total Phosphorus and Total Nitrogen for all sewage facilities. Therefore, routine monitoring for Total Phosphorous and Total Nitrogen are recommended to be introduced on a 2/week basis for this permit renewal.

*Total Dissolved Solids*

The existing TDS discharge limit of 1000 mg/L (AVG) will be maintained from the previous permit. DMR records indicate that the existing facility is meeting this limit.

**Additional Considerations**

*DRBC*

This fact sheet will be forwarded to the DRBC for review and comment.

*Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

*Monitoring Frequency and Sample Type*

The facility currently is required to collect 24-hr composite effluent samples 2/ week. The existing and proposed monitoring frequencies for all pollutants will remain the same as those specified in the existing permit.

*Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

*Anti-backsliding Requirement*

All effluent limits proposed in this fact sheet are as stringent as effluent limits specified in the existing permit renewal. This approach is in accordance with 40 CFR §122.44(l)(1).

*Mass Loading Limitations*

All effluent mass loading limits are based on the formula: design flow x concentration limit x conversion factor of 8.34.

*Pre-Treatment*

The application states that there are no industrial users connected to the treatment plant.

**Whole Effluent Toxicity (WET)**

For Outfall 001,  Acute  Chronic WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other:

The dilution series used for the tests was: 100%, 73%, 45%, 23%, and 11%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 45.

**Summary of Four Most Recent Test Results**

(NOTE – Enter results into one table, depending on which data analysis method was used).

NOEC/LC50 Data Analysis

Test Date	Ceriodaphnia Results (% Effluent)			Pimephales Results (% Effluent)			Pass? *
	NOEC Survival	NOEC Reproduction	LC50	NOEC Survival	NOEC Growth	LC50	
3/17/14	100%	73%	>100%	100%	100%	>100%	Pass
6/17/13	100%	100%	>100%	100%	100%	>100%	Pass
9/24/13	100%	100%	>100%	100%	100%	>100%	Pass
12/17/13	100%	100%	>100%	100%	100%	>100%	Pass

\* A "passing" result is that which is greater than or equal to the TIWC value.

TST Data Analysis

Test Date	Ceriodaphnia Results (Pass/Fail)		Pimephales Results (Pass/Fail)	
	Survival	Reproduction	Survival	Growth
3/17/14	Pass	Fail	Pass	Pass
6/17/13	Pass	Fail	Pass	Pass
9/24/13	Pass	Pass	Pass	Fail
12/17/13	Pass	Pass	Pass	Pass

\* A "passing" result is that in which the replicate data for the TIWC is not statistically significant from the control condition. This is exhibited when the calculated t value ("T-Test Result") is greater than the critical t value. A "failing" result is exhibited when the calculated t value ("T-Test Result") is less than the critical t value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? (NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).

YES  NO

Comments: N/A

**Evaluation of Test Type, IWC and Dilution Series for Renewed Permit**

Acute Partial Mix Factor (PMFa): 1.0

Chronic Partial Mix Factor (PMFc): 1.0

**1. Determine IWC – Acute (IWC<sub>a</sub>):**

$$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$$

$$[(1.225 \text{ MGD} \times 1.547) / ((3.99 \text{ cfs} \times 1.0) + (1.225 \text{ MGD} \times 1.547))] \times 100 = 32\%$$

Is IWC<sub>a</sub> < 1%?  YES  NO (YES - Acute Tests Required OR NO - Chronic Tests Required)

If the discharge is to the tidal portion of the Delaware River, indicate how the type of test was determined:

N/A

Type of Test for Permit Renewal: Chronic

**2a. Determine Target IWCa (If Acute Tests Required)**

TIWCa = N/A

**2b. Determine Target IWCc (If Chronic Tests Required)**

$(Q_d \times 1.547) / (Q_{7-10} \times PMFC) + (Q_d \times 1.547)$

$[(1.225 \text{ MGD} \times 1.547) / ((3.99 \text{ cfs} \times 1.0) + (1.225 \text{ MGD} \times 1.547))] \times 100 = 32\%$

**3. Determine Dilution Series**

*(NOTE – check Attachment C of WET SOP for dilution series based on TIWCa or TIWCc, whichever applies).*

Dilution Series = 100%, 66%, 32%, 16%, and 8%.

**WET Limits**

Has reasonable potential been determined?  YES  NO

Will WET limits be established in the permit?  YES  NO

If WET limits will be established, identify the species and the limit values for the permit (TU).

N/A

If WET limits will not be established, but reasonable potential was determined, indicate the rationale for not establishing WET limits:

**WET testing for this renewal was conducted by QC laboratories (Eurofins QC). Per the email from Maria Schumack on October 26, 2017, it is assumed that all tests performed by Eurofins QC should be considered invalid. Quarterly sampling for the first year of the permit term and annual sampling will be resumed in the second year provided they pass all 4 quarterly tests**

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.21	XXX	0.68	1/day	Grab
CBOD5	255	383	XXX	25.0	40.0	50	2/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS	306	460	XXX	30.0	45.0	60	2/week	24-Hr Composite
Total Dissolved Solids	XXX	Report Daily Max	XXX	1,000.0	XXX	XXX	1/quarter	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/week	Grab
Total Nitrogen	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Ammonia Nov 1 - Apr 30	77.0	XXX	XXX	7.5	XXX	15	2/week	24-Hr Composite
Ammonia May 1 - Oct 31	26.0	XXX	XXX	2.5	XXX	5	2/week	24-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Copper (ug/L)	Report	XXX	XXX	Report	XXX	Report	1/week	24-Hr Composite
Free Cyanide (ug/L)	Report	XXX	XXX	Report	XXX	Report	1/week	24-Hr Composite
Total Lead (ug/L)	Report	XXX	XXX	Report	XXX	Report	1/week	24-Hr Composite
Dibromochloro-methane (ug/L)	Report	XXX	XXX	Report	XXX	Report	1/week	24-Hr Composite

Compliance Sampling Location: Outfall 001



Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]