

Application Type Renewal  
 Facility Type Municipal  
 Major / Minor Major

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0026981  
 APS ID 956101  
 Authorization ID 1208327

**Applicant and Facility Information**

Applicant Name	<b>Pennsylvania-American Water Company</b>	Facility Name	<b>City of Duquesne STP</b>
Applicant Address	800 West Hersheypark Drive	Facility Address	North Duquesne Boulevard
	Hershey, PA 17033		Duquesne, PA 15110
Applicant Contact	Ms. Brandy Braun	Facility Contact	Same as Applicant
Applicant Phone	412.384.5115	Facility Phone	Same as Applicant
Client ID	87712	Site ID	262922
Ch 94 Load Status	Not Overloaded	Municipality	Duquesne City
Connection Status		County	Allegheny
Date Application Received	<u>October 24, 2017</u>	EPA Waived?	No
Date Application Accepted		If No, Reason	Major Facility
Purpose of Application	Application for a renewal and transfer of an NPDES permit for discharge of treated Sewage		

**Summary of Review**

The permittee has applied for a renewal and transfer of NPDES Permit No. PA0026981 from the Municipal Authority of the City of McKeesport (MACM) to Pennsylvania-American Water Company (PAWC).

NPDES Permit No. PA0026981 was previously issued by the Department on September 05, 2003. That permit expired on September 5, 2008.

The permit is being transferred from MACM, POTW, to PAWC, a publicly-traded investor-owned public utility. PAWC is also Purchasing Port Vue Borough, PA0254690, Dravosburg Borough, PA0028401 and City of McKeesport, PA0026913, collection and treatment facilities from MACM.

This permit will be issued directly to PAWC upon completion of the public comment period and sale of all assets from MACM to PAWC. PAWC has entered into a COA with the Department to manage the transfer of assets. The COA covers the transfer of all NPDES and WQM Permits, addresses operation and maintenance of the collection/treatment system (including NMC implementation), and submission of a revised Long Term Control Plan (LTCP).

Outfalls 002, 003, 005 & IMP 201 are again permitted to serve as CSOs. Please note that Outfall 004, Overland Avenue has been renamed IMP 201. Part C.III has been incorporated into the permit and all scheduled interim milestones were taken from the Departments LTCP Approval Letter, Dated February 17, 2009, which was based upon the City of Duquesne LTCP submission, dated September 24, 2008. The COA requires that another revision of the LTCP be submitted to the Department for review. Upon approval, this NPDES Permit will be amended to reflect revised scheduled interim milestones.

Part C.II.B., includes site specific NMC implementation and documentation obligations taken from the Pennsylvania American Water Company Nine Minimum Control Plan Update, dated December 5, 2017. All NMCs shall be implemented

Approve	Deny	Signatures	Date
X		/s/ William C. Mitchell, E.I.T. / Project Manager	01/08/2018
X		/s/ Donald J. Leone, P.E. / Environmental Engineer Manager	01/12/2018

### Summary of Review

utilizing best professional judgement and best management practices to ensure maximum efficacy.

STP effluent sampling shall be taken at an Internal Monitoring Point (IMP) 101, which is located at the discharge pipe of the chlorine contact tank prior to combining with the flow from the CSO diversion chamber. CSO monitoring shall be taking at IMP 201, which is located at the diversion chamber of the CSO prior to combining with the effluent from the STP.

IMP 101 & IMP 201 are authorized to discharge from Outfall 002 to the Thompson Run, which is classified as a WWF, located in State Watershed No. 19-C.

When evaluating effluent limits the Point of First Use is the Monongahela River. Thompson Run is impaired for metals with the source being AMD. On Wednesday, December 6, 2017, I visited the STP to verify outfall location. Outfall 001 discharges to Thompson Run 49.2 feet from where Thompson Run is culverted, under the former US Steel Duquesne Works, to the Monongahela River. There are four pictures attached to showing evidence of AMD in the vicinity of the discharge prior to being culverted.

All pages of the permit have been revised to be consistent with NPDES Permit Language 3800-PM-BCW0012, Rev. 10/2017 for Individual Municipal NPDES Permits. All References to POTW have been removed as the facility and permitted CSO will no longer be owned by a Municipal Authority or Municipality.

Storm Water Outfall 010 is again permitted for the discharge of un-contaminated storm water runoff from areas in and around the treatment plant. These outfalls are subject to the Departments current storm water conditions listed in Part C.VI of the Permit. Please note that Outfall 010 was previously called SW-1.

Since PAWC owns both the McKeesport STP, PA002691 and the City of Duquesne STP, PA0026981 and their combined flow is greater than 5.0 MGD, PART C.III, Industrial Pretreatment Program Implementation, has been added to the permit.

The permittee currently submits their Discharge Monitoring Reports through DEP's electronic Discharges Monitoring System.

The applicant has complied with Act 14 Notifications and no comments were received.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	2.0
Latitude	40° 22' 47.05"	Longitude	-79° 51' 1.92"
Quad Name	Braddock	Quad Code	
Wastewater Description:	Combined Sewer Overflow & Sewage Effluent		
Receiving Waters	Thompson Run	Stream Code	37449
NHD Com ID	134839893	RMI	0.30
Drainage Area	5.32	Yield (cfs/mi <sup>2</sup> )	0.0114
Q <sub>7-10</sub> Flow (cfs)	0.0607	Q <sub>7-10</sub> Basis	USGS StreamStats 4.0
Elevation (ft)	734	Slope (ft/ft)	
Watershed No.	19-A	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Metals		
Source(s) of Impairment	Abandoned Mine Drainage		
TMDL Status	Final	Name	Thompson Run
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake		Pennsylvania-American Water Company, Pittsburgh	
PWS Waters	Monongahela River	Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	

Changes Since Last Permit Issuance: NONE

Discharge, Receiving Waters and Water Supply Information		
Outfall No.	Point of First Use for Outfall 001	Design Flow (MGD)
Latitude	40° 22' 53.40"	Longitude
Quad Name	Braddock	Quad Code
Wastewater Description:	Sewage Effluent	
Receiving Waters	Monongahela River	Stream Code
NHD Com ID	99408094	RMI
Drainage Area	7180	Yield (cfs/mi <sup>2</sup> )
Q <sub>7-10</sub> Flow (cfs)	1060	Q <sub>7-10</sub> Basis
Elevation (ft)	712	Slope (ft/ft)
Watershed No.	19-A	Chapter 93 Class.
Existing Use	WWF	
Exceptions to Use	Existing Use Qualifier	
Assessment Status	Impaired	
Cause(s) of Impairment	PCB	
Source(s) of Impairment	Source Unknown	
TMDL Status	Final	Name
Background/Ambient Data	Monongahela River TMDL	
pH (SU)	Data Source	
Temperature (°F)		
Hardness (mg/L)		
Other:		
Nearest Downstream Public Water Supply Intake	Pennsylvania-American Water Company, Pittsburgh	
PWS Waters	Monongahela River	Flow at Intake (cfs)
PWS RMI	Distance from Outfall (mi)	

Changes Since Last Permit Issuance: NONE

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Duquesne STP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
462S022		06/26/1962		
462S022 A-1		08/2000		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>		<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Activated Sludge Facility Consisting of Trash Rack, Parshall Flume, Comminutor/Bypass Bar Screen Chamber, Grit Removal, 4 Aeration Tanks, 2 Clarifiers, Chlorine Contact Tank & Stabilization Tank.		Gas Chlorine
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>		<b>Biosolids Treatment</b>
2.0	2,780	Not Overloaded		Biosolids Use/Disposal

Changes Since Last Permit Issuance: NONE

**Compliance History**

**Operations Compliance Check Summary Report**

**Facility:** City of Duquesne STP

**NPDES Permit No.:** PA0026981

**Compliance Review Period:** 12/04/2012 – 12/04/2017

**Open Violations By Client Summary Report**

One open violation in eFACTS by Safe Drinking Water Program.

**Inspection Summary**

INSP ID	INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC	# OF VIOLATIONS
2596245	05/04/2017	Chapter 94 Inspection	PA Dept of Environmental Protection	No Violations Noted	0
2585208	04/05/2017	Compliance Evaluation	County Health Dept	Violation(s) Noted	5
2526799	10/06/2016	Incident-Response to Accident or Event	County Health Dept	Violation(s) Noted	2
2501494	07/06/2016	Compliance Evaluation	County Health Dept	Violation(s) Noted	3
2500286	05/11/2016	Chapter 94 Inspection	County Health Dept	No Violations Noted	0
2366970	03/26/2015	Compliance Evaluation	County Health Dept	Violation(s) Noted	1
2338124	01/13/2015	Routine/Partial Inspection	County Health Dept	Violation(s) Noted	1
2288405	05/08/2014	Compliance Evaluation	County Health Dept	Violation(s) Noted	2
2162787	04/10/2013	Compliance Schedule Evaluation	County Health Dept	Violation(s) Noted	5

**Violation Summary**

VIOL ID	VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC	RESOLVED DATE
783707	04/05/2017	92A.61(D)	NPDES - Failure to monitor flow as required by the NPDES permit	
783708	04/05/2017	92A.41(A)10C	NPDES - Failure to collect representative samples	

**NPDES Permit Fact Sheet**  
**City of Duquesne STP**

**NPDES Permit No. PA0026981**

783709	04/05/2017	92A.41(A)5	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance	
783710	04/05/2017	92A.41(A)10B	NPDES - Failure to utilize approved analytical methods	
783711	04/05/2017	92A.41(A)1	NPDES - Non-compliance with an issued permit, not classified by any other code	
770127	10/06/2016	92A.41(A)10C	NPDES - Failure to collect representative samples	
770128	10/06/2016	92A.41(A)1	NPDES - Non-compliance with an issued permit, not classified by any other code	
763669	07/06/2016	92A.61(D)	NPDES - Failure to monitor flow as required by the NPDES permit	08/25/2016
763670	07/06/2016	92A.41(A)10B	NPDES - Failure to utilize approved analytical methods	08/25/2016
763671	07/06/2016	92A.41(A)10C	NPDES - Failure to collect representative samples	08/25/2016
721835	03/26/2015	92A.61(D)	NPDES - Failure to monitor flow as required by the NPDES permit	07/07/2015
714483	01/13/2015	92A.61(D)	NPDES - Failure to monitor flow as required by the NPDES permit	07/07/2015
700951	05/08/2014	92A.41(A)5	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance	07/22/2014
700952	05/08/2014	94.12	Wasteload Management - Failure to submit a Chapter 94 report that meets regulatory requirements	07/22/2014
666929	04/10/2013	92A.41(5)O&M	Operation and Maintenance violations were present	12/11/2013
666930	04/10/2013	94.12MWMR	Chapter 94 Report not complete or inaccurate	12/11/2013
666931	04/10/2013	271.906	Biosolids - Permittee failed to collect and analyze representative samples for pathogens and pollutants according to the applicable standards	12/11/2013
666932	04/10/2013	92A.27LTCP	Long Term Control Plan not implemented	12/11/2013

666933	04/10/2013	91.33POLLINC	Pollution incident was not reported to DEP.	12/11/2013
--------	------------	--------------	---	------------

### Enforcement Summary

ENF ID	ENF TYPE DESC	EXECUTED DATE	VIOLATIONS	# OF VIOLATIONS	PENALTY AMOUNT
347235	Notice of Violation	08/25/2016	92A.41(A)10B; 92A.61(D)	2	
328763	Notice of Violation	07/07/2015	92A.61(D)	2	
313345	Notice of Violation	07/22/2014	92A.41(A)5; 94.12	2	
297103	Notice of Violation	05/01/2013	271.906; 91.33POLLINC; 92A.27LTCP; 92A.41(5)O&M; 94.12MWMR	5	

### DMR Violation Summary

Current eDMR user.

Effluent limit violation summary in eDMR:

None listed in eDMR.

### Compliance Status:

Facility had numerous violations in 2013 through 2017 for operational violations, which are to be addressed with transfer of facility to new client. New client has one open violation by Safe Drinking Water Program in eFACTs.

Completed by: David Roote

Completed date: 12/4/2017

**Development of Effluent Limitations**

<b>IMP</b>	IMP 101 Point of First Use is Monongahela River	<b>Design Flow (MGD)</b>	2
<b>Latitude</b>		<b>Longitude Outfall</b>	
<b>Outfall 001</b>	40° 22' 47.05"	<b>001</b>	-79° 51' 03.61"

**Wastewater Description:** Sewage Effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

<b>Pollutant</b>	<b>Limit (mg/l)</b>	<b>SBC</b>	<b>Federal Regulation</b>	<b>State Regulation</b>
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Water Quality Analysis Modeling for CBOD5, DO and Ammonia-Nitrogen are not necessary and we will again re-impose Federal Minimum Secondary Effluent Limitations due to the large dilution available in the Monongahela River. Q7-10 flow of the Monongahela River is 1060 cfs.

**Water Quality-Based Limitations**

A "Reasonable Potential Analysis determined that Benzo(a)Anthracene, Benzo(a)Pyrene, Bis(2-Ethylhexyl) Phthalate, Chrysene, Free Cyanide & Dichlorobromomethane were candidates for Water Quality Modeling using PENTOXSD Version 2.0c. Please see the attached Toxics Screening Analysis Spreadsheet and PENTOXSD Modeling Data for more details.

No limitations resulted from water quality modeling using PENTOXSD and there will be no WQBELs imposed on this facility during this permit cycle.

Please note that no reporting requirement will be imposed for 1,4-Dioxane due to the fact that there are no significant industrial user tributary to the City of Duquesne STP. All three samples collected for 1,4-Dioxane were listed none detect with 20 ug/l being the minimum detection level used by the lab. There currently no Aquatic Life or Human Health Criteria for 1,4-Dioxane.

**Best Professional Judgment (BPJ) Limitations**

A Dissolved Oxygen minimum limitation of 4.0 mg/L will be implemented based on the standard in 25 PA Code Chapter 93 and best professional judgment. This is an additional limit that was not previously imposed on the facility.

**Additional Considerations**

The Average Monthly and Instantaneous Maximum Total Residual Chlorine (TRC) effluent limitations imposed in the previous NPDES permit were 1.4 mg/l and 3.3 mg/l, respectively. At that time, those values were considered BAT

limitations per the SWRO's TRC Implementation for Sewage Facilities Planning Section Interim Guidance, dated June 20, 1995 for an existing minor facility having a design flow  $\leq 0.1$  mgd permitted before July 1995. An average monthly limitation of 0.5 mg/l for TRC is now a regulatory standard under §§92a.47(a)(8) and 92a.48(b) and will be imposed.

Nutrient monitoring is required to establish the nutrient load from the waste water treatment facility and the impacts that load may have on the quality of the receiving stream(s). A 1/quarter monitor and report requirement for Total N & Total P has been added to the permit as per Chapter 92.a.61.

Average Monthly Mass loading limits are applicable for this facility. Current policy also requires an average weekly mass loading limit be established for CBOD<sub>5</sub>, TSS. Average monthly mass loading limits (lbs/day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations.

For facilities with design flows greater than 2,000 GPD influent BOD<sub>5</sub> and TSS monitoring must be established in the permit, and the monitoring should be consistent with the same frequency and sample type as is used for other effluent parameters.

For existing discharges, with federal minimum secondary effluent limitations, a year-round monitoring requirement for ammonia-nitrogen, will be established. The monitoring requirements for ammonia nitrogen are consistent with CBOD<sub>5</sub>, TSS, and Fecal Coliform and Table 6-3 of the Permits Writers Manual.

The permit does not include a monitor and report requirements for TDS, sulfate, and chloride because the concentration of TDS in the discharge does not exceed 1,000 mg/L and the discharge flow exceeds 0.1 MGD.

The discharge is to the Thompson Run, which has a Final TMDL and is impaired by metals and pH. This sewage discharge is not expected to contribute to the stream impairment for which abandoned mine drainage is source of such impairment. A 1/quarter report requirement for Iron, Manganese, and Aluminum is established in the permit to verify that the sewage discharge is not contributing to the impairment. The same sample type for these parameters is used as for the other main parameters in the permit such as CBOD<sub>5</sub>, and TSS. They are to be specified as Daily Max Reporting. The monitoring frequency is quarterly for plants rated greater than 0.499 MGD.

The STP discharges indirectly to the Monongahela River which has an EPA Approved TMDL and is impaired by PCBs and Chlordane. No WLAs have been developed for this sewage discharge as neither PCB nor Chlordane is typically found in sewage, but instead found in legacy sediments.

#### Anti-Backsliding

Not Applicable

**Whole Effluent Toxicity (WET)**

For IMP 101,  **Acute**  **Chronic** WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other:

The dilution series used for the tests was: 100%, 50%, 25%, 12.5%, and 6.25%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 9.63.

**Summary of Four Most Recent Test Results**

(NOTE – Enter results into one table, depending on which data analysis method was used).

NOEC/LC50 Data Analysis

Test Date	Ceriodaphnia Results (% Effluent)			Pimephales Results (% Effluent)			Pass? *
	NOEC Survival	NOEC Reproduction	LC50	NOEC Survival	NOEC Growth	LC50	
09/04/2008	<span style="background-color: yellow;"> </span>	<span style="background-color: yellow;"> </span>	95	<span style="background-color: yellow;"> </span>	<span style="background-color: yellow;"> </span>	90	Yes
11/07/2008			100			95	Yes
01/07/2009			90			95	Yes
02/07/2009			95			95	Yes

\* A "passing" result is that which is greater than or equal to the TIWC value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? (NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).

YES  NO

**Evaluation of Test Type, IWC and Dilution Series for Renewed Permit**

Acute Partial Mix Factor (PMFa): **0.098**

Chronic Partial Mix Factor (PMFc): **0.67**

**1. Determine IWC – Acute (IWCa):**

$$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$$

$$[(2.0 \text{ MGD} \times 1.547) / ((1060 \text{ cfs} \times 0.098) + (2.0 \text{ MGD} \times 1.547))] \times 100 = **2.89\%**$$

Is IWCa < 1%?  YES  NO **(YES - Acute Tests Required OR NO - Chronic Tests Required)**

Type of Test for Permit Renewal: **Chronic Tests Required**

**2a. Determine Target IWCa (If Acute Tests Required)**

$$TIWCa = 2.89 / 0.3 = **9.63\%**$$

**2b. Determine Target IWCC (If Chronic Tests Required)**

$$(Q_d \times 1.547) / (Q_{7-10} \times PMFc) + (Q_d \times 1.547)$$

$$[(2.0 \text{ MGD} \times 1.547) / ((1060 \text{ cfs} \times 0.679) + (2.0 \text{ MGD} \times 1.547))] \times 100 = **0.43\% PART C.V. States TIWC = 1%**$$

**3. Determine Dilution Series**

*(NOTE – check Attachment C of WET SOP for dilution series based on TIWCa or TIWCc, whichever applies).*

Dilution Series = 100%, 60%, 30%, 2%, and 1%.

**WET Limits**

Has reasonable potential been determined?  YES  NO

Will WET limits be established in the permit?  YES  NO

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**IMP 101, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	2/week	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	417.0	626.0	XXX	25.0	37.5	50	2/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS	500.0	751.0	XXX	30.0	45.0	60	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000.0 Geo Mean	XXX	10000.0	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200.0 Geo Mean	XXX	1000.0	2/week	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite
Ammonia	Report	XXX	XXX	Report	XXX	Report	2/week	24-Hr Composite
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite

**IMP 101 , Continued (from Permit Effective Date through Permit Expiration Date )**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Aluminum	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite
Total Iron	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite
Total Manganese	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location: IMP 101, located at the discharge pipe of the chlorine contact tank prior to combining with flow from CSO diversion chamber.

TRC\_CALC

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 109.308		1.3.2.iii	WLA_cfc = 106.559
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 40.731		5.1d	LTA_cfc = 61.948
Effluent Limit Calculations					
PENTOXSD TRG	5.1f	AML MULT = 1.231			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.635			
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))...\\ ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_afc		$EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)$			
LTA_afc		wla_afc*LTAMULT_afc			
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))...\\ ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_cfc		$EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)$			
LTA_cfc		wla_cfc*LTAMULT_cfc			
AML MULT		$EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))$			
AVG MON LIMIT		MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)			
INST MAX LIMIT		1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)			

**Applicant:** Pennsylvania-American Water Company  
**Name of plant:** Duquesne STP  
**Permit Number:** PA0026981  
**Municipality:** City of Duquesne  
**County:** Allegheny County  
**Receiving stream:** Thompson Run, Point of First Use is Monongahela River

The following program will calculate partial mix factors for acute and chronic conditions:

calculated fields

net stream flow (Qs cfs)= **1060**  
 discharge flow (Qd mgd)= **2**  
 velocity (fps)= **0.157**  
 width (feet) = **845**  
 depth (feet) = **8**  
 slope (ft/ft) = **0.00076**

complete mix time (min) = **1559.78**

**FOR ACUTE CONDITIONS: IF COMPLETE MIX TIME < 15 MINUTES**

THEN PMF = 1, IF > 15 MINUTES CALCULATE PMFa

PMFa = **0.098**  
 or **9.81 %**

**FOR CHRONIC CONDITIONS: IF COMPLETE MIX TIME < 720 MINUTES**

THEN PMF = 1, IF > 720 MINUTES CALCULATE PMFc

PMFc = **0.679**  
 or **67.94 %**

IWCc=[ Qd \* 1.547 ] / [ ( Qs\*PMFc ) + ( Qd \* 1.547 ) ] = **0.0043**

Target IWCc=IWCc/1= **0.004** **0.43 %**

IWCa=[ Qd \* 1.547 ] / [ ( Qs\*PMFa ) + ( Qd \* 1.547 ) ] = **0.0289**

Target IWCa=IWCa/0.3= **0.096** **or** **9.63 %**

WET tests should pass if percentage for C.dubia LC50 and P.promelas LC50 are greater than the target IWCa (acute) or NOEC > target IWCc (chronic).

Program run by : **William C. Mitchell** on **December 8, 2017**

For Department use only

Date: December 8, 2017

**Subject:** WETT Testing Results  
Pennsylvania-American Water Company  
Duquesne STP  
PA0026981  
City of Duquesne  
Allegheny County

**To:** Donald J. Leone, P.E.  
Planning Chief  
Water Management

**From:** William C. Mitchell  
Planning Engineer  
Water Management

I have reviewed all four quarterly Whole Effluent Toxicity Tests (WETT) conducted by EnviroScience, Inc. for the referenced sewage treatment plant. The results are as follows:

$Q_{\text{discharge}} (\text{mgd}) = 2$   
 $Q_{7-10} (\text{cfs}) = 1060$   
 $\text{PMF}_a \% = 9.81$   
 $\text{PMF}_c \% = 67.94$   
 $\text{TIWC}_a \% = 9.63$

Tests: Acute, 48-hour *Ceriodaphnia dubia*  
Acute, 96-hour *Pimephales promelas*  
Dilution Series: 100, 50, 25, 12.5, 6.25%

#### Acute WETT Summary

Quarter	1	2	3	4
96 hr $LC_{50}$ mg/l (minnow) info only	0.0067	0.0058	0.0064	0.0062
48 hr $LC_{50}$ mg/l (daphnia) info only	0.0017	0.0015	0.0017	0.0020
$LC_{50}$ (Pp-96) %	90	95	95	95
$LC_{50}$ (Cd-48) %	95	100	90	95
$Tu_a$ permit (minnow)	10.379	10.379	10.379	10.379
$Tu_a$ permit (daphnia)	10.379	10.379	10.379	10.379
$Tu_a$ endpoint (minnow)	1.1111	1.0526	1.0526	1.0526
$Tu_a$ endpoint (daphnia)	1.0526	1.0000	1.1111	1.0526

Reasonable potential to exceed Pennsylvania's narrative WET criterion is defined by the following equations:



$$Tu_a(\text{endpoint}) > Tu_a(\text{permit})$$

$$LC_{50} < TIWC_a$$

Potential failure for minnow	None	None	None	None
Potential failure for daphnia	None	None	None	None
$LC_{50}$ (Pp-96) Results	Pass	Pass	Pass	Pass
$LC_{50}$ (Cd-48) Results	Pass	Pass	Pass	Pass

Conclusion: Reasonable potential to exceed Pennsylvania's narrative WET criterion was not demonstrated for all four quarters.





TOXICS SCREENING ANALYSIS  
WATER QUALITY POLLUTANTS OF CONCERN  
VERSION 2.4

Facility: Duquesne STP  
Analysis Hardness (mg/L): 100

NPDES Permit No.: PA0026981  
Discharge Flow (MGD): 2

Outfall: IMP 101  
Analysis pH (SU): 7

Parameter	Maximum Concentration In Application or DMRs (µg/L)	Most Stringent Criterion (µg/L)	Candidate for PENTOXSD Modeling?	Most Stringent WQBEL (µg/L)	Screening Recommendation
<b>Group 1</b>					
Total Dissolved Solids	550000	500000	Yes		
Chloride	200000	250000	No		
Bromide	1000	N/A	No		
Sulfate	100000	250000	No		
Total Aluminum	73	750	No		
Total Antimony	0.5	5.6	No		
Total Arsenic	0.6	10	No		
Total Barium	17.2	2400	No		
Total Beryllium	0.5	N/A	No		
Total Boron	187	1600	No		
Total Cadmium	0.1	0.271	No		
Total Chromium	5.5	N/A	No		
Hexavalent Chromium	0.5	10.4	No		
Total Cobalt	2	19	No		
Total Copper	4.4	9.3	No		
Free Available Cyanide	<	10	5.2	487.475	No Limits/Monitoring
Total Cyanide		10	N/A		
Dissolved Iron	30	300	No		
Total Iron	163	1500	No		
Total Lead	0.6	3.2	No		
Total Manganese	67.5	1000	No		
Total Mercury	0.0031	0.05	No		
Total Nickel	10.2	52.2	No		
Total Phenols (Phenolics)	2.5	5	No		
Total Selenium	1	5.0	No		
Total Silver	0.1	3.8	No		
Total Thallium	0.1	0.24	No		
Total Zinc	38.5	119.8	No		
Total Molybdenum	10	N/A	No		
Acrolein	<	1	3	No (Value < QL)	
Acrylonitrile	<	0.5	0.051	No (Value < QL)	
Benzene	<	0.2	1.2	No (Value < QL)	
Bromoform	<	0.2	4.3	No (Value < QL)	
Carbon Tetrachloride	<	0.2	0.23	No (Value < QL)	
Chlorobenzene	<	0.2	130	No (Value < QL)	
Chlorodibromomethane	<	0.4	0.4	No (Value < QL)	
Chloroethane	<	0.2	N/A	No (Value < QL)	
2-Chloroethyl Vinyl Ether	<	0.5	3500	No (Value < QL)	
Chloform		4.6	5.7	No	
Dichlore bromomethane		1.9	0.55	572.332	No Limits/Monitoring
1,1-Dichloroethane	<	0.2	N/A	No (Value < QL)	
1,2-Dichloroethane	<	0.2	0.38	No (Value < QL)	
1,1-Dichloroethylene	<	0.2	33	No (Value < QL)	
1,2-Dichloropropane	<	0.2	2200	No (Value < QL)	
1,3-Dichloropropylene	<	0.2	0.34	No (Value < QL)	
1,4-Dioxane	<	20	N/A	No	Monitor
Ethylbenzene	<	0.2	530	No (Value < QL)	
Methyl Bromide	<	0.5	47	No (Value < QL)	
Methyl Chloride	<	0.2	5500	No (Value < QL)	
Methylene Chloride	<	0.2	4.6	No (Value < QL)	
1,1,2,2-Tetrachloroethane	<	0.2	0.17	No (Value < QL)	
Tetrachloroethylene	<	0.2	0.69	No (Value < QL)	
Toluene		1.2	330	No	
1,2-trans-Dichloroethylene	<	0.5	140	No (Value < QL)	
1,1,1-Trichloroethane	<	0.2	610	No (Value < QL)	
1,1,2-Trichloroethane	<	0.5	0.59	No (Value < QL)	
Trichloroethylene	<	0.2	2.5	No (Value < QL)	
Vinyl Chloride	<	0.2	0.025	No (Value < QL)	
2-Chlorophenol	<	0.21	81	No (Value < QL)	
2,4-Dichlorophenol	<	0.21	77	No (Value < QL)	
2,4-Dimethylphenol	<	0.21	130	No (Value < QL)	
4,6-Dinitro- <i>o</i> -Cresol			13		
2,4-Dinitrophenol	<	1.03	69	No (Value < QL)	
2-Nitrophenol	<	0.21	1600	No (Value < QL)	
4-Nitrophenol	<	0.21	470	No (Value < QL)	
p-Chloro- <i>m</i> -Cresol			30		
Pentachlorophenol	<	0.2	0.27	No (Value < QL)	
Phenol	<	0.2	10400	No (Value < QL)	
2,4,6-Trichlorophenol		0.3	1.4	No	
Acenaphthene	<	0.1	17	No (Value < QL)	

## NPDES Permit Fact Sheet

NPDES Permit No. PA0026981

CITY OF DULUTHSIE STP						
	<	0.1	N/A	No (Value < QL)		
Acenaphthylene	<	0.1	8300	No (Value < QL)		
Anthracene	<	0.1	0.000086	No (Value < QL)		
Benzidine	<	0.1	0.0038	Yes	3.954	No Limits/Monitoring
Benzo(a)Anthracene		0.4	0.0038	Yes	3.954	No Limits/Monitoring
Benzo(a)Pyrene		0.3	0.0038	No (Value < QL)		
3,4-BenzoFluoranthene	<	0.1	0.0038	No (Value < QL)		
Benzo(ghi)Perylene	<	0.1	N/A	No (Value < QL)		
Benzo(k)Fluoranthene	<	0.1	0.0038	No (Value < QL)		
Bis(2-Chloroethoxy)Methane	<	0.1	N/A	No (Value < QL)		
Bis(2-Chloroethyl)Ether	<	0.1	0.03	No (Value < QL)		
Bis(2-Chloroisopropyl)Ether	<	0.1	1400	No (Value < QL)		
Bis(2-Ethylhexyl)Phthalate		1.7	1.2	Yes	1248.723	No Limits/Monitoring
4-Bromophenyl Phenyl Ether	<	0.1	54	No (Value < QL)		
Butyl Benzyl Phthalate	<	1.03	35	No (Value < QL)		
2-Chloronaphthalene	<	0.1	1000	No (Value < QL)		
4-Chlorophenyl Phenyl Ether	<	0.1	N/A	No (Value < QL)		
Chrysene		0.3	0.0038	Yes	3.954	No Limits/Monitoring
Dibenzo(a,h)Anthracene	<	0.1	0.0038	No (Value < QL)		
1,2-Dichlorobenzene	<	0.1	160	No (Value < QL)		
1,3-Dichlorobenzene	<	0.1	69	No (Value < QL)		
1,4-Dichlorobenzene	<	0.1	150	No (Value < QL)		
3,3-Dichlorobenzidine	<	0.1	0.021	No (Value < QL)		
Diethyl Phthalate	<	1.03	800	No (Value < QL)		
Dimethyl Phthalate	<	1.03	500	No (Value < QL)		
Di-n-Butyl Phthalate	<	1.03	21	No (Value < QL)		
2,4-Dinitrotoluene	<	0.1	0.05	No (Value < QL)		
2,6-Dinitrotoluene	<	0.1	0.05	No (Value < QL)		
Di-n-Octyl Phthalate	<	1.03	N/A	No (Value < QL)		
1,2-Diphenylhydrazine	<	0.1	0.036	No (Value < QL)		
Fluoranthene		1	40	No		
Fluorene	<	0.1	1100	No (Value < QL)		
Hexachlorobenzene	<	0.1	0.00028	No (Value < QL)		
Hexachlorobutadiene	<	0.1	0.44	No (Value < QL)		
Hexachlorocyclopentadiene	<	0.1	1	No (Value < QL)		
Hexachloroethane	<	0.1	1.4	No (Value < QL)		
Indeno(1,2,3-cd)Pyrene	<	0.1	0.0038	No (Value < QL)		
Isophorone	<	0.1	35	No (Value < QL)		
Naphthalene	<	0.1	43	No (Value < QL)		
Nitrobenzene	<	0.1	17	No (Value < QL)		
n-Nitrosodimethylamine	<	0.1	0.00069	No (Value < QL)		
n-Nitrosodi-n-Propylamine	<	0.1	0.005	No (Value < QL)		
n-Nitrosodiphenylamine	<	0.1	3.3	No (Value < QL)		
Phenanthrene		0.4	1	No		
Pyrene		0.6	830	No		
1,2,4-Trichlorobenzene	<	0.1	26	No (Value < QL)		
Aldrin	<		0.000049			
alpha-BHC	<		0.0026			
beta-BHC	<		0.0091			
gamma-BHC	<		0.098			
delta BHC	<		N/A			
Chlordane	<		0.0008			
4,4-DDT	<		0.00022			
4,4-DDE	<		0.00022			
4,4-DDD	<		0.00031			
Dieldrin	<		0.000052			
alpha-Endosulfan	<		0.056			
beta-Endosulfan	<		0.056			
Endosulfan Sulfate	<		N/A			
Endrin	<		0.036			
Endrin Aldehyde	<		0.29			
Heptachlor	<		0.000079			
Heptachlor Epoxide	<		0.000039			
Toxaphene	<		0.0002			
2,3,7,8-TCDD	<		0.000000005			
Gross Alpha (pCi/L)	<		N/A			
Total Beta (pCi/L)	<		N/A			
Radium 226/228 (pCi/L)	<		N/A			
Total Strontium	<		4000			
Total Uranium	<		N/A			

PENTOXSD

Modeling Input Data

Stream Code	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope	PWS With (mgd)	Apply FC					
37185	12.26	712.00	7180.00	0.00000	0.00	<input checked="" type="checkbox"/>					
<b>Stream Data</b>											
LFY	Trib Flow (cfs)	Stream Flow (cfs)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (ft)	Rch Velocity (fps)	Rch Trav Time (days)	Hard pH (mg/L)	Stream pH (mg/L)	Hard pH (mg/L)	Analysis pH
Q7-10	0.147	0	1060	0	845	8	0	0	100	7	0
Qh		0	0	0	0	0	0	100	7	0	0
<b>Discharge Data</b>											
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	AFC PMF	CFC PMF	THH PMF	CRL PMF	Disc Hard	Disc pH
Duquesne STP	PA0026981	0	0	2	0	0	0	0	0	100	7
<b>Parameter Data</b>											
Parameter Name	Disc Conc ( $\mu$ g/L)	Trib Conc ( $\mu$ g/L)	Disc Daily CV	Disc Hourly CV	Steam Conc ( $\mu$ g/L)	Stream CV	Fate Coef	FOS	Crit Mod	Max Disc Conc ( $\mu$ g/L)	
BENZO(a)ANTHRACENE	1E+07	0	0.5	0.5	0	0	0	0	1	0	
BENZO(a)PYRENE	1E+07	0	0.5	0.5	0	0	0	0	1	0	
BIS(2-ETHYLHEXYL) PHTHALATE	1E+07	0	0.5	0.5	0	0	0	0	1	0	
CHRYSENE	1E+07	0	0.5	0.5	0	0	0	0	1	0	
CYANIDE, FREE	1E+07	0	0.5	0.5	0	0	0	0	1	0	
DICHLOROBROMOMETHANE	1E+07	0	0.5	0.5	0	0	0	0	1	0	

Stream Code	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope	PWS With (mgd)	Apply FC					
37185	11.76	710.00	7190.00	0.00000	0.00	<input checked="" type="checkbox"/>					
<b>Stream Data</b>											
LFY	Trib Flow	Stream Flow	WD Ratio	Rch Width	Rch Depth	Rch Velocity	Rch Trav Time (days)	Tributary Hard (mg/L)	Stream Hard pH (mg/L)	Analysis Hard pH (mg/L)	
(cfsm)	(cfs)	(cfs)		(ft)	(ft)	(fps)	(days)	(mg/L)	(mg/L)	(mg/L)	
Q7-10	0.147	0	0	0	0	0	0	100	7	0	0
Qh		0	0	0	0	0	0	100	7	0	0
<b>Discharge Data</b>											
Name	Permit Number	Existing Disc Flow	Permitted Disc Flow	Design Disc Flow	Reserve Factor	AFC PMF	CFC PMF	THH PMF	CRL PMF	Disc Hard	Disc pH
		(mgd)	(mgd)	(mgd)							(mg/L)
		0	0	0	0	0	0	0	0	100	7
<b>Parameter Data</b>											
Parameter Name	Disc Conc	Trib Conc	Disc Daily CV	Disc Hourly CV	Stream Conc	Stream CV	Fate Coef	FOS	Crit Mod	Max Disc Conc	(µg/L)
	(µg/L)	(µg/L)			(µg/L)						
BENZO(a)ANTHRACENE	0	0	0.5	0.5	0	0	0	0	1	0	
BENZO(a)PYRENE	0	0	0.5	0.5	0	0	0	0	1	0	
BIS(2-ETHYLHEXYL) PHTHALATE	0	0	0.5	0.5	0	0	0	0	1	0	
CHRYSENE	0	0	0.5	0.5	0	0	0	0	1	0	
CYANIDE, FREE	0	0	0.5	0.5	0	0	0	0	1	0	
DICHLOROBROMOMETHANE	0	0	0.5	0.5	0	0	0	0	1	0	

**PENTOXSD Analysis Results**

**Hydrodynamics**

<u>SWP Basin</u>		<u>Stream Code:</u>			<u>Stream Name:</u>						
19A		37185			MONONGAHELA RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	WD Ratio	Velocity	Reach Trav Time	CMT
	(cfs)		(cfs)	(cfs)		(ft)	(ft)		(fps)	(days)	(min)

**Q7-10 Hydrodynamics**

12.260	1060	0	1060	3.094	0.0008	8	845	105.63	0.1573	0.1943	1000+
11.760	1061.5	0	1061.5	NA	0	0	0	0	0	0	NA

**Qh Hydrodynamics**

12.260	3274.2	0	3274.2	3.094	0.0008	13.129	845	64.362	0.2954	0.1034	746.052
11.760	3278.2	0	3278.2	NA	0	0	0	0	0	0	NA

**PENTOXSD Analysis Results**

**Wasteload Allocations**

RMI	Name	Permit Number							
12.26	Duquesne STP	PA0026981							
<b>AFC</b>									
Q7-10:	CCT (min)	15	PMF	0.097	Analysis pH	7	Analysis Hardness	100	
	Parameter		Stream Conc. ( $\mu\text{g/L}$ )	Stream CV	Trib Conc. ( $\mu\text{g/L}$ )	Fate Coef	WQC ( $\mu\text{g/L}$ )	WQ Obj ( $\mu\text{g/L}$ )	WLA ( $\mu\text{g/L}$ )
CYANIDE, FREE									
DICHLOROBROMOMETHANE									
BENZO(a)ANTHRACENE									
BENZO(a)PYRENE									
BIS(2-ETHYLHEXYL) PHTHALATE									
CHRYSENE									
<b>CFC</b>									
Q7-10:	CCT (min)	720	PMF	0.678	Analysis pH	7	Analysis Hardness	100	
	Parameter		Stream Conc. ( $\mu\text{g/L}$ )	Stream CV	Trib Conc. ( $\mu\text{g/L}$ )	Fate Coef	WQC ( $\mu\text{g/L}$ )	WQ Obj ( $\mu\text{g/L}$ )	WLA ( $\mu\text{g/L}$ )
CYANIDE, FREE									
DICHLOROBROMOMETHANE									
BENZO(a)ANTHRACENE									
BENZO(a)PYRENE									
BIS(2-ETHYLHEXYL) PHTHALATE									
CHRYSENE									
<b>THH</b>									
Q7-10:	CCT (min)	720	PMF	0.678	Analysis pH	NA	Analysis Hardness	NA	
	Parameter		Stream Conc. ( $\mu\text{g/L}$ )	Stream CV	Trib Conc. ( $\mu\text{g/L}$ )	Fate Coef	WQC ( $\mu\text{g/L}$ )	WQ Obj ( $\mu\text{g/L}$ )	WLA ( $\mu\text{g/L}$ )
CYANIDE, FREE									
DICHLOROBROMOMETHANE									

**PENTOXSD Analysis Results**

**Wasteload Allocations**

RMI	Name	Permit Number	0	0	0	0	NA	NA	NA
12.26	Duquesne STP	PA0026981							
	BENZO(a)ANTHRACENE		0	0	0	0	NA	NA	NA
	BENZO(a)PYRENE		0	0	0	0	NA	NA	NA
	BIS(2-ETHYLHEXYL) PHTHALATE		0	0	0	0	NA	NA	NA
	CHRYSENE		0	0	0	0	NA	NA	NA

**CRL**

Qh:	CCT (min)	720	PMF	0.982	Stream Conc ( $\mu\text{g/L}$ )	Stream CV	Trib Conc ( $\mu\text{g/L}$ )	Fate Coef	WQC ( $\mu\text{g/L}$ )	WQ Obj ( $\mu\text{g/L}$ )	WLA ( $\mu\text{g/L}$ )
	Parameter										
	CYANIDE, FREE				0	0	0	0	NA	NA	NA
	DICHLOROBROMOMETHANE				0	0	0	0	0.55	0.55	572.332
	BENZO(a)ANTHRACENE				0	0	0	0	0.004	0.004	3.954
	BENZO(a)PYRENE				0	0	0	0	0.004	0.004	3.954
	BIS(2-ETHYLHEXYL) PHTHALATE				0	0	0	0	1.2	1.2	1248.723
	CHRYSENE				0	0	0	0	0.004	0.004	3.954

### PENTOXSD Analysis Results

#### Recommended Effluent Limitations

<u>SWP Basin</u>	<u>Stream Code:</u>	<u>Stream Name:</u>		
19A	37185	MONONGAHELA RIVER		
RMI	Name	Permit Number	Disc Flow (mgd)	
12.26	Duquesne STP	PA0026981	2.0000	
Parameter	Effluent Limit ( $\mu\text{g/L}$ )	Governing Criterion	Max. Daily Limit ( $\mu\text{g/L}$ )	Most Stringent WQBEL ( $\mu\text{g/L}$ )
BENZO(a)ANTHRACENE	3.954	CRL	6.169	3.954
BENZO(a)PYRENE	3.954	CRL	6.169	3.954
BIS(2-ETHYLHEXYL) PHTHALATE	1248.723	CRL	1948.209	1248.723
CHRYSENE	3.954	CRL	6.169	3.954
CYANIDE, FREE	487.475	AFC	760.539	487.475
DICHLOROBROMOMETHANE	572.332	CRL	892.929	572.332