



Application Type
Facility Type
Major / Minor

Renewal
Industrial
Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. **PA0027537**
APS ID **1131670**
Authorization ID **1517078**

Applicant and Facility Information



Applicant Name	Hampton Shaler Water Authority	Facility Name	Hampton Shaler Water Authority
Applicant Address	PO Box 66	Facility Address	1037 E Ohio Street
Applicant Contact	Allison Park, PA 15101-1331	Facility Contact	Pittsburgh, PA 15223-2018
Applicant Phone	April Winkelman	Facility Phone	Jane Flohr
Client ID	(412) 486-4867	Site ID	(412) 486-4867
SIC Code	290303	Municipality	263795
SIC Description	4941	County	Shaler Township
Date Application Received	Trans. & Utilities - Water Supply	EPA Waived?	Allegheny
Date Application Accepted	January 29, 2025	If No, Reason	Yes
Purpose of Application	Renewal of NPDES Permit Coverage		

Summary of Review

The Department received an NPDES permit renewal application from Hampton Shaler Water Authority on January 29, 2025 for coverage of the discharge from its Hampton Shaler Water Authority Water Treatment Plant in Shaler Township of Allegheny County. The facility is a municipal water treatment plant with an SIC Code 4941 (Water Supply). The current NPDES permit was renewed on June 24, 2020 and expires on June 30, 2025. In addition to the NPDES permit renewal application, Hampton Shaler Water Authority also submitted an application for NPDES/WQM permit transfer. The Hampton Shaler Water Authority Water Treatment Plant was originally transferred from Shaler Township to Hampton Shaler Water Authority January 2012. However, no transfer application was submitted to the Department at the time of the transfer. The current submission of the transfer application serves to correct this omission.

Hampton Shaler Water Authority (HSWA) Water Treatment Plant (WTP) operates as a public drinking water treatment and supply facility providing potable drinking water to over 62,000 people daily in eleven municipalities. The plant has a design capacity of 9.0 MGD. HSWA treats groundwater from 12 wells along the banks of the Allegheny River to produce potable drinking water. The plant draws groundwater through two raw water lines. The water is divided into four raw water lines inside the plant and each line is pre-chlorinated with sodium hypochlorite.

The plant is divided into two main sections described as "old" and "new", with each receiving two of the four raw water lines. The "new" side of the plant treats approximately 40% of the water. Two (of six total) anthracite greensand filters are used for iron and manganese removal. The "old" side of the plant treats approximately 60% of the water and uses four filters for iron and manganese removal.

Approve	Deny	Signatures	Date
X		 Jamie Ley / Environmental Engineering Specialist	March 13, 2025
X		 Michael E. Fifth, P.E. / Environmental Engineer Manager	March 17, 2025

Summary of Review

Chemical treatment includes sodium hypochlorite for disinfection of both source water and finished water for 4-log treatment and sodium chloride for zeolite regeneration. A 70,000-gallon capacity Softener Backwash Holding Tank collects initial filter and softener backwash wastewater. The backwash water is diluted and gradually discharged to the ALCOSAN sanitary sewer. Filters are backwashed with finished water from the 103,000-gallon Filter Backwash Holding Tank when head loss reaches 8 ft. or run time reaches 72 hours. The backwash water is retained for solids settling. The tank supernatant is returned to the head of the plant at the raw water line to Filters No. 5 and 6. The Filter Backwash Holding Tank also collects sludge from the reactor clarifier and the sedimentation basin whenever these units are removed from operation and drained for cleaning and inspection. Sludge from both the sedimentation basin and the backwash holding tanks is discharged to an ALCOSAN sewer. Rewash (flushing process water to wash out the brine) water from the filters and softeners and the spent brine from the softener regeneration process is collected in the Rewash Holding Tank and discharged through Outfall 001 to the Allegheny River.

The facility has one outfall, Outfall 001, which discharges to the Allegheny River, designated in 25 PA Code Chapter 93 as a Warm Water Fishery (WWF). Outfall 001 discharges rewash water through a partially open gate valve at the bottom of the Rewash Holding Tank. The partially open gate valve ensures that the outfall maintains a low flow rate. Between November 2022 and October 2024, Outfall 001 discharged at an average flow of 0.086 MGD and reported a maximum flow of 0.145 MGD. Several catch basins on the plant property also convey stormwater to Outfall 001. The stormwater is not affiliated with any industrial activities and no materials are stored outdoors. Most of the stormwater infiltrates at the drainage ditch between Route 28 and the railroad tracks, and reportedly does not significantly contribute to the flow at Outfall 001. Sampling is performed after all treatment processes and prior to commingling with stormwater. It is completed at the discharge point from the Rewash Holding Tank.

Draft Permit issuance is recommended.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.086
Latitude	40° 29' 15.00"	Longitude	-79° 57' 17.00"
Quad Name	Pittsburgh East	Quad Code	1506
Wastewater Description:	Rewash water from six filters & six softeners & spent brine from the softener regeneration process		
Receiving Waters	Allegheny River	Stream Code	42122
NHD Com ID	123972952	RMI	4.7526
Drainage Area	11,700 mi ²	Yield (cfs/mi ²)	0.2043
Q ₇₋₁₀ Flow (cfs)	2,390	Q ₇₋₁₀ Basis	U.S. Army Corp of Engineers
Elevation (ft)	714	Slope (ft/ft)	0.001
Watershed No.	18-A	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	POLYCHLORINATED BIPHENYLS (PCBS)		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status	Final	Name	Allegheny River
Nearest Downstream Public Water Supply Intake		West View Water Authority	
PWS Waters	Ohio River	Flow at Intake (cfs)	4,730
PWS RMI	35.38	Distance from Outfall (mi)	~ 9.50

Changes Since Last Permit Issuance:

Other Comments:

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 29' 15.00"

Design Flow (MGD) 0.086
Longitude -79° 57' 17.00"

Wastewater Description: Rewash water from six filters & six softeners & spent brine from the softener regeneration process

Technology-Based Limitations

Regulatory Effluent Standards and Monitoring Requirements

Flow monitoring is required pursuant to 25 Pa. Code § 92a.61(d)(1) which is displayed in Table 1 below.

Effluent standards for pH are imposed in accordance with 25 Pa. Code §§ 95.2(1) which is displayed in Table 1 below.

Pennsylvania regulations at 25 Pa. Code § 92a.48(b) require the imposition of technology-based TRC limits for facilities that use chlorination and that are not already subject to TRC limits based on applicable federal ELGs or a facility-specific BPJ evaluation which is displayed in Table 1 below.

Table 1. Regulatory Effluent Standards

Parameter	Monthly Avg	Daily Max	IMAX
Flow (MGD)	Monitor	Monitor	----
Total Residual Chlorine (mg/L)	0.5	1.0	1.6
pH (S.U.)	6.0 – 9.0 at all times		

Best Practicable Control Technology Currently Achievable (BPT)

BPT for wastewater from treatment of WTP sludges and filter backwash is found in DEPs Technology-Based Control Requirements for Water Treatment Plant Wastes Document which is imposed under Best Professional Judgement under 40 CFR § 125.3. The effluent limitations from this document are displayed below in Table 2.

Table 2: BPT Limits for WTP Sludge and Filter Backwash Wastewater

Parameter	Monthly Avg (mg/l)	Daily Max (mg/l)
Suspended solids	30.0	60.0
Iron (total)	2.0	4.0
Aluminum (total)	4.0	8.0
Manganese (total)	1.0	2.0
Flow (MGD)	Monitor	----
pH (S.U.)	Not less than 6.0 nor greater than 9.0 at all times	
Total Residual Chlorine	0.5	1.0

Water Quality-Based Limitations

Toxics Management Spread Sheet

The Department of Environmental Protection (DEP) has developed the DEP Toxics Management Spreadsheet ("TMS") to facilitate calculations necessary for completing a reasonable potential (RP) analysis and determining water quality-based effluent limitations for discharges of toxic pollutants. The Toxics Management Spreadsheet is a macro-enabled Excel binary file that combines the functions of the PENTOXSD model and the Toxics Screening Analysis spreadsheet to evaluate the reasonable potential for discharges to cause excursions above water quality standards and to determine WQBELs. The Toxics Management Spread Sheet is a single discharge, mass-balance water quality calculation spread sheet that includes consideration for mixing, first-order decay and other factors to determine recommended WQBELs for toxic substances and several non-toxic substances. Required input data including stream code, river mile index, elevation, drainage area,

discharge name, NPDES permit number, discharge flow rate and the discharge concentrations for parameters in the permit application or in DMRs, which are entered into the spread sheet to establish site-specific discharge conditions. Other data such as low flow yield, reach dimensions and partial mix factors may also be entered to further characterize the conditions of the discharge and receiving water. Discharge concentrations for the parameters are chosen to represent the "worst case" quality of the discharge (i.e., maximum reported discharge concentrations). The spread sheet then evaluates each parameter by computing a Waste Load Allocation for each applicable criterion, determining a recommended maximum WQBEL and comparing that recommended WQBEL with the input discharge concentration to determine which is more stringent. Based on this evaluation, the Toxics Management Spread sheet recommends average monthly and maximum daily WQBELs.

Reasonable Potential Analysis and WQBEL Development for Outfall 001

Discharges from Outfall 001 are evaluated based on concentrations reported on the application and on DMRs; data from those sources are entered into the Toxics Management Spread Sheet. The maximum reported value of the parameters from the application form or from previous DMRs is used as the input concentration in the Toxics Management Spread Sheet. All toxic pollutants whose maximum concentrations, as reported in the permit application or on DMRs, are greater than the most stringent applicable water quality criterion are considered to be pollutants of concern. [This includes pollutants reported as "Not Detectable" or as "<MDL" where the method detection limit for the analytical method used by the applicant is greater than the most stringent water quality criterion]. The Toxics Management Spread Sheet was run with the discharge and receiving stream characteristics shown in Table 3.

Table 3: TMS Inputs for Outfall 001

Parameter	Value
River Mile Index	4.75
Design Flow (MGD)	0.086
Basin/Stream Characteristics	
Parameter	Value
Area in Square Miles	11,700
Q ₇₋₁₀ (cfs)	2,390
Low-flow yield (cfs/mi ²)	0.2043
Elevation (ft)	714
Slope	0.001

For IW discharges, the design flow used in modeling is the average flow during production or operation taken from the permit application or DMRs. Pollutants for which water quality standards have not been promulgated (e.g., TSS, oil and grease) are excluded from the analysis. All the parameters are evaluated using the model to determine the water quality-based effluent limits applicable to the discharge and the receiving stream. The spreadsheet then compares the reported discharge concentrations to the calculated water quality-based effluent limitations to determine if a reasonable potential exists to exceed the calculated WQBELs. Effluent limitations are established in the draft permit where a pollutant's maximum reported discharge concentration equals or exceeds 50% of the WQBEL. For non-conservative pollutants, monitoring requirements are established where the maximum reported concentration is between 25% - 50% of the WQBEL. For conservative pollutants, monitoring requirements are established where the maximum reported concentration is between 10% - 50% of the WQBEL. The information described above including the maximum reported discharge concentrations, the most stringent water quality criteria, the pollutant-of-concern (reasonable potential) determinations, the calculated WQBELs, and the WQBEL/monitoring recommendations are displayed in the Toxics Management Spread Sheet in Attachment B of this Fact Sheet. No WQBELs were recommended for Outfall 001.

Total Residual Chlorine

To determine if WQBELs are required for discharges containing total residual chlorine (TRC), a discharge evaluation is performed using a DEP program called TRC_CALC created with Microsoft Excel for Windows. TRC_CALC calculates TRC Waste Load Allocations (WLAs) through the application of a mass balance model which considers TRC losses due to stream and discharge chlorine demands and first-order chlorine decay. Input values for the program include flow rates and chlorine demands for the receiving stream and the discharge, the number of samples taken per month, coefficients of TRC variability, partial mix factors, and an optional factor of safety. The mass balance model calculates WLAs for acute and chronic criteria that are then converted to long term averages using calculated multipliers. The multipliers are functions of the number of samples taken per month and the TRC variability coefficients (normally kept at default values unless site specific information is available). The most stringent limitation between the acute and chronic long-term averages is converted to an average monthly limit for comparison to the BAT average monthly limit of 0.5 mg/l from 25 Pa. Code § 92a.48(b)(2). The more stringent of these average monthly TRC limitations is imposed in the permit. The results of the modeling, included in Attachment C, indicate that no WQBELs are required for TRC.

Total Maximum Daily Load (TMDL)

Wastewater discharges from Hampton Shaler Water Authority are located in the Allegheny River Watershed, for which the Department has developed a TMDL. A TMDL establishes the amount of a pollutant that a water body can assimilate without exceeding the water quality criteria for that pollutant. TMDLs provide the scientific basis for a state to establish water quality-based controls to reduce pollution from both point and non-point sources in order to restore and maintain the quality of the state's water resources (USEPA 1991a). The TMDL was finalized on April 9, 2001 and addresses contamination of fish tissue, in the Allegheny River from Lock and Dam 3 (River Mile 14.5) to the mouth (River Mile 0.0), by PCB and chlordane. Water quality criteria for the TMDL watershed do not apply to the wastewater discharges from HSWA.

Anti-Backsliding

Previous limits can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l) and are displayed below in Table 4.

Table 4: Current Effluent Limitation for Outfall 001

Parameters	Mass (lb/day)		Concentration			Monitoring Requirements		
	Average Monthly	Daily Maximum	Daily Minimum	Average Monthly	Daily Maximum	Instant. Maximum	Frequency	Sample Type
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	2/Month	Measure
Total Suspended Solids (mg/L)	XXX	XXX	XXX	30.0	60.0	XXX	2/Month	Grab
Total Residual Chlorine (mg/L)	XXX	XXX	XXX	0.5	XXX	1.0	2/Month	Grab
Total Dissolved Solids (mg/L)	XXX	XXX	XXX	Report	Report	XXX	2/Month	Grab
Total Aluminum (mg/L)	XXX	XXX	XXX	4.0	8.0	XXX	2/Month	Grab
Total Iron (mg/L)	XXX	XXX	XXX	2.0	4.0	XXX	2/Month	Grab
Total Manganese (mg/L)	XXX	XXX	XXX	1.0	2.0	XXX	2/Month	Grab
Total Sulfate (mg/L)	XXX	XXX	XXX	Report	Report	XXX	2/Month	Grab
Chloride (mg/L)	XXX	XXX	XXX	Report	Report	XXX	2/Month	Grab
Bromide (mg/L)	XXX	XXX	XXX	Report	Report	XXX	2/Month	Grab
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	2/Month	Grab

Proposed Effluent Limitations for Outfall 001

The proposed effluent limitations and monitoring requirements for Outfall 001 are shown below in Table 5. The limits are the most stringent values from the above limitation analysis. Note that the value for TRC was incorrectly labeled as IMAX in the previous permit when it should have been labeled as Daily Max. This has been changed to reflect existing permitting practices. Monitoring frequencies will remain the same as the current permit, twice per month.

Table 5: Proposed Effluent Limitation for Outfall 001

Parameters	Mass (lb/day)		Concentration			Monitoring Requirements		
	Average Monthly	Daily Maximum	Daily Minimum	Average Monthly	Daily Maximum	Instant. Maximum	Frequency	Sample Type
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	2/Month	Measure
Total Suspended Solids (mg/L)	XXX	XXX	XXX	30.0	60.0	XXX	2/Month	Grab
Total Residual Chlorine (mg/L)	XXX	XXX	XXX	0.5	1.0	XXX	2/Month	Grab
Total Dissolved Solids (mg/L)	XXX	XXX	XXX	Report	Report	XXX	2/Month	Grab
Total Aluminum (mg/L)	XXX	XXX	XXX	4.0	8.0	XXX	2/Month	Grab
Total Iron (mg/L)	XXX	XXX	XXX	2.0	4.0	XXX	2/Month	Grab
Total Manganese (mg/L)	XXX	XXX	XXX	1.0	2.0	XXX	2/Month	Grab
Total Sulfate (mg/L)	XXX	XXX	XXX	Report	Report	XXX	2/Month	Grab
Chloride (mg/L)	XXX	XXX	XXX	Report	Report	XXX	2/Month	Grab
Bromide (mg/L)	XXX	XXX	XXX	Report	Report	XXX	2/Month	Grab
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	2/Month	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	Toxics Management Spreadsheet (see Attachment B)
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment C)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input checked="" type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-001, BCW-PMT-032, BCW-PMT-033, BCW-PMT-037
<input type="checkbox"/>	Other: [REDACTED]

Attachment A – Outfall 001 StreamStats

StreamStats Report_Outfall 001 HSWA

Region ID: PA

Workspace ID: PA20250303165158815000

Clicked Point (Latitude, Longitude): 40.48631, -79.95414

Time: 2025-03-03 11:52:35 -0500



[+ Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	11700	square miles
ELEV	Mean Basin Elevation	1591	feet
PRECIP	Mean Annual Precipitation	44	inches

► Low-Flow Statistics

Low-Flow Statistics Parameters [96.0 Percent (11200 square miles) Low Flow Region 3]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	11700	square miles	2.33	1720
ELEV	Mean Basin Elevation	1591	feet	898	2700

Attachment B – Outfall 001 TMS Input & Results



Discharge Information

Instructions		Discharge		Stream								
Facility: Hampton Shaler Water Authority			NPDES Permit No.: PA0027537									
Evaluation Type: Major Sewage / Industrial Waste			Wastewater Description: Rewash Water Holding Tank Discharge									
Discharge Characteristics												
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)			Complete Mix Times (min)						
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _h				
0.086	1390	7										
Discharge Pollutant		Units	Max Discharge Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteri a Mod	Chem Transl
Group 1		mg/L	9460									
		mg/L	6140									
		mg/L	0.6									
		mg/L	96									
		mg/L	< 0.1									
Group 2		µg/L	< 100									
		µg/L	< 2									
		µg/L	< 4									
		µg/L	1110									
		µg/L	< 1									
		mg/L	< 0.1									
		µg/L	< 0.2									
		µg/L	< 2									
		mg/L	< 0.005									
		µg/L	< 1									
		µg/L	80.5									
		µg/L										
		µg/L	< 5									
		mg/L	0.02									
		mg/L	0.4									
		µg/L	< 1									
		mg/L	2									
		mg/L	< 0.0002									
		µg/L	14.3									
		µg/L	50									
		mg/L	< 0.005									
		µg/L	< 0.4									
		µg/L	< 2									
		µg/L	< 5									
		µg/L	2.69									



Stream / Surface Water Information

Hampton Shaler Water Authority, NPDES Permit No. PA0027537, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Allegheny River**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042122	4.75	714	11700	0.001		Yes
End of Reach 1	042122	4.25	713	11700.5	0.001		Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	4.75	0.2043	2390		10							100	7		
End of Reach 1	4.25	0.2043	2390												

Q_h

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	4.75														
End of Reach 1	4.25														

Model Results

Hampton Shaler Water Authority, NPDES Permit No. PA0027537, Outfall 001

Instructions **Results** RETURN TO INPUTS SAVE AS PDF PRINT All Inputs Results Limits

Hydrodynamics

Q₇₋₁₀

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
4.75	2,390		2,390	0.133	0.001	0.871	8.706	10.	2.101	0.015	4.044
4.25	2,390		2,390								

Q_h

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
4.75	6663.59		6663.59	0.133	0.001	1.367	8.706	6.369	3.73	0.008	2.056
4.25	6663.595		6663.59								

Wasteload Allocations

AFC CCT (min): **4.044** PMF: **1** Analysis Hardness (mg/l): **100.07** Analysis pH: **7.00**

Pollutants	Stream Conc	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	750	750	13,473,939	
Total Antimony	0	0		0	1,100	1,100	19,761,777	
Total Arsenic	0	0		0	340	340	6,108,186	Chem Translator of 1 applied
Total Barium	0	0		0	21,000	21,000	#####	
Total Boron	0	0		0	8,100	8,100	#####	
Total Cadmium	0	0		0	2,015	2.13	38,351	Chem Translator of 0.944 applied
Total Chromium (III)	0	0		0	570,099	1,804	32,411,277	Chem Translator of 0.316 applied
Hexavalent Chromium	0	0		0	16	16.3	292,713	Chem Translator of 0.982 applied
Total Cobalt	0	0		0	95	95.0	1,706,699	
Total Copper	0	0		0	13,448	14.0	251,667	Chem Translator of 0.96 applied

NPDES Permit Fact Sheet
Hampton Shaler Water Authority

NPDES Permit No. PA0027537

Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	64.632	81.7	1,468,115	Chem Translator of 0.791 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	1.400	1.65	29,590	Chem Translator of 0.85 applied
Total Nickel	0	0		0	468.520	469	8,433,951	Chem Translator of 0.998 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	Chem Translator of 0.922 applied
Total Silver	0	0		0	3.221	3.79	68,072	Chem Translator of 0.85 applied
Total Thallium	0	0		0	65	65.0	1,167,741	
Total Zinc	0	0		0	117.252	120	2,153,842	Chem Translator of 0.978 applied

CFC

CCT (min): 4.044

PMF: 1

Analysis Hardness (mg/l): 100.07

Analysis pH: 7.00

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	220	220	3,952,355	
Total Arsenic	0	0		0	150	150	2,694,788	Chem Translator of 1 applied
Total Barium	0	0		0	4,100	4,100	73,657,533	
Total Boron	0	0		0	1,600	1,600	28,744,403	
Total Cadmium	0	0		0	0.246	0.27	4,864	Chem Translator of 0.909 applied
Total Chromium (III)	0	0		0	74.158	86.2	1,549,150	Chem Translator of 0.86 applied
Hexavalent Chromium	0	0		0	10	10.4	186,749	Chem Translator of 0.962 applied
Total Cobalt	0	0		0	19	19.0	341,340	
Total Copper	0	0		0	8.961	9.33	167,699	Chem Translator of 0.96 applied
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	1,500	1,500	26,947,878	WQC = 30 day average; PMF = 1
Total Lead	0	0		0	2.519	3.18	57,210	Chem Translator of 0.791 applied
Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	0.770	0.91	16,274	Chem Translator of 0.85 applied
Total Nickel	0	0		0	52.038	52.2	937,691	Chem Translator of 0.997 applied
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	4.600	4.99	89,631	Chem Translator of 0.922 applied
Total Silver	0	0		0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0		0	13	13.0	233,548	
Total Zinc	0	0		0	118.211	120	2,153,842	Chem Translator of 0.986 applied

THH

CCT (min): 4.044

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	

NPDES Permit Fact Sheet
Hampton Shaler Water Authority

NPDES Permit No. PA0027537

Chloride (PWS)	0	0		0	250,000	250,000	N/A
Sulfate (PWS)	0	0		0	250,000	250,000	N/A
Fluoride (PWS)	0	0		0	2,000	2,000	N/A
Total Aluminum	0	0		0	N/A	N/A	N/A
Total Antimony	0	0		0	5.6	5.6	100,605
Total Arsenic	0	0		0	10	10.0	179,653
Total Barium	0	0		0	2,400	2,400	43,116,605
Total Boron	0	0		0	3,100	3,100	55,692,281
Total Cadmium	0	0		0	N/A	N/A	N/A
Total Chromium (III)	0	0		0	N/A	N/A	N/A
Hexavalent Chromium	0	0		0	N/A	N/A	N/A
Total Cobalt	0	0		0	N/A	N/A	N/A
Total Copper	0	0		0	N/A	N/A	N/A
Dissolved Iron	0	0		0	300	300	5,389,576
Total Iron	0	0		0	N/A	N/A	N/A
Total Lead	0	0		0	N/A	N/A	N/A
Total Manganese	0	0		0	1,000	1,000	17,965,252
Total Mercury	0	0		0	0.050	0.05	898
Total Nickel	0	0		0	610	610	10,958,804
Total Phenols (Phenolics) (PWS)	0	0		0	5	5.0	N/A
Total Selenium	0	0		0	N/A	N/A	N/A
Total Silver	0	0		0	N/A	N/A	N/A
Total Thallium	0	0		0	0.24	0.24	4,312
Total Zinc	0	0		0	N/A	N/A	N/A

CRL

CCT (min): 2.056

PMF: 1

Analysis Hardness (mg/l):

N/A

Analysis pH:

N/A

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Fluoride (PWS)	0	0		0	N/A	N/A	N/A	
Total Aluminum	0	0		0	N/A	N/A	N/A	
Total Antimony	0	0		0	N/A	N/A	N/A	
Total Arsenic	0	0		0	N/A	N/A	N/A	
Total Barium	0	0		0	N/A	N/A	N/A	
Total Boron	0	0		0	N/A	N/A	N/A	
Total Cadmium	0	0		0	N/A	N/A	N/A	
Total Chromium (III)	0	0		0	N/A	N/A	N/A	
Hexavalent Chromium	0	0		0	N/A	N/A	N/A	
Total Cobalt	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Dissolved Iron	0	0		0	N/A	N/A	N/A	
Total Iron	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	

Total Manganese	0	0		0	N/A	N/A	N/A	
Total Mercury	0	0		0	N/A	N/A	N/A	
Total Nickel	0	0		0	N/A	N/A	N/A	
Total Phenols (Phenolics) (PWS)	0	0		0	N/A	N/A	N/A	
Total Selenium	0	0		0	N/A	N/A	N/A	
Total Silver	0	0		0	N/A	N/A	N/A	
Total Thallium	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable
Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Fluoride (PWS)	N/A	N/A	Discharge Conc < TQL
Total Aluminum	8,636,251	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	179,653	µg/L	Discharge Conc ≤ 10% WQBEL
Total Barium	43,116,605	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	28,744	mg/L	Discharge Conc < TQL
Total Cadmium	4,864	µg/L	Discharge Conc < TQL
Total Chromium (III)	1,549,150	µg/L	Discharge Conc < TQL
Hexavalent Chromium	187	mg/L	Discharge Conc ≤ 10% WQBEL
Total Cobalt	341,340	µg/L	Discharge Conc < TQL
Total Copper	161,308	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	5,390	mg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	26,948	mg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	57,210	µg/L	Discharge Conc < TQL
Total Manganese	17,965	mg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.9	mg/L	Discharge Conc < TQL
Total Nickel	937,691	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)		µg/L	PWS Not Applicable
Total Selenium	89.6	mg/L	Discharge Conc < TQL
Total Silver	43,631	µg/L	Discharge Conc < TQL
Total Thallium	4,312	µg/L	Discharge Conc < TQL
Total Zinc	1,380,526	µg/L	Discharge Conc < TQL
Total Molybdenum	N/A	N/A	No WQS

Attachment C – TRC Evaluation Model for Outfall 001

TRC_CALC_HSWA


TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 5730.615		1.3.2.iii	WLA_cfc = 5586.893
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 2135.364		5.1d	LTA_cfc = 3247.958
Effluent Limit Calculations					
PENTOXSD TRG	5.1f	AML MULT = 1.720			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST MAX LIMIT (mg/l) = 1.170			
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... \\ ... + Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_afc		$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$			
LTA_afc		wla_afc*LTAMULT_afc			
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... \\ ... + Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)$			
LTAMULT_cfc		$\text{EXP}((0.5*\text{LN}(cvd^2/no_samples+1))-2.326*\text{LN}(cvd^2/no_samples+1)^0.5)$			
LTA_cfc		wla_cfc*LTAMULT_cfc			
AML MULT		$\text{EXP}(2.326*\text{LN}((cvd^2/no_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no_samples+1))$			
AVG MON LIMIT		$\text{MIN}(\text{BAT_BPJ}, \text{MIN}(\text{LTA_afc}, \text{LTA_cfc})*\text{AML_MULT})$			
INST MAX LIMIT		$1.5*((\text{av_mon_limit}/\text{AML_MULT})/\text{LTAMULT_afc})$			


Attachment D – Site Mapping/Flow Schematic

- 1 - WASH WATER TANK
- 2 - LEVEL TRANSMITTER PIT
- 3 - WASH WATER TANKS
- 4 - CAUSTIC SODA TANK Storage Shed
- 5 - SUBSTATION
- 6 - SALT STORAGE TANK ABANDONED
- 7 - MAIN BLD. WATER SOFTENER & FILTER PLANT
- 8 - BELOW GROUND CLEARWELL NO. 2
- 9 - WASTE WATER AND SALT TANKS

- ASPHALT PAVED AREA
- RETAINING WALL
- PROPERTY LINE
- CURBING
- STORM WATER INLET
- DRAINING DITCH

EXHIBIT IV





WASTEWATER SCHEMATIC DIAGRAM

EXHIBIT J