

Application Type Renewal
Facility Type Municipal
Major / Minor Major

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0027693
APS ID 626326
Authorization ID 1243149

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|--|
| Applicant Name | <u>Minersville Borough Sewer Authority</u> | Facility Name | <u>Minersville Sewer Authority WWTP</u> |
| Applicant Address | <u>2 E Sunbury Street</u> <u>Minersville, PA 17954-1719</u> | Facility Address | <u>State Route 901</u> <u>Minersville, PA 17954</u> |
| Applicant Contact | <u>Joseph Bass</u> | Facility Contact | <u>Raymond Sukeena</u> |
| Applicant Phone | <u>(570) 544-2149</u> | Facility Phone | <u>(570) 544-6843</u> |
| Client ID | <u>74952</u> | Site ID | <u>258146</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Minersville Borough</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Schuylkill</u> |
| Date Application Received | <u>August 27, 2018</u> | EPA Waived? | <u>No</u> |
| Date Application Accepted | <u>December 26, 2018</u> | If No, Reason | <u>Major Facility with CSOs</u> |
| Purpose of Application | <u>RENEWAL OF EXISTING NPDES PERMIT.</u> | | |

Summary of Review

The applicant is requesting renewal of an NPDES permit to discharge treated sewage to the West Branch Schuylkill River (CWF-MF), a cold water fishery, migratory fishery-designated receiving stream in State Water Plan Basin 03A (Upper Schuylkill River). The average annual design flow is 1.0 MGD, which is the same as the previous permit. As per the Department's current existing use list, the receiving streams do not have an existing use classification that is more protective than the designated use. The discharge is not expected to affect public water supplies.

For outfall 001 the CBOD5, TSS, Fecal Coliform, TRC and pH limits are technology-based. The NH3-N (summer), TDS, and WET limits are water quality-based.

A TMDL (Total Maximum Daily Load) for the West Branch Schuylkill River Watershed was approved by EPA on April 1, 2005. The TMDL addresses metals (iron, manganese, and aluminum) and depressed pH associated with acid mine drainage (AMD). The TMDL allocations apply to nonpoint sources of pollution from mining sites, and to one point-source permitted mine drainage discharge. Per the SOP for Establishing Effluent Limitations for Individual Sewage Permits, for renewals, if there are Waste Load Allocations (WLAs) that are specific to the discharge then consistent effluent limits should be established in the permit. Since the TMDL did not consider sewage dischargers, there are no WLAs to apply. Since there are industrial users, monitoring for iron, manganese and aluminum will be continued to allow assessment of existing loadings without limits.

Quarterly limit for Total Dissolved Solids per DRBC Docket No. D-1970-201 will be introduced. Toxic modelling has produced no other limits.

For Outfall 002 (stormwater only) the monitoring requirements will be updated accordingly for parameters and frequency of the present state-wide NPDES PAG-03 General Permit Appendix J.

| Approve | Deny | Signatures | Date |
|---------|------|--|---------------|
| X | | Bernard Feist (signed) Bernard Feist, P.E. / Environmental Engineer | April 1, 2021 |
| X | | Amy M. Bellanca (signed) Amy M. Bellanca, P.E. / Environmental Engineer Manager | 4-6-21 |

Summary of Review

Combined Sewer Overflow (CSO)

The goals of the EPA's 1994 Combined Sewer Overflow (CSO) Control Policy (Volume 59 of the Federal Register (FR) 18688 and 18689, April 19, 1994) are:

1. To ensure that if CSOs occur, they are only as a result of wet weather,
2. To bring all wet weather CSO discharge points into compliance with the technology-based and water quality-based requirements of the Clean Water Act (CWA) and
3. To minimize water quality, aquatic biota and human health impacts from CSOs from all Publicly Owned Treatment Works (POTW) Treatment Plants (as defined in Title 40 of the Code of Federal Regulations (CFR) Part 403.3(p))."

NPDES Compliance - EPA Publication Number: 305-K-17-001 Interim Revised Version, January 2017

EPA's CSO Policy outlines the NMCs and the minimum elements of an LTCP. Table 12-1 lists the NMCs, while Table 12-2 lists the elements of the LTCP.

Table 12-1. Nine Minimum CSO Controls

- Proper operation and regular maintenance programs for the sewer system and the CSOs.
- Maximum use of the collection system for storage.
- Review and modification of pretreatment requirements to ensure that CSO impacts are minimized.
- Maximization of flow to the POTW for treatment.
- Prohibition of CSOs during dry weather.
- Control of solid and floatable materials in CSOs.
- Establishment of pollution prevention programs.
- Public notification to ensure that the public receives adequate notification of CSO occurrences and CSO impacts.
- Monitoring to effectively characterize CSO impacts and the efficacy of CSO controls.

Table 12-2. Elements of the Long-Term CSO Control Plan

- Characterization, monitoring, and modeling of the Combined Sewer System
- Public Participation
- Consideration of Sensitive Areas
- Evaluation of Alternatives
- Cost/Performance Considerations
- Operational Plan
- Maximizing Treatment at the Existing POTW Treatment Plant
- Implementation Schedule
- Post-Construction Compliance Monitoring Program

<https://www.epa.gov/sites/production/files/2017-03/documents/npdesinspect-chapter-12.pdf>

The key elements of CSO control is to:

- Eliminate or relocate overflows that discharge to sensitive areas wherever physically possible and economically achievable, and where not possible, provide treatment necessary to meet WQS for full protection of existing and designated uses.
- Coordinate the review and appropriate revision of water quality standards and implementation procedures on CSO-impacted waters with development of long-term CSO control plans.
 - Evaluate a reasonable range of alternatives for the CSO control plan that could achieve the necessary level of control/treatment, and select the controls to be implemented based on cost/performance evaluations.
 - Develop an implementation schedule based on the relative importance of adverse impacts on WQS and designated uses, priority projects identified in the long-term plan LTCP, and on the permittee's financial capability.
- Maximize treatment of wet weather flows at the existing POTW treatment plant.

Summary of Review

All future PADEP Inspections and Permits will obtain information to determine compliance in the following areas:

- CSO prevention during dry weather.
- Implementation of the nine minimum CSO controls.
- Adherence to a schedule for development, submission, and implementation of a LTCP, including any interim deliverables.
- Adherence to schedule for implementation of the CSO controls selected from the LTCP.
- Elimination or relocation of overflows from identified sensitive areas, as defined in the approved LTCP.
- Meeting narrative, performance-based, or numerical water quality-based effluent limitations.
- Monitoring program, including baseline information on frequency, duration, and impacts of CSOs.
- PADEP will incorporate E. coli monitoring in subsequently reissued NPDES permits and ensure that it is included in CSO post-construction compliance monitoring (PCCM) plans to verify compliance with water quality standard and designated uses.

The Department wants the Applicant to be aware of a guidance document offered by the Environmental Protection Agency. It is a planning tool for the development of LTCPs in Small Communities (jurisdictions with populations under 75,000), which might be useful in development of any revised LTCP. The links to the instructions and LTCP-EZ Template can be found at: <https://www.epa.gov/npdes/npdes-cso-guidance-documents>.

Long Term Control Plan

The required Long-Term Control Plan (LTCP) is a document by which the permittee evaluates the existing CSS infrastructure and the hydraulic relationship between the CSS, wet weather, overflows and treatment capacity. Cost effective alternatives for reducing or eliminating overflows are evaluated and a plan forward to eventually meet water quality standards is selected. An implementation schedule is then developed to achieve that goal. The three LTCP options are demonstrative, presumptive and total separation. The demonstrative approach shows that the current plan is adequate to meet the water quality-based requirements of the CWA based on data, while the presumptive approach will implement a minimum level of treatment that is presumed to meet the water quality-based requirements of the CWA.

PADEP's Annual CSO Status Report (Chapter 94 Report)

The Annual CSO Status Report is part of the permittee's annual Chapter 94 Municipal Wasteload Management Report. In this annual report, the permittee includes

1. The summary of the frequency, duration and volume of the CSO events from the past year,
2. The operational status of the CSO outfalls,
3. Identification of any known in-stream water quality impacts,
4. A summary of all actions taken to implement NMCs and the LTCP and effectiveness of those actions,
5. A progress report and evaluation of the NMC implementation,
6. Rain gauge data for each event and
7. Documentation of annual inspections and maintenance.

Minersville has four (4) CSOs remaining within the collection system permitted under NPDES Permit No. PA0027693. The Authority had previously abandoned and eliminated a total of six (6) CSOs as part of two (2) separation and upgrade projects. Currently, overflows would occur only when the combined sewer system exceeds conveyance and wastewater treatment capacities during wet weather periods. At no time are there dry weather discharges through a CSO. Weir plate elevations are designed above manhole inverts which hold solids below weir elevations plus there are approximately 450 catch basins located in the service area. Any observed objects, contributing to a partial restriction, which may have been removed from a CSO are taken to the WWTP for proper disposal.

Items listed in their Long Term Control Plan include:

The Borough has implemented a regular street sweeping program and inlet/catch basin cleaning and lists any combined sewer system issues on their monthly agenda for the public meeting each month.

Summary of Review

| CSO # / DEP Outfall # | Latitude | Longitude | Receiving Water |
|--------------------------|-----------|-----------|---|
| CSO-002 / Outfall 003 | 40°41'21" | 76°15'26" | Culvert which discharges to West Branch of Schuylkill River |
| CSO-004 / Outfall 004 | 40°41'27" | 76°15'24" | West Branch of Schuylkill River |
| CSO-006 / Outfall 005 | 40°41'39" | 76°15'50" | Wolf Creek Culvert |
| CSO-007 / Outfall 006 | 40°41'34" | 76°15'48" | Wolf Creek Culvert |

The Minersville Sewer Authority has chosen to proceed with the EPA “demonstrated goal” procedure to demonstrate the attainment of compliance with the CSO LTCP. Sampling of the West Branch with and without active CSO discharges was conducted in October 2018.

| Pollutant Parameter | West Branch Dry Weather No Active CSOs | West Branch Wet Weather – Outfall 004 and 005/006 Active | | | |
|-----------------------------|---|---|-----------------------|-----------------------------|-----------------------------|
| | | Above Outfall #004 | Below Outfall #004 | Above Outfalls #005/#006 | Below Outfalls #005/#006 |
| BOD 5 (mg/L) | ND | ND | 2 | ND | ND |
| Fecal Coliform (#/100ml) | 100 | 5,400 | 15,200 | 9,200 | 5,800 |
| pH (S.U.) | 6.66 | 6.47 | 6.50 | 6.37 | 6.42 |
| TDS (mg/L) | 394 | 276 | 276 | 240 | 164 |
| TSS (mg/L) | 18 | 1490 | 1120 | 950 | 910 |
| Aluminum (mg/L) | 1.01 | 9.48 | 10.5 | 9.45 | 8.75 |
| Iron (mg/L) | 4.29 | 25.0 | 27 | 23.2 | 20.9 |
| Manganese (mg/L) | 1.84 | 1.77 | 1.61 | 1.68 | 1.69 |

The Authority must submit an annual report to DEP providing documentation on action taken by the Authority during the previous calendar year to implement the NMCs. The Authority’s CSO Status Report is due by March 31st of each year. Special supplemental CSO Discharge Monitoring Reports are also required as part of the Authority’s current NPDES Permit.

Summary of Review

Minersville Borough Combined Sewer Overflow Summary for 2017

| Month | WWTP Average Flow MGD | WWTP Max Daily Flow MGD | Outfall 003 Flow MGD (# Events) | Outfall 004 Flow MGD (# Events) | Outfall 005 Flow MGD (# Events) | Outfall 006 Flow MGD (# Events) |
|-----------|-----------------------|-------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|
| January | 0.521 | 1.119 | 0.000 | 0.000 | 0.000 | 0.000 |
| February | 0.437 | 0.931 | 0.000 | 0.000 | 0.009 (1) | 0.009 (1) |
| March | 0.606 | 0.955 | 0.000 | 0.000 | 0.018 (1) | 0.018 (1) |
| April | 0.8 | 3.043 | 0.000 | 0.000 | 0.048 (1) | 0.048 (1) |
| May | 0.597 | 1.594 | 0.000 | 0.000 | 0.000 | 0.000 |
| June | 0.488 | 1.269 | 0.000 | 0.000 | 0.012 (1) | 0.012 (1) |
| July | 0.77 | 2.495 | 0.000 | 0.000 | 0.029 (2) | 0.029 (2) |
| August | 0.594 | 1.505 | 0.000 | 0.000 | 0.023 (1) | 0.000 |
| September | 0.391 | 0.846 | 0.000 | 0.000 | 0.000 | 0.000 |
| October | 0.525 | 1.225 | 0.000 | 0.000 | 0.000 | 0.000 |
| November | 0.434 | 0.734 | 0.000 | 0.000 | 0.000 | 0.000 |
| December | 0.383 | 0.713 | 0.000 | 0.000 | 0.000 | 0.000 |

As required, signs are installed near each CSO, which identifies its location, designation, and contact information. There are currently no sensitive areas in the vicinity of the CSO outfalls. The impaired quality of the West Branch does not provide for recreation or public uses.

303(d) Sub-List

State Water Plan (SWP) Subbasin: 03-A West Branch Schuylkill River

| Year | Miles | Segment ID Assessment ID | DEP Stream Code | Stream Name | Designated Use | Data Source | Source | EPA 305(b) Cause Code |
|------|-------|--------------------------|-----------------|------------------------------|----------------|---------------|---------------------|-----------------------|
| 1996 | 9 | 0446 | 02329 | West Branch Schuylkill River | CWF | 305(b) Report | Resource Extraction | metals |
| 1998 | 9.02 | 0446 | 02329 | West Branch Schuylkill River | CWF | SWMP | AMD | metals |
| 2002 | 12.9 | 20000718-0800-CJD | 02329 | West Branch Schuylkill River | CWF | SWAP | AMD | siltation |

Cold Water Fishes=CWF
Surface Water Monitoring Program = SWMP
Surface Water Assessment Program = SWAP

Summary of Review



RPT.LTCP
Minersville.103018 F

The NMS query “Inspections & Inspectors – Inspections – Inspection History by Permit” was run. An Administrative/File Review Compliance Evaluation was done on 04/27/2020 with No Violations Noted.

The NMS query “Violations – eFACTS – Open Violations for Client was run. There are currently no open violations.

The existing permit is Administratively extended and the application was received on August 27, 2018.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP’s discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information

Outfall No. 001 Design Flow (MGD) 1
 Latitude 40° 40' 51.29" Longitude -76° 14' 58.82"
 Quad Name _____ Quad Code _____
 Wastewater Description: Sewage Effluent

Receiving Waters West Branch Schuylkill River (CWF) Stream Code 2329
 NHD Com ID 25982480 RMI 7.6
 Drainage Area 20.8 Yield (cfs/mi²) 0.37
 Q₇₋₁₀ Flow (cfs) 7.7 Q₇₋₁₀ Basis USGS 01468500 DFlow
 Elevation (ft) _____ Slope (ft/ft) 0.0044
 Watershed No. 3-A Chapter 93 Class. CWF,MF
 Existing Use _____ Existing Use Qualifier _____
 Exceptions to Use _____ Exceptions to Criteria _____

Assessment Status Impaired
 Cause(s) of Impairment flow regime modification, habitat alterations, habitat, metals, pcb's, siltation, acid mine drainage, channelization, highway/road/bridge runoff
 Source(s) of Impairment source unknown, streambank modifications/destabilization, urban runoff/storm sewers
 TMDL Status Final, Schuylkill River PCB TMDL
Final, Upper Schuylkill River
Tentative Name West Branch Schuylkill River Watershed

Nearest Downstream Public Water Supply Intake Pottstown Borough Water Authority
 PWS Waters Schuylkill River Flow at Intake (cfs) _____
 PWS RMI _____ Distance from Outfall (mi) Approximately 60 miles

River Mile: 7.6 WRDS: 2329 HUC 8 Code: 02040203

STATION.--01468500 SCHUYLKILL RIVER AT LANDINGVILLE, PA

LOCATION.--Lat 40° 37'45", long 76° 07'30", Schuylkill County, Hydrologic Unit 02040203, on left bank 10 ft upstream from highway bridge on SR 2011 at Landingville, 0.1 mi upstream from Mahannon Creek, and 5.0 mi downstream from West Branch Schuylkill River.

DRAINAGE AREA.--133 square miles.

| Gage | Period | Zero/Mis+ | 1B3 | 7Q10 | Harmonic |
|---|-------------------------|-----------|------|------|----------|
| 01468500 - Schuylkill River at Landingville, PA | 1993/04/01 - 2018/04/01 | 0/0 | 45.9 | 49.8 | 1.64E+02 |

Double-click on biological flow value for excursion analysis

DFLOW Results 01468500 - Schuylkill River at Landingville, PA

Q₇₋₁₀ LowFlowYield (cfs/mi²)= 49.8/133 = 0.37


RMI 7.6 Outfall 001 Elevation of 684 feet at River Mile: 7.6 WRDS: 2329 HUC 8 Code: 02040203

Clicked Point (Latitude, Longitude):

40.68575, -76.25494

Time:

2019-05-20 14:02:35



Low-Flow Statistics Parameters (Low Flow Region 2)

| Parameter Code | Parameter Name | Value | Units |
|----------------|------------------------|-------|--------------------|
| DRNAREA | Drainage Area | 20.8 | square miles |
| | 7 Day 10 Year Low Flow | 6.29 | ft ³ /s |

Streamflow = $0.37 * 20.8 = 7.7$ CFS; Dilution = 5:1


RMI 6.55 at confluence with trib 02345 elevation 675 ft

Clicked Point (Latitude, Longitude):

40.67484, -76.24374

Time:

2019-05-20 14:23:14 -0



Low-Flow Statistics Parameters [Low Flow Region 2]

| Parameter Code | Parameter Name | Value | Units |
|----------------|----------------|-------|--------------|
| DRNAREA | Drainage Area | 22.8 | square miles |

| Treatment Facility Summary | | | | |
|--|-----------------------------------|---------------------|----------------------------|-------------------------------|
| Treatment Facility Name: Minersville Sewer Authority WWTP | | | | |
| WQM Permit No. | Issuance Date | | | |
| 5470403 | 12/3/1970 | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Activated Sludge | Chlorine | 1.0 |
| Hydraulic Capacity (MGD) | | | | |
| 1.0 | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| | 1,360 | Not Overloaded | Aerobic Digestion | Combination of methods |

The Minersville Sewer Authority (Authority) owns the wastewater collection, conveyance, and treatment facilities serving the Borough and portions of Norwegian, Branch and Cass Townships.

The WWTP facilities consist of a fine screen, a grit collector, a pump house, two splitter boxes, two aeration tanks, two clarifiers, a sludge thickening tank, two aerobic digesters, a plat and frame press, and two chlorine contact tanks.

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at an approved facility. Class B biosolids are land applied by Reading Anthracite Company under Permit PAG082220 @ 90 Dry Tons/year.

The two (2) industries that are connected to the sewer system are “dry” and only discharge domestic wastewater and non-contact cooling water. First, Tredegar discharges domestic wastewater and non-contact cooling water only. Second, World Resources Company, Inc. discharges domestic wastewater only to the collection system, any industrial flow is hauled to the WWTP by tanker truck. An average of 14,000 gallons per week is received at the WWTP and tankers are randomly sampled and analyzed with no historical problems.

The wastewater collection system consists of separate sanitary and combined sewers. Combined sewers collect a combination of sanitary and stormwater flows. Combined sewer flows were originally regulated at ten (10) Combined Sewer Overflows (CSOs). In 2006 and 2007, three (3) CSOs were abandoned and separation projects have eliminated an additional three (3) CSOs leaving four (4) permitted CSOs currently in the system. The receiving stream for all of the Minersville CSOs is the West Branch of the Schuylkill River (West Branch) which is affected by pollution from Acid Mine Drainage (AMD).

The population of the Borough of Minersville, based on the 2010 US Census is approximately 4,397, well below the designation for small systems.

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 1.0
 Latitude 40° 41' 9.00" Longitude -76° 15' 20.00"
 Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:


| Parameter | Minimum | Average Monthly | Average Weekly | IMAX | Basis |
|---|---------|-----------------|------------------|--------|-------------------|
| Flow (MGD) | XXX | Report | Report Max Daily | XXX | §§ 92a.27, 92a.61 |
| CBOD5 (mg/L) | XXX | 25 | 40 | 50 | § 92a.47 |
| TSS (mg/L) | XXX | 30 | 45 | 60 | § 92a.47 |
| TRC (mg/L) | XXX | 0.5 | XXX | 1.6 | §§ 92a.47-48 |
| NH3-N (mg/L) | XXX | 25 | XXX | 50 | BPJ |
| D.O. (mg/L) | 4 | XXX | XXX | XXX | BPJ |
| pH (SU) | 6 | XXX | XXX | 9 | § 92a.47, § 95.2 |
| Total N (mg/L) | XXX | Report | XXX | XXX | § 92a.61 |
| Total P (mg/L) | XXX | Report | XXX | XXX | § 92a.61 |
| Fecal Coliform (No./100 ml) (May-Sept) | XXX | 200 Geo Mean | XXX | 1,000 | § 92a.47 |
| Fecal Coliform (No./100 ml) (Oct-April) | XXX | 2,000 Geo Mean | XXX | 10,000 | § 92a.47 |
| E. Coli (No./100 ml)* | XXX | XXX | XXX | Report | § 92a.61 |

*2021 update - Sewage discharges will include monitoring, at a minimum, for E. Coli, in new and reissued permits, with a monitoring frequency of 1/month for design flows >= 1 MGD, 1/quarter for design flows >= 0.05 and < 1 MGD, 1/year for design flows of 0.002 – 0.05 MGD.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files in Appendix A):

| Parameter | Limit (mg/l) | SBC | Model |
|--------------------|--------------|-----------------|---------|
| NH ₃ -N | 12 existing | Average Monthly | WQM 7.0 |



| TRC EVALUATION | | | | | |
|---|--------------------------------|-------------------------------|-----------------|--------------------------------------|---------------------|
| Input appropriate values in A3:A9 and D3:D9 | | | Minerville 2019 | | |
| 7.7 | = Q stream (cfs) | | 0.5 | = CV Daily | |
| 1 | = Q discharge (MGD) | | 0.5 | = CV Hourly | |
| 30 | = no. samples | | 1 | = AFC_Partial Mix Factor | |
| 0.3 | = Chlorine Demand of Stream | | 1 | = CFC_Partial Mix Factor | |
| 0 | = Chlorine Demand of Discharge | | 15 | = AFC_Criteria Compliance Time (min) | |
| 0.5 | = BAT/BPJ Value | | 720 | = CFC_Criteria Compliance Time (min) | |
| 0 | = % Factor of Safety (FOS) | | | =Decay Coefficient (K) | |
| Source | Reference | AFC Calculations | | Reference | CFC Calculations |
| TRC | 1.3.2.iii | WLA afc = 1.607 | | 1.3.2.iii | WLA cfc = 1.559 |
| PENTOXSD TRG | 5.1a | LTAMULT afc = 0.373 | | 5.1c | LTAMULT cfc = 0.581 |
| PENTOXSD TRG | 5.1b | LTA_afc = 0.599 | | 5.1d | LTA_cfc = 0.906 |
| Source | Effluent Limit Calculations | | | | |
| PENTOXSD TRG | 5.1f | AML MULT = 1.231 | | | |
| PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | | BAT/BPJ | |
| | | INST MAX LIMIT (mg/l) = 1.635 | | | |

Toxics Screening Analysis revealed these items of concern.

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Rectangular Slip

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|----------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Aluminum | Report | Report | Report | Report | Report | µg/L | 1,977 | AFC | Discharge Conc > 10% WQBEL (no RP) |
| Total Copper | Report | Report | Report | Report | Report | µg/L | 38.2 | AFC | Discharge Conc > 10% WQBEL (no RP) |
| Total Zinc | Report | Report | Report | Report | Report | µg/L | 326 | AFC | Discharge Conc > 10% WQBEL (no RP) |



TMS%20PA0027693
%202021%20v1.3.pd

TMS v1.3

EFFLUENT TABLE A-2: DRBC Parameters Not Included in NPDES Permit

| OUTFALL 001 (Discharging to West Branch Schuylkill River) | | |
|---|-------------|------------|
| PARAMETER | LIMIT | MONITORING |
| Total Dissolved Solids* | 1,000 mg/l* | Quarterly |

DRBC Docket

Best Professional Judgment (BPJ) Limitations

WEST BRANCH SCHUYLKILL RIVER WATERSHED TMDL For Acid Mine Drainage Affected Segments No required reductions of permit limits are needed at this time. All necessary reductions are assigned to mining non-point sources.

FINAL UPPER SCHUYLKILL RIVER WATERSHED TMDL For Acid Mine Drainage Affected Segments All impairments resulted from acid drainage from abandoned coalmines. The TMDL addresses the three primary metals associated with acid mine drainage (iron, manganese, aluminum) and pH. The twelve (12) major discharges in the watershed are all caused by abandoned mines and are treated as non-point sources.

Anti-Backsliding

The previous existing Permit limits will be retained. M&R for Copper & Zinc will be added as recommended by TMS v1.3.

Whole Effluent Toxicity (WET)

For Outfall 001, Acute Chronic WET Testing was completed:

| Type of WET Test | Date of Test Completion | Pass/Fail | Analysis T-Test/ LC50 NOEC | Re-test (Pass/Fail and Date) |
|------------------|-------------------------|-----------|----------------------------|------------------------------|
|------------------|-------------------------|-----------|----------------------------|------------------------------|

Utilizing :

Q7-10 Flow* 6.39 cfs PMFa* 0.751 PMFc* 1.0 WETT Required by Permit?
 IWCa 24.38 % Test Type Test Type for Failures(s) Chronic WETT Failure(s)?
 IWCC 19.49 % 1st 2nd 3rd 4th 5th Test Type (Other)
 TIWC 19 % Dilution Series 5 10 19 60 100 Comments
 Species Type* Species
 CDUBI Ceriodaphnia Dubia
 PPRON Pimephales Promelas

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other: See Permit Part C Yearly requirements

The dilution series used for the tests was: 100%, 60%,19%,10%, and 5%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 19.



Miner%202019%20
Wet.pdf



Miner%202020%20
Wet.pdf

2019 Results-Pass

2020 Results-Pass

Anti-Backsliding

The existing Dilution Series and 5.26 Survival (TUc) limits will be retained.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001 Sewage Effluent:

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|---------------------|-----------------------|---------------------|------------------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Recorded |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | 9.0 Max | XXX | 1/day | Grab |
| TRC | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| CBOD5 | 208 | 334 | XXX | 25.0 | 40.0 Wkly Avg | 50.0 | 1/week | 24-Hr Composite |
| BOD5 Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| TSS Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| TSS | 250 | 375 | XXX | 30.0 | 45.0 Wkly Avg | 60.0 | 1/week | 24-Hr Composite |
| Fecal Coliform (CFU/100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2,000 Geo Mean | XXX | 10,000 | 1/week | Grab |
| Fecal Coliform (CFU/100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | 1,000 | 1/week | Grab |
| Ammonia Nov 1 - Apr 30 | Report | XXX | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Ammonia May 1 - Oct 31 | 100 | XXX | XXX | 12.0 | XXX | 24.0 | 1/week | 24-Hr Composite |
| TKN | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |
| Total Phosphorus | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |
| Total Aluminum | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |
| Total Iron | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---|-------------------------------------|----------------|-----------------------|------------------|---------------|------------------|--|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Daily Maximum | Instant. Maximum | | |
| Total Manganese | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |
| Total Copper | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |
| Zinc | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |
| Total Dissolved Solids | Report Avg Qrtly | XXX | XXX | 1,000 | XXX | XXX | 1/quarter | 24-Hr Composite |
| Nitrate-Nitrite | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | 24-Hr Composite |
| Total Nitrogen | Report Avg Qrtly | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | Calculation |
| E. Coli (No./100 ml) | XXX | XXX | XXX | Report | XXX | XXX | 1/Month | 24-Hr Composite |
| Chronic WET - Ceriodaphnia Survival (TUc) | XXX | XXX | XXX | XXX | 5.26 | XXX | See Permit | 24-Hr Composite |
| Chronic WET - Ceriodaphnia Reproduction (TUc) | XXX | XXX | XXX | XXX | 5.26 | XXX | See Permit | 24-Hr Composite |
| Chronic WET - Pimephales Survival (TUc) | XXX | XXX | XXX | XXX | 5.26 | XXX | See Permit | 24-Hr Composite |
| Chronic WET - Pimephales Growth (TUc) | XXX | XXX | XXX | XXX | 5.26 | XXX | See Permit | 24-Hr Composite |

Outfall 002 Stormwater:

PAG 03 General Stormwater Appendix J Standards

| Parameter | Monitoring Requirements | | Benchmark Values |
|-------------------------------------|-------------------------------|-------------|------------------|
| | Minimum Measurement Frequency | Sample Type | |
| Total Suspended Solids (TSS) (mg/L) | 1 / 6 months | Grab | 100 |
| Oil and Grease (mg/L) | 1 / 6 months | Grab | 30 |

Compliance History

DMR Data for Outfall 001 (from February 1, 2020 to January 31, 2021)

| Parameter | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 | JUL-20 | JUN-20 | MAY-20 | APR-20 | MAR-20 | FEB-20 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.484 | 0.587 | 0.42 | 0.355 | 0.366 | 0.412 | 0.36 | 0.588 | 0.585 | 0.602 | 0.504 | 0.466 |
| Flow (MGD) Daily Maximum | 0.941 | 2.376 | 0.687 | 1.298 | 0.751 | 0.911 | 0.663 | 1.301 | 1.343 | 1.186 | 0.935 | 0.818 |
| pH (S.U.) Minimum | 6.0 | 6.0 | 6.1 | 6.0 | 6.0 | 6.3 | 6.1 | 6.1 | 6.0 | 6.1 | 6.4 | 6.7 |
| pH (S.U.) Maximum | 7.1 | 7.0 | 6.8 | 6.6 | 7.0 | 7.2 | 7.0 | 7.1 | 6.8 | 7.7 | 7.6 | 7.8 |
| TRC (mg/L) Average Monthly | 0.44 | 0.42 | 0.49 | 0.49 | 0.44 | 0.49 | 0.47 | 0.49 | 0.49 | 0.50 | 0.43 | 0.46 |
| TRC (mg/L) Instantaneous Maximum | 0.72 | 0.72 | 0.78 | 0.73 | 0.83 | 0.75 | 0.99 | 0.98 | 0.9 | 0.97 | 0.8 | 0.82 |
| CBOD5 (lbs/day) Average Monthly | < 8 | < 9 | < 6 | < 5 | < 8 | < 7 | < 7 | < 11 | < 11 | < 18 | 2 | < 14 |
| CBOD5 (lbs/day) Weekly Average | < 9 | < 11 | < 7 | < 6 | 16 | 13 | 12 | < 15 | < 15 | 39 | 12 | 25 |
| CBOD5 (mg/L) Average Monthly | < 2 | < 2 | < 2 | < 2 | < 2 | < 3 | < 2 | < 2 | < 2 | < 4 | < 3 | < 3 |
| CBOD5 (mg/L) Weekly Average | < 2 | < 2 | < 2 | < 2 | 4 | 5 | 3 | 3 | 2 | 10 | 3 | 4 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 459 | 690 | 511 | 446 | 511 | 564 | 455 | 556 | 692 | 790 | 616 | 632 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 495 | 861 | 594 | 557 | 717 | 1075 | 633 | 805 | 1130 | 999 | 854 | 962 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 124 | 169 | 162 | 171.4 | 171 | 210 | 157 | 121.1 | 124 | 175.9 | 193 | 137 |
| TSS (lbs/day) Average Monthly | < 15 | < 10 | < 13 | < 8 | 7 | 3 | 12 | 29 | < 8 | 16 | < 8 | 25 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 292 | 357 | 1272 | 264 | 290 | 194 | 251 | 316 | 295 | 287 | 484 | 380 |
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 332 | 432 | 3670 | 348 | 657 | 293 | 373 | 417 | 639 | 381 | 844 | 573 |
| TSS (lbs/day) Weekly Average | 19 | < 14 | 24 | 18 | 12 | 5 | 22 | 52 | 17 | 53 | 12 | 68 |
| TSS (mg/L) Average Monthly | < 4 | < 2 | < 4 | < 3 | 2 | 1 | 4 | 6 | < 2 | 4 | < 3 | 5 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 75 | 84 | 420 | 100 | 98 | 73 | 89 | 67 | 50 | 64 | 151 | 83 |
| TSS (mg/L) Weekly Average | 5 | 4 | 7 | 6 | 4 | 2 | 7 | 10 | 3 | 13 | 3 | 10 |
| Total Dissolved Solids (lbs/day) Average Quarterly | | 338 | | | 977 | | | 2090 | | | 1118 | |
| Total Dissolved Solids (mg/L) Average Quarterly | | 83 | | | 328 | | | 351 | | | 350 | |
| Fecal Coliform (CFU/100 ml) Geometric Mean | 10 | 1 | 2 | 2 | 2 | 1 | 1 | 17 | 2 | 28 | 2 | 11 |
| Fecal Coliform (CFU/100 ml) Instantaneous Maximum | 100 | 1 | 10 | 30 | 10 | 1 | 1 | 4000 | 10 | 8000 | 30 | 40 |

| | | | | | | | | | | | | |
|--|-------|-------|-------|-------|--------|-----|-----|-------|-------|-------|-------|-------|
| Nitrate-Nitrite (lbs/day) Average Quarterly | | 11 | | | 32 | | | 65 | | | 28 | |
| Nitrate-Nitrite (mg/L) Average Quarterly | | 2.61 | | | 10.8 | | | 10.9 | | | 8.7 | |
| Total Nitrogen (lbs/day) Average Quarterly | | 11 | | | 35 | | | 113 | | | 33 | |
| Total Nitrogen (mg/L) Average Quarterly | | 2.61 | | | 11.59 | | | 18.94 | | | 10.33 | |
| Ammonia (lbs/day) Average Monthly | < 0.4 | < 0.5 | < 0.5 | < 0.3 | < 0.5 | < 1 | < 3 | < 3 | < 0.5 | < 0.5 | < 0.3 | < 1 |
| Ammonia (mg/L) Average Monthly | < 0.1 | < 0.1 | < 1 | < 0.1 | < 0.1 | < 1 | < 1 | < 1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 |
| TKN (lbs/day) Average Quarterly | | < 2 | | | 2 | | | 48 | | | 5 | |
| TKN (mg/L) Average Quarterly | | < 0.5 | | | 0.79 | | | 8.04 | | | 1.63 | |
| Total Phosphorus (lbs/day) Average Quarterly | | 1 | | | 5 | | | 12 | | | 5 | |
| Total Phosphorus (mg/L) Average Quarterly | | 0.29 | | | 1.54 | | | 2 | | | 1.53 | |
| Total Aluminum (lbs/day) Average Quarterly | | 0.1 | | | < 0.06 | | | 0.5 | | | 0.2 | |
| Total Aluminum (mg/L) Average Quarterly | | 0.03 | | | < 0.02 | | | 0.08 | | | 0.06 | |
| Total Iron (lbs/day) Average Quarterly | | 0.2 | | | 0.2 | | | 0.5 | | | 0.2 | |
| Total Iron (mg/L) Average Quarterly | | 0.05 | | | 0.06 | | | 0.08 | | | 0.07 | |
| Total Manganese (lbs/day) Average Quarterly | | 0.2 | | | 0.2 | | | 0.6 | | | 0.3 | |
| Total Manganese (mg/L) Average Quarterly | | 0.037 | | | 0.078 | | | 0.104 | | | 0.108 | |
| Chronic WET - Ceriodaphnia Survival (TUc) Daily Maximum | | GG | | | 5.26 | | | GG | | | GG | |
| Chronic WET - Ceriodaphnia Reproduction (TUc) Daily Maximum | | GG | | | 5.26 | | | GG | | | GG | |
| Chronic WET - Pimephales Survival (TUc) Daily Maximum | | GG | | | 5.26 | | | GG | | | GG | |
| Chronic WET - Pimephales Growth (TUc) Daily Maximum | | GG | | | 5.26 | | | GG | | | GG | |

DMR Data for Outfall 002 (from February 1, 2020 to January 31, 2021)

| Parameter | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 | JUL-20 | JUN-20 | MAY-20 | APR-20 | MAR-20 | FEB-20 |
|------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| TSS (mg/L) Daily Maximum | | 3 | | | | | | | | | | |
| TKN (mg/L) Daily Maximum | | < 0.50 | | | | | | | | | | |
| Total Iron (mg/L) Daily Maximum | | < 0.02 | | | | | | | | | | |