

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0028134
APS ID 997646
Authorization ID 1280773

Applicant and Facility Information

Applicant Name	<u>PA American Water Company</u>	Facility Name	<u>PA American Water Kittanning</u>
Applicant Address	<u>852 Wesley Drive</u> <u>Mechanicsburg, PA 17055-4436</u>	Facility Address	<u>104 Watertower Road</u> <u>Kittanning, PA 16201</u>
Applicant Contact	<u>Chris Abruzzo</u>	Facility Contact	<u>Kevin Mortimer (Superintendent)</u>
Applicant Phone	<u>(717) 550-1542</u>	Facility Phone	<u>(724) 287-7150 Ext. 5</u>
Client ID	<u>87712</u>	Site ID	<u>255172</u>
SIC Code	<u>4941</u>	Municipality	<u>Rayburn Township</u>
SIC Description	<u>Trans. & Utilities - Water Supply</u>	County	<u>Armstrong</u>
Date Application Received	<u>July 2, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>July 25, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit for an existing discharge of industrial waste.</u>		

Summary of Review

Raw water is withdrawn from the Allegheny River and is purified by clarification, sedimentation and filtration for use by customers in Kittanning Borough and Rayburn Township.

The discharge consists of mainly of treated filter backwash water and minimal amount of miscellaneous wastewater from lab sample taps and analyzers. The filter backwash wastewater discharge occurs 20 hours/day, 7 days/week. The maximum discharge rate is 0.099 MGD and the long-term average discharge rate is 0.032 MGD.

The permittee requested in the renewal application that sample type for the monitoring requirements remain the same as the current permit due to the plant operating unmanned.

PPC Plan for the facility was last updated in 2019.

There are currently 6 open violations listed in EFACTS for this client at other facilities (5/15/2020).

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Adam Pesek Adam J. Pesek, E.I.T. / Environmental Engineering Specialist	May 15, 2020
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	May 27, 2020

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.032</u>
Latitude	<u>40° 49' 10"</u>	Longitude	<u>-79° 30' 47"</u>
Quad Name	<u>Kittanning</u>	Quad Code	<u>1209</u>
Wastewater Description:	<u>Filter backwash water and miscellaneous wastewater from lab sample taps and analyzers</u>		
Receiving Waters	<u>Allegheny River</u>	Stream Code	<u>42122</u>
NHD Com ID	<u>123860342</u>	RMI	<u>45.6</u>
Drainage Area	<u>8970</u>	Yield (cfs/mi ²)	<u>---</u>
Q ₇₋₁₀ Flow (cfs)	<u>2070</u>	Q ₇₋₁₀ Basis	<u>L&D 7 min. release rate</u>
Elevation (ft)	<u>782</u>	Slope (ft/ft)	<u>0.0001</u>
Watershed No.	<u>17-E</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>Add N</u>	Exceptions to Criteria	<u>Add TON</u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>POLYCHLORINATED BIPHENYLS (PCBS)</u>		
Source(s) of Impairment	<u>SOURCE UNKNOWN</u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.4</u>		<u>9/28/2018 sample at USGS # 03036500</u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u>50.8</u>		<u>Application sample for the renewal application</u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>Buffalo Township Municipal Authority</u>		
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>2070</u>
PWS RMI	<u>29.4</u>	Distance from Outfall (mi)	<u>16.2</u>

Changes Since Last Permit Issuance:

Other Comments: The stream segment is impaired for PCBs. There are no expected sources of PCB's from this facility beyond that in the source water, which is from the receiving stream. Therefore, monitoring of PCBs will not be proposed in the draft permit.

Treatment Facility Summary				
Treatment Facility Name: Kittanning Filter Plant				
WQM Permit No.		Issuance Date		
0376202 A-1 T-1		11/03/2008		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Industrial	Primary	Settling	Liquid dechlorination	
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
		Not Overloaded		

Changes Since Last Permit Issuance:

Other Comments: Solids are removed on a yearly basis from the backwash holding tank and land applied.

Compliance History

DMR Data for Outfall 001 (from March 1, 2019 to February 29, 2020)

Parameter	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19
Flow (MGD) Average Monthly	0.030	0.031	0.031	0.030	0.035	0.040	0.043	0.034	0.036	0.031	0.027	0.025
Flow (MGD) Daily Maximum	0.042	0.042	0.042	0.042	0.042	0.050	0.050	0.050	0.078	0.053	0.049	0.047
pH (S.U.) Minimum	7.0	7.3	7.5	7.4	7.2	7.0	7.2	7.1	6.9	7.1	7.0	7.2
pH (S.U.) Maximum	7.5	7.6	8.7	7.8	7.6	7.6	7.5	8.7	7.2	7.4	7.3	7.4
TRC (mg/L) Average Monthly	0.28	0.37	0.28	0.28	0.21	0.19	0.19	0.17	0.25	0.22	0.20	0.19
TRC (mg/L) Instantaneous Maximum	0.36	0.44	0.40	0.37	0.28	0.30	0.28	0.23	0.37	0.45	0.43	0.27
TSS (mg/L) Average Monthly	2	4	< 2	< 5	< 2	< 2	2.0	< 2.0	< 2	< 2	< 2	4.5
TSS (mg/L) Instantaneous Maximum	2	4	< 2	7	< 2	< 2	2.0	< 2.0	2	< 2	< 2	5.0
Total Aluminum (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1	< 0.10	< 0.1	< 0.1	< 0.1	< 0.1
Total Aluminum (mg/L) Instantaneous Maximum	< 0.1	< 0.1	< 0.1	0.1	< 0.1	< 0.1	< 0.1	< 0.10	< 0.1	< 0.1	< 0.1	< 0.1
Total Iron (mg/L) Average Monthly	0.62	0.70	0.60	0.59	0.27	0.17	0.24	0.26	0.40	0.30	0.63	0.75
Total Iron (mg/L) Instantaneous Maximum	0.71	0.72	0.64	0.74	0.28	0.18	0.24	0.26	0.45	0.34	0.72	0.83
Total Manganese (mg/L) Average Monthly	0.07	0.07	0.10	0.15	0.08	0.07	0.13	0.15	0.29	0.15	0.08	0.07
Total Manganese (mg/L) Instantaneous Maximum	0.08	0.07	0.10	0.19	0.08	0.07	0.13	0.16	0.31	0.17	0.09	0.08

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.032
 Latitude 40° 49' 10.00" Longitude -79° 30' 47.00"
 Wastewater Description: IW Process Effluent without ELG

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Parameter	Limit (mg/l)	SBC	Federal Regulation	State Regulation
Total Suspended Solids	30	Average Monthly		362-2183-003
Total Suspended Solids	40	Daily Maximum		362-2183-003
Aluminum	4.0	Average Monthly		362-2183-003
Aluminum	8.0	Daily Maximum		362-2183-003
Manganese	1.0	Average Monthly		362-2183-003
Manganese	2.0	Daily Maximum		362-2183-003
Total Iron	2.0	Average Monthly		362-2183-003
Total Iron	4.0	Daily Maximum		362-2183-003
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
Total Residual Chlorine	1.0	Daily Maximum		362-2183-003
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)

Comments: 362-2183-003 References the Department’s technical guidance document entitled “Technology-based Control Requirements for Water Treatment Plant Wastes.” The limits are BPT (Best Practical Control Technology) and are not based on actual regulation. The Department has identified the TSD requirements as the Best Available Treatment (BAT) that, as a minimum, the permittee will be required to meet. Since no federal effluent limitation guidelines (ELGs) have been promulgated, the Department’s Best Professional Judgment of BAT, as outlined in the TSD, satisfies the Federal requirements of the 40 CFR 125.3(d) regulations. All of the technology-based effluent limitations are documented in the Pollution Report for this facility and are incorporated herein as a reference.

Water Quality-Based Limitations

A “Reasonable Potential Analysis” (Attachment A) determined the following parameters were candidates for limitations: total led and total phenols.

Comments: The Dilution Ratio, a comparison of low stream flow rate to discharge flow rate, was found to be 41,814 to one. Therefore, performing a water quality toxic modeling is not deemed necessary for the parameters of concern.

Best Professional Judgment (BPJ) Limitations

Comments: None

Anti-Backsliding

The daily maximum limits found in the “Technology-Based Limitations” section above were previously applied as instantaneous maximum limits as a regional policy in the Southwest region and the limits have been able to be consistently achieved. Therefore, the limits will continue to be applied in the renewed NPDES Permit.

Other Considerations

Calcium thiosulfite is used as a wastewater treatment chemical to dechlorinate the filter backwash wastewater prior to discharge if needed.

Monitoring frequencies and sampling types in the permit are based on Table 6-4 of the Department's August 1993 "Technical Guidance for the Development and Specification of Effluent Limitations and Other Conditions in NPDES Permits" (Permit Writer's Guide).

The discharge from this facility is non-continuous and the characteristics of the wastewater are relatively constant. Based on the review of Discharge Monitoring Reports, this facility is in compliance with the current NPDES permit limits. Therefore, grab samples are specified instead of composite samples.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Daily Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	2/month	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	Grab
Total Aluminum	XXX	XXX	XXX	4.0	XXX	8	2/month	Grab
Total Iron	XXX	XXX	XXX	2.0	XXX	4	2/month	Grab
Total Manganese	XXX	XXX	XXX	1.0	XXX	2	2/month	Grab

Compliance Sampling Location: Outfall 001 (after disinfection)

Other Comments:

ATTACHMENT A

TOXICS SCREENING ANALYSIS WATER QUALITY POLLUTANTS OF CONCERN VERSION 2.7						
Facility: Kittanning Water Systems		NPDES Permit No.: PA0028134	Outfall: 001			
Analysis Hardness (mg/L): 60.8		Discharge Flow (MGD): 0.632	Analysis pH (SU): 7.4			
Stream Flow, Q ₇₋₁₀ (cfs): 2070						
Parameter	Maximum Concentration in Application or DMRs (µg/L)	Most Stringent Criterion (µg/L)	Candidate for PENTOXSD Modeling?	Most Stringent WQBEL (µg/L)	Screening Recommendation	
Group 1	Total Dissolved Solids	141000	50000	No		
	Chloride	30000	250000	No		
	Bromide	100	N/A	No		
	Sulfate	23000	250000	No		
	Fluoride	600	2000	No		
Group 2	Total Aluminum	<	50	750	No	
	Total Antimony	<	0.5	5.6	No (Value < QL)	
	Total Arsenic	<	0.5	10	No (Value < QL)	
	Total Barium	<	30.9	2400	No	
	Total Beryllium	<	0.5	N/A	No	
	Total Boron	<	20	1600	No (Value < QL)	
	Total Cadmium	<	0.1	0.164	No (Value < QL)	
	Total Chromium	<	0.5	N/A	No	
	Hexavalent Chromium	<	0.5	10.4	No (Value < QL)	
	Total Cobalt	<	0.4	19	No	
	Total Copper	<	4.2	5.2	No	
	Total Cyanide	<	10	N/A	No	
	Total Iron	<	366	1500	No	
	Dissolved Iron	<	20	300	No (Value < QL)	
	Total Lead	<	3	1.3	Yes	
	Total Manganese	<	220	1000	No	
	Total Mercury	<	0.1	0.06	No (Value < QL)	
	Total Molybdenum	<	10	N/A	No	
	Total Nickel	<	5	29.4	No	
	Total Phenols (Phenolics)	<	83	5	Yes	
	Total Selenium	<	0.5	5.0	No (Value < QL)	
	Total Silver	<	0.1	1.2	No (Value < QL)	
	Total Thallium	<	0.1	0.24	No (Value < QL)	
	Total Zinc	<	13	67.5	No	
	Group 3	Acrolein	<	3		
		Acrylamide	<	0.07		
		Acrylonitrile	<	0.051		
		Benzene	<	1.2		
Bromoform		<	4.3			
Carbon Tetrachloride		<	0.23			
Chlorobenzene		<	130			
Chlorodibromomethane		<	0.4			
Chloroethane		<	N/A			
2-Chloroethyl Vinyl Ether		<	3500			
Chloroform		<	5.7			
Dichlorobromomethane		<	0.55			
1,1-Dichloroethane		<	N/A			
1,2-Dichloroethane		<	0.38			
1,1-Dichloroethylene		<	33			
1,2-Dichloropropane		<	2200			
1,3-Dichloropropylene		<	0.34			
Ethylbenzene		<	530			
Methyl Bromide		<	47			
Methyl Chloride		<	5500			
Methylene Chloride		<	4.6			
1,1,2,2-Tetrachloroethane		<	0.17			
Tetrachloroethylene		<	0.69			
Toluene		<	330			
1,2-trans-Dichloroethylene		<	140			
1,1,1-Trichloroethane		<	610			
1,1,2-Trichloroethane		<	0.59			
Trichloroethylene		<	2.5			
Vinyl Chloride	<	0.025				
Group 4	2-Chlorophenol	<	81			
	2,4-Dichlorophenol	<	77			
	2,4-Dimethylphenol	<	130			
	4,6-Dinitro-p-Cresol	<	13			
	2,4-Dinitrophenol	<	69			
	2-Nitrophenol	<	1600			
	4-Nitrophenol	<	470			
	p-Chloro-m-Cresol	<	30			
	Pentachlorophenol	<	0.27			
	Phenol	<	10400			
2,4,6-Trichlorophenol	<	1.4				