

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0028193
APS ID 694932
Authorization ID 1221694

Applicant and Facility Information

Applicant Name	<u>McCandless Township Sanitary Authority</u>	Facility Name	<u>Longvue #2 STP</u>
Applicant Address	<u>418 Arcadia Drive Pittsburgh, PA 15237-5557</u>	Facility Address	<u>Sunderland Drive Pittsburgh, PA 15237</u>
Applicant Contact	<u>Mr. William Youngblood</u>	Facility Contact	<u>Mr. Edward Bricker</u>
Applicant Phone	<u>(412) 364-2119</u>	Facility Phone	<u>(724) 935-8050</u>
Client ID	<u>75745</u>	Site ID	<u>250310</u>
Ch 94 Load Status	<u></u>	Municipality	<u>Ross Township</u>
Connection Status	<u></u>	County	<u>Allegheny</u>
Date Application Received	<u>March 23, 2018</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 26, 2018</u>	If No, Reason	<u></u>
Purpose of Application	<u>Application for renewal of an NPDES permit for the discharge of treated Sewage.</u>		

Summary of Review



The applicant has applied for a renewal of an existing NPDES Permit No. PA0028193, which was previously issued by the Department on September 10, 2013. That permit expired on September 30, 2018. The first draft NPDES Permit was issued on November 11, 2018. This permit is being redrafted for a second time due to changes in Department Policy and Water Quality Criteria.

WQM Permit No. 8046 authorized the construction of the plant to treat an annual average design flow of 0.1 MGD and later amended on January 27, 2020 to replace chlorine UV for disinfection purposes. The existing treatment process consists of primary clarification, a trickling filter, secondary clarification, and UV disinfection. The design organic capacity is 680 lbs/day.

The receiving stream, Unnamed Tributary to Girtys Run, is currently classified as a WWF and is located in State Watershed No. 18-A.

The applicant has complied with Act 14 Notifications and no comments were received.

Sludge use and disposal description and location(s): Sludge from the Longvue #2 STP is hauled to the Digesters at the Pine Creek Treatment Facility (PA0027669 owned and operated by MTSA) where it is dewatered via Centrifuge.

Approve	Deny	Signatures	Date
X		 William C. Mitchell, E.I.T. / Environmental Engineering Specialist	September 22, 2022
X		 Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineer Manager	September 29, 2022

Summary of Review

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.1</u>
Latitude	<u>40° 33' 1.00"</u>	Longitude	<u>80° 01' 40.00"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Girtys Run</u>	Stream Code	<u>UNT to 42124</u>
NHD Com ID	<u></u>	RMI	<u>0.42</u>
Drainage Area	<u>0.0804</u>	Yield (cfs/mi ²)	<u>0.00453</u>
Q ₇₋₁₀ Flow (cfs)	<u>0.000365</u>	Q ₇₋₁₀ Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>18-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Other Habitat Alteration and Organic Enrichment/Low D.O.</u>		
Source(s) of Impairment	<u>Bank Modifications, Urban Runoff/Storm Sewers, and Removal of Vegetation</u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>West View Water Authority</u>		
PWS Waters	<u>Ohio River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI		Distance from Outfall (mi)	<u>15.0</u>

Changes Since Last Permit Issuance: None

Other Comments: From April 16, 2019 through Jun 4, 2019, The Department conducted a cause and effect survey on Girtys Run, in the vicinity of the confluence of Girtys Run and a drainage channel (UNT to Girtys Run) that carries the Longvue #2 STP discharge. The purpose of the survey was to see if copper is exceeding Chapter 93 Water Quality Criteria above or below the discharge, to determine if Longvue #2 STP is having an impact and/or causing or contributing to nonattainment of the protected use, and to reassess Girtys Run.

The Longvue #2 STP discharges to a drainage channel (UNT to Girtys Run) and then enters an enclosure downstream from the discharge, so a cause and effect survey on this stream segment was not feasible. Therefore, for the purpose of the cause and effect study, the discharge of the Longvue#2 STP was considered to be at the confluence of the UNT and Girtys Run.

The point of first use is Girtys Run and effluent limitations for this facility will be evaluated at RMI 6.59 on Girtys Run, Stream Code 42124. The elevation is 1051.05 ft, Drainage Area is 0.88 sq mi, LFY is 0.008 cfs/mi², slope is 0.0130 ft/ft, and stream hardness is 201 mg/L.

Treatment Facility Summary				
Treatment Facility Name: Longvue #2 STP				
WQM Permit No.		Issuance Date		
8046				
8046 A-1		01/27/2020		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with Ammonia Reduction	Primary Clarification, a Trickling Filter, and Secondary Clarification	UV	0.095 (2017)
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.1	680		Sludge Digester	Hauled to Pine Creek WWTP

Changes Since Last Permit Issuance: UV Disinfection was Installed to replace chlorination. Post Construction Certification Form dated March 7, 2020.

Other Comments: N/A

Compliance History

Operations Compliance Check Summary Report

Facility: Longvue STP #2 (McCandless Twp)

NPDES Permit No.: PA0028193

Compliance Review Period: 2/2017 – 2/2022

Inspection Summary:

INSP ID	INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC
3166859	02/24/2021	Compliance Evaluation	County Health Dept	Violation(s) Noted
2859226	03/19/2019	Compliance Evaluation	County Health Dept	Violation(s) Noted
2732102	05/08/2018	Compliance Evaluation	County Health Dept	Violation(s) Noted
2726439	04/12/2018	Chapter 94 Inspection	PA Dept of Environmental Protection	Administratively Closed
2592038	05/03/2017	Chapter 94 Inspection	County Health Dept	Administratively Closed
2585200	03/29/2017	Compliance Evaluation	County Health Dept	Violation(s) Noted

Violation Summary:

VIOL ID	VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC	RESOLVED DATE
912904	02/24/2021	92A.44	NPDES - Violation of effluent limits in Part A of permit	10/28/2021
845056	03/19/2019	92A.44	NPDES - Violation of effluent limits in Part A of permit	04/22/2019
817188	05/08/2018	92A.44	NPDES - Violation of effluent limits in Part A of permit	07/26/2018
783705	03/29/2017	92A.44	NPDES - Violation of effluent limits in Part A of permit	10/15/2018
783706	03/29/2017	92A.41(A)5	NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance	10/15/2018

Open Violations by Client ID:

No open violations for client 75745

Enforcement Summary:

ENF ID	ENF TYPE	EXECUTED DATE	VIOLATIONS	ENF FINALSTATUS	ENF CLOSED DATE
373986	NOV	04/02/2019	92A.44	Administrative Close Out	04/09/2021
367134	NOV	07/26/2018	92A.44	Administrative Close Out	08/30/2019

DMR Violation Summary:

Monitor end date	PARAMETER	STAT_BASE_CODE	PERMIT_VALU E	SAMPL E VALUE	UNIT_OF_MEASUR E
6/30/2021	CBOD	Weekly Average	15	17	mg/L
10/31/2020	Copper, Total	Average Monthly	0.06	0.065	mg/L
5/31/2019	Copper, Total	Average Monthly	0.06	0.064	mg/L
4/30/2019	Copper, Total	Average Monthly	0.06	0.094	mg/L
4/30/2019	Copper, Total	Daily Maximum Instantaneous	0.15	0.361	mg/L
10/31/2018	Fecal Coliform	Maximum	10000	32000	CFU/100 ml
9/30/2018	Ammonia-Nitrogen	Weekly Average	2.5	2.7	lbs/day
5/31/2018	Copper, Total	Average Monthly	0.06	0.123	mg/L
5/31/2018	Copper, Total	Daily Maximum Instantaneous	0.15	0.361	mg/L
5/31/2018	Fecal Coliform	Maximum	1000	4600	CFU/100 ml
4/30/2018	Fecal Coliform	Maximum	10000	36200	CFU/100 ml
2/28/2018	Flow	Average Monthly Instantaneous	0.1	0.176	MGD
11/30/2017	Fecal Coliform	Maximum	10000	160000	CFU/100 ml
7/31/2017	Fecal Coliform	Maximum	1000	5500	CFU/100 ml
6/30/2017	Fecal Coliform	Maximum	1000	200000	CFU/100 ml
5/31/2017	Ammonia-Nitrogen	Weekly Average Instantaneous	2.5	2.9	lbs/day
5/31/2017	Fecal Coliform	Maximum	1000	25100	CFU/100 ml
2/28/2017	Fecal Coliform	Maximum	10000	16700	CFU/100 ml

Compliance Status: No open violation or enforcements

Completed by: John Murphy

Completed date: 2/3/2022

Development of Effluent Limitations

Outfall No. 001
 Latitude 40° 33' 1.00"
 Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.1
 Longitude -80° 1' 40.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above Technology-Based Limitations are imposed for TSS, pH, and Fecal Coliform.

Water Quality-Based Limitations

A “Reasonable Potential Analysis” (TMS Version 1.3) was conducted.

The following limitations were determined through water quality modeling for the facility (Attachment # 3, 4, and 5):

Parameter	Limit (mg/l)	SBC	Model
Dissolved Oxygen	5.0	Instantaneous Minimum	WQM 7.0 Version 1.1
CBOD ₅	10	Average Monthly	WQM 7.0 Version 1.1
Ammonia Nov 1 - Apr 30	3.0	Average Monthly	WQM 7.0 Version 1.1
Ammonia May 1 - Oct 31	1.9	Average Monthly	WQM 7.0 Version 1.1
Total Copper (ug/L)	10.1	Average Monthly	TMS Version 1.3

Comments: The previous NPDES Permit established a total copper effluent limit based upon the use of a Water Effects Ratio (WER) Study that is over ten years old. The metal translator and WER can no longer be carried forward in this renewal NPDES Permit. The WQBEL for total copper was established using the Department’s TOXCONC Version 2.0 and TMS Model Version 1.3 (Attachment # 2 and 5). The applicant will have two years to comply with the new total copper limit. Please see Part C.III, Water Quality-Based Effluent Limitations for Toxic Pollutants, for further details regarding these WQBELs, Site-Specific Data Collection Studies, and Compliance Report.

The TMS recommended monitoring for total zinc because the discharge concentration is greater than 10% of the WQBEL.

Best Professional Judgment (BPJ) Limitations

Comments: N/A

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

The facility is not seeking to revise the previously permitted effluent limits.

Additional Considerations

Ultraviolet (UV) disinfection is used, and therefore, Total Residual Chlorine (TRC) limits are not applicable. Routine monitoring of UV Transmittance will be at the same monitoring frequency that is used for TRC.

For pH, Dissolved Oxygen (DO) and UV Transmittance, a monitoring frequency of 1/day has been imposed. In general, less frequent monitoring may be established only when the permittee demonstrates that there will be no discharge on days where monitoring is not required.

Sewage discharges will include monitoring, at a minimum, for *E. Coli*, in new and reissued permits, with a monitoring frequency of 1/quarter for facilities with a design flows ≥ 0.05 and < 1.0 MGD per Chapter 92.a.61.

Nutrient monitoring is required to establish the nutrient load from the wastewater treatment facility and the impacts that load may have on the quality of the receiving stream(s). A 1/quarter monitoring requirement for Total N & Total P has been added to the permit per Chapter 92.a.61.

Mass loading limits are applicable for publicly owned treatment works (POTWs). Current policy requires average monthly mass loading limits be established for CBOD₅, TSS, and NH₃-N and average weekly mass loading limits be established for CBOD₅ and TSS. Average monthly mass loading limits (lbs/day) are based on the formula: design flow (MGD) x concentration limit (mg/L) x conversion factor (8.34).

For POTWs with design flows greater than 2,000 GPD, influent BOD₅ and TSS monitoring must be established in the permit and the monitoring should be consistent with the same frequency and sample type as is used for other effluent parameters.

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (362-0400-001).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	8.0	12.0	XXX	10.0	15.0	20	1/week	8-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	1/week	8-Hr Composite
TSS	20.0	31.0	XXX	25.0	37.5	50	1/week	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
UV Transmittance (%)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Ammonia Nov 1 - Apr 30	2.5	XXX	XXX	3.0	XXX	6	1/week	8-Hr Composite
Ammonia May 1 - Oct 31	1.5	XXX	XXX	1.9	XXX	3.9	1/week	8-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Instantaneous Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Zinc (ug/L)	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	1/week	24-Hr Composite

Compliance Sampling Location: Outfall # 001

Other Comments: N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through 24th Month.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Copper (ug/L)	0.050	0.125 Daily Max	XXX	60.0	150.0 Daily Max	XXX	1/week	24-Hr Composite

Compliance Sampling Location: Outfall # 001

Other Comments: N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: 25th Month through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Total Copper (ug/L)	0.008	0.014 Daily Max	XXX	10.1	17.0 Daily Max	25.3	1/week	24-Hr Composite


Compliance Sampling Location: Outfall # 001

Other Comments: N/A

Attachment #1 – USGS StreamStats Report

StreamStats Report

Region ID: PA
 Workspace ID: PA20220204142629446000
 Clicked Point (Latitude, Longitude): 40.54493, -80.03104
 Time: 2022-02-04 09:26:51 -0500



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.88	square miles
ELEV	Mean Basin Elevation	1171	feet

Low-Flow Statistics Parameters [Low Flow Region 4]					
Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.88	square miles	2.26	1400

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
ELEV	Mean Basin Elevation	1171	feet	1050	2580
Low-Flow Statistics Disclaimers [Low Flow Region 4]					
One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors					
Low-Flow Statistics Flow Report [Low Flow Region 4]					
Statistic		Value	Unit		
7 Day 2 Year Low Flow		0.0238	ft ³ /s		
30 Day 2 Year Low Flow		0.0461	ft ³ /s		
7 Day 10 Year Low Flow		0.00692	ft ³ /s		
30 Day 10 Year Low Flow		0.0149	ft ³ /s		
90 Day 10 Year Low Flow		0.0306	ft ³ /s		
<i>Low-Flow Statistics Citations</i>					
Stuckey, M.H.,2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (http://pubs.usgs.gov/sir/2006/5130/)					

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.6.2

StreamStats Services Version: 1.2.22

Attachment #2 – TOXCONC Version 2.0

Facility: Longvue #2		Reviewer/Permit Engineer: W. Mitchell	
NPDES #: PA0028193			
Outfall No: 001			
n (Samples/Month): 4			
Parameter	Distribution Applied	Coefficient of Variation (daily)	Avg. Monthly
Total Copper (mg/L)	Lognormal	0.6500520	0.0921210

Attachment #3 – WQM 7.0 Version 1.1 – Warmer Period

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42124	GIRTYS RUN	6.590	1051.05	0.88	0.01300	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.008	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Longvue #2 STP	PA0028193	0.1000	0.0000	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	10.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	2.00	0.00	0.00	0.60

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42124	GIRTYS RUN	6.000	1011.29	1.38	0.01300	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.008	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18A		42124				GIRTYS RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
6.590	0.01	0.00	0.01	.1547	0.01300	.377	5.08	13.46	0.08	0.428	20.21	7.00
Q1-10 Flow												
6.590	0.00	0.00	0.00	.1547	0.01300	NA	NA	NA	0.08	0.431	20.14	7.00
Q30-10 Flow												
6.590	0.01	0.00	0.01	.1547	0.01300	NA	NA	NA	0.09	0.424	20.29	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input checked="" type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
18A	42124	GIRTYS RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
6.590	Longvue #2 STP	16.57	4	16.57	4	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
6.590	Longvue #2 STP	1.85	1.97	1.85	1.97	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
6.59	Longvue #2 STP	10	10	1.97	1.97	5	5	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18A	42124	GIRTYS RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
6.590	0.100	20.214	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
5.079	0.377	13.456	0.084	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
9.66	1.481	1.88	0.610	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.139	25.092	Owens	5	
<u>Reach Travel Time (days)</u>	Subreach Results			
0.428	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.043	9.06	1.83	7.08
	0.086	8.50	1.79	7.78
	0.128	7.97	1.74	8.05
	0.171	7.48	1.69	8.18
	0.214	7.01	1.65	8.21
	0.257	6.58	1.61	8.21
	0.299	6.17	1.57	8.21
	0.342	5.79	1.53	8.21
	0.385	5.43	1.49	8.21
	0.428	5.09	1.45	8.21

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18A		42124		GIRTYS RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
6.590	Longvue #2 STP	PA0028193	0.100	CBOD5	10		
				NH3-N	1.97	3.94	
				Dissolved Oxygen			5

Attachment #4 – WQM 7.0 Version 1.1 – Colder Period

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42124	GIRTYS RUN	6.590	1051.05	0.88	0.01300	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.016	0.00	0.00	0.000	0.000	0.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Longvue #2 STP	PA0028193	0.1000	0.0000	0.0000	0.000	15.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	10.00	2.00	0.00	1.50			
Dissolved Oxygen	4.00	12.51	0.00	0.00			
NH3-N	3.00	0.00	0.00	0.60			

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18A	42124	GIRTYS RUN	6.000	1011.29	1.38	0.01300	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.016	0.00	0.00	0.000	0.000	0.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
18A		42124				GIRTYS RUN						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
6.590	0.01	0.00	0.01	.1547	0.01300	.38	5.14	13.52	0.09	0.418	14.18	7.00
Q1-10 Flow												
6.590	0.01	0.00	0.01	.1547	0.01300	NA	NA	NA	0.08	0.425	14.46	7.00
Q30-10 Flow												
6.590	0.02	0.00	0.02	.1547	0.01300	NA	NA	NA	0.09	0.411	13.92	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input checked="" type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
 18A 42124 GIRTYS RUN

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
6.590	Longvue #2 STP	24.1	6	24.1	6	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
6.590	Longvue #2 STP	2.79	3	2.79	3	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
6.59	Longvue #2 STP	10	10	3	3	5	5	0	0

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
18A	42124	GIRTYS RUN		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
6.590	0.100	14.179	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
5.138	0.380	13.518	0.086	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
9.34	1.466	2.75	0.383	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.616	25.166	Owens	5	
<u>Reach Travel Time (days)</u>				
0.418				
Subreach Results				
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.042	8.92	2.71	8.13
	0.084	8.51	2.67	9.03
	0.125	8.12	2.62	9.25
	0.167	7.75	2.58	9.25
	0.209	7.39	2.54	9.25
	0.251	7.05	2.50	9.25
	0.292	6.73	2.46	9.25
	0.334	6.42	2.42	9.25
	0.376	6.13	2.38	9.25
	0.418	5.85	2.35	9.25

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
18A		42124		GIRTYS RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
6.590	Longvue #2 STP	PA0028193	0.100	CBOD5	10		
				NH3-N	3	6	
				Dissolved Oxygen			5

Attachment #5 – TMS Version 1.3



Toxics Management Spreadsheet
Version 1.3, March 2021

Discharge Information

Instructions **Discharge** Stream

Facility: Longvue #2 NPDES Permit No.: PA0028193 Outfall No.: 001
 Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Sewage Effluent - Minor < 0.1 MGD

Discharge Characteristics								
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)	
			AFC	CFC	THH	CRL	Q ₇₋₁₀	Q _n
0.1	100	7						

Discharge Pollutant	Units	Max Discharge Conc	0 if left blank		0.5 if left blank		0 if left blank			1 if left blank		
			Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl	
Group 1	Total Dissolved Solids (PWS)	mg/L	573									
	Chloride (PWS)	mg/L	183									
	Bromide	mg/L	0.099									
	Sulfate (PWS)	mg/L	37.1									
	Fluoride (PWS)	mg/L										
Group 2	Total Aluminum	µg/L										
	Total Antimony	µg/L										
	Total Arsenic	µg/L										
	Total Barium	µg/L										
	Total Beryllium	µg/L										
	Total Boron	µg/L										
	Total Cadmium	µg/L										
	Total Chromium (III)	µg/L										
	Hexavalent Chromium	µg/L										
	Total Cobalt	µg/L										
	Total Copper	µg/L	92.12			0.6501						
	Free Cyanide	µg/L										
	Total Cyanide	µg/L										
	Dissolved Iron	µg/L										
	Total Iron	µg/L										
	Total Lead	µg/L	< 0.8									
	Total Manganese	µg/L										
	Total Mercury	µg/L										
	Total Nickel	µg/L										
	Total Phenols (Phenolics) (PWS)	µg/L										
Total Selenium	µg/L											
Total Silver	µg/L											
Total Thallium	µg/L											
Total Zinc	µg/L	14										
Total Molybdenum	µg/L											
Acrolein	µg/L	<										
Acrylamide	µg/L	<										
Acrylonitrile	µg/L	<										
Benzene	µg/L	<										
Bromoform	µg/L	<										

Group 3	Carbon Tetrachloride	µg/L	<																		
	Chlorobenzene	µg/L																			
	Chlorodibromomethane	µg/L	<																		
	Chloroethane	µg/L	<																		
	2-Chloroethyl Vinyl Ether	µg/L	<																		
	Chloroform	µg/L	<																		
	Dichlorobromomethane	µg/L	<																		
	1,1-Dichloroethane	µg/L	<																		
	1,2-Dichloroethane	µg/L	<																		
	1,1-Dichloroethylene	µg/L	<																		
	1,2-Dichloropropane	µg/L	<																		
	1,3-Dichloropropylene	µg/L	<																		
	1,4-Dioxane	µg/L	<																		
	Ethylbenzene	µg/L	<																		
	Methyl Bromide	µg/L	<																		
	Methyl Chloride	µg/L	<																		
	Methylene Chloride	µg/L	<																		
	1,1,2,2-Tetrachloroethane	µg/L	<																		
	Tetrachloroethylene	µg/L	<																		
	Toluene	µg/L	<																		
	1,2-trans-Dichloroethylene	µg/L	<																		
1,1,1-Trichloroethane	µg/L	<																			
1,1,2-Trichloroethane	µg/L	<																			
Trichloroethylene	µg/L	<																			
Vinyl Chloride	µg/L	<																			
Group 4	2-Chlorophenol	µg/L	<																		
	2,4-Dichlorophenol	µg/L	<																		
	2,4-Dimethylphenol	µg/L	<																		
	4,6-Dinitro-o-Cresol	µg/L	<																		
	2,4-Dinitrophenol	µg/L	<																		
	2-Nitrophenol	µg/L	<																		
	4-Nitrophenol	µg/L	<																		
	p-Chloro-m-Cresol	µg/L	<																		
	Pentachlorophenol	µg/L	<																		
	Phenol	µg/L	<																		
	2,4,6-Trichlorophenol	µg/L	<																		
Group 5	Acenaphthene	µg/L	<																		
	Acenaphthylene	µg/L	<																		
	Anthracene	µg/L	<																		
	Benzidine	µg/L	<																		
	Benzo(a)Anthracene	µg/L	<																		
	Benzo(a)Pyrene	µg/L	<																		
	3,4-Benzofluoranthene	µg/L	<																		
	Benzo(ghi)Perylene	µg/L	<																		
	Benzo(k)Fluoranthene	µg/L	<																		
	Bis(2-Chloroethoxy)Methane	µg/L	<																		
	Bis(2-Chloroethyl)Ether	µg/L	<																		
	Bis(2-Chloroisopropyl)Ether	µg/L	<																		
	Bis(2-Ethylhexyl)Phthalate	µg/L	<																		
	4-Bromophenyl Phenyl Ether	µg/L	<																		
	Butyl Benzyl Phthalate	µg/L	<																		
	2-Chloronaphthalene	µg/L	<																		
	4-Chlorophenyl Phenyl Ether	µg/L	<																		
	Chrysene	µg/L	<																		
	Dibenzo(a,h)Anthracene	µg/L	<																		
	1,2-Dichlorobenzene	µg/L	<																		
	1,3-Dichlorobenzene	µg/L	<																		
	1,4-Dichlorobenzene	µg/L	<																		
	3,3-Dichlorobenzidine	µg/L	<																		
	Diethyl Phthalate	µg/L	<																		
Dimethyl Phthalate	µg/L	<																			
Di-n-Butyl Phthalate	µg/L	<																			
2,4-Dinitrotoluene	µg/L	<																			

	2,6-Dinitrotoluene	µg/L	<																				
	Di-n-Octyl Phthalate	µg/L	<																				
	1,2-Diphenylhydrazine	µg/L	<																				
	Fluoranthene	µg/L	<																				
	Fluorene	µg/L	<																				
	Hexachlorobenzene	µg/L	<																				
	Hexachlorobutadiene	µg/L	<																				
	Hexachlorocyclopentadiene	µg/L	<																				
	Hexachloroethane	µg/L	<																				
	Indeno(1,2,3-cd)Pyrene	µg/L	<																				
	Isophorone	µg/L	<																				
	Naphthalene	µg/L	<																				
	Nitrobenzene	µg/L	<																				
	n-Nitrosodimethylamine	µg/L	<																				
	n-Nitrosodi-n-Propylamine	µg/L	<																				
	n-Nitrosodiphenylamine	µg/L	<																				
	Phenanthrene	µg/L	<																				
	Pyrene	µg/L	<																				
	1,2,4-Trichlorobenzene	µg/L	<																				
Group 6	Aldrin	µg/L	<																				
	alpha-BHC	µg/L	<																				
	beta-BHC	µg/L	<																				
	gamma-BHC	µg/L	<																				
	delta BHC	µg/L	<																				
	Chlordane	µg/L	<																				
	4,4-DDT	µg/L	<																				
	4,4-DDE	µg/L	<																				
	4,4-DDD	µg/L	<																				
	Dieldrin	µg/L	<																				
	alpha-Endosulfan	µg/L	<																				
	beta-Endosulfan	µg/L	<																				
	Endosulfan Sulfate	µg/L	<																				
	Endrin	µg/L	<																				
	Endrin Aldehyde	µg/L	<																				
	Heptachlor	µg/L	<																				
	Heptachlor Epoxide	µg/L	<																				
	PCB-1016	µg/L	<																				
	PCB-1221	µg/L	<																				
	PCB-1232	µg/L	<																				
	PCB-1242	µg/L	<																				
	PCB-1248	µg/L	<																				
PCB-1254	µg/L	<																					
PCB-1260	µg/L	<																					
PCBs, Total	µg/L	<																					
Toxaphene	µg/L	<																					
2,3,7,8-TCDD	ng/L	<																					
Group 7	Gross Alpha	pCi/L																					
	Total Beta	pCi/L	<																				
	Radium 226/228	pCi/L	<																				
	Total Strontium	µg/L	<																				
	Total Uranium	µg/L	<																				
	Osmotic Pressure	mOs/kg																					



Stream / Surface Water Information

Longvue #2, NPDES Permit No. PA0028193, Outfall 001

Instructions Discharge Stream

Receiving Surface Water Name: Girtys Run No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi ²)*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	042124	6.59	1051.05	0.88			Yes
End of Reach 1	042124	6	1011.29	1.38			Yes

Q₇₋₁₀

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness*	pH*	Hardness	pH
Point of Discharge	6.59	0.00786										201	7		
End of Reach 1	6	0.00786													

Q_n

Location	RMI	LFY (cfs/mi ²)*	Flow (cfs)		W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary		Stream		Analysis	
			Stream	Tributary						Hardness	pH	Hardness	pH	Hardness	pH
Point of Discharge	6.59														
End of Reach 1	6														



Model Results

Longvue #2, NPDES Permit No. PA0028193, Outfall 001

Instructions

Results

RETURN TO INPUTS

SAVE AS PDF

PRINT

All

Inputs

Results

Limits

Hydrodynamics

Q₇₋₁₀

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
6.59	0.01		0.01	0.155	0.013	0.377	5.087	13.478	0.084	0.428	0.002
6	0.01		0.011								

Q_h

RMI	Stream Flow (cfs)	PWS Withdrawal (cfs)	Net Stream Flow (cfs)	Discharge Analysis Flow (cfs)	Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Travel Time (days)	Complete Mix Time (min)
6.59	0.10		0.10	0.155	0.013	0.458	5.087	11.107	0.108	0.335	0.149
6	0.143		0.14								

Wasteload Allocations

AFC

CCT (min): 0.002

PMF: 1

Analysis Hardness (mg/l): 104.32

Analysis pH: 7.00

Pollutants	Stream Conc (µg/l)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	13.986	14.6	15.2	Chem Translator of 0.96 applied
Total Lead	0	0		0	67.624	66.2	90.0	Chem Translator of 0.785 applied
Total Zinc	0	0		0	121.458	124	130	Chem Translator of 0.978 applied

CFC

CCT (min): 0.002

PMF: 1

Analysis Hardness (mg/l): 104.32

Analysis pH: 7.00

Pollutants	Stream Conc (µg/l)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	

Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	9.286	9.67	10.1	Chem Translator of 0.96 applied
Total Lead	0	0		0	2.635	3.36	3.51	Chem Translator of 0.785 applied
Total Zinc	0	0		0	122.452	124	130	Chem Translator of 0.986 applied

THH CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	500,000	500,000	N/A	
Chloride (PWS)	0	0		0	250,000	250,000	N/A	
Sulfate (PWS)	0	0		0	250,000	250,000	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQ Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0		0	N/A	N/A	N/A	
Chloride (PWS)	0	0		0	N/A	N/A	N/A	
Sulfate (PWS)	0	0		0	N/A	N/A	N/A	
Total Copper	0	0		0	N/A	N/A	N/A	
Total Lead	0	0		0	N/A	N/A	N/A	
Total Zinc	0	0		0	N/A	N/A	N/A	

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

Pollutants	Mass Limits		Concentration Limits				Governing WQBEL	WQBEL Basis	Comments
	AML (lbs/day)	MDL (lbs/day)	AML	MDL	IMAX	Units			
Total Copper	0.008	0.014	10.1	17.0	25.3	µg/L	10.1	CFC	Discharge Conc ≥ 50% WQBEL (RP)
Total Zinc	Report	Report	Report	Report	Report	µg/L	124	AFC	Discharge Conc > 10% WQBEL (no RP)

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS Not Applicable

Chloride (PWS)	N/A	N/A	PWS Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS Not Applicable
Total Lead	N/A	N/A	Discharge Conc < TQL