

Application Type Renewal
 Facility Type Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0028720
 APS ID 326511
 Authorization ID 999541

Applicant and Facility Information

| | | | |
|---------------------------|-------------------------------------------------------------|------------------|--------------------------------------------------------|
| Applicant Name | <u>Berks County Region Airport Authority</u> | Facility Name | <u>Reading Region Airport</u> |
| Applicant Address | <u>2385 Bernville Road</u> <u>Reading, PA 19605-9400</u> | Facility Address | <u>2501 Bernville Road</u> <u>Reading, PA 19605</u> |
| Applicant Contact | <u>Terry Sroka</u> | Facility Contact | <u>Terry Sroka</u> |
| Applicant Phone | <u>(610) 372-4666</u> | Facility Phone | <u>(610) 372-4666</u> |
| Client ID | <u>87485</u> | Site ID | <u>253636</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Bern Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Berks</u> |
| Date Application Received | <u>October 23, 2013</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>October 31, 2013</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>This is an application for NPDES renewal.</u> | | |

| Approve | Deny | Signatures | Date |
|---------|------|--------------------------------------------------------------------------------------------------|-------------------|
| X | | Nicholas Hong, P.E. / Environmental Engineer Nick Hong (via electronic signature) | December 9, 2021 |
| x | | Daniel W. Martin, P.E. / Environmental Engineer Manager Maria D. Bebenek for Daniel W. Martin | December 15, 2021 |
| x | | Maria D. Bebenek, P.E. / Environmental Program Manager Maria D. Bebenek | December 15, 2021 |

Summary of Review

The application submitted by the applicant requests a NPDES renewal permit for the Reading Regional Airport Authority located at 2501 Bernville Road, Reading, PA 19605 in Berks County, municipality of Bern Township. The existing permit became effective on June 1, 2009 and expired on May 31, 2014. The application for renewal was received by DEP Southcentral Regional Office (SCRO) on October 31, 2013. A revised application was received on May 24, 2018.

The purpose of this Fact Sheet is to present the basis of information used for establishing the proposed NPDES permit effluent limitations. The Fact Sheet includes a description of the facility, a description of the facility's receiving waters, a description of the facility's receiving waters attainment/non-attainment assessment status, and a description of any changes to the proposed monitoring/sampling frequency. Section 6 provides the justification for the proposed NPDES effluent limits derived from technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), total maximum daily loading (TMDL), antidegradation, anti-backsliding, and/or whole effluent toxicity (WET). A brief summary of the outlined descriptions has been included in the Summary of Review section.

The subject facility is a 0.42 MGD annual average design flow treatment facility. As of the revised/updated application submitted in May 2018, the applicant did not anticipate any proposed upgrades to the treatment facility in the next five years. The NPDES application has been processed as a Minor Sewage Facility due to the type of sewage and the design flow rate for the facility. The applicant disclosed the Act 14 via the Act 67, 68, and 127 requirements to Berks County Planning Commission and Bern Township and the notice was received by the parties on July 23, 2013. A planning approval letter was not necessary as the facility is neither new or expanding.

Utilizing the DEP's web-based Emap-PA information system, the receiving waters has been determined to be the Schuylkill River. The sequence of receiving streams that the Schuylkill River discharges into are the Delaware River which eventually drains into the Delaware Bay. The receiving water has protected water usage for warm water fishes (WWF) and migratory fishes (MF). No Class A Wild Trout fisheries are impacted by this discharge. The absence of high quality and/or exceptional value surface waters removes the need for an additional evaluation of anti-degradation requirements.

The Schuylkill River is a Category 2 and 4a stream listed in the 2020 Integrated List of All Waters (formerly 303d Listed Streams). This stream is an attaining stream that supports aquatic life, recreational uses, and potable water supply. The receiving stream is also impaired for fish consumption due to PCBs from an unknown source. The receiving waters is subject to the Schuylkill River PCB total maximum daily load (TMDL) plan to improve water quality in the subject facility's watershed.

The existing permit and proposed permit differ as follows:

- **Adjustment to permit limit for TDS due to typographical error in existing permit**
- **Due to EPA triennial, E- Coli shall be monitored**
- **Monitoring for stormwater parameters on a 2x/yr basis**

Sludge use and disposal description and location(s): Sewage Sludge/Biosolids is disposed at the Exeter Township in Berks County under DEP Permit No. PA0026972 and/or Lehigh County Authority WWTP in Lehigh County under DEP Permit No. PAS902202

The proposed permit will expire five (5) years from the effective date.

Based on the review in this report, it is recommended that the permit be drafted. DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Any additional information or public review of documents associated with the discharge or facility may be available at PA DEP Southcentral Regional Office (SCRO), 909 Elmerton Avenue, Harrisburg, PA 17110. To make an appointment for file review, contact the SCRO File Review Coordinator at 717.705.4700.

1.0 Applicant

1.1 General Information

This fact sheet summarizes PA Department of Environmental Protection’s review for the NPDES renewal for the following subject facility.

Facility Name: Reading Regional Airport Authority

NPDES Permit # PA0028720

Physical Address: 2501 Bernville Road
Reading, PA 19605

Mailing Address: 2501 Bernville Road
Reading, PA 19605

Contact: Terry Sroka
Manager
tsroka@readingairport.org

Consultant: Christina Crawford, PE/MBA
Spotts, Stevens, and McCoy
christina.crawford@ssmgroup.com

1.2 Permit History

Description of Facility

On February 10, 2017, DEP issued a letter to the facility informing that DEP no longer considers the storm sewer system within the facility’s jurisdiction to be a regulated small MS4. As a result, DEP does not expect a submittal for NOI or permit application for stormwater.

Reading Regional Airport Authority (RRAA) reportedly sold a 154-acre track of land to Berks County Industrial Development Authority (BCIDA). The parcel of land included the original stormwater outfalls 002, 003, and 004. RRAA continues to hold the parcel that includes stormwater outfalls 005, 006, 007, and 008.

In prior issued NPDES permits, the facility was categorized as Sewage- Non-public. This has been corrected to Sewage-Public. By regulatory definition, an authority is public. The facility is also considered municipal. This seems appropriate since wastewater contributions prior to around 2006 did not include St. Joseph Hospital and Bern Township.

Sources of Water

The facility receives wastewater contributions from the locations summarized in the table.

| Tributary Information | |
|-----------------------------------------|--------------------------|
| Municipalities Served | Flow Contribution |
| Airport and the Airport Industrial Park | 27% |
| Saint Joseph Medical Center | 47% |
| Bern Township | 26% |
| Total | 100% |

DRBC Docket

On June 12, 2019, the Delaware River Basin Commission, issued Docket No D-1986-038 CP-4 for the Reading Regional Airport Authority. The docket was issued for the renewal of the existing WWTP and its discharge in conjunction with the PA DEP NPDES permit.

Section 3.10.4D.2. of the Commission's *Water Quality Regulations (WQR)* establishes the basin-wide total dissolved solids (TDS) effluent standard as 1,000 mg/l. A variance to the Commission's TDS effluent limit was approved on an average monthly and instantaneous maximum basis of 2,605 mg/l and 5,210 mg/l, respectively.

The docket expires on June 30, 2025.

Permit submittal included the following information.

- NPDES Application
- Flow Diagrams
- Influent Sample Data
- Effluent Sample Data

2.0 Treatment Facility Summary

2.1.1 Site location

The physical address for the facility is 2501 Bernville Road, Reading, PA 19605. A topographical and an aerial photograph of the facility are depicted as Figure 1 and Figure 2.

Figure 1: Topographical map of the subject facility





Figure 2: Aerial Photograph of the subject facility



2.1.2 Sources of Wastewater/Stormwater

The NPDES application notes that there is one industrial user. Industrial Metal Plating discharges approximately 0.0204 MGD. The facility uses a pretreatment system that processes wastewater from their metal finishing process. The facility is not a significant industrial user.

The table summarizes the facility's industrial/commercial users.

RRAA SEWER TENANTS - AVERAGE DAILY USAGE

| RRAA SEWER TENANTS | | | | | | | | |
|--------------------|------------------------------------------|------------------------|------------------|------------------|------------------|------------------|--------------|------------------------------|
| Meter Location | Company | Business Type | 2017 Qtr 1 Usage | 2017 Qtr 2 Usage | 2017 Qtr 3 Usage | 2017 Qtr 4 Usage | ANNUAL TOTAL | AVERAGE GALLONS USED PER DAY |
| TERM | READING AIRPORT | AVIATION | 5,000 | 3,000 | 7,000 | 4,000 | 19,000 | 52.05 |
| ARFF | READING AIRPORT | EMERGENCY SERVICES | 7,170 | 12,650 | 900 | 7,000 | 27,720 | 75.95 |
| SHOP | READING AIRPORT | MAINTENANCE | 8,650 | 23,910 | 18,010 | 13,440 | 64,010 | 175.37 |
| STP | READING AIRPORT | SEWAGE TREATMENT | 196,300 | 251,500 | 303,000 | 186,100 | 936,900 | 2,566.85 |
| Hgr 406 | GALYANO ASSOC | OFFICE | 4,780 | 4,630 | 3,920 | 2,970 | 16,300 | 44.66 |
| Hgr 515 | ATLANTIC COAST AIRCRAFT SVC | AVIATION | 15,600 | 17,400 | 12,200 | 15,500 | 60,700 | 166.30 |
| | BARCO INC | MANUFACTURING | 15,000 | 13,300 | 10,900 | 18,500 | 57,700 | 158.08 |
| | BURGOE REALTY | WAREHOUSING | 14,100 | 12,500 | 10,500 | 10,300 | 47,400 | 129.86 |
| | BURGOE REALTY | WAREHOUSING | 39,100 | 24,900 | 24,300 | 21,200 | 109,500 | 300.00 |
| | BURGOE REALTY | WAREHOUSING | 266,300 | 240,000 | 382,700 | 369,500 | 1,280,500 | 3,508.22 |
| Bldg 207 | CIVIL AIR PATROL | OFFICE | 710 | 2,920 | 810 | 810 | 5,250 | 14.38 |
| Tower | FAA AIRWAYS FACILITIES | AVIATION | 21,016 | 28,144 | 16,767 | 22,683 | 88,610 | 242.77 |
| G&T | G & T INDUSTRIES | WAREHOUSING | 71,760 | 63,600 | 66,330 | 65,260 | 266,950 | 731.37 |
| | KLINGER'S AT THE AIRPORT | RESTAURANT | 84,000 | 59,100 | 63,700 | 59,800 | 266,600 | 730.41 |
| | HOLIDAY INN EXPRESS | HOTEL | 705,500 | 700,700 | 804,400 | 629,300 | 2,839,900 | 7,780.55 |
| Landis | INDCOR PROPERTIES INC. | OFFICE | 5,100 | 13,600 | 25,000 | 15,300 | 59,000 | 161.64 |
| | INDUSTRIAL METAL PLATING | MANUFACTURING | 2,159,500 | 1,698,600 | 1,856,300 | 1,729,500 | 7,445,900 | 20,399.73 |
| Bldg 206 | MID ATLANTIC AIR MUSEUM | AVIATION | 2,710 | 11,760 | 26,840 | 2,170 | 43,480 | 119.12 |
| Bldg 205 | MID ATLANTIC AIR MUSEUM | AVIATION | 5,180 | 6,720 | 5,130 | 5,200 | 22,230 | 60.90 |
| Hgr 514 | PENN NATNL GAMING (RDG NORTHERN) | AVIATION | 1,600 | 1,500 | 1,800 | 35,200 | 40,100 | 109.86 |
| meter 2 | PHILLIPS VAN HEUSEN | MANUFACTURING | 27,000 | 27,000 | 26,000 | 30,000 | 110,000 | 301.37 |
| meter 1 | PHILLIPS VAN HEUSEN | MANUFACTURING | 123,620 | 77,810 | 85,090 | 93,790 | 380,310 | 1,041.95 |
| Bldg 404 | READING AERO CLUB | AVIATION | 870 | 1,410 | 1,120 | 1,190 | 4,590 | 12.58 |
| Hgr 401 | READING JET CENTER | AVIATION | 30 | 10 | - | - | 40 | 0.11 |
| Hgr 402 | READING JET CENTER | AVIATION | 2,660 | 2,190 | 2,330 | 1,650 | 8,830 | 24.19 |
| Hgr 407 | READING JET CENTER | AVIATION | 9,040 | 9,100 | 11,330 | 9,990 | 39,460 | 108.11 |
| Bldg 203-A | READING JET CTR (AFS OR R.A.C.) | AVIATION | 1,350 | 1,880 | 2,205 | 1,687 | 7,122 | 19.51 |
| Hgr 3 | READING JET CTR (AFS OR R.A.C.) | AVIATION | 2,720 | 2,940 | 1,030 | 1,150 | 7,840 | 21.48 |
| Bldg 203 | READING JET CTR (AFS OR R.A.C.) | AVIATION | 5,210 | 8,870 | 15,530 | 8,500 | 38,110 | 104.41 |
| Bldg 233 | READING POLICE DEPARTMENT | POLICE | 1,370 | 1,940 | 2,130 | 1,900 | 7,340 | 20.11 |
| Bldg 238 | READING POLICE DEPARTMENT | POLICE | 390 | 730 | 1,030 | 620 | 2,770 | 7.59 |
| Bldg 130 | RON MACHINE | MANUFACTURING | 1,740 | 1,340 | 1,110 | 1,000 | 5,190 | 14.22 |
| Prologis | SUPPLY ONE PLASTICS | MANUFACTURING | 5,605 | 6,315 | 5,060 | 7,390 | 24,370 | 66.77 |
| Prologis | SUPPLY ONE PLASTICS | MANUFACTURING | 21,680 | 23,410 | 20,460 | 17,840 | 83,390 | 228.47 |
| XO Comm | INDCOR PROPS/FORMERLY X O COMMUNICATIONS | COMMUNICATIONS | 13,200 | 10,200 | 11,300 | 14,300 | 49,000 | 134.25 |
| | DIRECT LINK | OFFICE | 2,133,800 | 2,381,900 | 2,836,400 | 2,259,000 | 9,613,100 | 26,337.26 |
| | ST. JOSEPH'S MEDICAL CENTER | HOSPITAL | 3,354,380 | 3,658,180 | 3,877,210 | 4,142,140 | 15,031,910 | 41,183.32 |
| | BTMA (METER 1) | COMMERCIAL/RESIDENTIAL | 1,400,400 | 1,002,000 | 948,200 | 743,900 | 4,094,500 | 11,217.61 |
| | BTMA (METER 2) | COMMERCIAL/RESIDENTIAL | 1,526,900 | 1,146,500 | 1,052,900 | 1,321,400 | 5,047,700 | 13,829.32 |
| | RRAA (STP) | AVIATION | 2,670,420 | 4,616,020 | 5,644,190 | 4,829,260 | 17,759,890 | 48,657.23 |

| | | | | | |
|--------------------|-----------|------------|------------|------------|------------|
| RRAA TENANTS | 6,001,361 | 5,747,479 | 6,666,632 | 5,663,740 | 24,079,212 |
| ST JOE'S/BTMA/RRAA | 8,952,100 | 10,422,700 | 11,522,500 | 11,036,700 | 41,934,000 |

The facility has the following outfall information for stormwater.

| | | | |
|---------------------------------------------------------------------|----------------|--------------------------|-----------------|
| Outfall No. | 002 | Design Flow (MGD) | 0 |
| Latitude | 40° 22' 32.09" | Longitude | -75° 57' 21.91" |
| Wastewater Description: Stormwater; Some deicing activities. | | | |

| | | | |
|------------------------------------------------------------------------------------------------------|----------------|--------------------------|-----------------|
| Outfall No. | 003 | Design Flow (MGD) | 0 |
| Latitude | 40° 22' 47.77" | Longitude | -75° 57' 36.04" |
| Wastewater Description: Stormwater; Runways and taxiways, turf, etc. Some deicing activities. | | | |

| | | | |
|------------------------------------------------------------------------------------------------------|----------------|--------------------------|-----------------|
| Outfall No. | 004 | Design Flow (MGD) | 0 |
| Latitude | 40° 22' 59.61" | Longitude | -75° 57' 34.97" |
| Wastewater Description: Stormwater; Runways and taxiways, turf, etc. Some deicing activities. | | | |

| | | | |
|--------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------|-----------------|
| Outfall No. | 005 | Design Flow (MGD) | 0 |
| Latitude | 40° 23' 8.85" | Longitude | -75° 57' 58.68" |
| Wastewater Description: | Stormwater; The drainage area is approximately 343.84 acres. The stormwater originates from runways and taxiways, light manufacturing, auto parking lot, aircraft hanger, aircraft parking apron, aboveground fuel storage tanks, wooded area, and turf. Some deicing activities. | | |

| | | | |
|--------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------|-----------------|
| Outfall No. | 006 | Design Flow (MGD) | 0 |
| Latitude | 40° 22' 33.16" | Longitude | -75° 58' 32.84" |
| Wastewater Description: | Stormwater; The drainage area is approximately 102.46 acres. The stormwater originates from runways and taxiways, office building, auto parking lot, light manufacturing, warehousing, truck parking lot, and turf. | | |

| | | | |
|--------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------|-----------------|
| Outfall No. | 007 | Design Flow (MGD) | 0 |
| Latitude | 40° 22' 31.34" | Longitude | -75° 58' 26.53" |
| Wastewater Description: | Stormwater; The drainage area is approximately 93.35 acres. The stormwater originates from aircraft hanger, warehousing, truck parking lot, auto parking lot, and turf. Some deicing activities. | | |

| | | | |
|--------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------|-----------------|
| Outfall No. | 008 | Design Flow (MGD) | 0 |
| Latitude | 40° 22' 15.73" | Longitude | -75° 57' 24.17" |
| Wastewater Description: | Stormwater; The drainage area is approximately 21.15 acres. The stormwater originates from airport maintenance garage, runway and taxiway, auto parking lot, and turf. | | |

| | | | |
|---------------------------------------------------------------------|----------------|--------------------------|----------------|
| Outfall No. | 009 | Design Flow (MGD) | 0 |
| Latitude | 40° 22' 25.17" | Longitude | -75° 58' 9.70" |
| Wastewater Description: Stormwater; Some deicing activities. | | | |


The locations of the stormwater outfalls are depicted in the map.

The red outline encircles the Reading Regional Airport Authority property. The yellow outline encircles the BCIDA property.

Outfall 002 is just outside the airport parcel and will receive little contribution from BCIDA stormwater. The facility will seek permission from BCIDA to continue sampling at this outfall.

Outfalls 003 and 004 were relocated to move the outfalls upstream from the BCIDA property as much as possible to avoid drainage from the BCIDA site. Due to the sale of the property to BCIDA, the facility will no longer have access to the stormwater outfalls.

Outfall 009 is a new outfall.




2.2 Description of Wastewater Treatment Process

The subject facility is a 0.42 MGD design flow facility. The subject facility treats wastewater using a sequencing batch reactor(s) (SBR) and a chlorine contact tank prior to discharge through the outfall. The facility is being evaluated for flow, pH, dissolved oxygen, TRC, TSS, CBOD, oil and grease, ammonia-nitrogen, TDS, PCBs, and fecal coliform. The existing permits limits for the facility is summarized in Section 2.4.

The treatment process is summarized in the table.

| Treatment Facility Summary | | | | |
|------------------------------------------------------------|-----------------------------------|--------------------------|------------------------------|-------------------------------|
| Treatment Facility Name: Reading Region Airport STP | | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Secondary | Sequencing Batch Reactor | Chlorine With Dechlorination | 0.42 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.504 | 1043 | Not Overloaded | Aerobic Digestion | Combination of methods |

A process flow diagram for the facility is depicted.



2.3 Facility Outfall Information

The facility has the following outfall information for wastewater.

| | | | |
|--------------------------------|------------------------|--------------------------|------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>.42</u> |
| Latitude | <u>40° 22' 58.15"</u> | Longitude | <u>-75° 57' 11.29"</u> |
| Wastewater Description: | <u>Sewage Effluent</u> | | |

2.3.1 Operational Considerations- Chemical Additives

Chemical additives are chemical products introduced into a waste stream that is used for cleaning, disinfecting, or maintenance and which may be detected in effluent discharged to waters of the Commonwealth. Chemicals excluded are those used for neutralization of waste streams, the production of goods, and treatment of wastewater.

The subject facility utilizes the following chemicals as part of their treatment process.

- Chlorine for chlorination
- Sulfur dioxide for dichlorination

2.4 Existing NPDES Permits Limits

The existing NPDES permit limits are summarized in the table.

Permit No. PA 0028720

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. For Outfall 001, Latitude 40°22'56", Longitude 75°57'10", River Mile Index 80.3, Stream Code 00833, Discharging to Schuylkill River

which receives wastewater from the wastewater treatment plant.

1. The permittee is authorized to discharge during the period from June 1, 2009 through May 31, 2014.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements, Footnotes, and Supplemental Information).

| Discharge Parameter | Effluent Limitations | | | | | | | Monitoring Requirements | |
|----------------------------------------------------|-------------------------------------|------------------|-----------------------|-----------------|----------------|---------------|-----------------------|----------------------------------------------|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | | Minimum ⁽³⁾ Measurement Frequency | Required Sample Type |
| | Monthly Average | Weekly Average | Minimum | Monthly Average | Weekly Average | Maximum Daily | Instantaneous Maximum | | |
| Flow (mgd) | Report | Report Daily Max | XXX | XXX | XXX | XXX | XXX | Continuous | Measured |
| Influent (BOD ₅ and TSS) ⁽⁴⁾ | Report | Report Daily Max | XXX | Report | XXX | XXX | XXX | 2/Month | 24-hr comp |
| pH (S.U.) | XXX | XXX | 6.0 | XXX | XXX | XXX | 9.0 | 1/Day | Grab |
| Dissolved Oxygen | XXX | XXX | 5.0 | XXX | XXX | XXX | XXX | 1/Day | Grab |
| Total Residual Chlorine | XXX | XXX | XXX | 0.5 | XXX | XXX | 1.60 | 1/Day | Grab |
| Total Suspended Solids | 105 | 157 | XXX | 30 | 45 | XXX | 60 | 1/Week | 24-hr comp |
| CBOD ₅ | 87 | 140 | XXX | 25 | 40 | XXX | 50 | 1/Week | 24-hr comp |
| Oil and Grease | 52 | XXX | XXX | 15 | XXX | XXX | 30 | 1/Week | 24-hr comp |
| NH ₃ -N | 70 | XXX | XXX | 20 | XXX | XXX | 40 | 1/Week | 24-hr comp |
| Total Dissolved Solids | XXX | XXX | XXX | 2,625 | XXX | 5,210 | 5,210 | 1/Week | 24-hr comp |
| Total PCBs ⁽⁵⁾ | XXX | XXX | XXX | Report | XXX | XXX | XXX | 2/Year | 24-hr comp |
| Fecal Coliform ⁽⁶⁾ (5/1 to 9/30) | XXX | XXX | XXX | 200 | XXX | XXX | XXX | 1/Week | Grab |
| Fecal Coliform ^{(6),(7)} (10/1 to 4/30) | XXX | XXX | XXX | 2,000 | XXX | XXX | XXX | 1/Week | Grab |

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

- ° at discharge from facility.

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING, AND REPORTING REQUIREMENTS

B. Monitoring Requirements for Stormwater Outfalls 002, 003, 004, 005, 006, 007, and 008.⁽⁷⁾

| Parameter | MONITORING REQUIREMENTS | |
|------------------------|-------------------------|-------------------|
| | Grab Sample (mg/l) | Monitor Frequency |
| CBOD ₅ | Monitor & Report | 1/year |
| Chemical Oxygen Demand | Monitor & Report | 1/year |
| Total Suspended Solids | Monitor & Report | 1/year |
| Total Potassium | Monitor & Report | 1/year |
| Diethylene Glycol | Monitor & Report | 1/year |
| Propylene Glycol | Monitor & Report | 1/year |
| Ethylene Glycol | Monitor & Report | 1/year |
| pH (S.U.) | Monitor & Report | 1/year |
| Oil and Grease | Monitor & Report | 1/year |
| Total Iron | Monitor & Report | 1/year |

3.0 Facility NPDES Compliance History

3.1 Summary of Inspections

A summary of the most recent inspections during the existing permit review cycle is as follows.

The DEP inspector noted the following during the inspection.

07/06/2016:

- The raw influent was tinted orange/red. The facility suspects the industrial metal plating may be responsible for the dye in the influent. Metal sampling was conducted around June 27, 2016.
- A charcoal and sand mixture were observed in the influent channel. The facility noticed the grit beginning on June 7 over the course of about a week. The grit resembles a media used in the industrial metal plating pretreatment process.

04/11/2017:

- The inspection was precipitated by an incident. Approximately 3,000 gallons was overflow due to a PLC failure. Lime was applied to the ground in the area of overflow.

07/02/2018:

- The following repairs/replacements were made since the last inspection: Effluent sampler, utility water pump rebuilt, gasket gate valves repaired, influent screen had new brushes and wear plates, blower #3 rebuilt, PLC power supply fixed.
- The SCADA system was adjusted so it would not register a storm event when entering in fill decant mode.
- The industrial metal plating pretreatment was upgraded.
- The pump station is maintained by Bern Township.
- The flow to the treatment plant from Bern township is monitored along Leisczs Bridge Road.

3.2 Summary of DMR Data

A review of approximately 1-year of DMR data shows that the monthly average flow data for the facility below the design capacity of the treatment system. The maximum average flow data for the DMR reviewed was 0.185 MGD in March 2021. The hydraulic design capacity of the treatment system is 0.504 MGD.

The off-site laboratory used for the analysis of the parameters were QCL, QC Laboratories located at 1205 Industrial Blvd, PO Box 514 Southampton, PA 18966 and Atlantic Coast Laboratories located at 630 Churchmans Road, Newark, DE 19702.

DMR Data for Outfall 001 (from October 1, 2020 to September 30, 2021)

| Parameter | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 |
|-------------------------------------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.157 | 0.098 | 0.090 | 0.085 | 0.065 | 0.107 | 0.185 | 0.093 | 0.079 | 0.182 | 0.113 | 0.117 |
| Flow (MGD) Daily Maximum | 0.303 | 0.160 | 0.126 | 0.131 | 0.134 | 0.213 | 0.269 | 0.219 | 0.105 | 1.337 | 0.340 | 0.171 |
| pH (S.U.) Minimum | 6.0 | 7.1 | 7.2 | 7.1 | 6.7 | 7.0 | 7.0 | 6.9 | 6.7 | 6.2 | 6.9 | 7.0 |
| pH (S.U.) Instantaneous Maximum | 7.4 | 7.8 | 7.6 | 7.6 | 7.8 | 7.6 | 7.6 | 7.6 | 7.9 | 7.6 | 7.6 | 7.8 |
| DO (mg/L) Minimum | 5.4 | 5.2 | 5.7 | 5.9 | 6.8 | 7.1 | 7.8 | 8.3 | 7.0 | 6.1 | 7.2 | 7.1 |
| TRC (mg/L) Minimum | 0.01 | 0.01 | 0.01 | < 0.1 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 | 0.01 |
| TRC (mg/L) Average Monthly | 0.1 | 0.1 | 0.03 | 0.1 | 0.1 | 0.1 | 0.1 | 0.2 | 0.1 | 0.2 | 0.1 | 0.1 |
| TRC (mg/L) Instantaneous Maximum | 0.4 | 0.3 | 0.1 | 0.7 | 1.0 | 0.8 | 0.4 | 1.4 | 0.6 | 1.0 | 0.4 | 0.1 |
| CBOD5 (lbs/day) Average Monthly | 4 | < 2 | < 2 | < 2 | < 1 | 2 | < 6 | 3 | < 2 | 6 | < 2 | < 2 |
| CBOD5 (lbs/day) Weekly Average | 5 | < 3 | 2 | < 2 | < 1 | 3 | 13 | 5 | 3 | 17 | < 2 | < 2 |
| CBOD5 (mg/L) Average Monthly | 3 | < 2 | < 2 | < 2 | < 2 | 2 | < 4 | 5 | < 3 | 4 | < 2 | < 2 |
| CBOD5 (mg/L) Weekly Average | 5 | < 2 | 2 | < 2 | 2 | 3 | 10 | 6 | 3 | 9 | < 2 | < 2 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 94 | 118 | 194 | 204 | 221 | 83 | 136 | 202 | 139 | 162 | 108 | 137 |
| BOD5 (lbs/day) Raw Sewage Influent Daily Maximum | 134 | 136 | 232 | 269 | 301 | 84 | 156 | 227 | 178 | 190 | 116 | 157 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 60 | 131 | 221 | 214 | 260 | 77 | 80 | 198 | 181 | 220 | 104 | 133 |
| TSS (lbs/day) Average Monthly | 29 | < 5 | < 4 | < 3 | < 2 | < 4 | < 14 | 9 | < 6 | < 8 | 7 | 5 |

NPDES Permit Fact Sheet
Reading Region Airport

NPDES Permit No. PA0028720

| | | | | | | | | | | | | |
|------------------------------------------------------------------|--------|--------|--------|--------|--------|--------|-------|--------|--------|--------|--------|--------|
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 77 | 111 | 198 | 220 | 140 | 73 | 139 | 187 | 99 | 85 | 108 | 121 |
| TSS (lbs/day) Raw Sewage Influent Daily Maximum | 103 | 156 | 218 | 226 | 162 | 74 | 167 | 234 | 108 | 93 | 161 | 161 |
| TSS (lbs/day) Weekly Average | 38 | < 5 | 4 | < 3 | < 3 | 6 | 30 | 11 | 12 | < 15 | 9 | 7 |
| TSS (mg/L) Average Monthly | 23 | < 5 | < 4 | < 4 | < 4 | < 4 | < 10 | 16 | < 8 | < 7 | 8 | 5 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 50 | 124 | 223 | 232 | 165 | 68 | 82 | 182 | 132 | 116 | 108 | 115 |
| TSS (mg/L) Weekly Average | 51 | < 4 | 5 | 4 | < 4 | 5 | 22 | 20 | 15 | 11 | 10 | 6 |
| Total Dissolved Solids (mg/L) Average Monthly | 816.3 | 1544.0 | 1527.5 | 1364.0 | 1190.0 | 894.0 | 716.4 | 1053.5 | 1016.5 | 1121.2 | 1155.0 | 1137.5 |
| Total Dissolved Solids (mg/L) Daily Maximum | 992.0 | 1620.0 | 1610.0 | 1450.0 | 1220.0 | 1070.0 | 874.0 | 1220.0 | 1090.0 | 1300.0 | 1200.0 | 1180.0 |
| Oil and Grease (lbs/day) Average Monthly | < 9 | < 5 | < 6 | < 4 | < 3 | < 5 | < 9 | < 4 | < 4 | < 8 | < 5 | < 6 |
| Oil and Grease (mg/L) Average Monthly | < 6 | < 5 | < 7 | < 5 | < 6 | < 5 | < 6 | < 5 | < 6 | < 5 | < 5 | < 5 |
| Fecal Coliform (CFU/100 ml) Geometric Mean | > 4573 | < 14 | 2 | 11 | < 4 | 36 | 8 | < 2 | 5 | < 48 | 553 | 51 |
| Ammonia (lbs/day) Average Monthly | < 0.2 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | 1 | 3 | < 2 | < 0.1 | < 9 | < 0.1 | < 0.1 |
| Ammonia (mg/L) Average Monthly | < 0.2 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | 1 | 2 | < 2.4 | < 0.1 | < 3 | < 0.1 | < 0.1 |
| PCBs (Dry Weather) (ng/L) Average Monthly | | | | | | | | | | 0.641 | | |
| PCBs (Wet Weather) (ng/L) Average Monthly | | | | | | | | | | 0.703 | | |

DMR Data for Outfall 005 (from October 1, 2020 to September 30, 2021)

| Parameter | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 |
|------------------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| pH (S.U.) Average Monthly | | | | | | | | | | 6.74 | | |
| CBOD5 (mg/L) Average Monthly | | | | | | | | | | < 2.0 | | |
| COD (mg/L) Average Monthly | | | | | | | | | | E | | |
| TSS (mg/L) Average Monthly | | | | | | | | | | 4.8 | | |
| Oil and Grease (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |
| Total Iron (mg/L) Average Monthly | | | | | | | | | | 0.15 | | |
| Total Potassium (mg/L) Average Monthly | | | | | | | | | | 0.983 | | |
| Ethylene Glycol (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |
| Propylene Glycol (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |
| Diethylene Glycol (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |

DMR Data for Outfall 006 (from October 1, 2020 to September 30, 2021)

| Parameter | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 |
|------------------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| pH (S.U.) Average Monthly | | | | | | | | | | 7.13 | | |
| CBOD5 (mg/L) Average Monthly | | | | | | | | | | < 2.0 | | |
| COD (mg/L) Average Monthly | | | | | | | | | | E | | |
| TSS (mg/L) Average Monthly | | | | | | | | | | 7.2 | | |
| Oil and Grease (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |
| Total Iron (mg/L) Average Monthly | | | | | | | | | | 0.106 | | |
| Total Potassium (mg/L) Average Monthly | | | | | | | | | | 0.853 | | |
| Ethylene Glycol (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |
| Propylene Glycol (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |
| Diethylene Glycol (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |

DMR Data for Outfall 007 (from October 1, 2020 to September 30, 2021)

| Parameter | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 |
|------------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| pH (S.U.) Average Monthly | | | | | | | | | | 7.20 | | |
| CBOD5 (mg/L) Average Monthly | | | | | | | | | | < 2.0 | | |
| COD (mg/L) Average Monthly | | | | | | | | | | E | | |
| TSS (mg/L) Average Monthly | | | | | | | | | | 7.6 | | |
| Oil and Grease (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |

**NPDES Permit Fact Sheet
Reading Region Airport**

NPDES Permit No. PA0028720

| | | | | | | | | | | | | | |
|---------------------------------------------|--|--|--|--|--|--|--|--|--|--|--------|--|--|
| Total Iron (mg/L) Average Monthly | | | | | | | | | | | < 0.05 | | |
| Total Potassium (mg/L) Average Monthly | | | | | | | | | | | < 0.5 | | |
| Ethylene Glycol (mg/L) Average Monthly | | | | | | | | | | | < 5.0 | | |
| Propylene Glycol (mg/L) Average Monthly | | | | | | | | | | | < 5.0 | | |
| Diethylene Glycol (mg/L) Average Monthly | | | | | | | | | | | < 5.0 | | |

DMR Data for Outfall 008 (from October 1, 2020 to September 30, 2021)

| Parameter | SEP-21 | AUG-21 | JUL-21 | JUN-21 | MAY-21 | APR-21 | MAR-21 | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 |
|---------------------------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| pH (S.U.) Average Monthly | | | | | | | | | | 6.80 | | |
| CBOD5 (mg/L) Average Monthly | | | | | | | | | | 2.3 | | |
| COD (mg/L) Average Monthly | | | | | | | | | | E | | |
| TSS (mg/L) Average Monthly | | | | | | | | | | 4.5 | | |
| Oil and Grease (mg/L) Average Monthly | | | | | | | | | | < 5.3 | | |
| Total Iron (mg/L) Average Monthly | | | | | | | | | | 0.107 | | |
| Total Potassium (mg/L) Average Monthly | | | | | | | | | | 3.14 | | |
| Ethylene Glycol (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |
| Propylene Glycol (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |
| Diethylene Glycol (mg/L) Average Monthly | | | | | | | | | | < 5.0 | | |

3.3 Non-Compliance

3.3.1 Non-Compliance- NPDES Effluent

A summary of the non-compliance to the permit limits for the existing permit cycle is as follows.

From the DMR data beginning in June 1, 2009 and ending November 20, 2021, the following were the observed effluent non-compliances.

**Summary of Non-Compliance with NPDES Permit Limits
Beginning June 1, 2009 and Ending November 20, 2021**

| NON COMPLIANCE DATE | PARAMETER | SAMPLE VALUE | VIOLATION CONDITION | PERMIT VALUE | UNIT OF MEASURE | STATISTICAL BASE CODE |
|---------------------|-------------------------------|--------------|---------------------|--------------|-----------------|-----------------------|
| 06/07/2017 | Total Suspended Solids | 54 | > | 45 | mg/L | Weekly Average |
| 02/15/2018 | Total Suspended Solids | 47 | > | 45 | mg/L | Weekly Average |
| 03/15/2018 | Total Suspended Solids | 84 | > | 45 | mg/L | Weekly Average |
| 05/20/2018 | Total Suspended Solids | 53 | > | 45 | mg/L | Weekly Average |
| 09/27/2019 | Fecal Coliform | 230 | > | 200 | CFU/100 ml | Geometric Mean |
| 01/21/2020 | Total Residual Chlorine (TRC) | 2.0 | > | 1.6 | mg/L | Instantaneous |
| 04/27/2020 | Total Suspended Solids | 51 | > | 45 | mg/L | Weekly Average |
| 10/27/2021 | Fecal Coliform | > 4573 | > | 200 | CFU/100 ml | Geometric Mean |
| 10/27/2021 | Total Suspended Solids | 51 | > | 45 | mg/L | Weekly Average |

3.3.2 Non-Compliance- Enforcement Actions

A summary of the non-compliance enforcement actions for the current permit cycle is as follows:

Beginning in June 1, 2009 to December 7, 2021, there were no observed enforcement actions.

3.4 Summary of Biosolids Disposal

A summary of the biosolids disposed of from the facility is as follows.

| 2021 | | | |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------|----------|----------|
| Sewage Sludge / Biosolids Production Information | | | |
| Hauled Off-Site | | | |
| Date (YEAR) | Gallons | % Solids | Dry Tons |
| January | | | 0 |
| February | | | 0 |
| March | | | 0 |
| April | | | 0 |
| May | | | 0 |
| June | | | 0 |
| July | 34,600 | 2.8 | 4.041 |
| August | | | 0 |
| September | | | 0 |
| Notes: | | | |
| Sewage Sludge/Biosolids disposed at Exeter Township in Berks County under DEP Permit No. PA0026972 and Lehigh County Authority WWTP in Lehigh County under DEP Permit No. PAS902202 | | | |

3.5 Open Violations

No open violations existed as of December 2021.

4.0 Receiving Waters and Water Supply Information Detail Summary

4.1 Receiving Waters

The receiving waters has been determined to be the Schuylkill River. The sequence of receiving streams that the Schuylkill River discharges into are the Delaware River which eventually drains into the Delaware Bay.

4.2 Public Water Supply (PWS) Intake

The closest PWS to the subject facility is the Pottstown Borough Water Authority (PWS ID #1460037) located approximately 23 miles downstream of the subject facility on the Schuylkill River. Based upon the distance and the flow rate of the facility, the PWS should not be impacted.

4.3 Class A Wild Trout Streams

Class A Wild Trout Streams are waters that support a population of naturally produced trout of sufficient size and abundance to support long-term and rewarding sport fishery. DEP classifies these waters as high-quality coldwater fisheries.

The information obtained from EMAP suggests that no Class A Wild Trout Fishery will be impacted by this discharge.

4.4 2020 Integrated List of All Waters (303d Listed Streams):

Section 303(d) of the Clean Water Act requires States to list all impaired surface waters not supporting uses even after appropriate and required water pollution control technologies have been applied. The 303(d) list includes the reason for impairment which may be one or more point sources (i.e. industrial or sewage discharges) or non-point sources (i.e. abandoned mine lands or agricultural runoff and the pollutant causing the impairment such as metals, pH, mercury or siltation).

States or the U.S. Environmental Protection Agency (EPA) must determine the conditions that would return the water to a condition that meets water quality standards. As a follow-up to listing, the state or EPA must develop a Total Maximum Daily Load (TMDL) for each waterbody on the list. A TMDL identifies allowable pollutant loads to a waterbody from both point and non-point sources that will prevent a violation of water quality standards. A TMDL also includes a margin of safety to ensure protection of the water.

The water quality status of Pennsylvania's waters uses a five-part categorization (lists) of waters per their attainment use status. The categories represent varying levels of attainment, ranging from Category 1, where all designated water uses are met to Category 5 where impairment by pollutants requires a TMDL for water quality protection.

The receiving waters is listed in the 2020 Pennsylvania Integrated Water Quality Monitoring and Assessment Report as a Category 2 and 4a waterbody. The surface waters is an attaining stream that supports aquatic life, recreational uses, and a potable water supply. The receiving waters is impaired for fish consumption due to PCBs from an unknown source. The designated use has been classified as protected waters for warm water fishes (WWF) and migratory fishes (MF).

4.5 Low Flow Stream Conditions

Water quality modeling estimates are based upon conservative data inputs. The data are typically estimated using either a stream gauge or through USGS web based StreamStats program. The NPDES effluent limits are based upon the combined flows from both the stream and the facility discharge.

A conservative approach to estimate the impact of the facility discharge using values which minimize the total combined volume of the stream and the facility discharge. The volumetric flow rate for the stream is based upon the seven-day, 10-year low flow (Q710) which is the lowest estimated flow rate of the stream during a 7 consecutive day period that occurs once in 10 -year time period. The facility discharge is based upon a known design capacity of the subject facility.

The closest WQN station to the subject facility is the Schuylkill River station (WQN111). This WQN station is located approximately 26 miles downstream of the subject facility.

The closest gauge station to the subject facility is the Schuylkill River station at Reading, PA (USGS station number 1471510). This gauge station is located approximately 4 miles downstream of the subject facility.

For WQM modeling, pH and stream water temperature data from the water quality network station was used. pH was estimated to be 8.05 and the stream water temperature was estimated to be 23.3 C.

The hardness of the stream was estimated from the water quality network to be 136 mg/l CaCO₃.

The low flow yield and the Q710 for the subject facility was estimated using StreamStats.

The low flow yield is 0.24 ft³/s/mi².

The Q710 is 153 ft³/s. This Q710 estimate is consistent with the consultant's Q710 reported in the Application for the Discharge of Pollutants into Surface Waters or Groundwaters of the Delaware River Basin, Section C- Receiving Waterbody Information.

4.6.1 Summary of Discharge, Receiving Waters and Water Supply Information

| | | | |
|------------------------------------------------|-----------------------|-------------------|------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>.42</u> |
| Latitude | <u>40° 22' 59.08"</u> | Longitude | <u>-75° 57' 10.33"</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |

| | | | |
|------------------------------|-----------------------------------------|------------------------------|----------------------------------|
| Receiving Waters | <u>Schuylkill River (WWF, MF)</u> | Stream Code | <u>833</u> |
| NHD Com ID | <u>26000386</u> | RMI | <u>79.4</u> |
| Drainage Area | <u>648</u> | Yield (cfs/mi ²) | <u>0.24</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>153</u> | Q ₇₋₁₀ Basis | <u>StreamStats</u> |
| Elevation (ft) | <u>228</u> | Slope (ft/ft) | <u></u> |
| Watershed No. | <u>3-C</u> | Chapter 93 Class. | <u>WWF, MF</u> |
| Existing Use | <u>Same as Chapter 93 class.</u> | Existing Use Qualifier | <u></u> |
| Exceptions to Use | <u></u> | Exceptions to Criteria | <u></u> |
| Assessment Status | <u>Impaired</u> | | |
| Cause(s) of Impairment | <u>POLYCHLORINATED BIPHENYLS (PCBS)</u> | | |
| Source(s) of Impairment | <u>SOURCE UNKNOWN</u> | | |
| TMDL Status | <u>Final</u> | Name | <u>Schuylkill River PCB TMDL</u> |

| | | | |
|-------------------------|-------------|-----------------------------|---------|
| Background/Ambient Data | | Data Source | |
| pH (SU) | <u>8.05</u> | WQN111; Median July to Sept | <u></u> |
| Temperature (°C) | <u>23.3</u> | WQN111; Median July to Sept | <u></u> |
| Hardness (mg/L) | <u>136</u> | WQN111; Historical Median | <u></u> |
| Other: | <u></u> | | <u></u> |

| | | | |
|-----------------------------------------------|------------------------------------------|----------------------------|-----------|
| Nearest Downstream Public Water Supply Intake | <u>Pottstown Borough Water Authority</u> | | |
| PWS Waters | <u>Schuylkill River</u> | Flow at Intake (cfs) | <u></u> |
| PWS RMI | <u>56</u> | Distance from Outfall (mi) | <u>23</u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|-----------------------------------|-------------------|------------------------|
| Outfall No. | <u>002</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 22' 32.09"</u> | Longitude | <u>-75° 57' 21.91"</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Schuylkill River (WWF, MF)</u> | Stream Code | <u></u> |
| NHD Com ID | <u>26000386</u> | RMI | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|-----------------------------------|-------------------|------------------------|
| Outfall No. | <u>003</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 22' 47.77"</u> | Longitude | <u>-75° 57' 36.04"</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Schuylkill River (WWF, MF)</u> | Stream Code | <u></u> |
| NHD Com ID | <u>26000390</u> | RMI | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|-----------------------------------|-------------------|------------------------|
| Outfall No. | <u>004</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 22' 59.61"</u> | Longitude | <u>-75° 57' 34.97"</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Schuylkill River (WWF, MF)</u> | Stream Code | <u></u> |
| NHD Com ID | <u>26000386</u> | RMI | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|-----------------------------------|-------------------|------------------------|
| Outfall No. | <u>005</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 23' 8.85"</u> | Longitude | <u>-75° 57' 58.68"</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Schuylkill River (WWF, MF)</u> | Stream Code | <u></u> |
| NHD Com ID | <u>26000386</u> | RMI | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|-----------------------------------------------------|-------------------|------------------------|
| Outfall No. | <u>006</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 22' 33.16"</u> | Longitude | <u>-75° 58' 32.84"</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Unnamed Tributary of Tulpehocken Creek (WWF)</u> | Stream Code | <u></u> |
| NHD Com ID | <u>26000278</u> | RMI | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|----------------------------------------------------|-------------------|------------------------|
| Outfall No. | <u>007</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 22' 31.34"</u> | Longitude | <u>-75° 58' 26.53"</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Unnamed Tributary to Schuylkill River (WWF)</u> | Stream Code | <u></u> |
| NHD Com ID | <u>26000252</u> | RMI | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|-----------------------------------|-------------------|------------------------|
| Outfall No. | <u>008</u> | Design Flow (MGD) | <u>0</u> |
| Latitude | <u>40° 22' 15.73"</u> | Longitude | <u>-75° 57' 24.17"</u> |
| Quad Name | <u></u> | Quad Code | <u></u> |
| Wastewater Description: <u>Stormwater</u> | | | |
| Receiving Waters | <u>Schuylkill River (WWF, MF)</u> | Stream Code | <u></u> |

| Discharge, Receiving Waters and Water Supply Information | | | |
|----------------------------------------------------------|--------------------------------------------------|-------------------|---------------|
| Outfall No. | 009 | Design Flow (MGD) | 0 |
| Latitude | 40° 22' 25.17" | Longitude | -75° 58' 9.7" |
| Quad Name | | Quad Code | |
| Wastewater Description: Stormwater | | | |
| Receiving Waters | Unnamed Tributary of Tulpehocken Creek (WWF, MF) | Stream Code | |
| NHD Com ID | 25992838 | RMI | 0.3000 |

5.0: Overview of Presiding Water Quality Standards

5.1 General

There are at least six (6) different policies which determines the effluent performance limits for the NPDES permit. The policies are technology based effluent limits (TBEL), water quality based effluent limits (WQBEL), antidegradation, total maximum daily loading (TMDL), anti-backsliding, and whole effluent toxicity (WET) The effluent performance limitations enforced are the selected permit limits that is most protective to the designated use of the receiving waters. An overview of each of the policies that are applicable to the subject facility has been presented in Section 6.

5.2.1 Technology-Based Limitations

TBEL treatment requirements under section 301(b) of the Act represent the minimum level of control that must be imposed in a permit issued under section 402 of the Act (40 CFR 125.3). Available TBEL requirements for the state of Pennsylvania are itemized in PA Code 25, Chapter 92a.47.

The presiding sources for the basis for the effluent limitations are governed by either federal or state regulation. The reference sources for each of the parameters is itemized in the tables. The following technology-based limitations apply, subject to water quality analysis and best professional judgement (BPJ) where applicable:

| Parameter | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Industrial facilities are commonly restricted to effluent limitations established by federal effluent limitation guidelines (ELG). The applicable ELG for this type of industrial facility is Airport Deicing Subcategory (i.e. 40 CFR 449)

The Effluent Guidelines require existing and new primary airports with 1,000 or more annual jet departures that discharge wastewater associated with airfield pavement deicing to use non-urea-containing deicers, or alternatively, meet a numeric effluent limitation for ammonia.

New airports with 10,000 annual departures located in certain cold climate zones are required to collect 60 percent of aircraft deicing fluid after deicing. Airports that discharge the collected aircraft deicing fluid directly to waters of the U.S. must also meet numeric discharge requirements for chemical oxygen demand.

Spotts, Stevens, and McCoy, the facility's consultant, suggested that there are no discharges subject to ELG since the facility is not a primary airport. The facility has approximately 1,544 passengers boarding/yr and all the passengers are by way of chartered flights. There is minimal commercial flights. The airport does not have scheduled airline services.

5.2.2 Mass Based Limits

For publicly owned treatment works (POTW), mass loadings are calculated based upon design flow rate of the facility and the permit limit concentration. The generalized calculation for mass loadings is shown below:

$$Quantity \left(\frac{lb}{day} \right) = (MGD)(Concentration)(8.34)$$

5.3 Water Quality-Based Limitations

WQBEL are based on the need to attain or maintain the water quality criteria and to assure protection of designated and existing uses (PA Code 25, Chapter 92a.2). The subject facility that is typically enforced is the more stringent limit of either the TBEL or the WQBEL.

Determination of WQBEL is calculated by spreadsheet analysis or by a computer modeling program developed by DEP. DEP permit engineers utilize the following computing programs for WQBEL permit limitations: (1) MS Excel worksheet for Total Residual Chlorine (TRC); (2) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1.1 (WQM Model) and (3) Toxics using DEP Toxics Management Spreadsheet for Toxics pollutants.

The modeling point nodes utilized for this facility are summarized below.

| General Data 1 (Modeling Point #1) | Input Value | Units |
|-----------------------------------------------|--------------------|--------------|
| Stream Code | 833 | |
| River Mile Index | 79.4 | miles |
| Elevation | 228 | feet |
| Latitude | 40.382222 | |
| Longitude | -75.952778 | |
| Drainage Area | 648 | sq miles |
| Reach Slope | Default | ft/ft |
| Low Flow Yield | 0.24 | cfs/sq mile |
| Potable Water Supply Withdrawal | Default | mgd |
| | | |
| General Data 2 (Modeling Point #2) | Input Value | Units |
| Stream Code | 833 | |
| River Mile Index | 77.57 | miles |
| Elevation | 201 | feet |
| Latitude | 40.364273 | |
| Longitude | -75.941234 | |
| Drainage Area | 658 | sq miles |
| Reach Slope | Default | ft/ft |
| Low Flow Yield | 0.24 | cfs/sq mile |
| Potable Water Supply Withdrawal | Default | mgd |

5.3.1 Water Quality Modeling 7.0

The WQM Model is a computer model that is used to determine NPDES discharge effluent limitations for Carbonaceous BOD (CBOD5), Ammonia Nitrogen (NH3-N), and Dissolved Oxygen (DO) for single and multiple point source discharges scenarios. WQM Model is a complete-mix model which means that the discharge flow and the stream flow are assumed to instantly and completely mixed at the discharge node.

WQM recommends effluent limits for DO, CBOD5, and NH3-N in mg/l for the discharge(s) in the simulation.

Four types of limits may be recommended. The limits are

- (a) a minimum concentration for DO in the discharge as 30-day average;
- (b) a 30-day average concentration for CBOD5 in the discharge;
- (c) a 30-day average concentration for the NH3-N in the discharge;
- (d) 24-hour average concentration for NH3-N in the discharge.

The WQM Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow,

Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

The applicable WQM Effluent Limit Type are discussed in Section 6 under the corresponding parameter which is either DO, CBOD, or ammonia-nitrogen.

5.3.2 Toxics Modeling

The Toxics Management Spreadsheet model is a computer model that is used to determine effluent limitations for toxics (and other substances) for single discharge wasteload allocations. This computer model uses a mass-balance water quality analysis that includes consideration for mixing, first-order decay, and other factors used to determine recommended water quality-based effluent limits. Toxics Management Spreadsheet does not assume that all discharges completely mix with the stream. The point of compliance with water quality criteria are established using criteria compliance times (CCTs). The available CCTs are either acute fish criterion (AFC), chronic fish criterion (CFC), or human health criteria (THH & CRL).

Acute Fish Criterion (AFC) measures the criteria compliance time as either the maximum criteria compliance time (i.e. 15 minutes travel time downstream of the current discharge) or the complete mix time whichever comes first. AFC is evaluated at Q710 conditions.

Chronic Fish Criterion (CFC) measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CFC is evaluated at Q710 conditions.

Threshold Human Health (THH) measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the estimated travel time downstream to the nearest potable water supply intake whichever comes first. THH is evaluated at Q710 conditions.

Cancer Risk Level (CRL) measures the criteria compliance time as either the maximum criteria compliance time (i.e. 12 hours travel time downstream of the current discharge) or the complete mix time whichever comes first. CRL is evaluated at Qh (harmonic mean or normal flow) conditions.

The Toxics Model requires several input values for calculating output values. The source of data originates from either EMAP, the National Map, or Stream Stats. Data for stream gauge information, if any, was abstracted from USGS Low-Flow, Base-Flow, and Mean-Flow Regression Equations for Pennsylvania Streams authored by Marla H. Stuckey (Scientific Investigations Report 2006-5130).

5.3.2.1 Determining if NPDES Permit Will Require Monitoring/Limits in the Proposed Permit for Toxic Pollutants

To determine if Toxics modeling is necessary, DEP has developed a Toxics Management Spreadsheet to identify toxics of concern. Toxic pollutants whose maximum concentrations as reported in the permit application or on DMRs are greater than the most stringent applicable water quality criterion are pollutants of concern. A Reasonable Potential Analysis was utilized to determine (a) if the toxic parameters modeled would require monitoring or (b) if permit limitations would be required for the parameters. The toxics reviewed for reasonable potential were the following pollutants- TDS, chloride, bromide, sulfate, total copper, total lead, and total zinc.

Based upon the SOP- Establishing Water Quality-Based Effluent Limitations (WQBELs) and Permit Conditions for Toxic Pollutants (Revised January 10, 2019), monitoring and/or limits will be established as follows.

- (a) When reasonable potential is demonstrated, establish limits where the maximum reported concentration equals or exceeds 50% of the WQBEL.
- (b) For non-conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 25% - 50% of the WQBEL.
- (c) For conservative pollutants, establish monitoring requirements where the maximum reported concentration is between 10% - 50% of the WQBEL.

Toxics Management Spreadsheet did not observe toxics with reasonable potential.

The Toxics Management Spreadsheet output has been included in Attachment B.

5.3.3 Whole Effluent Toxicity (WET)

The facility is not subject to WET limits.

5.4 Total Maximum Daily Loading (TMDL)

5.4.1 TMDL

The goal of the Clean Water Act (CWA), which governs water pollution, is to ensure that all of the Nation's waters are clean and healthy enough to support aquatic life and recreation. To achieve this goal, the CWA created programs designed to regulate and reduce the amount of pollution entering United States waters. Section 303(d) of the CWA requires states to assess their waterbodies to identify those not meeting water quality standards. If a waterbody is not meeting standards, it is listed as impaired and reported to the U.S. Environmental Protection Agency. The state then develops a plan to clean up the impaired waterbody. This plan includes the development of a Total Maximum Daily Load (TMDL) for the pollutant(s) that were found to be the cause of the water quality violations. A Total Maximum Daily Load (TMDL) calculates the maximum amount of a specific pollutant that a waterbody can receive and still meet water quality standards.

A TMDL for a given pollutant and waterbody is composed of the sum of individual wasteload allocations (WLAs) for point sources and load allocations (LAs) for nonpoint sources and natural background levels. In addition, the TMDL must include an implicit or explicit margin of safety (MOS) to account for the uncertainty in the relationship between pollutant loads and the quality of the receiving waterbody. The TMDL components are illustrated using the following equation:

$$\text{TMDL} = \Sigma \text{WLAs} + \Sigma \text{LAs} + \text{MOS}$$

Pennsylvania has committed to restoring all impaired waters by developing TMDLs and TMDL alternatives for all impaired waterbodies. The TMDL serves as the starting point or planning tool for restoring water quality.

5.4.1.1 Local TMDL

The subject facility discharges into a local TMDL- PCB TMDL Development for the Schuylkill River, Pennsylvania. The TMDL was published in April 2007.

The Schuylkill River, in southeastern Pennsylvania, is the focus of the TMDL study. The Schuylkill River watershed is the largest subwatershed in the Delaware River Basin. Pennsylvania's 2004 section 303(d) list includes multiple mainstem and tributary segments in the Schuylkill River Basin as impaired due to elevated polychlorinated biphenyl (PCB) concentrations. The elevated PCB concentrations were found in fish tissue and sediment samples taken throughout the basin.

Pennsylvania's 1996 303(d) list identifies 73.5 miles along the mainstem of the Schuylkill River as impaired due to PCBs.

PCBs are a group of synthetic chemicals that consist of 209 individual compounds (known as congeners). Physically, they are either oily liquids or solids. They are colorless to light yellow in color and have no known smell or taste. PCBs made in the United States were marketed under the trade name Aroclor.

Review of the USEPA's Permit Compliance System (PCS) and DRBC monitoring data presented in the 2003 Delaware River PCBs TMDL identified 40 likely and potential point sources in the Schuylkill River watershed. They include 21 publicly owned wastewater treatment plants (POTWs) with pretreatment facilities that had historically been permitted for PCB discharges, 1 POTW that has been explicitly permitted for PCB discharges, 1 PCB-contaminated industrial site contributing storm water discharges, and 3 industrial facilities identified by the DRBC as discharging PCBs.

Of the 40 facilities identified, 27 on and discharging directly to the mainstem of the Schuylkill River are considered explicitly by the steady-state model. In addition, four facilities suspected of PCB-contaminated storm water discharges are considered as well. Point source facilities (including storm water dischargers) and the model segments and subsegments to which they are assigned are presented in Table 3-1 of the TMDL.

Reading Regional Airport is not listed as one of the 40 likely and potential point sources in the Schuylkill River watershed (Refer to Figure 3-1 of the PCB TMDL for the Schuylkill River, Page 57).

5.5 Anti-Degradation Requirement

Chapter 93.4a of the PA regulations requires that surface water of the Commonwealth of Pennsylvania may not be degraded below levels that protect the existing uses. The regulations specifically state that *Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected*. Antidegradation requirements are implemented through DEP's guidance manual entitled Water Quality Antidegradation Implementation Guidance (Document #391-0300-02).

The policy requires DEP to protect the existing uses of all surface waters and the existing quality of High Quality (HQ) and Exceptional Value (EV) Waters. Existing uses are protected when DEP makes a final decision on any permit or approval for an activity that may affect a protected use. Existing uses are protected based upon DEP's evaluation of the best available information (which satisfies DEP protocols and Quality Assurance/Quality Control (QA/QC) procedures) that indicates the protected use of the waterbody.

For a new, additional, or increased point source discharge to an HQ or EV water, the person proposing the discharge is required to utilize a nondischarge alternative that is cost-effective and environmentally sound when compared with the cost of the proposed discharge. If a nondischarge alternative is not cost-effective and environmentally sound, the person must use the best available combination of treatment, pollution prevention, and wastewater reuse technologies and assure that any discharge is nondegrading. In the case of HQ waters, DEP may find that after satisfaction of intergovernmental coordination and public participation requirements lower water quality is necessary to accommodate important economic or social development in the area in which the waters are located. In addition, DEP will assure that cost-effective and reasonable best management practices for nonpoint source control in HQ and EV waters are achieved.

The subject facility's discharge will be to a non-special protection waters and the permit conditions are imposed to protect existing instream water quality and uses. Neither HQ waters or EV waters is impacted by this discharge.

5.6 Anti-Backsliding

Anti-backsliding is a federal regulation which prohibits a permit from being renewed, reissued, or modified containing effluent limitations which are less stringent than the comparable effluent limitations in the previous permit (40 CFR 122.1.1 and 40 CFR 122.1.2). A review of the existing permit limitations with the proposed permit limitations confirm that the facility is consistent with anti-backsliding requirements. The facility has proposed effluent limitations that are as stringent as the existing permit.

6.0 NPDES Parameter Details

The basis for the proposed sampling and their monitoring frequency that will appear in the permit for each individual parameter are itemized in this Section. The final limits are the more stringent of technology based effluent treatment (TBEL) requirements, water quality based (WQBEL) limits, TMDL, antidegradation, anti-degradation, or WET.

The reader will find in this section:

- a) a justification of recommended permit monitoring requirements and limitations for each parameter in the proposed NPDES permit;
- b) a summary of changes from the existing NPDES permit to the proposed permit; and
- c) a summary of the proposed NPDES effluent limits.

6.1 Recommended Monitoring Requirements and Effluent Limitations

A summary of the recommended monitoring requirements and effluent limitations are itemized in the tables. The tables are categorized by (a) Conventional Pollutants and Disinfection, (b) Nitrogen Species and Phosphorus, and (c) Toxics.

6.1.1.1 Conventional Pollutants and Disinfection (Sewage Outfall)

| Summary of Proposed NPDES Parameter Details for Conventional Pollutants and Disinfection Reading Regional Airport, PA0028720 | | |
|---------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Parameter | Permit Limitation Required by ¹ : | Recommendation |
| pH (S.U.) | TBEL | Monitoring: The monitoring frequency shall be daily as a grab sample (Table 6-3). |
| | | Effluent Limit: Effluent limits may range from pH = 6.0 to 9.0 |
| | | Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 95.2(1). |
| Dissolved Oxygen | BPJ | Monitoring: The monitoring frequency shall be daily as a grab sample (Table 6-3). |
| | | Effluent Limit: Effluent limits shall be greater than 5.0 mg/l. |
| | | Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by best professional judgement. |
| CBOD | TBEL | Monitoring: The monitoring frequency shall be 1x/wk as a 24-hr composite sample (Table 6-3). |
| | | Effluent Limit: Effluent limits shall not exceed 87 lbs/day and 25 mg/l as an average monthly. |
| | | Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). WQM modeling indicates that the TBEL is more stringent than the WQBEL. Thus, the permit limit is confined to TBEL. |
| TSS | TBEL | Monitoring: The monitoring frequency shall be 1x/wk as a 24-hr composite sample (Table 6-3). |
| | | Effluent Limit: Effluent limits shall not exceed 105 lbs/day and 30 mg/l as an average monthly. |
| | | Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(1). While there is no WQM modeling for this parameter, the permit limit for TSS is generally assigned similar effluent limits as CBOD or BOD. Since the TBEL is more stringent than TBEL, TBEL will apply. |
| TRC | TBEL | Monitoring: The monitoring frequency shall be on a daily basis as a grab sample (Table 6-3). |
| | | Effluent Limit: The average monthly limit should not exceed 0.5 mg/l and/or 1.6 mg/l as an instantaneous maximum. |
| | | Rationale: Chlorine in both combined (chloramine) and free form is extremely toxic to freshwater fish and other forms of aquatic life (Implementation Guidance Total Residual Chlorine 1). The TRC effluent limitations to be imposed on a discharger shall be the more stringent of either the WQBEL or TBEL requirements and shall be expressed in the NPDES permit as an average monthly and instantaneous maximum effluent concentration (Implementation Guidance Total Residual Chlorine 4). Based on the stream flow rate (lowest 7-day flow rate in 10 years) and the design flow rate of the subject facility calculated by the TRC Evaluation worksheet, the TBEL is more stringent than the WQBEL. The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.48(b)(2) |
| Fecal Coliform | TBEL | Monitoring: The monitoring frequency shall be 1x/wk as a grab sample (Table 6-3). |
| | | Effluent Limit: Summer effluent limits shall not exceed 200 No./100 mL as a geometric mean. Winter effluent limits shall not exceed 2000 No./100 mL as a geometric mean. |
| | | Rationale: The monitoring frequency has been assigned in accordance with Table 6-3 and the effluent limits assigned by Chapter 92a.47(a)(4) and 92a.47(a)(5). |
| E. Coli | SOP; Chapter 92a.61 | Monitoring: The monitoring frequency shall be 1x/quarter as a grab sample (SOP). |
| | | Effluent Limit: No effluent requirements. |
| | | Rationale: Consistent with the SOP- Establishing Effluent Limitations for Individual Sewage Permits (Revised March 22, 2019) and under the authority of Chapter 92a.61, the facility will be required to monitor for E.Coli. |
| Oil and Grease | TBEL; BPJ | Monitoring: The monitoring frequency shall be 1x/wk as a 24-hr composite sample. |
| | | Effluent Limit: Effluent limits shall not exceed 15 mg/l as an average monthly and 30 mg/l as an instantaneous maximum. |
| | | Rationale: The monitoring frequency has been assigned in accordance with best professional judgment and the effluent limits assigned by Chapter 95.2.(2)(ii) |

Notes:

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.42 MGD.
- 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (Document # 362-0400-001) Revised 10/97
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017

6.1.1.2 Nitrogen Species and Phosphorus (Sewage Outfall)

| Summary of Proposed NPDES Parameter Details for Nitrogen Species and Phosphorus | | |
|---------------------------------------------------------------------------------|----------------------------------------------|------------------------------------------------------------------------------------------------|
| Reading Regional Airport, PA0028720 | | |
| Parameter | Permit Limitation Required by ¹ : | Recommendation |
| Ammonia-Nitrogen | WQBEL | Monitoring: The monitoring frequency shall be 1x/wk as a 24-hr composite sample |
| | | Effluent Limit: Effluent limits shall not exceed 70 lbs/day and 20 mg/l as an average monthly. |
| | | Rationale: Water quality modeling recommends limits. |

Notes:

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.42 MGD.
- 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017

6.1.1.3 Toxics (Sewage Outfall)

| Summary of Proposed NPDES Parameter Details for Toxics | | |
|--------------------------------------------------------|----------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------|
| Reading Regional Airport, PA0028720 | | |
| Parameter | Permit Limitation Required by ¹ : | Recommendation |
| TDS | DRBC Docket | Monitoring: The monitoring frequency shall be 1x/wk as a 24-hr composite sample |
| | | Effluent Limit: Effluent limits shall not exceed 2,605 mg/l as an average monthly and 5,210 mg/l as a daily maximum. |
| | | Rationale: Based on the DRBC docket, monitoring and effluent limits are required. |
| Total PCBs | TMDL | Monitoring: The monitoring frequency shall be 2x/yr as a 24-hr composite sample. |
| | | Effluent Limit: No effluent requirements. |
| | | Rationale: Due to the TMDL, monitoring shall be required. The monitoring frequency has been assigned in accordance with best professional judgment. |

Notes:

- 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other
- 2 Monitoring frequency based on flow rate of 0.42 MGD.
- 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97
- 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002)
- 5 Phase 2 Watershed Implementation Plan Wastewater Supplement, Revised September 6, 2017

6.1.2.1 Stormwater Monitoring

Consistent with the PAG03 general permit, the requirements in Appendix G (Air Transportation Facility) apply to stormwater discharges associated with industrial activity from Air Transportation facilities as identified by the following SIC Codes: 4512-4581.

The GIF form reported the facility is classified by SIC code 4581.

This General Permit authorizes stormwater discharges from only those portions of the air transportation facility that are involved in vehicle maintenance (including vehicle rehabilitation, mechanical repairs, painting, fueling and lubrication), equipment cleaning operations or deicing operations.

An individual NPDES permit is required for the following discharges:

- Discharges of aircraft, ground vehicle, runway and equipment wash waters.
- Dry weather discharges containing deicing chemicals.
- Runoff containing urea from airfield pavement deicing at existing and new primary airports with 1,000 or more annual non-propeller aircraft departures, subject to effluent limitation guidelines in 40 CFR Part 449.

The permittee must monitor and report analytical results for the parameters listed below on Discharge Monitoring Reports (DMRs) for representative outfalls, subject to footnotes provided. The benchmark values listed below are not effluent limitations, and exceedances do not constitute permit violations. However, if the permittee’s sampling demonstrates exceedances of benchmark values for two consecutive monitoring periods, the permittee shall submit a corrective action plan within 90 days of the end of the monitoring period triggering the plan.

| Parameter | Monitoring Requirements⁽¹⁾ | Sample Type | Benchmark Values | Units |
|------------------|----------------------------------------------|--------------------|-------------------------|--------------|
| pH | 1/6 months | Grab | XXX | SU |
| BOD | 1/6 months | Grab | 30 | mg/l |
| COD | 1/6 months | Grab | 120 | mg/l |
| TSS | 1/6 months | Grab | 100 | mg/l |
| Ammonia-Nitrogen | 1/6 months | Grab | XXX | mg/l |
| TDS | 1/6 months | Grab | XXX | mg/l |

Footnotes

- (1) The permittee shall monitor the listed parameters only at those outfalls that receive runoff from areas where deicing activities occur. The permittee shall conduct the required monitoring during the deicing season, which is defined for the purpose of this appendix as the period from October 1 – March 31. One sample must be collected during the period October 1 – December 31 (to be submitted on a DMR due January 28) and one sample must be collected during the period January 1 – March 31 (to be submitted on a DMR due July 28). Additional monitoring outside of the deicing season is optional.

Consistent with the March 17, 2021 letter from Spotts, Stevens, and McCoy, (a) the facility is not considered a primary airport; (b) there are no dry weather discharges (c) only Outfalls 006 and 008 are not affected by de-icing contributions (d) the facility will obtain permission from BCIDA to sample Outfall 002.

6.1.3.2 Toxics (Stormwater Outfall)

| Summary of Proposed NPDES Parameter Details for Toxics | | | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|-----------------|------------------------------------------------------------------------------------|
| Reading Regional Airport; PA0028720; Outfalls 002, 003, 004, 005, 006, 007, 008, and 009 | | | |
| Parameter | Permit Limitation Required by ¹ : | Recommendation | |
| Oil and Grease | Antibacksliding | Monitoring: | The monitoring frequency shall be 2x/yr as a grab sample |
| | | Effluent Limit: | No effluent requirement. |
| | | Rationale: | Due to antibacksliding regulations, this parameter shall continue to be monitored. |
| Total Potassium | Antibacksliding | Monitoring: | The monitoring frequency shall be 2x/yr as a grab sample |
| | | Effluent Limit: | No effluent requirement. |
| | | Rationale: | Due to antibacksliding regulations, this parameter shall continue to be monitored. |
| Diethylene Glycol | Antibacksliding | Monitoring: | The monitoring frequency shall be 2x/yr as a grab sample |
| | | Effluent Limit: | No effluent requirement. |
| | | Rationale: | Due to antibacksliding regulations, this parameter shall continue to be monitored. |
| Propylene Glycol | Antibacksliding | Monitoring: | The monitoring frequency shall be 2x/yr as a grab sample |
| | | Effluent Limit: | No effluent requirement. |
| | | Rationale: | Due to antibacksliding regulations, this parameter shall continue to be monitored. |
| Ethylene Glycol | Antibacksliding | Monitoring: | The monitoring frequency shall be 2x/yr as a grab sample |
| | | Effluent Limit: | No effluent requirement. |
| | | Rationale: | Due to antibacksliding regulations, this parameter shall continue to be monitored. |
| Total Iron | Antibacksliding | Monitoring: | The monitoring frequency shall be 2x/yr as a grab sample |
| | | Effluent Limit: | No effluent requirement. |
| | | Rationale: | Due to antibacksliding regulations, this parameter shall continue to be monitored. |
| Notes: | | | |
| 1 The NPDES permit was limited by (a) anti-Backsliding, (b) Anti-Degradation, (c) SOP, (d) TBEL, (e) TMDL, (f) WQBEL, (g) WET, or (h) Other | | | |
| 2 Monitoring frequency based on PAG03- Appendix G | | | |
| 3 Table 6-3 (Self Monitoring Requirements for Sewage Discharges) in Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits) (Document # 362-0400-001) Revised 10/97 | | | |
| 4 Water Quality Antidegradation Implementaton Guidance (Document # 391-0300-002) | | | |
| 5 Chesapeake Bay Phase 3 Watershed Implementation Plan Wastewater Supplement, Revised September 13, 2021 | | | |

6.2 Summary of Changes From Existing Permit to Proposed Permit

A summary of how the proposed NPDES permit differs from the existing NPDES permit is summarized as follows.

This table summarizes changes for sewage effluent.

| Changes in Permit Monitoring or Effluent Quality (Sewage Effluent) | | |
|--------------------------------------------------------------------|---------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Parameter | Existing Permit | Draft Permit |
| E.Coli | No monitoring or effluent limits | Due to EPA directive, monitoring shall be required on a 1x/quarter basis |
| TDS | Effluent limits not to exceed 2,625 mg/l as an average monthly and 5,210 mg/l as a daily maximum. | Effluent limits shall not exceed 2,605 mg/l as an average monthly and 5,210 mg/l as a daily maximum. The current permit may have had a typographical error with a limit of 2,625 mg/l. |

This table summarizes changes for stormwater monitoring.

| Changes in Permit Monitoring or Effluent Quality (Stormwater) | | |
|------------------------------------------------------------------------------------------------------------------|----------------------------------|------------------------------------------------------------------------------------------------------------------|
| Parameter | Existing Permit | Draft Permit |
| pH, CBOD, TSS, Oil and Grease, Total Potassium, Diethylene Glycol, Propylene Glycol, Ethylene Glycol, Total Iron | Monitoring is required 1x/yr. | Consistent with other monitoring parameters in PAG03- Appendix G, monitoring shall be required on a 2x/yr basis. |
| Ammonia-Nitrogen | No monitoring or effluent limits | Consistent with PAG03- Appendix G, monitoring shall be required on a 2x/yr basis. |
| TDS | No monitoring or effluent limits | Consistent with PAG03- Appendix G, monitoring shall be required on a 2x/yr basis. |

6.3.1 Summary of Proposed NPDES Effluent Limits

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

The proposed NPDES effluent limitations are summarized in the table below.

PART A - EFFLUENT LIMITATIONS, MONITORING, RECORDKEEPING AND REPORTING REQUIREMENTS

I. A. For Outfall 001, Latitude 40° 22' 58.03", Longitude 75° 57' 10.00", River Mile Index 79.4, Stream Code 833

Receiving Waters: Schuylkill River (WWF, MF)

Type of Effluent: Sewage Effluent

1. The permittee is authorized to discharge during the period from **Permit Effective Date** through **Permit Expiration Date**.
2. Based on the anticipated wastewater characteristics and flows described in the permit application and its supporting documents and/or amendments, the following effluent limitations and monitoring requirements apply (see also Additional Requirements and Footnotes).

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------------------------------------|-------------------------------------|------------------|-----------------------|-----------------|------------------|------------------|----------------------------------------------|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report Daily Max | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | Inst Min 8.0 | XXX | XXX | 9.0 | 1/day | Grab |
| Dissolved Oxygen | XXX | XXX | Inst Min 5.0 | XXX | XXX | XXX | 1/day | Grab |
| Total Residual Chlorine (TRC) | XXX | XXX | XXX | 0.5 | XXX | 1.6 | 1/day | Grab |
| Carbonaceous Biochemical Oxygen Demand (CBOD5) | 87 | 140 | XXX | 25.0 | 40.0 | 50 | 1/week | 24-Hr Composite |
| Biochemical Oxygen Demand (BOD5) Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Total Suspended Solids | 105 | 157 | XXX | 30.0 | 45.0 | 60 | 1/week | 24-Hr Composite |
| Total Suspended Solids Raw Sewage Influent | Report | Report Daily Max | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Total Dissolved Solids | Report | XXX | XXX | 2605.0 | 5210.0 Daily Max | 5210 | 1/week | 24-Hr Composite |
| Oil and Grease | 52 | XXX | XXX | 15.0 | XXX | 30 | 1/week | Grab |
| Fecal Coliform (No./100 ml) Oct 1 - Apr 30 | XXX | XXX | XXX | 2000 Geo Mean | XXX | XXX | 1/week | Grab |

Outfall001, Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--------------------------------------------|-------------------------------------|----------------|-----------------------|-----------------|------------------|------------------|----------------------------------------------|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Fecal Coliform (No./100 ml) May 1 - Sep 30 | XXX | XXX | XXX | 200 Geo Mean | XXX | XXX | 1/week | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | Report Daily Max | XXX | 1/quarter | Grab |
| Ammonia-Nitrogen | 70 | XXX | XXX | 20.0 | XXX | 40 | 1/week | 24-Hr Composite |

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location(s):

at Outfall 001

For Stormwater Outfalls 002 to 009, the table summarizes the monitoring requirements.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------------------------------|-------------------------------------|----------------|-----------------------|---------------------|---------|------------------|----------------------------------------------|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Semi-Annual Average | Maximum | Instant. Maximum | | |
| pH (S.U.) | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Carbonaceous Biochemical Oxygen Demand (CBOD5) | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Chemical Oxygen Demand (COD) | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Total Suspended Solids | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Total Dissolved Solids | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Oil and Grease | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Iron, Total | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Potassium, Total | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Ethylene Glycol | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Propylene Glycol | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |
| Diethylene Glycol | XXX | XXX | XXX | Report | XXX | XXX | 1/6 months | Grab |

6.3.2 Summary of Proposed Permit Part C Conditions

The subject facility has the following Part C conditions.

- Chlorine Minimization
- SBR Batch Discharge Condition
- Hauled-in Waste Restrictions
- Solids Management for Non-Lagoon Treatment Systems
- Stormwater Requirements
- Stormwater BMPs
- Schuylkill River PCB TMDL- Monitoring Requirements
- Schuylkill River PCB TMDL- Submit Plan

| Tools and References Used to Develop Permit | |
|---------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <input type="checkbox"/> | WQM for Windows Model (see Attachment [REDACTED]) |
| <input checked="" type="checkbox"/> | Toxics Management Spreadsheet (see Attachment [REDACTED]) |
| <input checked="" type="checkbox"/> | TRC Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Temperature Model Spreadsheet (see Attachment [REDACTED]) |
| <input type="checkbox"/> | Water Quality Toxics Management Strategy, 361-0100-003, 4/06. |
| <input type="checkbox"/> | Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97. |
| <input type="checkbox"/> | Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98. |
| <input type="checkbox"/> | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96. |
| <input type="checkbox"/> | Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97. |
| <input type="checkbox"/> | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97. |
| <input type="checkbox"/> | Pennsylvania CSO Policy, 385-2000-011, 9/08. |
| <input type="checkbox"/> | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03. |
| <input type="checkbox"/> | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97. |
| <input type="checkbox"/> | Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97. |
| <input type="checkbox"/> | Implementation Guidance Design Conditions, 391-2000-006, 9/97. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004. |
| <input type="checkbox"/> | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99. |
| <input type="checkbox"/> | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004. |
| <input type="checkbox"/> | Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97. |
| <input type="checkbox"/> | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008. |
| <input type="checkbox"/> | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994. |
| <input type="checkbox"/> | Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09. |
| <input type="checkbox"/> | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97. |
| <input type="checkbox"/> | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99. |
| <input type="checkbox"/> | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999. |
| <input type="checkbox"/> | Design Stream Flows, 391-2000-023, 9/98. |
| <input type="checkbox"/> | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98. |
| <input type="checkbox"/> | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97. |
| <input type="checkbox"/> | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07. |
| <input checked="" type="checkbox"/> | SOP: New and Reissuance Sewage Individual NPDES permit Applications, rev January 6, 2020 |
| <input type="checkbox"/> | Other: [REDACTED] |

Attachment A

Stream Stats/Gauge Data

10 Selected Streamflow Statistics for Streamgauge Locations in and near Pennsylvania

Table 1. List of U.S. Geological Survey streamgauge locations in and near Pennsylvania with updated streamflow statistics.—Continued

[Latitude and Longitude in decimal degrees; mi², square miles]

| Streamgauge number | Streamgauge name | Latitude | Longitude | Drainage area (mi ²) | Regulated ¹ |
|--------------------|-----------------------------------------------------------|----------|-----------|----------------------------------|------------------------|
| 01465780 | Poquessing Creek above Byberry Creek at Phila., Pa. | 40.070 | -74.975 | 13.2 | N |
| 01465798 | Poquessing Creek at Grant Ave. at Philadelphia, Pa. | 40.057 | -74.985 | 21.4 | N |
| 01465850 | South Branch Rancocas Creek at Vincentown, N.J. | 39.94 | -74.763 | 64.5 | N |
| 01466500 | McDonalds Branch in Byrne State Forest, N.J. | 39.885 | -74.505 | 2.35 | N |
| 01467000 | North Branch Rancocas Creek at Pemberton, N.J. | 39.97 | -74.684 | 118 | N |
| 01467042 | Pennypack Creek at Pine Road, at Philadelphia, Pa. | 40.090 | -75.069 | 37.9 | N |
| 01467048 | Pennypack Creek at Lower Rhawn St Bdg, Phila., Pa. | 40.050 | -75.033 | 49.8 | N |
| 01467050 | Wooden Bridge Run at Philadelphia, Pa. | 40.055 | -75.022 | 3.35 | N |
| 01467081 | South Branch Pennsauken Creek at Cherry Hill, N.J. | 39.942 | -75.001 | 8.98 | N |
| 01467086 | Tacony Creek ab Adams Avenue, Philadelphia, Pa. | 40.047 | -75.111 | 16.7 | N |
| 01467087 | Frankford Creek at Castor Ave, Philadelphia, Pa. | 40.016 | -75.097 | 30.4 | N |
| 01467089 | Frankford Creek at Torresdale Ave., Phila., Pa. | 40.007 | -75.092 | 33.8 | N |
| 01467150 | Cooper River at Haddonfield, N.J. | 39.903 | -75.021 | 17.0 | N |
| 01467500 | Schuylkill River at Pottsville, Pa. | 40.684 | -76.186 | 53.4 | N |
| 01468500 | Schuylkill River at Landingville, Pa. | 40.629 | -76.125 | 133 | N |
| 01469500 | Little Schuylkill River at Tamaqua, Pa. | 40.807 | -75.972 | 42.9 | N |
| 01470500 | Schuylkill River at Berne, Pa. | 40.523 | -75.998 | 355 | N |
| 01470756 | Maiden Creek at Virginville, Pa. | 40.514 | -75.883 | 159 | N |
| 01470779 | Tulpehocken Creek near Bernville, Pa. | 40.413 | -76.172 | 66.5 | N |
| 01470853 | Furnace Creek at Robesonia, Pa. | 40.340 | -76.143 | 4.18 | N |
| 01470960 | Tulpehocken Creek at Blue Marsh Damsite near Reading, Pa. | 40.371 | -76.025 | 175 | Y |
| 01471000 | Tulpehocken Creek near Reading, Pa. | 40.369 | -75.979 | 211 | Y |
| 01471510 | Schuylkill River at Reading, Pa. | 40.335 | -75.936 | 880 | Y |
| 01471875 | Manatawny Creek near Spangsville, Pa. | 40.340 | -75.742 | 56.9 | N |
| 01471980 | Manatawny Creek near Pottstown, Pa. | 40.273 | -75.680 | 85.5 | N |
| 01472000 | Schuylkill River at Pottstown, Pa. | 40.242 | -75.652 | 1,147 | Y |
| 01472157 | French Creek near Phoenixville, Pa. | 40.151 | -75.601 | 59.1 | N |
| 01472174 | Pickering Creek near Chester Springs, Pa. | 40.090 | -75.630 | 5.98 | N |
| 01472198 | Perkiomen Creek at East Greenville, Pa. | 40.394 | -75.515 | 38.0 | N |
| 01472199 | West Branch Perkiomen Creek at Hillegass, Pa. | 40.374 | -75.522 | 23.0 | N |
| 01472500 | Perkiomen Creek near Frederick, Pa. | 40.275 | -75.455 | 152 | N |
| 01472620 | East Branch Perkiomen Creek near Dublin, Pa. | 40.404 | -75.234 | 4.05 | LF |
| 01472810 | East Branch Perkiomen Creek near Schwenksville, Pa. | 40.259 | -75.429 | 58.7 | LF |
| 01473000 | Perkiomen Creek at Graterford, Pa. | 40.230 | -75.452 | 279 | LF |
| 01473120 | Skippack Creek near Collegeville, Pa. | 40.165 | -75.433 | 53.7 | N |
| 01473169 | Valley Creek at Pa. Turnpike Br near Valley Forge, Pa. | 40.079 | -75.461 | 20.8 | N |
| 01473500 | Schuylkill River at Norristown, Pa. | 40.111 | -75.347 | 1,760 | N |
| 01473900 | Wissahickon Creek at Fort Washington, Pa. | 40.124 | -75.220 | 40.8 | N |
| 01473950 | Wissahickon Creek at Bells Mill Rd, Phila., Pa. | 40.080 | -75.226 | 53.6 | N |
| 01473980 | Wissahickon Creek at Livezey Lane, Phila., Pa. | 40.050 | -75.214 | 59.2 | N |
| 01474000 | Wissahickon Creek at Mouth, Philadelphia, Pa. | 40.015 | -75.207 | 64.0 | N |
| 01474500 | Schuylkill River at Philadelphia, Pa. | 39.968 | -75.189 | 1,893 | N |
| 01475000 | Mantua Creek at Pitman, N.J. | 39.737 | -75.113 | 6.05 | N |
| 01475300 | Darby Creek at Waterloo Mills near Devon, Pa. | 40.023 | -75.422 | 5.15 | N |
| 01475510 | Darby Creek near Darby, Pa. | 39.929 | -75.272 | 37.4 | N |

22 Selected Streamflow Statistics for Streamgauge Locations in and near Pennsylvania

Table 2. Selected low-flow statistics for streamgauge locations in and near Pennsylvania.—Continued

[ft³/s; cubic feet per second; —, statistic not computed; <, less than]

| Streamgauge number | Period of record used in analysis ¹ | Number of years used in analysis | 1-day, 10-year (ft ³ /s) | 7-day, 10-year (ft ³ /s) | 7-day, 2-year (ft ³ /s) | 30-day, 10-year (ft ³ /s) | 30-day, 2-year (ft ³ /s) | 90-day, 10-year (ft ³ /s) |
|--------------------|------------------------------------------------|----------------------------------|-------------------------------------|-------------------------------------|------------------------------------|--------------------------------------|-------------------------------------|--------------------------------------|
| 01453000 | ³ 1904–1927 | 18 | 237 | 312 | 447 | 378 | 546 | 472 |
| 01454700 | 1968–2005 | 38 | 471 | 510 | 745 | 600 | 902 | 760 |
| 01455500 | 1930–2008 | 52 | 0 | .4 | 7.8 | — | — | 6.0 |
| 01457000 | 1905–2008 | 89 | 40.6 | 45.6 | 70.5 | 52.2 | 81.7 | 62.5 |
| 01459500 | ² 1975–2008 | 34 | 1.9 | 2.1 | 4.1 | 2.9 | 7.1 | 5.7 |
| 01459500 | ³ 1937–1973 | 37 | .4 | .9 | 2.1 | 1.3 | 3.6 | 2.9 |
| 01463500 | 1914–2008 | 95 | 1,540 | 1,720 | 2,700 | 1,960 | 3,120 | 2,430 |
| 01463620 | 1974–2008 | 19 | 2.4 | 2.7 | 7.6 | 4.8 | 10.6 | 8.6 |
| 01464000 | 1925–2008 | 84 | 9.4 | 14.2 | 25.7 | 18.7 | 34.2 | 29.3 |
| 01464500 | 1942–2008 | 65 | 16.4 | 18.9 | 34.0 | 24.4 | 42.3 | 37.3 |
| 01464645 | 1987–2008 | 22 | 3.3 | 3.6 | 12.3 | 4.4 | 13.6 | 5.4 |
| 01464720 | 1992–2008 | 17 | 3.0 | 3.6 | 5.8 | 4.5 | 7.3 | 6.2 |
| 01465000 | 1886–1934 | 28 | — | 3.4 | 10.1 | 4.9 | 15.0 | 12.9 |
| 01465500 | 1936–2008 | 73 | 9.0 | 12.7 | 26.4 | 17.3 | 37.4 | 28.6 |
| 01465770 | 1966–1982 | 16 | .3 | .4 | 1.2 | .8 | 1.7 | 1.7 |
| 01465798 | 1967–2008 | 42 | 1.0 | 1.2 | 3.6 | 3.0 | 6.8 | 7.9 |
| 01465850 | 1963–2008 | 19 | 5.2 | 8.5 | 13.2 | 12.1 | 19.5 | 17.1 |
| 01466500 | 1955–2008 | 54 | .8 | .8 | 1.1 | .9 | 1.2 | .9 |
| 01467000 | 1923–2008 | 86 | 26.2 | 34.2 | 51.8 | 41.6 | 63.2 | 53.2 |
| 01467042 | 1966–1981 | 16 | 8.6 | 9.3 | 16.8 | 11.3 | 21.5 | 17.0 |
| 01467048 | 1967–2008 | 42 | 10.7 | 12.1 | 18.9 | 16.6 | 27.2 | 26.6 |
| 01467050 | 1967–1981 | 15 | .3 | .4 | .8 | .7 | 1.3 | 1.6 |
| 01467081 | 1969–2008 | 38 | 2.4 | 2.9 | 4.1 | 3.9 | 6.0 | 6.3 |
| 01467086 | 1967–1988 | 23 | 3.3 | 4.4 | 6.9 | 6.6 | 9.9 | 10.4 |
| 01467087 | 1984–2008 | 25 | 1.6 | 2.1 | 6.1 | 4.8 | 10.1 | 12.0 |
| 01467089 | 1968–1982 | 15 | 4.8 | 6.6 | 9.6 | 10.3 | 16.0 | 20.1 |
| 01467150 | 1965–2008 | 44 | 3.9 | 5.4 | 10.1 | 7.3 | 13.2 | 11.5 |
| 01467500 | 1945–1969 | 25 | 14.6 | 17.2 | 24.5 | 19.8 | 28.5 | 23.4 |
| 01468500 | 1949–2008 | 40 | 40.8 | 44.5 | 70.6 | 52.1 | 82.4 | 65.0 |
| 01469500 | 1921–2008 | 88 | 4.8 | 5.5 | 10.9 | 7.3 | 14.4 | 10.1 |
| 01470500 | 1949–2008 | 60 | 69.2 | 82.3 | 137 | 102 | 164 | 133 |
| 01470756 | 1974–1995 | 22 | 14.8 | 16.7 | 30.5 | 23.4 | 43.9 | 35.5 |
| 01470779 | 1976–2008 | 33 | 21.9 | 24.6 | 39.3 | 29.4 | 45.2 | 34.8 |
| 01470853 | 1984–2005 | 22 | .2 | .4 | 1.2 | .8 | 1.6 | 1.1 |
| 01470960 | ² 1980–2008 | 29 | 29.4 | 31.8 | 52.4 | 47.0 | 74.7 | 66.3 |
| 01470960 | ³ 1967–1978 | 12 | 32.7 | 38.2 | 74.0 | 47.6 | 88.3 | 59.5 |
| 01471000 | ² 1980–2008 | 29 | 36.9 | 43.4 | 69.4 | 58.9 | 93.9 | 81.0 |
| 01471000 | ³ 1952–1978 | 27 | 41.8 | 47.6 | 77.1 | 55.3 | 91.2 | 68.6 |
| 01471510 | ² 1980–2008 | 29 | 222 | 244 | 347 | 274 | 422 | 340 |
| 01471510 | ³ 1916–1930 | 10 | 142 | 173 | 279 | 206 | 337 | 245 |
| 01471875 | 1995–2008 | 14 | 10.9 | 11.8 | 21.2 | 14.1 | 25.3 | 19.0 |
| 01471980 | 1976–2004 | 29 | 16.5 | 17.8 | 29.2 | 21.7 | 34.9 | 29.7 |
| 01472000 | ² 1980–2008 | 29 | 276 | 301 | 432 | 349 | 527 | 453 |
| 01472000 | ³ 1929–1978 | 50 | 228 | 258 | 411 | 298 | 486 | 374 |
| 01472157 | 1970–2008 | 39 | 9.5 | 10.2 | 17.2 | 12.5 | 21.8 | 17.0 |

Attachment B

WQM 7.0 Modeling Output Values Toxics Management Spreadsheet Output Values

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | |
|------------------|------------|--------------------|-----------------|--------------------|--------------------------------|----------------------------|----------------------------|
| 03F | | 833 | | SCHUYLKILL RIVER | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 79.400 | Reading RA | PA0028720 | 0.420 | CBOD5 | 25 | | |
| | | | | NH3-N | 20 | 40 | |
| | | | | Dissolved Oxygen | | | 5 |

WQM 7.0 Wasteload Allocations

SWP Basin Stream Code Stream Name
03F 833 SCHUYLKILL RIVER

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 79.400 | Reading RA | 2.76 | 40 | 2.76 | 40 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 79.400 | Reading RA | .59 | 20 | .59 | 20 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|-------|----------------|-----------------|-----------------|-----------------|-----------------|-------------------------|-----------------|----------------|-------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 79.40 | Reading RA | 25 | 25 | 20 | 20 | 5 | 5 | 0 | 0 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|------------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 03F | 833 | SCHUYLKILL RIVER | 79.400 | 228.00 | 648.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.240 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 23.30 | 8.05 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Reading RA | PA0028720 | 0.4200 | 0.4200 | 0.4200 | 0.000 | 25.00 | 7.23 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 20.00 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|------------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 03F | 833 | SCHUYLKILL RIVER | 77.570 | 201.00 | 658.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary | | Stream | |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|-----------|------|-----------|------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | Temp (°C) | pH | Temp (°C) | pH |
| Q7-10 | 0.240 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 23.30 | 8.05 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|------------------|------------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | | |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 | | | |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 | | | |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 | | | |

WQM 7.0 D.O. Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|--------------------|
| 03F | 833 | SCHUYLKILL RIVER | | |
| <hr/> | | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | |
| 79.400 | 0.420 | 23.307 | 8.040 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | |
| 187.607 | 1.118 | 167.817 | 0.745 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | |
| 2.10 | 0.066 | 0.08 | 0.903 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | |
| 8.229 | 10.497 | Tsivoglou | 5 | |
| <u>Reach Travel Time (days)</u> | | | | |
| 0.150 | | | | |
| | <u>Subreach Results</u> | | | |
| | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> |
| | 0.015 | 2.09 | 0.08 | 7.76 |
| | 0.030 | 2.09 | 0.08 | 7.76 |
| | 0.045 | 2.09 | 0.08 | 7.76 |
| | 0.060 | 2.09 | 0.08 | 7.76 |
| | 0.075 | 2.08 | 0.08 | 7.76 |
| | 0.090 | 2.08 | 0.08 | 7.76 |
| | 0.105 | 2.08 | 0.08 | 7.76 |
| | 0.120 | 2.08 | 0.07 | 7.76 |
| | 0.135 | 2.07 | 0.07 | 7.76 |
| | 0.150 | 2.07 | 0.07 | 7.76 |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | | | | | | |
|--------------------|----------------------|--------------------|--------------------------|-----------------------------|------------------------|---------------|---------------|-----------|-------------------|---------------------------|-----------------------|-------------|
| 03F | | 833 | | SCHUYLKILL RIVER | | | | | | | | |
| RMI | Stream Flow (cfs) | PWS With (cfs) | Net Stream Flow (cfs) | Disc Analysis Flow (cfs) | Reach Slope (ft/ft) | Depth (ft) | Width (ft) | W/D Ratio | Velocity (fps) | Reach Trav Time (days) | Analysis Temp (°C) | Analysis pH |
| Q7-10 Flow | | | | | | | | | | | | |
| 79.400 | 155.52 | 0.00 | 155.52 | .6497 | 0.00279 | 1.118 | 187.61 | 167.82 | 0.74 | 0.150 | 23.31 | 8.04 |
| Q1-10 Flow | | | | | | | | | | | | |
| 79.400 | 141.52 | 0.00 | 141.52 | .6497 | 0.00279 | NA | NA | NA | 0.71 | 0.158 | 23.31 | 8.04 |
| Q30-10 Flow | | | | | | | | | | | | |
| 79.400 | 174.18 | 0.00 | 174.18 | .6497 | 0.00279 | NA | NA | NA | 0.79 | 0.141 | 23.31 | 8.04 |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.91 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.12 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 5 | | |



Discharge Information

Instructions Discharge Stream

Facility: Reading Regional Airport NPDES Permit No.: PA0028720 Outfall No.: 001
 Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Sewage Effluent

| Discharge Characteristics | | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|-----|--------------------------|----------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) | |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ | Q _h |
| 0.42 | 100 | 7.23 | | | | | | |

| Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | | 1 if left blank | |
|---------------------|---------------------------------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----|-----------------|-------------|
| | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteria Mod | Chem Transl |
| Group 1 | Total Dissolved Solids (PWS) | mg/L | 1628 | | | | | | | | |
| | Chloride (PWS) | mg/L | 303 | | | | | | | | |
| | Bromide | mg/L | 0.22 | | | | | | | | |
| | Sulfate (PWS) | mg/L | 366 | | | | | | | | |
| | Fluoride (PWS) | mg/L | | | | | | | | | |
| Group 2 | Total Aluminum | µg/L | | | | | | | | | |
| | Total Antimony | µg/L | | | | | | | | | |
| | Total Arsenic | µg/L | | | | | | | | | |
| | Total Barium | µg/L | | | | | | | | | |
| | Total Beryllium | µg/L | | | | | | | | | |
| | Total Boron | µg/L | | | | | | | | | |
| | Total Cadmium | µg/L | | | | | | | | | |
| | Total Chromium (III) | µg/L | | | | | | | | | |
| | Hexavalent Chromium | µg/L | | | | | | | | | |
| | Total Cobalt | µg/L | | | | | | | | | |
| | Total Copper | mg/L | 0.132 | | | | | | | | |
| | Free Cyanide | µg/L | | | | | | | | | |
| | Total Cyanide | µg/L | | | | | | | | | |
| | Dissolved Iron | µg/L | | | | | | | | | |
| | Total Iron | µg/L | | | | | | | | | |
| | Total Lead | mg/L | < 0.002 | | | | | | | | |
| | Total Manganese | µg/L | | | | | | | | | |
| | Total Mercury | µg/L | | | | | | | | | |
| | Total Nickel | µg/L | | | | | | | | | |
| | Total Phenols (Phenolics) (PWS) | µg/L | | | | | | | | | |
| Total Selenium | µg/L | | | | | | | | | | |
| Total Silver | µg/L | | | | | | | | | | |
| Total Thallium | µg/L | | | | | | | | | | |
| Total Zinc | mg/L | 0.0649 | | | | | | | | | |
| Total Molybdenum | µg/L | | | | | | | | | | |
| Acrolein | µg/L | < | | | | | | | | | |
| Acrylamide | µg/L | < | | | | | | | | | |
| Acrylonitrile | µg/L | < | | | | | | | | | |
| Benzene | µg/L | < | | | | | | | | | |
| Bromoform | µg/L | < | | | | | | | | | |



Stream / Surface Water Information

Reading Regional Airport, NPDES Permit No. PA0028720, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: Schuylkill River No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|-------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 000833 | 79.4 | 228 | 648 | | | Yes |
| End of Reach 1 | 000833 | 77.57 | 201 | 658 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|------|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 79.4 | 0.24 | | | | | | | | | | 136 | 8.05 | | |
| End of Reach 1 | 77.57 | 0.24 | | | | | | | | | | 136 | 8.05 | | |

Q_h

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|-------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|----------|----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness | pH | Hardness | pH |
| Point of Discharge | 79.4 | | | | | | | | | | | | | | |
| End of Reach 1 | 77.57 | | | | | | | | | | | | | | |

Stream / Surface Water Information

12/2/2021

Page 4

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|--------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Copper | Report | Report | Report | Report | Report | mg/L | 0.41 | AFC | Discharge Conc > 10% WQBEL (no RP) |

Attachment C

TRC Evaluation

Reading Regional Airport
PA0028720

November 2021

| 1A | B | C | D | E | F | G |
|----|-----------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------|-----------|--------------------------------------|---|
| 2 | TRC EVALUATION | | | | | |
| 3 | Input appropriate values in B4: B8 and E4: E7 | | | | | |
| 4 | 153 | = Q stream (cfs) | | 0.5 | = CV Daily | |
| 5 | 0.42 | = Q discharge (MGD) | | 0.5 | = CV Hourly | |
| 6 | 30 | = no. samples | | 1 | = AFC_Partial Mix Factor | |
| 7 | 0.3 | = Chlorine Demand of Stream | | 1 | = CFC_Partial Mix Factor | |
| 8 | 0 | = Chlorine Demand of Discharge | | 15 | = AFC_Criteria Compliance Time (min) | |
| 9 | 0.5 | = BAT/BPJ Value | | 720 | = CFC_Criteria Compliance Time (min) | |
| | 0 | = % Factor of Safety (FOS) | | 0 | = Decay Coefficient (K) | |
| 10 | Source | Reference | AFC Calculations | Reference | CFC Calculations | |
| 11 | TRC | 1.3.2.iii | WLA_afc = 75.137 | 1.3.2.iii | WLA_cfc = 73.245 | |
| 12 | PENTOXSD TRG | 5.1a | LTAMULT_afc = 0.373 | 5.1c | LTAMULT_cfc = 0.581 | |
| 13 | PENTOXSD TRG | 5.1b | LTA_afc = 27.998 | 5.1d | LTA_cfc = 42.581 | |
| 14 | | | | | | |
| 15 | Source | Effluent Limit Calculations | | | | |
| 16 | PENTOXSD TRG | 5.1f | AML_MULT = 1.231 | | | |
| 17 | PENTOXSD TRG | 5.1g | AVG MON LIMIT (mg/l) = 0.500 | | BAT/BPJ | |
| 18 | | | INST MAX LIMIT (mg/l) = 1.635 | | | |
| | WLA_afc | $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)]^{(1-FOS/100)}$ | | | | |
| | LTAMULT_afc | $EXP((0.5 \cdot LN(cv \cdot h^2 + 1)) - 2.326 \cdot LN(cv \cdot h^2 + 1)^{0.5})$ | | | | |
| | LTA_afc | wla_afc * LTAMULT_afc | | | | |
| | WLA_cfc | $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)]^{(1-FOS/100)}$ | | | | |
| | LTAMULT_cfc | $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$ | | | | |
| | LTA_cfc | wla_cfc * LTAMULT_cfc | | | | |
| | AML_MULT | $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$ | | | | |
| | AVG MON LIMIT | MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT) | | | | |
| | INST MAX LIMIT | 1.5 * (av_mon_limit / AML_MULT) / LTAMULT_afc | | | | |

Attachment D

DRBC Docket

DOCKET NO. D-1986-038 CP-4

DELAWARE RIVER BASIN COMMISSION

Reading Regional Airport Authority
Wastewater Treatment Plant
Bern Township, Berks County, Pennsylvania

PROCEEDINGS

This docket is issued in response to an application submitted to the Delaware River Basin Commission (DRBC or Commission) on May 23, 2018 (Application), for renewal of the existing wastewater treatment plant (WWTP) and its discharge. National Pollutant Discharge Elimination System (NPDES) Permit No. PA0028720 for this discharge was issued by the Pennsylvania Department of Environmental Protection (PADEP) on May 6, 2009. The NPDES Permit renewal is pending. The application was reviewed for continuation of the project in the Comprehensive Plan and approval under Section 3.8 of the *Delaware River Basin Compact*. The Berks County Planning Commission has been notified of pending action. A public hearing on this project was held by the DRBC on May 15, 2019.

A. DESCRIPTION

1. Purpose. The purpose of this docket is to renew approval of the docket holder's existing 0.42 million gallons per day (mgd) WWTP and its discharge.
2. Location. The docket holder's WWTP is located at Bernville Road in Bern Township, Berks County, Pennsylvania. The WWTP will continue to discharge treated effluent to the Schuylkill River at River Mile 92.47 – 80.3 (Delaware River – Schuylkill River) via Outfall No. 001.

The WWTP outfall is located in the Schuylkill River Watershed as follows:

| OUTFALL NO. | LATITUDE (N) | LONGITUDE (W) |
|-------------|--------------|---------------|
| 001 | 40° 22' 56" | 75° 57' 10" |

3. Area Served. The docket holder's WWTP will continue to serve the Reading Regional Airport, which includes the tenants of 3 Airport Industrial Parks and contained businesses, the Direct Link Building, and the Riveredge Restaurant. The WWTP also serves the St. Joseph Hospital and Medical Center, Water District (A), and the West Shore Area, which are all located within the limits of Bern Township, Berks County, Pennsylvania. For the purpose of defining the

D-1986-038 CP-4 (Reading Regional Airport Authority, WWTP)

2

Area Served, Section B (Type of Discharge) and D (Service Area) of the docket holder's Application are incorporated herein by reference, to the extent consistent with all other conditions contained in the DECISION Section of this docket.

4. **Design Criteria.** The docket holder's 0.42 mgd WWTP utilizes a sequencing batch reactor (SBR) treatment process with chlorine disinfection.

5. **Facilities.** The WWTP facilities consist of a fine influent screen, an influent wet well, 2 SBR treatment units, 2 aerobic digesters, 2 chlorine contact tanks, a Parshall flume, a sludge dewatering centrifuge, and a sludge holding tank.

The WWTP facilities are not located in the 100-year floodplain

Wasted sludge will continue to be hauled off-site by a licensed hauler for disposal at a state approved facility.

6. **Water withdrawals.** The potable water supply in the project service area is provided by the Reading Area Water Authority (RAWA). The RAWA water withdrawal is described in detail in Docket No. D-2000-059 CP-2, which was approved on May 11, 2011

7. **NPDES Permit / DRBC Effluent Requirements.** NPDES Permit No. PA0028720 was issued by the PADEP on May 6, 2009 and includes final effluent limitations for the project discharge to surface waters classified by the PADEP as supporting migratory fishes (MF) and warm water fishes (WWF). EFFLUENT TABLES C-1 & C-2 included in the DECISION section of this docket, contain effluent requirements for DRBC parameters that must be met as a condition of this approval (See DECISION Condition C.1.). Effluent requirements for Outfall No. 001 are based on a discharge rate of 0.42 mgd.

8. **Relationship to the Comprehensive Plan.** The existing WWTP was added to the Comprehensive Plan by Docket No. D-1986-038 CP on September 17, 1986. The WWTP approval was modified and renewed by Docket Nos. D-1986-038 CP-2 and D-1986-038 CP-3, on September 27, 2006 and September 12, 2013, respectively. Issuance of this docket will renew and continue the approval of the WWTP and its discharge in the Comprehensive Plan.

B. FINDINGS

The purpose of this docket is to renew the approval of the docket holder's existing 0.42 mgd WWTP and its related discharge.

1. Total Dissolved Solids

Section 3.10.4D.2. of the Commission's *Water Quality Regulations (WQR)* establishes the basin-wide total dissolved solids (TDS) effluent standard as 1,000 mg/l. The Commission's basin-wide in-stream criteria outlines that the TDS concentration of the receiving stream exhibit a

D-1986-038 CP-4 (Reading Regional Airport Authority, WWTP)

3

resultant of less than 133% of the background TDS concentration, in conjunction with a TDS less than 500 mg/l (Sections 3.10.3B.1b and 3.10.3B.2 of the Commission's *WQR*).

The 133% of the background TDS requirement is implemented for the protection of aquatic life. The 500 mg/l TDS requirement is utilized to protect the use of the receiving stream as a drinking water source; whereas, the EPA's Safe Drinking Water Act's secondary standard for TDS is 500 mg/l.

Background TDS is to be the observed concentration of TDS during Q₇₋₁₀ conditions or, in the absence thereof, an acceptable estimate to the Commission in accordance with Section 3.10.6G of the Commission's *WQR*. A letter from the Commission to the docket holder dated August 4, 2003 established the in-stream background TDS concentration and accompanying Q₇₋₁₀ flow at the WWTP's discharge as 400 mg/l and 101 mgd, respectively.

Within the referenced letter and Docket Nos. D-1986-38 CP-2 and D-1986-38 CP-3, a variance to the Commission's TDS effluent limit was approved on an average monthly and instantaneous maximum basis of 2,605 mg/l and 5,210 mg/l, respectively. The established in-stream background TDS concentration and Q₇₋₁₀ low flow evaluated at the docket holder's WWTP existing 0.42 mgd flow does not increase the stream's resultant concentration greater than the Commission's *WQR* criteria. Therefore, this docket continues an average monthly TDS effluent limit of 2,605 mg/l and an instantaneous maximum TDS effluent limit of 5,210 mg/l.

2. Other

At the docket holder's WWTP discharge, the Schuylkill River has an estimated seven-day low flow with a recurrence interval of ten years (Q₇₋₁₀) of 99.5 mgd (154 cfs). The ratio of this low flow to the hydraulic design wastewater discharge from the 0.42 mgd WWTP is 237 to 1.

The nearest surface water intake of record for public water supply is located on Schuylkill River approximately 24 River Miles downstream of the docket holder's WWTP and is operated by Pottstown Borough Authority.

The project does not conflict with the Comprehensive Plan and is designed to prevent substantial adverse impact on the water resources related environment, while sustaining the current and future water uses and development of the water resources of the Basin.

The effluent limits in the NPDES Permit are in compliance with Commission effluent quality requirements, where applicable.

The project is designed to produce a discharge meeting the effluent requirements as set forth in the Commission's *Water Quality Regulations (WQR)*.

D-1986-038 CP-4 (Reading Regional Airport Authority, WWTP)

4

C. DECISION

Effective on the approval date for Docket No. D-1986-038 CP-4 below, the project described in Docket No. D-1986-038 CP-3 is removed from the Comprehensive Plan to the extent that they are not included in Docket No. D-1986-038 CP-4; Docket No. D-1986-038 CP-3 is terminated and replaced by Docket No. D-1986-038 CP-4; and the project and the appurtenant facilities described in Section A. DESCRIPTION of this docket shall be continued in the Comprehensive Plan. The project and appurtenant facilities as described in Section A of this docket are approved pursuant to Section 3.8 of the *Compact*, subject to the following conditions

Monitoring and Reporting

1. The docket holder shall comply with the requirements contained in the EFFLUENT TABLES below. The docket holder shall submit the required monitoring results electronically to the DRBC Project Review Section via email aemr@drbc.state.nj.us on the **Annual Effluent Monitoring Report Form** located at this web address: <http://www.state.nj.us/drbc/programs/project/pr/info.html>. The monitoring results shall be submitted annually, absent any observed limit violations, by January 31. If a DRBC effluent limit is violated, the docket holder shall submit the result(s) to the DRBC within 30 days of the violation(s) and provide a written explanation that states the action(s) the docket holder has taken to correct the violation(s) and protect against any future violations. The following average monthly effluent limits are among those listed in the NPDES Permit and meet or are more stringent than the effluent requirements of the DRBC.

EFFLUENT TABLE C-1: DRBC Parameters Included in NPDES Permit

| OUTFALL 001 (Discharging to Schuylkill River) | | |
|-----------------------------------------------|-------------------------------------------------------------------|-----------------------------|
| PARAMETER | LIMIT | MONITORING |
| pH (Standard Units) | 6 to 9 at all times | As required by NPDES Permit |
| Total Suspended Solids | 30 mg/l | As required by NPDES Permit |
| CBOD ₅ (at 20° C) | 25 mg/l | As required by NPDES Permit |
| Ammonia Nitrogen | 20 mg/l | As required by NPDES Permit |
| Fecal Coliform (5-1 to 9-30) | 200 colonies per 100 ml as a geo. avg. | As required by NPDES Permit |
| (10-1 to 4-30) | 2000 colonies per 100 ml as a geo. avg. | |
| Total Dissolved Solids* | 2,605 mg/l (Average Monthly)** 5,210 mg/l (Instantaneous Max.) | As required by NPDES Permit |

* See DECISION Condition C.5.

** DRBC requirement; NPDES Permit does not match the approved DRBC limit value of 2,605 mg/l.

The following monitoring requirements and average monthly effluent limits are for DRBC parameters not listed in the NPDES Permit.

D-1986-038 CP-4 (Reading Regional Airport Authority, WWTP)

5

EFFLUENT TABLE C-2: DRBC Parameters Not Included in NPDES Permit

| OUTFALL 001 (Discharging to Schuylkill River) | | |
|-----------------------------------------------|---------------------------|-------------------------------------------------------------------|
| PARAMETER | LIMIT | MONITORING |
| CBOD ₅ (at 20° C) | Monitor & Report Influent | Monthly, paired with CBOD ₅ effluent monitoring sample |
| CBOD ₅ (at 20° C) | 85% Minimum Removal | Monthly |

Other Conditions

2. Nothing in this docket constitutes a defense to any penalty action for past conduct of the docket holder or ongoing activity not authorized by this approval. In particular, renewal of this docket does not resolve violations – whether in the past or continuing – of provisions of the Delaware River Basin Compact (“Compact”) or any rule, regulation, order or approval duly issued by the Commission or the Executive Director pursuant to the Compact. The Commission reserves its right to take appropriate enforcement action against the docket holder, including but not limited to recovery of financial penalties consistent with Section 14.17 of the Compact, for any and all such prior or continuing violations.

3. Except as otherwise authorized by this docket, if the docket holder seeks relief from any limitation based upon a DRBC water quality standard or minimum treatment requirement, the docket holder shall apply for approval from the Executive Director or for a docket revision in accordance with Section 3.8 of the *Compact* and the *Rules of Practice and Procedure*.

4. The docket holder may request of the Executive Director in writing the substitution of specific conductance for TDS. The request should include information that supports the effluent specific correlation between TDS and specific conductance. Upon review, the Executive Director may modify the docket to allow the substitution of specific conductance for TDS monitoring.

5. The docket holder is responsible for timely submittal to the DRBC of a docket renewal application on the appropriate application form including the appropriate docket application filing fee (see 18 CFR 401.43) at least 6 months in advance of the docket expiration date set forth below. The docket holder will be subject to late filed renewal surcharges in the event of untimely submittal of its renewal application, whether or not DRBC issues a reminder notice in advance of the deadline or the docket holder receives such notice. In the event that a timely and complete application for renewal has been submitted and the DRBC is unable, through no fault of the docket holder, to reissue the docket before the expiration date below, the terms and conditions of the current docket will remain fully effective and enforceable against the docket holder pending the grant or denial of the application for docket approval.

6. The docket holder is permitted to treat and discharge wastewater as set forth in the Area Served Section of this docket, which incorporates by reference Sections B (Type of Discharge) and D (Service Area) of the docket holder’s Application to the extent consistent with all other conditions of this DECISION Section.

7. The docket holder is prohibited from treating/pre-treating any hydraulic fracturing wastewater from sources in or out of the Basin at this time. Should the docket holder wish to

D-1986-038 CP-4 (Reading Regional Airport Authority, WWTP)

6

treat/pre-treat hydraulic fracturing wastewater in the future, the docket holder will need to first apply to the Commission to renew this docket and be issued a revised docket allowing such treatment and an expanded service area. Failure to obtain this approval prior to treatment/pre-treatment will result in action by the Commission.

8. The facility and operational records shall be available at all times for inspection by the DRBC.

9. The facility shall be operated at all times to comply with the requirements of the Commission's WQR.

10. If at any time the receiving treatment plant proves unable to produce an effluent that is consistent with the requirements of this docket approval, no further connections shall be permitted until the deficiency is remedied.

11. Nothing herein shall be construed to exempt the docket holder from obtaining all necessary permits and/or approvals from other State, Federal or local government agencies having jurisdiction over this project.

12. The docket holder shall discharge wastewater in such a manner as to avoid injury or damage to fish or wildlife and shall avoid any injury to public or private property.

13. No sewer service connections shall be made to newly constructed premises with plumbing fixtures and fittings that do not comply with water conservation performance standards contained in Resolution No. 88-2 (Revision 2).

14. The issuance of this docket approval shall not create any private or proprietary rights in the waters of the Basin, and the Commission reserves the right to amend, suspend or rescind the docket for cause, in order to ensure proper control, use and management of the water resources of the Basin.

15. The docket holder shall be subject to applicable DRBC regulatory program fees, in accordance with duly adopted DRBC resolutions and/or regulations (see 18 CFR 401.43).

16. This approval is transferable by request to the DRBC Executive Director provided that the project purpose and area served approved by the Commission in this docket will not be materially altered because of the change in project ownership. The request shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 CFR 401.43).

17. The docket holder shall request a name change of the entity to which this approval is issued if the name of the entity to which this approval is issued changes its name. The request for name change shall be submitted on the appropriate form and be accompanied by the appropriate fee (see 18 CFR 401.43).

18. The Executive Director may modify or suspend this approval or any condition thereof, or require mitigating measures pending additional review, if in the Executive Director's judgment such modification or suspension is required to protect the water resources of the Basin.

D-1986-038 CP-4 (Reading Regional Airport Authority, WWTP)

7

19. Any person who objects to a docket decision by the Commission may request a hearing in accordance with Article 6 of the Rules of Practice and Procedure. In accordance with Section 15.1(p) of the *Delaware River Basin Compact*, cases and controversies arising under the *Compact* are reviewable in the United States district courts.

BY THE COMMISSION

APPROVAL DATE: June 12, 2019

EXPIRATION DATE: June 30, 2025

Attachment E

Correspondence

Spotts, Stevens and McCoy
1047 N. Park Road > P.O. Box 6307 > Reading PA 19610-0307
610.621.2000 > F. 610.621.2001 > SSMGROUP.COM



May 21, 2018

Ms. Bonnie Boylan, Environmental Engineering Specialist
Clean Water Program
Department of Environmental Protection
Southcentral Regional Office
909 Elmerton Avenue
Harrisburg PA 17110-8200

RE: Reading Regional Airport Authority (RRAA)
NPDES Permit Renewal Application
Permit No. PA 0028720
SSM File 108580.0019

Ms. Boylan:

As you are aware, RRAA submitted the NPDES permit renewal application to the PADEP. On February 13, 2018 you responded to an email requesting information pertaining to the NPDES permit renewal and the stormwater outfall locations. We are formally providing a response to the February 13, 2018 email to be included with our original permit renewal application.

1. We included a list of industrial and commercial users for 2017 that were included in the 2017 Chapter 94 report. The list is slightly different from the 2013 customer list that was provided in the NPDES application. Several of the restaurant/nightclubs have closed down and a new restaurant (Klingers) was opened in the Airport terminal building. We have highlighted the changes between the two list to reflect that minimal changes have occurred from 2013 to 2017.
2. No additional influent/effluent sampling was performed that was not already submitted to the PADEP through the monthly reporting and/or the chapter 94 reporting.
3. As per the email, RRAA has sold a 154 acre portion of their property to Berks County Industrial Development Authority. They no longer own nor have access to stormwater outfall locations 002, 003, and 004. We have provided the attached Site Plan that shows the area in which the airport owns and the area in which BCIDA owns. Stormwater locations for 005, 006, 007 and 008 are shown in this figure. Outfall 001 is the NPDES permit outfall location for the wastewater treatment plant. An excerpt of module 1 is provided to show the four remaining outfalls for RRAA.
4. As per the contract operator, Peter Juzyk, Miller Environmental, sampling requirements under the NPDES permit are to be collected as a grab sample during the first 30 minutes but no later than 1 hour of the discharge resulting from a storm event that occurs at least 72 hours from the previously measurable storm event.

Ms. Bonnie Boylan | PADEP
SSM File 108580.0019
May 21, 2018
Page 2 of 2



Sampling at outfalls 003, 006, 007 and 008 had no flow during rain events in 2017 that meet the requirements. Sampling at outfalls 002, 003, 006, 007 and 008 had no flow during rain events in 2016 that meet the above requirements.

5. As per your email we have provided an excerpt from the 3800-PM-BCW0009b form. The industrial user portion was completed for Industrial Metal Plating which is not considered a significant industrial user as it does not supply more than 20% of the WWTP flow.
6. We are also attaching the DRBC docket renewal application that must be submitted to the DRBC by May 31, 2018, one year prior to the May 31, 2019 expiration date.
7. There have been no other changes that we are aware of since the 2013 submission.

Please contact us should you have any questions or require any additional information.

Sincerely,
SSM Group, Inc.


A handwritten signature in black ink, appearing to read "Christina Crawford".

Christina Crawford, PE/MBA
Water and Wastewater Services
christina.crawford@ssmgroup.com

Enclosures

cc: Terry Sroka, Manager – RRAA
Delaware River Basin Commission (included with DRBC Docket Application)

Spotts, Stevens and McCoy
1047 N. Park Road > P.O. Box 6307 > Reading PA 19610-0307
610.621.2000 > F. 610.621.2001 > SSMGROUP.COM



March 17, 2021

Mr. Daniel W. Martin, P.E, Environmental Engineer Manager
Clean Water Program
Department of Environmental Protection
Southcentral Regional Office
909 Elmerton Avenue
Harrisburg PA 17110-8200
[Via Email: danielmarti@pa.gov]

RE: Reading Regional Airport Authority (RRAA)
NPDES Permit Renewal Application – Stormwater Permitting
Permit No. PA 0028720
SSM File 108580.2021

Dear Mr. Martin:

We are writing in response to your March 2, 2021 correspondence relative to the Reading Regional Airport Authority (RRAA), Berks County, and the *NPDES Permit Renewal Application* to the Department. The *NPDES Permit Renewal* has been under Technical Review by the Department since October 31, 2013. In 2018, we provided supplemental information to the Department relative to the stormwater outfall locations.

In this supplemental information, we had provided an update to the Department relative to the Berks County Industrial Development Authority (BCIDA) and the purchase of a 154-acre property from the RRAA. Due to the sale and development of this property, the RRAA no longer has access to the Stormwater Outfalls previously labelled Outfall 003 and Outfall 004, or no longer feel that these Outfalls are representative of the RRAA stormwater discharge. Attached is a Site Plan showing the delineation of the RRAA ownership as well as the BCIDA ownership.

In the Department's March 2021 correspondence, the Department has requested additional information in response to new federal regulations as well as the sale of the property to the BCIDA. This correspondence is updated information in response to the Department's request:

- (1) Are there dry weather discharges from the airport runway areas? If so, a) what activities generate these discharges and what are the "known or believed present" parameters in the discharges? b) are there any sampling results for dry weather discharges from the airport runway areas to add to the permit application? c) where do these discharges leave the airport's property (specific outfall numbers or latitude and longitude locations)?
 - a. *No, there are no dry weather discharges. The only washing that occurs is within the hangar buildings, which have floor drains that discharge to the Authority's Wastewater Treatment Plant (WWTP).*
 - b. *Not applicable – there are no dry weather discharges.*

Mr. Daniel Martin | PADEP
SSM File 108580.2021
March 18, 2021
Page 2 of 3



c. The Outfall latitude and longitude locations are provided in the attached Outfall Location Map.

- (2) Are their discharges subject to the federal Effluent Limitation Guidelines for Airport Deicing, 40 CFR 449, discharges from de-icing operations at “Primary Airports”? “Primary airport” is defined in 49 U.S. Code 47102 as a commercial service airport with more than 10,000 passenger boardings each year.

There are no discharges subject to federal Effluent Limitation Guidelines for Airport Deicing for operations at “Primary Airports.” This item is not applicable, as this facility is not considered a Primary Airport; there are currently about 1,544 passengers boarding per year, and all passengers are by way of Chartered flights. There is minimal commercial flights, again by way of Charter only. The Reading Regional Airport Authority does not have scheduled airline services.

- (3) Are there less than 1000 annual non-propeller aircraft departures at this airport? ‘Annual non-propeller aircraft departures’ means the average number of commercial turbine-engine aircraft that are propelled by jet, i.e., turbojet or turbofan, that take off from an airport on an annual basis, as tabulated by the Federal Aviation Administration (FAA).

The only commercial, turbine-engine aircraft departures are by Southwest Airlines for “seasonal” Charters, which average about 10 to 15 departures per year. The only other aircraft departures with jets (turbojet or turbofan) are private or corporate-owned.

- (4) Is area used for de-icing operations or will it be used during the next five years? If so, where do these discharges leave the airport’s property (specific outfall numbers or latitude and longitude locations)?

Yes, there are several locations within the RRAA property containing de-icing operations. The de-icing locations are depicted in the attached Outfall Location Map, as well as the attached Stormwater Module. The only Stormwater Outfalls not affected by de-icing contributions are Outfalls 006 and 008, per the attached.

- (5) Please submit a drainage map for the stormwater leaving the property with current outfalls shown and with proposed sampling locations shown for stormwater since the sale of a portion of the property to Berks County Industrial Development Authority (BCIDA). If former outfalls 002, 003, and 004 are no longer on airport property but there is still stormwater runoff from the runways, taxiways, hangars, fuel storage tanks, treatment plant area, etc., more appropriate monitoring locations would be before the stormwater leaves the airport property, whether it is monitoring from storm drains or monitoring of runoff. For each proposed sampling location other than outfalls 005, 006, and 008, please provide the latitude and longitude. For outfall 007, please also provide the latitude and longitude. (The latitude and longitude for outfall 007 in Part C of the 2009 NPDES permit does not match the map submitted to DEP by SSM consultants in May 2018 and may need to be corrected.)

A drainage map depicting each of the Authority’s Stormwater Outfalls and the associated drainage areas for each Outfall are attached herein for the Department’s use and reference. Outfall 002 will remain, as there is very little contribution from the BCIDA property. The RRAA will obtain permission from the BCIDA to continue sampling at this location. Outfalls 003 and 004 are being relocated (see attached Outfall Location Map) in order to move the Outfalls upstream from the BCIDA property as much as possible and to avoid any drainage from the BCIDA site. The latitude

Mr. Daniel Martin | PADEP
SSM File 108580.2021
March 18, 2021
Page 3 of 3



and longitude coordinates for each of the Stormwater Outfalls is also contained in the attached Mapping. The BCIDA has also added Outfall 009, as provided herein.

- (6) Alternatively, if the airport proposes to continue using outfalls 002, 003, and 004 for monitoring of stormwater generated on the airport's property, a) it would need to have BCIDA's permission to access the stormwater outfalls and b) stormwater generated on BCIDA's property should not be mingled with the airport's stormwater. If BCIDA generates 'stormwater associated with industrial activity' now or in the future, they will be required to have their own NPDES permit for stormwater.

As stated above, Outfall 002 will remain in the same sampling location, and RRAA will obtain permission to continue sampling at this location. Outfalls 003 and 004 are being relocated to the Headwalls upstream of the BCIDA Property, as shown in the attachments.

- (7) Are there any changes to the previously submitted permit application, other than the sale of a portion of the property to BCIDA?

All revisions to the existing NPDES Permit Application have already been provided to the Department.

Please contact us should you have any questions or require any additional information.

Sincerely,
Spotts, Stevens and McCoy

A handwritten signature in black ink that reads "Jamie D. Lorah".

Jamie D. Lorah, P.E.
Manager, Process Engineering
jamie.lorah@ssmgroup.com

Enclosures

cc: Terry Sroka, Manager – RRAA
Bonnie Boylan, PA DEP [Via Email: bboylan@pa.gov]