

Northwest Regional Office
CLEAN WATER PROGRAM

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0028941
APS ID 1087669
Authorization ID 1438270

Applicant and Facility Information

| | | | |
|---------------------------|--|------------------|-------------------------------|
| Applicant Name | <u>Evans City Water & Sewer Authority</u> | Facility Name | <u>Evans City Borough STP</u> |
| Applicant Address | 216 Wahl Avenue | Facility Address | 220 Wahl Avenue |
| | Evans City, PA 16033-1053 | | Evans City, PA 16033-1053 |
| Applicant Contact | Martin Fabian | Facility Contact | |
| Applicant Phone | (724) 432-3428 | Facility Phone | (724) 538-8320 |
| Client ID | 275331 | Site ID | 628273 |
| Ch 94 Load Status | Not Overloaded | Municipality | Evans City Borough |
| Connection Status | No Limitations | County | Butler |
| Date Application Received | <u>April 20, 2023</u> | EPA Waived? | Yes |
| Date Application Accepted | | If No, Reason | |
| Purpose of Application | NPDES Renewal of a municipal sewage treatment plant (STP). | | |

Summary of Review

This is a renewal of an existing treated sewage discharge from a municipal sewage treatment plant (STP).

Act 14 – Proof of Notification was submitted and received.

Treatment consists of (WQM Permit No. 1072405 T-1): Comminutor with a bypass bar screen, (2) Circular Contact Stabilization Tanks (aeration, reaeration and aerobic digestion compartments and an 'inner ring' clarifier), Chemical feed system (for phosphorus control), Chlorination/Dechlorination & (4) Sludge Drying Beds.

The EPA Waiver is in effect.

There are 2 open violations in WMS for the subject Client ID (275331) as of 6/25/2025, but both are under Safe Drinking Water.

A compliance schedule for meeting the proposed Total Copper effluent limits has been included in the draft permit.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Approve | Deny | Signatures | Date |
|---------|------|---|--------------|
| X | | Jordan A. Frey, E.I.T. Jordan A. Frey, E.I.T. / Project Manager | July 2, 2025 |
| X | | Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager | July 3, 2025 |

Discharge, Receiving Waters and Water Supply Information

| | | | |
|---|------------------------------------|------------------------------|--|
| Outfall No. | 001 | Design Flow (MGD) | .85 |
| Latitude | 40° 46' 22.41" | Longitude | -80° 4' 12.20" |
| Quad Name | Evans City | Quad Code | 40080G1 |
| Wastewater Description: Sewage Effluent | | | |
| Receiving Waters | Breakneck Creek (WWF) | Stream Code | 35016 |
| NHD Com ID | 126218634 | RMI | |
| Drainage Area | 34.4 | Yield (cfs/mi ²) | 0.018 |
| Q ₇₋₁₀ Flow (cfs) | 0.62 | Q ₇₋₁₀ Basis | Streamstats |
| Elevation (ft) | 939 | Slope (ft/ft) | --- |
| Watershed No. | 20-C | Chapter 93 Class. | WWF |
| Existing Use | --- | Existing Use Qualifier | --- |
| Exceptions to Use | --- | Exceptions to Criteria | --- |
| Assessment Status | Impaired | | |
| Cause(s) of Impairment | CAUSE UNKNOWN, SILTATION | | |
| Source(s) of Impairment | DAM OR IMPOUNDMENT, SOURCE UNKNOWN | | |
| TMDL Status | Name _____ | | |
| Background/Ambient Data | | | |
| pH (SU) | 7.3 | Data Source | 9/89 TMDL/WLA Report for Breakneck Creek |
| Temperature (°F) | 25 | | Default |
| Hardness (mg/L) | 100 | | Default |
| Other: NH ₃ -N (mg/L) | 0.1 | | Default |
| Nearest Downstream Public Water Supply Intake | | | |
| PWS Waters | Beaver River | Flow at Intake (cfs) | 520 |
| PWS RMI | --- | Distance from Outfall (mi) | >25 |

Changes Since Last Permit Issuance: None

Other Comments: None

| Treatment Facility Summary | | | | |
|--|----------------------------|--|---------------------|------------------------|
| Treatment Facility Name: Evans City Water & Sewer Authority | | | | |
| WQM Permit No. | Issuance Date | | | |
| 1072405 T-1 | 2/21/2013 | | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Tertiary | Sequencing Batch Reactor W/Sol Removal | Ultraviolet | 0.85 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.85 | 1872 | Not Overloaded | Aerobic Digestion | Landfill |

Changes Since Last Permit Issuance: None.

Other Comments: Automated Bar Screen and Grit Removal, (2) Sequential Batch Reactors and UV disinfection. Sludge handling via an aerated sludge holding tank.

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 46' 23.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .85
Longitude -80° 4' 11.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| E. Coli | Report | IMAX | | 92a.61 |

Comments: E. Coli monitoring is based on the Department's SOP for new and reissued permits

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

| Parameter | Limit (mg/l) | SBC | Model |
|--------------------------------|--------------|-----------------|---|
| CBOD ₅ | 5.24 | Average Monthly | WQM 7.0 - DO/NH ₃ -N toxicity model |
| NH ₃ -N (5/1-10/31) | 1.6 | Average Monthly | WQM 7.0 - DO/NH ₃ -N toxicity model |
| NH ₃ -N (11/1-4/30) | 4.8 | Average Monthly | WQM 7.0 - DO/NH ₃ -N toxicity model |
| Phosphorus | 2 | Average Monthly | Stream Enrichment Risk Analysis (SERA) study on Conn. Ck. |
| Total Copper | 0.019 | Average Monthly | Toxics Management Spreadsheet |
| Total Zinc | Report | Average Monthly | Toxics Management Spreadsheet |

Comments: Ammonia-Nitrogen limits calculated by WQM were more stringent than existing limits, yielding the above limits in the table and shall be applied to this permit. Based on DMR data, the facility can currently meet these limits.

Previous permit renewals included seasonal limitations for CBOD₅. The Department no longer imposes seasonal limitations and water quality-based effluent limitations for CBOD₅ are imposed year-round. The WQM 7.0 model was evaluated due to the updated Ammonia-Nitrogen criteria resulting in an average monthly effluent limitation of 5.24 mg/l for CBOD₅. This effluent limitation will be imposed year-round. Based on DMR data, the facility can currently meet this limit.

The Toxics Management Spreadsheet determined a reasonable potential for Total Copper and Total Zinc based on the application sampling. The reported Total Copper concentration is greater than 50% of the calculated WQBEL so an effluent limitation with a 3-year compliance schedule will be included in the permit. The reported Total Zinc concentration is greater than 10% of the calculated WQBEL so monitoring only will be included in the permit.

Best Professional Judgment (BPJ) Limitations

| Parameter | Limit (mg/l) | SBC | Basis |
|--|---------------------------------|-----------------|-----------|
| Dissolved Oxygen | 4 | Inst. Min. | Dept. SOP |
| Total Nitrogen | Monitor & Report | Average Monthly | Dept. SOP |
| BOD5 influent | Monitor & Report (conc. & mass) | Average Monthly | Dept. SOP |
| TSS influent | Monitor & Report (conc. & mass) | Average Monthly | Dept. SOP |
| UV intensity ($\mu\text{W}/\text{cm}^2$) | Monitor & Report | Average Monthly | Dept. SOP |

Anti-Backsliding

N/A

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: July 1, 2028 through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--------------|-------------------------------------|-------------------|-----------------------|-----------------|--------------------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | | |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| Total Copper | 0.13 | 0.20 Daily Max | XXX | 0.019 | 0.028 Daily Max | 0.047 | 1/week | 24-Hr Composite |

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: None.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through June 30, 2028.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--------------|-------------------------------------|------------------|-----------------------|-----------------|------------------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Total Copper | Report | Report Daily Max | XXX | Report | Report Daily Max | XXX | 1/week | 24-Hr Composite |

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: None.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|--|-------------------------------------|----------------|-----------------------|-----------------|----------------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Flow (MGD) | Report | Report | XXX | XXX | XXX | XXX | Continuous | Measured |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 4.0 Inst Min | XXX | XXX | XXX | 1/day | Grab |
| CBOD5 | 38 | 57 | XXX | 5.3 | 8.0 | 10.6 | 1/week | 24-Hr Composite |
| BOD5 | | | | | | | | 24-Hr Composite |
| Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 1/week | Composite |
| TSS | 213 | 319 | XXX | 30 | 45 | 60 | 1/week | 24-Hr Composite |
| TSS | | | | | | | | 24-Hr Composite |
| Raw Sewage Influent | Report | XXX | XXX | Report | XXX | XXX | 1/week | Composite |
| Fecal Coliform (No./100 ml) | | | | 2000 | | | | |
| Oct 1 - Apr 30 | XXX | XXX | XXX | Geo Mean | XXX | 10000 | 1/week | Grab |
| Fecal Coliform (No./100 ml) | | | | 200 | | | | |
| May 1 - Sep 30 | XXX | XXX | XXX | Geo Mean | XXX | 1000 | 1/week | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | XXX | XXX | Report | 1/quarter | Grab |
| UV Intensity (μ w/cm ²) | XXX | XXX | XXX | Report | XXX | XXX | 1/day | Measured |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | XXX | 1/week | 24-Hr Composite |
| Ammonia | | | | | | | | 24-Hr Composite |
| Nov 1 - Apr 30 | 34 | XXX | XXX | 4.8 | XXX | 9.6 | 1/week | |

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|---------------------------|-------------------------------------|----------------|-----------------------|-----------------|----------------|------------------|---|----------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Weekly Average | Minimum | Average Monthly | Weekly Average | Instant. Maximum | | |
| Ammonia May 1 - Oct 31 | 11.3 | XXX | XXX | 1.6 | XXX | 3.2 | 1/week | 24-Hr Composite |
| Total Phosphorus | 14.2 | XXX | XXX | 2 | XXX | 4 | 1/week | 24-Hr Composite |
| Total Zinc | Report | Report | XXX | Report | Report | XXX | 1/week | 24-Hr Composite |

Compliance Sampling Location: Outfall 001, after disinfection.

Other Comments: None.

Compliance History

DMR Data for Outfall 001 (from April 1, 2023 to March 31, 2024)


| Parameter | MAR-24 | FEB-24 | JAN-24 | DEC-23 | NOV-23 | OCT-23 | SEP-23 | AUG-23 | JUL-23 | JUN-23 | MAY-23 | APR-23 |
|---|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.513 | 0.402 | 0.833 | 0.363 | 0.275 | 0.404 | 0.404 | 0.270 | 0.495 | 0.365 | 0.476 | 0.574 |
| Flow (MGD) Weekly Average | 0.566 | 0.546 | 1.209 | 0.689 | 0.380 | 0.450 | 0.467 | 0.357 | 0.525 | 0.460 | 0.782 | 0.618 |
| pH (S.U.) Instantaneous Minimum | 6.70 | 6.65 | 6.72 | 6.9 | 6.87 | 6.92 | 6.85 | 6.86 | 6.8 | 6.98 | 7.0 | 6.9 |
| pH (S.U.) Instantaneous Maximum | 7.02 | 6.82 | 6.94 | 7.0 | 7.56 | 7.13 | 7.47 | 7.39 | 7.1 | 7.33 | 7.16 | 7.2 |
| DO (mg/L) Instantaneous Minimum | 7.74 | 7.59 | 6.99 | 6.85 | 5.86 | 5.27 | 7.07 | 6.28 | 6.99 | 7.01 | 7.8 | 8.91 |
| CBOD5 (lbs/day) Average Monthly | 12.84 | 10.1 | 21.54 | 11.7 | 7.6 | 12.67 | 10.88 | 6.8 | 12.4 | 9.7 | 11.9 | 14.4 |
| CBOD5 (lbs/day) Weekly Average | 14.16 | 13.7 | 30.25 | 29.3 | 10.5 | 11.26 | 15.19 | 8.9 | 13.1 | 14.2 | 19.6 | 15.5 |
| CBOD5 (mg/L) Average Monthly | 3 | 3 | 3.1 | 3.85 | 3.3 | 3.76 | 3.23 | 3 | 3 | 3.2 | 3 | 3 |
| CBOD5 (mg/L) Weekly Average | 3 | 3 | 3 | 5.1 | 3.3 | 3 | 3.9 | 3 | 3 | 3.7 | 3 | 3 |
| BOD5 (lbs/day) Raw Sewage Influent Average Monthly | 771.19 | 704 | 856.59 | 625.2 | 540.3 | 637.69 | 579.53 | 205.4 | 342.03 | 596.6 | 312.35 | 685.0 |
| BOD5 (mg/L) Raw Sewage Influent Average Monthly | 180.25 | 210.0 | 123.3 | 206.5 | 235.6 | 189.26 | 172 | 91.2 | 82.85 | 196.3 | 78.68 | 143.1 |
| TSS (lbs/day) Average Monthly | 12.84 | 10.1 | 26.4 | 27.2 | 9.2 | 23.58 | 245.96 | 6.8 | 12.4 | 25.3 | 11.9 | 14.4 |
| TSS (lbs/day) Raw Sewage Influent Average Monthly | 564.75 | 476.1 | 534.94 | 480.8 | 429.6 | 526.96 | 538.26 | 292.7 | 398.38 | 332.7 | 425.57 | 461.0 |
| TSS (lbs/day) Weekly Average | 14.16 | 13.7 | 30.25 | 91.9 | 9.5 | 15.01 | 284.32 | 8.9 | 13.1 | 84.4 | 19.6 | 15.5 |

NPDES Permit Fact Sheet
Evans City Borough STP


NPDES Permit No. PA0028941

| | | | | | | | | | | | | |
|---|------|------|------|-------|-------|-------|--------|-------|------|-------|-------|-------|
| TSS (mg/L) Average Monthly | 3 | 3 | 3.8 | 9 | 4 | 7 | 73 | 3 | 3 | 8.3 | 3 | 3 |
| TSS (mg/L) Raw Sewage Influent Average Monthly | 132 | 142 | 77 | 158.8 | 187.3 | 156.4 | 159.75 | 130.0 | 96.5 | 109.3 | 107.2 | 96.3 |
| TSS (mg/L) Weekly Average | 3 | 3 | 3 | 16 | 4 | 4 | 73 | 3 | 3 | 22.0 | 3 | 3 |
| Fecal Coliform (No./100 ml) Geometric Mean | 2.78 | 1 | 1.32 | 2.34 | 1.2 | 1.89 | 32.96 | 26.7 | 13.3 | 183.4 | 31.2 | 11.49 |
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 12 | 1 | 4 | 15 | 2 | 4 | 276 | 462 | 205 | 550.0 | 366 | 91 |
| UV Intensity (μw/cm ²) Average Monthly | 74 | 78 | 78 | 82 | 77 | 75 | 74 | 74 | 78 | 78 | 74 | 76 |
| Total Nitrogen (mg/L) Average Monthly | 1.46 | 1.6 | 1.83 | 3.52 | 1.64 | 1.71 | 3.65 | 2.03 | 1.2 | 2.4 | 1.8 | 1.34 |
| Ammonia (lbs/day) Average Monthly | 0.47 | 0.6 | 0.97 | 2.27 | 0.37 | 0.47 | 0.81 | 0.25 | 0.54 | 0.3 | 0.48 | 0.53 |
| Ammonia (mg/L) Average Monthly | 0.11 | 0.18 | 0.14 | 0.75 | 0.16 | 0.14 | 0.24 | 0.11 | 0.13 | 0.1 | 0.12 | 0.11 |
| Total Phosphorus (lbs/day) Average Monthly | 6.16 | 2.31 | 4.65 | 3.45 | 2.9 | 4.99 | 5.12 | 3.2 | 4.08 | 5.5 | 4.49 | 8.0 |
| Total Phosphorus (mg/L) Average Monthly | 1.44 | 0.69 | 0.67 | 1.14 | 1.27 | 1.48 | 1.52 | 1.40 | 0.99 | 1.8 | 1.13 | 1.68 |

Attachment 1
eMap – Location Map



Attachment 2
Google Earth Imagery



Attachment 3
Toxics Management Spreadsheet



Toxics Management Spreadsheet
Version 1.4, May 2023

Discharge Information

Instructions **Discharge** Stream

Facility: Evans City Borough STP NPDES Permit No.: PA0028941 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Sewage

| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Discharge Characteristics | | | | | |
|-----------------------|------------------|----------|----------------------------|-----|-----|--------------------------|-------------------|----------------|
| | | | Partial Mix Factors (PMFs) | | | Complete Mix Times (min) | | |
| | | | AFC | CFC | THH | CRL | Q ₇₋₁₀ | Q _h |
| 0.85 | 100 | 7.1 | | | | | | |

| | | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | 1 if left blank | | | | | |
|---------|---------------------------------|---------------------|-------|--------------------|-----------|-----------------|----------|-----------------|------------|------------|-----|---------------|-------------|
| | | Discharge Pollutant | Units | Max Discharge Conc | Trib Conc | Stream Conc | Daily CV | Hourly CV | Strea m CV | Fate Coeff | FOS | Criteri a Mod | Chem Transl |
| Group 1 | Total Dissolved Solids (PWS) | mg/L | | 662 | | | | | | | | | |
| | Chloride (PWS) | mg/L | | 295 | | | | | | | | | |
| | Bromide | mg/L | | 0.1 | | | | | | | | | |
| | Sulfate (PWS) | mg/L | | 79.8 | | | | | | | | | |
| | Fluoride (PWS) | mg/L | | | | | | | | | | | |
| Group 2 | Total Aluminum | µg/L | | | | | | | | | | | |
| | Total Antimony | µg/L | | | | | | | | | | | |
| | Total Arsenic | µg/L | | | | | | | | | | | |
| | Total Barium | µg/L | | | | | | | | | | | |
| | Total Beryllium | µg/L | | | | | | | | | | | |
| | Total Boron | µg/L | | | | | | | | | | | |
| | Total Cadmium | µg/L | | | | | | | | | | | |
| | Total Chromium (III) | µg/L | | | | | | | | | | | |
| | Hexavalent Chromium | µg/L | | | | | | | | | | | |
| | Total Cobalt | µg/L | | | | | | | | | | | |
| | Total Copper | mg/L | | 0.018 | | | | | | | | | |
| | Free Cyanide | µg/L | | | | | | | | | | | |
| | Total Cyanide | µg/L | | | | | | | | | | | |
| | Dissolved Iron | µg/L | | | | | | | | | | | |
| | Total Iron | µg/L | | | | | | | | | | | |
| | Total Lead | µg/L | < | 1 | | | | | | | | | |
| | Total Manganese | µg/L | | | | | | | | | | | |
| | Total Mercury | µg/L | | | | | | | | | | | |
| | Total Nickel | µg/L | | | | | | | | | | | |
| | Total Phenols (Phenolics) (PWS) | µg/L | | | | | | | | | | | |
| | Total Selenium | µg/L | | | | | | | | | | | |
| | Total Silver | µg/L | | | | | | | | | | | |
| | Total Thallium | µg/L | | | | | | | | | | | |
| | Total Zinc | mg/L | | 0.0396 | | | | | | | | | |
| | Total Molybdenum | µg/L | | | | | | | | | | | |
| Group 3 | Acrolein | µg/L | < | | | | | | | | | | |
| | Acrylamide | µg/L | < | | | | | | | | | | |
| | Acrylonitrile | µg/L | < | | | | | | | | | | |
| | Benzene | µg/L | < | | | | | | | | | | |
| | Bromoform | µg/L | < | | | | | | | | | | |



Stream / Surface Water Information

Evans City Borough STP, NPDES Permit No. PA0028941, Outfall 001

Instructions **Discharge** Stream

Receiving Surface Water Name: **Breakneck Creek**

No. Reaches to Model: **1**

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 035016 | 2.55 | 926 | 34.02 | | | Yes |
| End of Reach 1 | 035016 | 0.01 | 903 | 42.6 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 2.55 | 0.043 | | | | | | | | | | 100 | 7 | | |
| End of Reach 1 | 0.01 | 0.043 | | | | | | | | | | | | | |

Q_h

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 2.55 | | | | | | | | | | | | | | |
| End of Reach 1 | 0.01 | | | | | | | | | | | | | | |



Model Results

Evans City Borough STP, NPDES Permit No. PA0028941, Outfall 001

Instructions **Results** [RETURN TO INPUTS](#) [SAVE AS PDF](#) [PRINT](#) All Inputs Results Limits

Hydrodynamics

Wasteload Allocations

AFC

CCT (min): 14.102

PMF: 1

Analysis Hardness (mg/l): 100

Analysis pH: 7.04

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | 13.439 | 14.0 | 29.6 | Chem Translator of 0.96 applied |
| Total Lead | 0 | 0 | | 0 | 64.581 | 81.6 | 172 | Chem Translator of 0.791 applied |
| Total Zinc | 0 | 0 | | 0 | 117.180 | 120 | 253 | Chem Translator of 0.978 applied |

CFC

CCT (min): 14.102

PMF: 1

Analysis Hardness (mg/l): 100

Analysis pH: 7.04

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | 8.956 | 9.33 | 19.7 | Chem Translator of 0.96 applied |
| Total Lead | 0 | 0 | | 0 | 2.517 | 3.18 | 6.72 | Chem Translator of 0.791 applied |
| Total Zinc | 0 | 0 | | 0 | 118.139 | 120 | 253 | Chem Translator of 0.986 applied |

THH

CCT (min): 14.102

PMF: 1

Analysis Hardness (mg/l): N/A

Analysis pH: N/A

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |

| | | | | | | | | |
|--------------|---|---|----------|---|-----|-----|-----|--|
| Total Copper | 0 | 0 | ████████ | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | ████████ | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | ████████ | 0 | N/A | N/A | N/A | |

CRL

CCT (min): 15.522

PMF: 1

Analysis Hardness (mg/l):

N/A

Analysis pH: N/A

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | ████████ | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | ████████ | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | ████████ | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | ████████ | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | ████████ | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | ████████ | 0 | N/A | N/A | N/A | |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month: 4

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|--------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Copper | 0.13 | 0.21 | 0.019 | 0.03 | 0.047 | mg/L | 0.019 | AFC | Discharge Conc ≥ 50% WQBEL (RP) |
| Total Zinc | Report | Report | Report | Report | Report | mg/L | 0.16 | AFC | Discharge Conc > 10% WQBEL (no RP) |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|------------------------------|-----------------|-------|----------------------|
| Total Dissolved Solids (PWS) | N/A | N/A | PWS Not Applicable |
| Chloride (PWS) | N/A | N/A | PWS Not Applicable |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | N/A | N/A | PWS Not Applicable |
| Total Lead | N/A | N/A | Discharge Conc < TQL |

**Attachment 4
WQM 7.0 Model**

WQM 7.0 Wasteload Allocations

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | | | |
|-------------------------------------|--------------------|---------------------------|---------------------|---------------------------|---------------------|-------------------------|-------------------|
| 20C | 35016 | BREAKNECK CREEK | | | | | |
| NH3-N Acute Allocations | | | | | | | |
| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
| 2.550 | Evans City STP | 8.57 | 11.1 | 8.57 | 11.1 | 1 | 0 |
| NH3-N Chronic Allocations | | | | | | | |
| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
| 2.550 | Evans City STP | 1.58 | 2.51 | 1.58 | 2.51 | 0 | 0 |
| Dissolved Oxygen Allocations | | | | | | | |
| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | |
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) |
| 2.55 | Evans City STP | 5.24 | 5.24 | 1.57 | 1.57 | 4 | 4 |
| | | | | | | 0 | 0 |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | |
|---------------------------------|-----------------------------------|----------------------------------|-----------------------------|----------------|
| 20C | 35016 | BREAKNECK CREEK | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | <u>Analysis pH</u> | |
| 2.550 | 0.850 | 21.589 | 7.075 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | <u>Reach Velocity (fps)</u> | |
| 24.811 | 0.608 | 40.810 | 0.128 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | <u>Reach Kn (1/days)</u> | |
| 4.21 | 0.258 | 1.11 | 1.582 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | <u>Reach DO Goal (mg/L)</u> | |
| 5.125 | 2.162 | Tsivoglou | 5 | |
| <u>Reach Travel Time (days)</u> | Subreach Results | | | |
| 1.215 | TravTime (days) | CBOD5 (mg/L) | NH3-N (mg/L) | D.O. (mg/L) |
| | 0.121 | 4.07 | 0.91 | 5.04 |
| | 0.243 | 3.94 | 0.75 | 5.11 |
| | 0.364 | 3.81 | 0.62 | 5.29 |
| | 0.486 | 3.68 | 0.51 | 5.52 |
| | 0.607 | 3.56 | 0.42 | 5.78 |
| | 0.729 | 3.44 | 0.35 | 6.05 |
| | 0.850 | 3.33 | 0.29 | 6.31 |
| | 0.972 | 3.22 | 0.24 | 6.56 |
| | 1.093 | 3.11 | 0.20 | 6.79 |
| | 1.215 | 3.01 | 0.16 | 7.01 |

| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
|-------|----------------|---------------|-----------------|------------------|--------------------------------|----------------------------|----------------------------|
| 2.550 | Evans City STP | PA0028941 | 0.850 | CBOD5 | 5.24 | | |
| | | | | NH3-N | 1.57 | 3.14 | |
| | | | | Dissolved Oxygen | | | 4 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC | | | | |
|-----------------------|------------------|--------------------|-----------------------------|------------------------------|---------------------------|----------------|----------------------|-------------------------------------|------------------------|---------------------|-----------------------|-----------------------|
| | | | (ft) | (ft) | (sq mi) | (ft/ft) | (mgd) | | | | | |
| 20C | 35016 | BREAKNECK CREEK | 2.550 | 926.00 | 34.02 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> | | | | |
| Stream Data | | | | | | | | | | | | |
| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
| Q7-10 | 0.018 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.30 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Discharge Data | | | | | | | | | Disc Temp (°C) | Disc pH | | |
| | Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | | | | | | |
| | Evans City STP | PA0028941 | 0.8500 | 0.8500 | 0.8500 | 0.000 | | | 20.00 | 7.00 | | |
| Parameter Data | | | | | | | | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
| | Parameter Name | | | | | | | | | | | |
| | CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | | | | | |
| | Dissolved Oxygen | | 4.00 | 7.54 | 0.00 | 0.00 | | | | | | |
| | NH3-N | | 25.00 | 0.10 | 0.00 | 1.40 | | | | | | |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation | Drainage Area | Slope | PWS Withdrawal | Apply FC | | | | |
|-----------------------|------------------|--------------------|-----------------------------|------------------------------|---------------------------|----------------|-------------------|-------------------------------------|------------------------|---------------------|-----------------------|-----------------------|
| | | | (ft) | (sq mi) | (ft/ft) | (mgd) | | | | | | |
| 20C | 35016 | BREAKNECK CREEK | 0.010 | 903.00 | 42.60 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> | | | | |
| Stream Data | | | | | | | | | | | | |
| Design Cond. | LFY (cfsm) | Trib Flow (cfs) | Stream Flow (cfs) | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | pH | Stream Temp (°C) | pH |
| Q7-10 | 0.018 | 0.00 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 25.00 | 7.30 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Discharge Data | | | | | | | | | Disc Temp (°C) | Disc pH | | |
| | Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | | | | | | |
| | | | 0.0000 | 0.0000 | 0.0000 | 0.000 | | | 0.00 | 7.00 | | |
| Parameter Data | | | | | | | | | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
| | Parameter Name | | | | | | | | | | | |
| | CBOD5 | | 25.00 | 2.00 | 0.00 | 1.50 | | | | | | |
| | Dissolved Oxygen | | 3.00 | 8.24 | 0.00 | 0.00 | | | | | | |
| | NH3-N | | 25.00 | 0.00 | 0.00 | 1.40 | | | | | | |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | | <u>Stream Code</u> | | <u>Stream Name</u> | | | | | | | | |
|--------------------|-------------|----------|--------------------|--------------------|--------------------|-------|-------|-----------|----------|-----------------|---------------|-------------|--|
| 20C | | | 35016 | | BREAKNECK CREEK | | | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH | |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | | |
| Q7-10 Flow | | | | | | | | | | | | | |
| 2.550 | 0.61 | 0.00 | 0.61 | 1.3149 | 0.00171 | .608 | 24.81 | 40.81 | 0.13 | 1.215 | 21.59 | 7.07 | |
| Q1-10 Flow | | | | | | | | | | | | | |
| 2.550 | 0.39 | 0.00 | 0.39 | 1.3149 | 0.00171 | NA | NA | NA | 0.12 | 1.300 | 21.15 | 7.05 | |
| Q30-10 Flow | | | | | | | | | | | | | |
| 2.550 | 0.83 | 0.00 | 0.83 | 1.3149 | 0.00171 | NA | NA | NA | 0.14 | 1.143 | 21.94 | 7.09 | |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 5 | | |