

Application Type  
Facility Type  
Major / Minor

Renewal  
Municipal  
Major

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. **PA0029122**  
APS ID **1118427**  
Authorization ID **1493361**

**Applicant and Facility Information**

Applicant Name	<b>Saxonburg Area Authority</b>	Facility Name	<b>Saxonburg Area Authority STP</b>
Applicant Address	420 W Main Street Saxonburg, PA 16056-9517	Facility Address	161 Renfrew Road Renfrew, PA 16053-9729
Applicant Contact	Paul Cornetti	Facility Contact	Paul Cornetti
Applicant Phone	(724) 352-1400	Facility Phone	(724) 352-1400
Client ID	34547	Site ID	657024
Ch 94 Load Status	Not Overloaded	Municipality	Saxonburg Borough
Connection Status	No Limitations	County	Butler
Date Application Received	July 15, 2024	EPA Waived?	No
Date Application Accepted	July 15, 2024	If No, Reason	Major Facility
Purpose of Application	NPDES Permit Renewal.		

**Summary of Review**

Saxonburg Area Authority (Saxonburg) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on January 23, 2020 and became effective on February 1, 2020. The permit expired on January 31, 2025 but the terms and conditions of the permit have been extended since that time.

Based on the review, it is recommended that the permit be drafted.

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jinsu Kim Jinsu Kim / Environmental Engineering Specialist	September 11, 2025
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	September 23, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	2.052
Latitude	40° 48' 24.0"	Longitude	-79° 57' 24.0"
Quad Name		Quad Code	
Wastewater Description:	Sewage Effluent		
Receiving Waters	Connoquenessing Creek (WWF)	Stream Code	34025
NHD Com ID	126217651	RMI	39.26
Drainage Area	136	Yield (cfs/mi <sup>2</sup> )	0.06
Q <sub>7-10</sub> Flow (cfs)	8.65	Q <sub>7-10</sub> Basis	See below
Elevation (ft)	982	Slope (ft/ft)	0.001167
Watershed No.	20-C	Chapter 93 Class.	WWF
Existing Use	none	Existing Use Qualifier	none
Exceptions to Use	none	Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	ORGANIC ENRICHMENT		
Source(s) of Impairment	AGRICULTURE		
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Beaver Falls Municipal Authority - Eastvale Plant		
PWS Waters	Beaver River	Flow at Intake (cfs)	561
PWS RMI	3.5	Distance from Outfall (mi)	46

### Drainage Area

The discharge is to Connoquenessing Creek at RM 39.26. A drainage area upstream of the discharge point is estimated to be 136 sq.mi. according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

### Streamflow

USGS StreamStats produced a Q<sub>7-10</sub> flow of 3.56 cfs at the point of discharge. However, based on the fact sheet developed for the last permit renewal, a minimum release from PA American Water at the Boydstown-Oneida and Thorn Run Reservoirs was factored in calculating the Q<sub>7-10</sub> flow. The calculation is as follows:

Drainage Area where the minimum flow release is monitored = 27.73 mi<sup>2</sup>

Drainage Area at Saxonburg's discharge point = 136 mi<sup>2</sup>

Stream yield rate used to estimate the Q<sub>7-10</sub> flow from unregulated drainage areas = 0.047 cfs/mi<sup>2</sup> - this is the last 20 years of recorded data rather than using the period of record for the gage. The more recent gage data is a better representation of the present flow conditions.

(136 - 27.73) mi<sup>2</sup> x 0.047 cfs/mi<sup>2</sup> = 5.09 cfs

(3.56 + 5.09) cfs = 8.65 cfs

### Connoquenessing Creek

DEP's latest integrated water quality report issued in 2024 shows that Connoquenessing Creek is impaired for organic enrichment as a result of agricultural activities. A Total Maximum Daily Load (TMDL) has not been developed to address this impairment; therefore no TMDL has been taken into consideration. However, all permit requirements will be developed to ensure that the discharge will not additionally contribute to this impairment.

**Public Water Intake**

The fact sheet developed for the last permit renewal shows that the nearest downstream public water supply intake is Beaver Falls Municipal Authority located on Beaver River approximately 46 miles from the discharge point. Given the distance, the discharge is not expected to affect the water supply intake.

<b>Treatment Facility Summary</b>				
<b>Treatment Facility Name:</b> Saxonburg Area Authority STP				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
1005401	07/5/2005			
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Oxidation Ditch	Ultraviolet	2.052
<b>Hydraulic Capacity (MGD)</b>	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
2.052	4094	Not Overloaded	Dewatering	Landfill

Saxonburg operates a municipal wastewater treatment facility serving Saxonburg Borough (21.05%), Jefferson Township (14.77%), Clinton Township (8.09%), Penn Township (24.9%), Middlesex Township (27.68%) and Richland Township (3.51%). All sewers are 100% separated. The facility is utilizing an oxidation ditch activated sludge treatment process consisting of influent pump station, screening, oxidation ditch, clarifiers (2), UV disinfection chambers (2), and cascade to the stream discharge. Sludge is handled by aerated holding tanks (2) and centrifuge. Any solids generated from this facility will be sent to Seneca Landfill for final treatment/disposal.

Polymer is added to centrifuge and aluminum sulfate is added for phosphorous control.

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	A summary of past 12-month DMR is presented on the next page.
<b>Summary of Inspections:</b>	08/11/2025: DEP conducted a routine inspection. No significant violations were noted at the time of inspection.  09/30/2024: DEP conducted a routine inspection. No significant violations were noted at the time of inspection.
<b>Other Comments:</b>	Since the last permit reissuance, the facility had a number of permit violations. These violations are shown on page 6 of this fact sheet.  DEP's database shows that there is no open violation associated with this facility.

Effluent Data

DMR Data for Outfall 001 (from August 1, 2024 to July 31, 2025)

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
Flow (MGD) Average Monthly	0.873	0.979	1.031	1.026	0.871	1.274	0.750	0.798	0.653	0.565	0.591	0.822
Flow (MGD) Weekly Average	1.059	1.209	1.676	1.430	1.039	1.764	0.989	0.907	0.814	0.614	0.642	1.242
pH (S.U.) Instantaneous Minimum	6.9	6.6	6.7	6.6	6.7	6.7	6.7	6.7	6.8	6.8	7.0	6.8
pH (S.U.) Instantaneous Maximum	7.5	7.3	6.9	6.8	6.9	6.9	6.8	6.9	6.9	7.1	7.2	7.3
DO (mg/L) Instantaneous Minimum	4.7	4.8	5.0	5.1	5.2	5.1	5.5	5.1	5.2	5.1	5.3	4.7
CBOD5 (lbs/day) Average Monthly	17.2	21.8	31.8	25.7	22.6	37.5	31.1	18.4	11.9	12.5	15.6	33.9
CBOD5 (lbs/day) Weekly Average	27.1	33.4	62.5	30.0	35.0	52.3	42.3	21.1	15.3	18.3	16.5	85.0
CBOD5 (mg/L) Average Monthly	2.3	2.8	3.2	3.7	3.2	4.6	5.2	2.8	2.3	2.6	3.3	4.2
CBOD5 (mg/L) Weekly Average	3.0	3.2	3.4	4.7	5.2	7.8	7.9	3.2	2.8	4.0	3.4	6.1
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	1759	1753	1688	1515	1372	1350	1541	1527	1260	1204	1297	970
BOD5 (mg/L) Raw Sewage Influent Average Monthly	235	231	204	219	197	162	254	236	243	257	272	174
TSS (lbs/day) Average Monthly	19.0	32.6	52.1	40.0	29.8	43.6	38.0	31.0	14.0	11.3	10.6	24.5
TSS (lbs/day) Raw Sewage Influent Average Monthly	2312	1850	1756	1562	1307	1239	1721	1681	1352	1524	1608	1153
TSS (lbs/day) Weekly Average	31.7	38.9	98.7	48.7	40.0	48.5	53.2	4.7	24.0	12.8	12.0	69.9
TSS (mg/L) Average Monthly	2.5	4.4	5.3	5.7	4.2	5.3	6.4	4.7	2.6	2.4	2.2	2.7
TSS (mg/L) Raw Sewage Influent Average Monthly	308	246	219	232	186	151	287	260	262	324	337	212

NPDES Permit Fact Sheet  
Saxonburg Area Authority STP

NPDES Permit No. PA0029122

Parameter	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24
TSS (mg/L) Weekly Average	3.4	5.1	5.6	7.1	5.3	7.1	9.9	5.6	3.3	2.7	2.6	5.1
Fecal Coliform (No./100 ml) Average Monthly	3.3	1.3	8.2	2.6	1.4	1.8	1.6	3.7	1.2	1.5	2.6	> 7.2
Fecal Coliform (No./100 ml) Instantaneous Maximum	31.8	3.0	579.4	38.8	3.1	4.1	6.3	29.2	2.0	7.4	248.1	> 2419.0
UV Intensity (μw/cm <sup>2</sup> ) Average Monthly	6642	7067	7171	7745	7268	11004	10935	6545	5620	5926	6300	6147
Total Nitrogen (mg/L) Average Monthly	11	14	17	14	9	13	10	15	15	13	11	10
Ammonia (lbs/day) Average Monthly	2.4	2.0	6.8	4.0	1.5	12.8	1.0	1.6	0.3	0.3	0.3	6.1
Ammonia (mg/L) Average Monthly	0.2	0.2	0.4	0.6	0.2	1.4	0.1	0.2	0.1	0.1	0.1	0.5
Total Phosphorus (lbs/day) Average Monthly	8.9	12.1	5.8	7.0	6.6	7.6	10.1	6.5	6.4	5.9	4.3	6.9
Total Phosphorus (mg/L) Average Monthly	1.1	1.6	0.7	1.1	1.0	0.9	1.7	0.9	1.2	1.3	0.9	1.1

Compliance History

Date	Description	Parameter	Results	Limits	Units	SBC
6/17/2020	Violation of permit condition	Total Phosphorus	2.05	2 mg/L	Average Monthly	
1/22/2021	Sample type not in accordance with permit					
2/19/2021	Sample type not in accordance with permit					
2/21/2023	Violation of permit condition	Total Suspended Solids	1168.9	512.9 lbs/day	Average Monthly	
2/21/2023	Violation of permit condition	Total Suspended Solids	311.5	45 mg/L	Weekly Average	
2/21/2023	Violation of permit condition	Total Suspended Solids	5059.6	769.3 lbs/day	Weekly Average	
2/21/2023	Violation of permit condition	Total Suspended Solids	73.7	30 mg/L	Average Monthly	
7/26/2023	Violation of permit condition	Total Phosphorus	2.6	2 mg/L	Average Monthly	
8/24/2023	Violation of permit condition	Total Phosphorus	2.1	2 mg/L	Average Monthly	
12/21/2023	Violation of permit condition	Total Phosphorus	2.1	2 mg/L	Average Monthly	
12/21/2023	Violation of permit condition	Total Suspended Solids	222.1	45 mg/L	Weekly Average	
12/21/2023	Violation of permit condition	Total Suspended Solids	2273.8	769.3 lbs/day	Weekly Average	
12/21/2023	Violation of permit condition	Total Suspended Solids	540.7	512.9 lbs/day	Average Monthly	
12/21/2023	Violation of permit condition	Total Suspended Solids	55.9	30 mg/L	Average Monthly	
2/22/2024	Violation of permit condition	Total Suspended Solids	1226.6	769.3 lbs/day	Weekly Average	
2/22/2024	Violation of permit condition	Total Suspended Solids	36	30 mg/L	Average Monthly	
2/22/2024	Violation of permit condition	Total Suspended Solids	88	45 mg/L	Weekly Average	
5/22/2024	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	> 1111.5	683.8 lbs/day	Weekly Average	
5/22/2024	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	> 21.3	40 mg/L	Weekly Average	
5/22/2024	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	> 255.9	427.4 lbs/day	Average Monthly	
5/22/2024	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	> 8.3	25 mg/L	Average Monthly	
5/22/2024	Violation of permit condition	Fecal Coliform	> 2419.6	10000 No./100 ml	Instantaneous Maximum	
5/22/2024	Violation of permit condition	Fecal Coliform	> 6.6	2000 No./100 ml	Average Monthly	
5/22/2024	Violation of permit condition	Total Phosphorus	60.8	34.1 lbs/day	Average Monthly	
5/22/2024	Violation of permit condition	Total Suspended Solids	12676.6	769.3 lbs/day	Weekly Average	
5/22/2024	Violation of permit condition	Total Suspended Solids	253.9	45 mg/L	Weekly Average	
5/22/2024	Violation of permit condition	Total Suspended Solids	2590.3	512.9 lbs/day	Average Monthly	
5/22/2024	Violation of permit condition	Total Suspended Solids	57.3	30 mg/L	Average Monthly	
9/17/2024	Violation of permit condition	Fecal Coliform	> 2419.0	1000 No./100 ml	Instantaneous Maximum	
9/17/2024	Violation of permit condition	Fecal Coliform	> 7.2	200 No./100 ml	Average Monthly	

**Existing Effluent Limits and Monitoring Requirements**

A table below summarizes effluent limits and monitoring requirements specified in the existing permit.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	4/week	Grab
Dissolved Oxygen	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	4/week	Grab
Ultraviolet light intensity ( $\mu$ w/cm <sup>2</sup> )	XXX	XXX	XXX	Report	XXX	XXX	4/week	Measured
Carbonaceous Biochemical Oxygen Demand (CBOD5) Nov 1 - Apr 30	427.4	683.8	XXX	25.0	40.0	50	2/week	24-Hr Composite
Carbonaceous Biochemical Oxygen Demand (CBOD5) May 1 - Oct 31	256.4	427.4	XXX	15.0	25.0	30	2/week	24-Hr Composite
Biochemical Oxygen Demand (BOD5) Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Suspended Solids Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Total Suspended Solids	512.9	769.3	XXX	30.0	45.0	60	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/week	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Ammonia-Nitrogen Nov 1 - Apr 30	230.8	XXX	XXX	13.5	XXX	27	2/week	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	76.9	XXX	XXX	4.5	XXX	9	2/week	24-Hr Composite
Total Phosphorus	34.1	XXX	XXX	2.0	XXX	4	2/week	24-Hr Composite

Development of Effluent Limitations				
Outfall No.	001	Design Flow (MGD)	2.052	
Latitude	40° 48' 24.00"	Longitude	-79° 57' 24.00"	
Wastewater Description:	Sewage Effluent			

### Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The facility utilizes UV disinfection; therefore, TRC effluent standard is not applicable.

### Water Quality-Based Limitations

#### *CBOD5, NH3-N and Dissolved Oxygen (DO)*

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP's technical guidance no. 391-2000-007 describes the technical methods contained in the model for conducting wasteload allocation analyses and for determining recommended limits for point source discharges. DEP recently updated this model (ver. 1.1) to include new ammonia criteria that has been approved by US EPA as part of the 2017 Triennial Review. The model output indicates that all existing effluent limits are still appropriate and protective of water quality.

#### *Toxics*

Effluent sample results for toxic pollutants reported on the renewal application were entered into DEP's Toxics Management Spreadsheet (TMD) to develop appropriate permit requirements for toxic pollutants of concern. TMS output shows that a routine monitoring for Total Copper and Total Zinc is needed. It is recommended that semi-monthly monitoring requirements will be included for Total Copper and Total Zinc. This approach is consistent with DEP's SOP no. DEP's SOP no. BPNPSM-PMT-033.

### Best Professional Judgment (BPJ) Limitations

#### *Total Phosphorus*

The existing effluent limits will remain unchanged in the permit based on the Stream Enrichment Risk Analysis (SERA) study on the Connoquenessing Creek. Because the receiving stream is impaired for nutrients, effluent limit of 2.0 mg/L is appropriate as per 25 Pa Code 96.5. This approach is consistent with DEP's SOP no. BPNPSM-PMT-033.

#### *Dissolved Oxygen*

A minimum of 4.0 mg/L for DO is an existing effluent limit and will remain unchanged in the permit to ensure adequate operation and maintenance. This approach is recommended by DEP's SOP no. BPNPSM-PMT-033.

### Additional Considerations

#### *Flow Monitoring*

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

#### *Per-and Polyfluoroalkyl (PFAS) Monitoring*

DEP has begun to implement PFAS monitoring requirements to major sewage facilities and industrial waste facilities to obtain ample datasets from these facilities. DEP's SOP no. BCW-PMT-033 recommends quarterly monitoring requirement to be included in the permit if sample results provided in the application reveals a detection of PFAS-related compounds including PFOA, PFOS, HFPO-DA and PFBS. The application shows the following effluent sample results for PFAS-related compounds:

#### **ANALYSIS RESULTS TABLE POLLUTANT GROUP 1 (PAGE 2 of 2)**

Please read instructions carefully before completing this form

ANALYSIS RESULTS TABLE POLLUTANT GROUP 1 (PAGE 2 of 2)														
APPLICANT NAME		Saxonburg Area Authority												
<input checked="" type="checkbox"/> Outfall Number: 001 (Show location of sampling point on Process Flow Diagram) <input type="checkbox"/> Treatment Facility Influent Sampling Results (Show location of sampling point on Process Flow Diagram) <input type="checkbox"/> Background Sampling Results (Specify Location: _____) <input type="checkbox"/> New Discharge (Basis for Information: _____)														
POLLUTANT GROUP 1 PARAMETERS	CONCENTRATION / MASS PRESENT						No. Analyses	No. "Non-Detect" Results	QL Used	Method Used				
	Min/Max Daily Value		Max Avg Monthly Value		Long-Term Avg Value									
	Conc	Mass (lbs/day)	Conc	Mass (lbs/day)	Conc	Mass (lbs/day)								
Perfluoroctanoic acid (PFOA) (µg/L)	0.00607	0.0536	0.0052	0.0437	0.0052	0.0437	3	0	0.00198	EPA 1633				
Perfluoroctanesulfonic acid (PFOS) (µg/L)	0.0206	0.196	0.0187	0.159	0.0187	0.159	3	0	0.00184	EPA 1633				
Perfluorobutanesulfonic acid (PFBS) (µg/L)	0.00501	0.0442	0.0042	0.0351	0.0042	0.0351	3	0	0.00175	EPA 1633				
Hexafluoropropylene oxide dimer acid (HFPO-DA) (µg/L)	<0.00198	<0.0181	<0.0019	<0.0159	<0.0019	<0.0159	3	3	0.00198	EPA 1633				

Based on this, quarterly sampling requirement will be included in the permit with the following footnote:

The permittee may discontinue monitoring for PFOA, PFOS, HFPO-DA, and PFBS if the results in 4 consecutive monitoring periods indicate non-detect results at or below Quantitation Limits of 4.0 ng/L for PFOA, 3.7 ng/L for PFOS, 3.5 ng/L for PFBS and 6.4 ng/L for HFPO-DA. When monitoring is discontinued, permittees must enter a No Discharge Indicator (NODI) Code of "GG" on DMRs.

#### *Influent BOD & TSS Monitoring*

As a result of negotiation with EPA, the existing influent monitoring reporting requirement for TSS and BOD5 will be maintained in the draft permit. This requirement has been consistently assigned to all municipal wastewater treatment facilities.

#### *E. Coli Monitoring Requirement*

DEP's SOP no. BCW-PMT-033 recommends a routine monitoring for E. Coli in all new and reissued sewage permits. As a result, a monthly monitoring requirement for E. Coli will be included in the permit given the facility's design flow is greater than 1.0 MGD.

#### *Ultraviolet Output Monitoring*

DEP's SOP no. BPNPSM-PMT-033 recommends a routine monitoring of UV output when the UV system is used for disinfection in lieu of chlorine. Therefore, the existing UV output intensity monitoring requirement will continue to be included in the permit.

#### *Total Dissolved Solids (TDS)*

TDS and its associated solids including Bromide, Chloride, and Sulfate have become statewide pollutants of concern. The requirement to monitor these pollutants must be considered under the criteria specified in 25 Pa. Code § 95.10 and the following January 23, 2014 DEP Central Office Directive:

For point source discharges and upon issuance or reissuance of an individual NPDES permit:

*-Where the concentration of TDS in the discharge exceeds 1,000 mg/L, or the net TDS load from a discharge exceeds 20,000 lbs/day, and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for TDS, sulfate, chloride, and bromide. Discharges of 0.1 MGD or less should monitor and report for TDS, sulfate, chloride, and bromide if the concentration of TDS in the discharge exceeds 5,000 mg/L.*

*-Where the concentration of bromide in a discharge exceeds 1 mg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for bromide. Discharges of 0.1 MGD or less should monitor and report for bromide if the concentration of bromide in the discharge exceeds 10 mg/L.*

*-Where the concentration of 1,4-dioxane (CAS 123-91-1) in a discharge exceeds 10 µg/L and the discharge flow exceeds 0.1 MGD, Part A of the permit should include monitor and report for 1,4-dioxane. Discharges of 0.1 MGD or less should monitor and report for 1,4-dioxane if the concentration of 1,4-dioxane in the discharge exceeds 100 µg/L.*

The facility reported the maximum effluent TDS concentration of 554 mg/L, Bromide of 0.14 mg/L and 1,4-dioxane of <5.0 µg/L. Based on this, no monitoring is recommended for these parameters

#### *Monitoring Frequency and Sample Type*

The monitoring frequency for pH, DO and UV output has changed from 4/week to 1/day. During the last permit renewal, it was set to 4/week per the draft permit comment with the understanding that the frequency will be set to 1/day in the next permit renewal. As a result, pH, DO and UV output monitoring frequency will be changed from 4/week to 1/day. This daily monitoring frequency is consistent with DEP's technical guidance no. 362-0400-001.

#### *Mass Loading Limitations*

All effluent mass loading limits will be based on the formula: design flow x concentration limit x conversion factor of 8.34.

#### *Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

#### *Class A Wild Trout Fishery*

No Class A Wild Trout Fisheries are also impacted by this discharge.

**Whole Effluent Toxicity (WET)**

For Outfall 001,  **Acute**  **Chronic** WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other: [REDACTED]

The dilution series used for the tests was: 100%, 64%, 28%, 14%, and 7%. The Target Instream Waste Concentration (TIWC) to be used for analysis of the results is: 28%.d

**Summary of Four Most Recent Test Results**

(NOTE – Enter results into one table, depending on which data analysis method was used).

NOEC/LC50 Data Analysis

Test Date	Ceriodaphnia Results (% Effluent)			Pimephales Results (% Effluent)			Pass? *
	NOEC Survival	NOEC Reproduction	LC50	NOEC Survival	NOEC Growth	LC50	
July 2024	100	100		100	100		Yes
June 2023	100	100		100	100		Yes
June 2022	100	64		100	100		Yes
June 2021	100	64		100	100		Yes

\* A "passing" result is that which is greater than or equal to the TIWC value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? (NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).

**YES**  **NO**

**Comments:** DEP's WET Analysis Spreadsheet is attached to this fact sheet.

**Evaluation of Test Type, IWC and Dilution Series for Renewed Permit**

Acute Partial Mix Factor (PMFa): **0.454**

Chronic Partial Mix Factor (PMFc): **1.0**

**1. Determine IWC – Acute (IWCA):**

$$(Q_d \times 1.547) / ((Q_{7-10} \times PMFa) + (Q_d \times 1.547))$$

$$[(2.052 \text{ MGD} \times 1.547) / ((8.65 \text{ cfs} \times 0.454) + (2.052 \text{ MGD} \times 1.547))] \times 100 = **44.7%**$$

Is IWCA < 1%?  **YES**  **NO** (**YES - Acute Tests Required OR NO - Chronic Tests Required**)

**Type of Test for Permit Renewal: Chronic**

**2b. Determine Target IWCC (If Chronic Tests Required)**

$$(Q_d \times 1.547) / (Q_{7-10} \times PMFc) + (Q_d \times 1.547)$$

$$[(2.052 \text{ MGD} \times 1.547) / ((8.65 \text{ cfs} \times 1.0) + (2.052 \text{ MGD} \times 1.547))] \times 100 = **26.8% = 27%**$$

**3. Determine Dilution Series**

(NOTE – check Attachment C of WET SOP for dilution series based on TIWCa or TIWCc, whichever applies).

Dilution Series = 100%, 64%, 27%, 14%, and 7%.

**WET Limits**

Has reasonable potential been determined?  YES  NO

Will WET limits be established in the permit?  YES  NO

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
CBOD5 Nov 1 - Apr 30	427.4	683.8	XXX	25.0	40.0	50	2/week	24-Hr Composite
CBOD5 May 1 - Oct 31	256.4	427.4	XXX	15.0	25.0	30	2/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
TSS	512.9	769.3	XXX	30.0	45.0	60	2/week	24-Hr Composite
TSS Raw Sewage Influent	Report	XXX	XXX	Report	XXX	XXX	2/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/week	Grab
UV Intensity ( $\mu$ w/cm <sup>2</sup> )	XXX	XXX	XXX	Report	XXX	XXX	1/day	Measured
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/month	24-Hr Composite
Ammonia Nov 1 - Apr 30	230.8	XXX	XXX	13.5	XXX	27	2/week	24-Hr Composite
Ammonia May 1 - Oct 31	76.9	XXX	XXX	4.5	XXX	9	2/week	24-Hr Composite

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Total Phosphorus	34.1	XXX	XXX	2.0	XXX	4	2/week	24-Hr Composite
E.Coli (No. / 100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/month	Grab
Total Copper	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	2/month	24-Hr Composite
Total Zinc	Report	Report Daily Max	XXX	Report	Report Daily Max	XXX	2/month	24-Hr Composite
PFOA (ng/L)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab
PFOS (ng/L)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab
PFBS (ng/L)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab
HFPO-DA (ng/L)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/quarter	Grab

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]


## StreamStats Report

Region ID: PA

Workspace ID: PA20250909114249327000

Clicked Point (Latitude, Longitude): 40.80679, -79.95672

Time: 2025-09-09 07:43:13 -0400



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	136	square miles
ELEV	Mean Basin Elevation	1225	feet

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	136	square miles	2.26	1400
ELEV	Mean Basin Elevation	1225	feet	1050	2580

**Low-Flow Statistics Flow Report [Low Flow Region 4]**

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	7.7	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	11.8	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	3.56	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow	5.27	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow	8.53	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.**  
(<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1


## StreamStats Report

Region ID: PA

Workspace ID: PA20250909114634316000

Clicked Point (Latitude, Longitude): 40.80933, -79.97021

Time: 2025-09-09 07:46:57 -0400



[Collapse All](#)

### ► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	138	square miles
ELEV	Mean Basin Elevation	1224	feet

### ► Low-Flow Statistics

#### Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	138	square miles	2.26	1400
ELEV	Mean Basin Elevation	1224	feet	1050	2580

Low-Flow Statistics Flow Report [Low Flow Region 4]

PIL: Lower 90% Prediction Interval, PIU: Upper 90% Prediction Interval, ASEp: Average Standard Error of Prediction, SE: Standard Error, PC: Percent Correct, RMSE: Root Mean Squared Error, PseudoR<sup>2</sup>: Pseudo R Squared (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	7.82	ft <sup>3</sup> /s	43	43
30 Day 2 Year Low Flow	12	ft <sup>3</sup> /s	38	38
7 Day 10 Year Low Flow	3.62	ft <sup>3</sup> /s	66	66
30 Day 10 Year Low Flow	5.36	ft <sup>3</sup> /s	54	54
90 Day 10 Year Low Flow	8.67	ft <sup>3</sup> /s	41	41

*Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p.**  
(<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.29.2

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20C		34025 CONNOQUENESSING CREEK			39.260	969.46	136.00	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.100	0.00	8.65	0.000	0.000	0.0	0.00	0.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	PA0029122	Saxonburg	2.0520	2.0520	2.0520	0.000	25.00	7.00		
<b>Parameter Data</b>										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	15.00	2.00	0.00	1.50					
	Dissolved Oxygen	4.00	8.24	0.00	0.00					
	NH3-N	4.50	0.00	0.00	0.70					

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC	
20C		34025 CONNOQUENESSING CREEK		38.390	952.80	138.00	0.00000	0.00	<input checked="" type="checkbox"/>	
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio (ft)	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.100	0.00	8.71	0.000	0.000	0.0	0.00	0.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	25.00	7.00		
<b>Parameter Data</b>										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				













## Discharge Information

Instructions **Discharge** Stream

Facility: Saxonburg Area Authority NPDES Permit No.: PA0029122 Outfall No.: 001

Evaluation Type Major Sewage / Industrial Waste Wastewater Description: Sewage

Discharge Characteristics												
Design Flow (MGD)*	Hardness (mg/l)*	pH (SU)*	Partial Mix Factors (PMFs)				Complete Mix Times (min)					
			AFC	CFC	THH	CRL	Q <sub>7-10</sub>	Q <sub>h</sub>				
2.052	127	7										
Discharge Pollutant			Max Discharge Conc	0 if left blank		0.5 if left blank	0 if left blank		1 if left blank			
Group 1	Units	Units	Conc	Trib Conc	Stream Conc	Daily CV	Hourly CV	Stream CV	Fate Coeff	FOS	Criteria Mod	Chem Transl
	mg/L	mg/L	5541									
	mg/L	mg/L	219									
	mg/L	mg/L	0.14									
	mg/L	mg/L	39.1									
	mg/L	mg/L										
	µg/L	µg/L	50.6									
	µg/L	µg/L	< 2									
	µg/L	µg/L	< 2									
	µg/L	µg/L	78.1									
Group 2	µg/L	µg/L	< 1									
	µg/L	µg/L	24									
	µg/L	µg/L	< 0.2									
	µg/L	µg/L	2									
	µg/L	µg/L	< 1									
	µg/L	µg/L	4									
	µg/L	µg/L	4									
	µg/L	µg/L	< 5									
	µg/L	µg/L	< 5									
	µg/L	µg/L	110									
	µg/L	µg/L	20									
	µg/L	µg/L	< 1									
	µg/L	µg/L	131									
	µg/L	µg/L	< 0.1									
	µg/L	µg/L	6.2									
	µg/L	µg/L	70									
	µg/L	µg/L	< 5									
	µg/L	µg/L	0.4									
	µg/L	µg/L	< 2									
	µg/L	µg/L	30.2									
	µg/L	µg/L	3.3									
	µg/L	µg/L	< 1									
	µg/L	µg/L	< 0.1									
	µg/L	µg/L	<									
	µg/L	µg/L	< 0.5									
	µg/L	µg/L	< 0.5									
	µg/L	µg/L	< 0.5									

Chlorobenzene	µg/L	< 0.5	Shaded							Shaded
Chlorodibromomethane	µg/L	< 0.5								
Chloroethane	µg/L	< 0.5	Shaded							
2-Chloroethyl Vinyl Ether	µg/L	< 5								
Chloroform	µg/L	< 0.5								
Dichlorobromomethane	µg/L	< 0.5								
1,1-Dichloroethane	µg/L	< 0.5	Shaded							Shaded
1,2-Dichloroethane	µg/L	< 0.5								
1,1-Dichloroethylene	µg/L	< 0.5								
1,2-Dichloropropane	µg/L	< 0.5								
1,3-Dichloropropylene	µg/L	< 0.5								
1,4-Dioxane	µg/L	< 0.263	Shaded							Shaded
Ethylbenzene	µg/L	< 0.5								
Methyl Bromide	µg/L	< 0.5								
Methyl Chloride	µg/L	< 0.5								
Methylene Chloride	µg/L	< 0.5								
1,1,2,2-Tetrachloroethane	µg/L	< 0.5								
Tetrachloroethylene	µg/L	< 0.5	Shaded							
Toluene	µg/L	< 0.5								
1,2-trans-Dichloroethylene	µg/L	< 0.5								
1,1,1-Trichloroethane	µg/L	< 0.5								
1,1,2-Trichloroethane	µg/L	< 0.5								
Trichloroethylene	µg/L	< 0.5								
Vinyl Chloride	µg/L	< 0.5								
2-Chlorophenol	µg/L	< 0.263								
2,4-Dichlorophenol	µg/L	< 0.263	Shaded							
2,4-Dimethylphenol	µg/L	< 0.263								
4,6-Dinitro- <i>o</i> -Cresol	µg/L	< 2.11								
2,4-Dinitrophenol	µg/L	< 5.26								
2-Nitrophenol	µg/L	< 0.263								
4-Nitrophenol	µg/L	< 0.263								
p-Chloro- <i>m</i> -Cresol	µg/L	< 0.263								
Pentachlorophenol	µg/L	< 5.26								
Phenol	µg/L	< 0.263								
2,4,6-Trichlorophenol	µg/L	< 0.263								
Acenaphthene	µg/L	< 0.263								
Acenaphthylene	µg/L	< 0.263								
Anthracene	µg/L	< 0.263	Shaded							
Benzidine	µg/L	< 0.263								
Benzo(a)Anthracene	µg/L	< 0.263								
Benzo(a)Pyrene	µg/L	< 0.263								
3,4-Benzofluoranthene	µg/L	< 0.263								
Benzo(ghi)Perylene	µg/L	< 0.263								
Benzo(k)Fluoranthene	µg/L	< 0.263								
Bis(2-Chloroethoxy)Methane	µg/L	< 0.263								
Bis(2-Chloroethyl)Ether	µg/L	< 0.263	Shaded							
Bis(2-Chloroisopropyl)Ether	µg/L	< 0.263								
Bis(2-Ethylhexyl)Phthalate	µg/L	0.41								
4-Bromophenyl Phenyl Ether	µg/L	< 0.263								
Butyl Benzyl Phthalate	µg/L	< 0.263	Shaded							
2-Chloronaphthalene	µg/L	< 0.263								
4-Chlorophenyl Phenyl Ether	µg/L	< 0.263								
Chrysene	µg/L	< 0.263								
Dibenz(a,h)Anthracene	µg/L	< 0.263	Shaded							
1,2-Dichlorobenzene	µg/L	< 0.263								
1,3-Dichlorobenzene	µg/L	< 0.263								
1,4-Dichlorobenzene	µg/L	< 0.263								
3,3-Dichlorobenzidine	µg/L	< 0.263	Shaded							
Diethyl Phthalate	µg/L	< 0.263								
Dimethyl Phthalate	µg/L	< 0.263								
Di-n-Butyl Phthalate	µg/L	< 0.263								
2,4-Dinitrotoluene	µg/L	< 0.263								
2,6-Dinitrotoluene	µg/L	< 0.263								
Di-n-Octyl Phthalate	µg/L	< 0.263	Shaded							





Toxics Management Spreadsheet  
Version 1.4, May 2025

## Stream / Surface Water Information

Instructions

Discharge

Stream

Saxonburg Area Authority, NPDES Permit No. PA0029122, Outfall 001

Receiving Surface Water Name: Connoquenessing Creek

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

Location	Stream Code*	RMI*	Elevation (ft)*	DA (mi <sup>2</sup> )*	Slope (ft/ft)	PWS Withdrawal (MGD)	Apply Fish Criteria*
Point of Discharge	034025	39.26	969.46	136			Yes
End of Reach 1	034025	38.39	952.8	138			Yes

Q<sub>10</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs) Stream	Flow (cfs) Tributary	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary pH	Stream Hardness* <th>Stream pH*</th> <th>Analysis Hardness<th>Analysis pH</th></th>	Stream pH*	Analysis Hardness <th>Analysis pH</th>	Analysis pH
Point of Discharge	39.26	0.1								61	7			
End of Reach 1	38.39	0.1												

Q<sub>h</sub>

Location	RMI	LFY (cfs/mi <sup>2</sup> )*	Flow (cfs) Stream	Flow (cfs) Tributary	W/D Ratio	Width (ft)	Depth (ft)	Velocity (fps)	Travel Time (days)	Tributary pH	Stream Hardness* <th>Stream pH*<th>Analysis Hardness<th>Analysis pH</th></th></th>	Stream pH* <th>Analysis Hardness<th>Analysis pH</th></th>	Analysis Hardness <th>Analysis pH</th>	Analysis pH
Point of Discharge	39.26													
End of Reach 1	38.39													



## Model Results

**Instructions**     **Results**

Saxonburg Area Authority, NPDES Permit No. PA0029122, Outfall 001

**Wasteload Allocations**

**PRINT**     **SAVE AS PDF**

**RETURN TO INPUTS**     **PMF:**      **Analysis Hardness (mg/l):**      **Analysis pH:**

**Hydrodynamics**

**AFC**

**CCT (min):**

**PMF:**

Pollutants	Stream Conc (µg/L)	Stream Cv	trib conc (µg/L)	Fate Coef	WQC (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	
Total Aluminum	0	0	0	0	750	750	2,210
Total Antimony	0	0	0	0	1,100	1,100	3,241
Total Arsenic	0	0	0	0	340	340	1,002
Total Barium	0	0	0	0	21,000	21,000	61,876
Total Boron	0	0	0	0	8,100	8,100	23,867
Total Cadmium	0	0	0	0	1,688	1,777	5,233
Total Chromium (III)	0	0	0	0	491,052	1,5564	4,5779
Hexavalent Chromium	0	0	0	0	16	16,3	48,0
Total Cobalt	0	0	0	0	95	95,0	280
Total Copper	0	0	0	0	11,326	11,8	34,8
Free Cyanide	0	0	0	0	22	22,0	64,8
Dissolved Iron	0	0	0	0	N/A	N/A	
Total Iron	0	0	0	0	N/A	N/A	
Total Lead	0	0	0	0	52,970	64,8	191
Total Manganese	0	0	0	0	N/A	N/A	
Total Mercury	0	0	0	0	1,400	1,65	4,85
Total Nickel	0	0	0	0	401,577	402	1,186
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	
Total Selenium	0	0	0	0	N/A	N/A	
Total Silver	0	0	0	0	2,354	2,77	8,16
Total Thallium	0	0	0	0	65	65,0	192
Total Zinc	0	0	0	0	100,475	103	303
Acrolein	0	0	0	0	3	3,0	8,84
Acrylamide	0	0	0	0	N/A	N/A	
Model Results	0	0	0	0	640,110,202,640	640,110,202,640	1,886
Benzene	0	0	0	0			

Bromoform	0	0	0	1,800	1,800	5,304
Carbon Tetrachloride	0	0	0	2,800	2,800	8,250
Chlorobenzene	0	0	0	1,200	1,200	3,536
Chlorodibromomethane	0	0	0	N/A	N/A	N/A
2-Chloroethyl Vinyl Ether	0	0	0	18,000	18,000	53,037
Chloroform	0	0	0	1,900	1,900	5,598
Dichlorobromomethane	0	0	0	N/A	N/A	N/A
1,2-Dichloroethane	0	0	0	15,000	15,000	44,197
1,1-Dichloroethylene	0	0	0	7,500	7,500	22,099
1,2-Dichloropropane	0	0	0	11,000	11,000	32,411
1,3-Dichloropropylene	0	0	0	310	310	913
Ethylbenzene	0	0	0	2,900	2,900	8,545
Methyl Bromide	0	0	0	550	550	1,621
Methyl Chloride	0	0	0	28,000	28,000	82,502
Methylene Chloride	0	0	0	12,000	12,000	35,358
1,1,2,2-Tetrachloroethane	0	0	0	1,000	1,000	2,946
Tetrachloroethylene	0	0	0	700	700	2,063
Toluene	0	0	0	1,700	1,700	5,009
1,2-Trans-Dichloroethylene	0	0	0	6,800	6,800	20,036
1,1,1,Trichloroethane	0	0	0	3,000	3,000	8,839
1,1,2-Trichloroethane	0	0	0	3,400	3,400	10,018
Trichloroethylene	0	0	0	2,300	2,300	6,777
Vinyl Chloride	0	0	0	N/A	N/A	N/A
2-Chlorophenol	0	0	0	560	560	1,650
2,4-Dichlorophenol	0	0	0	1,700	1,700	5,009
2,4-Dimethylphenol	0	0	0	660	660	1,945
4,6-Dinitro-o-Cresol	0	0	0	80	80	236
2,4-Dinitrophenol	0	0	0	660	660	1,945
2-Nitrophenol	0	0	0	8,000	8,000	23,572
4-Nitrophenol	0	0	0	2,300	2,300	6,777
p-Chloro-m-Cresol	0	0	0	160	160	471
Pentachlorophenol	0	0	0	8,723	8,723	25,7
Phenol	0	0	0	N/A	N/A	N/A
2,4,6-Trichlorophenol	0	0	0	460	460	1,355
Acenaphthene	0	0	0	83	83	245
Anthracene	0	0	0	N/A	N/A	N/A
Benzidine	0	0	0	300	300	884
Benzo(a)Anthracene	0	0	0	0.5	0.5	1,47
Benzo(a)Pyrene	0	0	0	N/A	N/A	N/A
3,4-Benzo[1,2-a]anthracene	0	0	0	N/A	N/A	N/A
Benzo(k)Fluoranthene	0	0	0	N/A	N/A	N/A
Bis(2-Chloroethyl)Ether	0	0	0	30,000	30,000	88,395
Bis(2-Ethylhexyl)Phthalate	0	0	0	4,500	4,500	13,259
4-Bromophenyl Phenyl Ether	0	0	0	270	270	796
Butyl Benzyl Phthalate	0	0	0	140	140	413
2-Chloronaphthalene	0	0	0	N/A	N/A	N/A
Chrysene	0	0	0	N/A	N/A	N/A
Dibenz(a,h)Anthracene	0	0	0	N/A	N/A	N/A

Model Results

9/10/2025

Page 6

1,2-Dichlorobenzene	0	0	820	820	2,416
1,3-Dichlorobenzene	0	0	350	350	1,031
1,4-Dichlorobenzene	0	0	730	730	2,151
3,3-Dichlorobenzidine	0	0	0	N/A	N/A
Diethyl Phthalate	0	0	0	4,000	11,786
Dimethyl Phthalate	0	0	0	2,500	7,366
Di-n-Butyl Phthalate	0	0	0	110	324
2,4-Dinitrotoluene	0	0	0	1,600	4,714
2,6-Dinitrotoluene	0	0	0	990	2,917
1,2-Diphenylhydrazine	0	0	0	15	44.2
Fluoranthene	0	0	0	200	589
Fluorene	0	0	0	N/A	N/A
Hexachlorobenzene	0	0	0	N/A	N/A
Hexachlorobutadiene	0	0	0	10	10.0
Hexachlorocyclopentadiene	0	0	0	5	5.0
Hexachloroethane	0	0	0	60	177
Indeno(1,2,3-cd)Pyrene	0	0	0	N/A	N/A
Isophorone	0	0	0	10,000	29,465
Naphthalene	0	0	0	140	413
Nitrobenzene	0	0	0	4,000	11,786
n-Nitrosodimethylamine	0	0	0	17,000	50,090
n-Nitrosodi-n-Propylamine	0	0	0	N/A	N/A
n-Nitrosodiphenylamine	0	0	0	300	884
Phenanthrene	0	0	0	5	5.0
Pyrene	0	0	0	N/A	N/A
1,2,4-Trichlorobenzene	0	0	0	130	383

CFC      CCT (min): 72,665      PMF: 1      Analysis Hardness (mg/L): 73.49      Analysis pH: 7.00

Pollutants	Stream	Stream Conc (ug/L)	Trib Conc (ug/L)	Fate Coef	WQC (ug/L)	WQA Obj (ug/L)	WLA (ug/L)	Comments
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A	
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A	
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A	
Total Aluminum	0	0	0	0	N/A	N/A	N/A	
Total Antimony	0	0	0	220	220	1,163		Chem Translator of 1 applied
Total Arsenic	0	0	0	150	150	793		
Total Barium	0	0	0	4,100	4,100	21,665		
Total Boron	0	0	0	1,600	1,600	8,455		
Total Cadmium	0	0	0	0.199	0.22	1.14		Chem Translator of 0.922 applied
Total Chromium (III)	0	0	0	57.590	67.0	354		Chem Translator of 0.86 applied
Hexavalent Chromium	0	0	0	10	10.4	54.9		Chem Translator of 0.962 applied
Total Cobalt	0	0	0	19	19.0	100		
Total Copper	0	0	0	6,883	7.17	37.9		Chem Translator of 0.96 applied
Free Cyanide	0	0	0	5.2	5.2	27.5		
Dissolved Iron	0	0	0	N/A	N/A	N/A		
Total Iron	0	0	0	1,500	1,500	7,926		WQC = 30 day average; PMF = 1

Master Results      9/10/2025

Page 7

Total Lead	0	0	0	1,797	2.15	11.4	Chem Translator of 0.836 applied
Total Manganese	0	0	0	N/A	N/A	N/A	
Total Mercury	0	0	0	0.770	0.91	4.79	Chem Translator of 0.85 applied
Total Nickel	0	0	0	40.076	40.2	212	Chem Translator of 0.987 applied
Total Phenols (Phenolics) (PWS)	0	0	0	N/A	N/A	N/A	
Total Selenium	0	0	0	4,600	4,99	26.4	Chem Translator of 0.922 applied
Total Silver	0	0	0	N/A	N/A	N/A	Chem Translator of 1 applied
Total Thallium	0	0	0	13	13.0	68.7	
Total Zinc	0	0	0	91,002	92.3	488	Chem Translator of 0.986 applied
Acrolein	0	0	0	3	3.0	15.9	
Acrylamide	0	0	0	N/A	N/A	N/A	
Benzene	0	0	0	130	130	687	
Bromoform	0	0	0	370	370	1,955	
Carbon Tetrachloride	0	0	0	560	560	2,959	
Chlorobenzene	0	0	0	240	240	1,268	
Chlorodibromomethane	0	0	0	N/A	N/A	N/A	
2-Chloroethyl Vinyl Ether	0	0	0	3,500	3,500	18,495	
Chloroform	0	0	0	390	390	2,061	
Dichlorobromomethane	0	0	0	N/A	N/A	N/A	
1,2-Dichloroethane	0	0	0	3,100	3,100	16,381	
1,1-Dichloroethylene	0	0	0	1,500	1,500	7,926	
1,2-Dichloropropane	0	0	0	2,200	2,200	11,625	
1,3-Dichloropropylene	0	0	0	61	61.0	322	
Ethylbenzene	0	0	0	580	580	3,065	
Methyl Bromide	0	0	0	110	110	581	
Methyl Chloride	0	0	0	5,500	5,500	29,063	
Methylene Chloride	0	0	0	2,400	2,400	12,682	
1,1,2,2-Tetrachloroethane	0	0	0	210	210	1,110	
Tetrachloroethylene	0	0	0	140	140	740	
Toluene	0	0	0	330	330	1,744	
1,2-trans-Dichloroethylene	0	0	0	1,400	1,400	7,398	
1,1,1-Trichloroethane	0	0	0	610	610	3,223	
1,1,2-Trichloroethane	0	0	0	680	680	3,593	
Trichloroethylene	0	0	0	450	450	2,378	
Vinyl Chloride	0	0	0	N/A	N/A	N/A	
2-Chlorophenol	0	0	0	110	110	581	
2,4-Dichlorophenol	0	0	0	340	340	1,797	
2,4-Dimethylphenol	0	0	0	130	130	687	
4,6-Dinitro-o-Cresol	0	0	0	16	16.0	84.5	
2,4-Dinitrophenol	0	0	0	130	130	687	
2-Nitrophenol	0	0	0	1,600	1,600	8,455	
4-Nitrophenol	0	0	0	470	470	2,484	
p-Chloro-m-Cresol	0	0	0	500	500	2,642	
Pentachlorophenol	0	0	0	6,693	6,693	35.4	
Phenol	0	0	0	N/A	N/A	N/A	
2,4,6-Trichlorophenol	0	0	0	91	91.0	481	
Model Results	0	0	0	17,910	17,70	89.8	

THE

CCT (min): **72.665**

N/A

Analysis pH:

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQC (µg/L)	WQA Obj (µg/L)	WLA (µg/L)	Comments
Total Dissolved Solids (TDS)	0	0	0	0	500,000	<500,000	N/A	
Chloride (Cl <sup>-</sup> )	0	0	0	0	500,000	<500,000	N/A	

Chloride (PWS)	0	0	0	250,000	250,000	N/A
Sulfate (PWS)	0	0	0	250,000	250,000	N/A
Total Aluminum	0	0	0	N/A	N/A	N/A
Total Antimony	0	0	0	5.6	5.6	29.6
Total Arsenic	0	0	0	10	10.0	52.8
Total Barium	0	0	0	2,400	2,400	12,682
Total Boron	0	0	0	3,100	3,100	16,381
Total Cadmium	0	0	0	N/A	N/A	N/A
Total Chromium (III)	0	0	0	N/A	N/A	N/A
Hexavalent Chromium	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	N/A	N/A	N/A
Free Cyanide	0	0	0	4	4.0	21.1
Dissolved Iron	0	0	0	300	300	1,585
Total Iron	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	1,000	1,000	5,284
Total Mercury	0	0	0	0.050	0.05	0.26
Total Nickel	0	0	0	610	610	3,223
Total Phenols (Phenolics) (PWS)	0	0	0	5	5.0	N/A
Total Selenium	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0.24	0.24	1.27
Total Zinc	0	0	0	N/A	N/A	N/A
Acrolein	0	0	0	3	3.0	15.9
Acrylamide	0	0	0	N/A	N/A	N/A
Benzene	0	0	0	N/A	N/A	N/A
Bromofom	0	0	0	N/A	N/A	N/A
Carbon Tetrachloride	0	0	0	N/A	N/A	N/A
Chlorobenzene	0	0	0	100	100.0	528
Chlorodibromomethane	0	0	0	N/A	N/A	N/A
2-Chloroethyl Vinyl Ether	0	0	0	N/A	N/A	N/A
Chloroform	0	0	0	5.7	5.7	30.1
Dichlorobromomethane	0	0	0	N/A	N/A	N/A
1,2-Dichloroethane	0	0	0	N/A	N/A	N/A
1,1-Dichloroethylene	0	0	0	33	33.0	174
1,2-Dichloropropane	0	0	0	N/A	N/A	N/A
1,3-Dichloropropylene	0	0	0	N/A	N/A	N/A
Ethylbenzene	0	0	0	68	68.0	359
Methyl Bromide	0	0	0	100	100.0	528
Methyl Chloride	0	0	0	N/A	N/A	N/A
Methylene Chloride	0	0	0	N/A	N/A	N/A
1,1,2,2-Tetrachloroethane	0	0	0	N/A	N/A	N/A
Tetrachloroethylene	0	0	0	N/A	N/A	N/A
Toluene	0	0	0	57	57.0	301
1,2-trans-Dichloroethylene	0	0	0	100	100.0	528
Model Results	1,1-Trichloroethane	0	0	10,099	10,099	52,842

Page 10

1,1,2-Trichloroethane	0	0	0	N/A	N/A	N/A	N/A
Trichloroethylene	0	0	0	N/A	N/A	N/A	N/A
Vinyl Chloride	0	0	0	N/A	N/A	N/A	N/A
2-Chlorophenol	0	0	0	30	30.0	159	
2,4-Dichlorophenol	0	0	0	10	10.0	52.8	
2,4-Dimethylphenol	0	0	0	100	100.0	528	
4,6-Dinitro- <i>o</i> -Cresol	0	0	0	2	2.0	10.6	
2,4-Dinitrophenol	0	0	0	10	10.0	52.8	
2-Nitrophenol	0	0	0	N/A	N/A	N/A	N/A
4-Nitrophenol	0	0	0	N/A	N/A	N/A	N/A
p-Chloro- <i>m</i> -Cresol	0	0	0	N/A	N/A	N/A	N/A
Pentachlorophenol	0	0	0	N/A	N/A	N/A	N/A
Phenol	0	0	0	4,000	4,000	21,137	
2,4,6-Trichlorophenol	0	0	0	N/A	N/A	N/A	N/A
Acenaphthene	0	0	0	70	70.0	370	
Anthracene	0	0	0	300	300	1,585	
Benzidine	0	0	0	N/A	N/A	N/A	N/A
Benzol(a)Anthracene	0	0	0	N/A	N/A	N/A	N/A
Benzol(a)Pyrene	0	0	0	N/A	N/A	N/A	N/A
3,4-Benzofluoranthene	0	0	0	N/A	N/A	N/A	N/A
Benzol(k)Fluoranthene	0	0	0	N/A	N/A	N/A	N/A
Bis(2-Chloroethyl)Ether	0	0	0	N/A	N/A	N/A	N/A
Bis(2-Chloroisopropyl)Ether	0	0	0	200	200	1,057	
Bis(2-Ethylhexyl)Phthalate	0	0	0	N/A	N/A	N/A	N/A
4-Bromophenyl Phenyl Ether	0	0	0	N/A	N/A	N/A	N/A
Butyl Benzyl Phthalate	0	0	0	0.1	0.1	0.53	
2-Chloronaphthalene	0	0	0	800	800	4,227	
Chrysene	0	0	0	N/A	N/A	N/A	N/A
Dibenzol(a,h)Anthracene	0	0	0	N/A	N/A	N/A	N/A
1,2-Dichlorobenzene	0	0	0	1,000	1,000	5,284	
1,3-Dichlorobenzene	0	0	0	7	7.0	37.0	
1,4-Dichlorobenzene	0	0	0	300	300	1,585	
3,3-Dichlorobenzidine	0	0	0	N/A	N/A	N/A	N/A
Diethyl Phthalate	0	0	0	600	600	3,171	
Dimethyl Phthalate	0	0	0	2,000	2,000	10,568	
Di-n-Butyl Phthalate	0	0	0	20	20.0	106	
2,4-Dinitrotoluene	0	0	0	N/A	N/A	N/A	N/A
2,6-Dinitrotoluene	0	0	0	N/A	N/A	N/A	N/A
1,2-Diphenylhydrazine	0	0	0	4	4.0	21.1	
Fluoranthene	0	0	0	20	20.0	106	
Fluorene	0	0	0	50	50.0	264	
Hexachlorobenzene	0	0	0	N/A	N/A	N/A	N/A
Hexachlorodadiene	0	0	0	N/A	N/A	N/A	N/A
Hexachlorocyclopentadiene	0	0	0	N/A	N/A	N/A	N/A
Hexachloroethane	0	0	0	N/A	N/A	N/A	N/A
Indeno(1,2,3- <i>cd</i> )Pyrene	0	0	0	N/A	N/A	N/A	N/A
Model Results	Isophorone	0	0	349,101,202,34.0	180		

Naphthalene	0	0	0	N/A	N/A	N/A
Nitrobenzene	0	0	0	10	10.0	52.8
n-Nitrosodimethylamine	0	0	0	N/A	N/A	N/A
n-Nitrosodi-n-Propylamine	0	0	0	N/A	N/A	N/A
n-Nitrosodiphenylamine	0	0	0	N/A	N/A	N/A
Phenanthrene	0	0	0	N/A	N/A	N/A
Pyrene	0	0	0	20	20.0	106
1,2,4-Trichlorobenzene	0	0	0	0.07	0.07	0.37

Pollutants	Stream Conc (µg/L)	Stream CV	Trib Conc (µg/L)	Fate Coef	WQA Obj		Comments
					WQC (µg/L)	WLA (µg/L)	
Total Dissolved Solids (PWS)	0	0	0	0	N/A	N/A	N/A
Chloride (PWS)	0	0	0	0	N/A	N/A	N/A
Sulfate (PWS)	0	0	0	0	N/A	N/A	N/A
Total Aluminum	0	0	0	0	N/A	N/A	N/A
Total Antimony	0	0	0	0	N/A	N/A	N/A
Total Arsenic	0	0	0	0	N/A	N/A	N/A
Total Barium	0	0	0	0	N/A	N/A	N/A
Total Boron	0	0	0	0	N/A	N/A	N/A
Total Cadmium	0	0	0	0	N/A	N/A	N/A
Total Chromium (III)	0	0	0	0	N/A	N/A	N/A
Hexavalent Chromium	0	0	0	0	N/A	N/A	N/A
Total Cobalt	0	0	0	0	N/A	N/A	N/A
Total Copper	0	0	0	0	N/A	N/A	N/A
Free Cyanide	0	0	0	0	N/A	N/A	N/A
Dissolved Iron	0	0	0	0	N/A	N/A	N/A
Total Iron	0	0	0	0	N/A	N/A	N/A
Total Lead	0	0	0	0	N/A	N/A	N/A
Total Manganese	0	0	0	0	N/A	N/A	N/A
Total Mercury	0	0	0	0	N/A	N/A	N/A
Total Nickel	0	0	0	0	N/A	N/A	N/A
Total Phenols (Phenolics) (PWS)	0	0	0	0	N/A	N/A	N/A
Total Selenium	0	0	0	0	N/A	N/A	N/A
Total Silver	0	0	0	0	N/A	N/A	N/A
Total Thallium	0	0	0	0	N/A	N/A	N/A
Total Zinc	0	0	0	0	N/A	N/A	N/A
Acrolein	0	0	0	0	N/A	N/A	N/A
Acrylamide	0	0	0	0.07	0.07	1.67	
Benzene	0	0	0	0	0.58	0.58	13.9
Bromoform	0	0	0	7	7.0	167	
Carbon Tetrachloride	0	0	0	0.4	0.4	9.56	
Chlorobenzene	0	0	0	0	N/A	N/A	N/A
Chlorodibromomethane	0	0	0	0.8	0.8	19.1	
Model Result Chloroethyl Vinyl Ether	0	0	0	0	N/A <sub>1/10/2025</sub>	N/A	N/A

Chloroform	0	0	0	N/A	N/A	N/A	N/A
Dichloromethane	0	0	0	0.95	0.95	22.7	
1,2-Dichloroethane	0	0	0	9.9	9.9	23.7	
1,1-Dichloroethylene	0	0	0	N/A	N/A	N/A	
1,2-Dichloropropane	0	0	0	0.9	0.9	21.5	
1,3-Dichloropropene	0	0	0	0.27	0.27	6.46	
Ethylbenzene	0	0	0	N/A	N/A	N/A	
Methyl Bromide	0	0	0	N/A	N/A	N/A	
Methyl Chloride	0	0	0	N/A	N/A	N/A	
Methylene Chloride	0	0	0	20	20	478	
1,1,2,2-Tetrachloroethane	0	0	0	0.2	0.2	4.78	
Tetrachloroethylene	0	0	0	10	10.0	239	
Toluene	0	0	0	N/A	N/A	N/A	
1,2-Trans-Dichloroethylene	0	0	0	N/A	N/A	N/A	
1,1,1-Trichloroethane	0	0	0	N/A	N/A	N/A	
1,1,2-Trichloroethane	0	0	0	0.55	0.55	13.2	
Trichloroethylene	0	0	0	0.6	0.6	14.3	
Vinyl Chloride	0	0	0	0.02	0.02	0.48	
2-Chlorophenol	0	0	0	N/A	N/A	N/A	
2,4-Dichlorophenol	0	0	0	N/A	N/A	N/A	
2,4-Dimethylphenol	0	0	0	N/A	N/A	N/A	
4,6-Dinitro- <i>o</i> -Cresol	0	0	0	N/A	N/A	N/A	
2,4-Dinitrophenol	0	0	0	N/A	N/A	N/A	
2-Nitrophenol	0	0	0	N/A	N/A	N/A	
4-Nitrophenol	0	0	0	N/A	N/A	N/A	
p-Chloro- <i>m</i> -Cresol	0	0	0	N/A	N/A	N/A	
Pentachlorophenol	0	0	0	0.030	0.03	0.72	
Phenol	0	0	0	N/A	N/A	N/A	
2,4,6-Trichlorophenol	0	0	0	1.5	1.5	35.9	
Acenaphthene	0	0	0	N/A	N/A	N/A	
Anthracene	0	0	0	N/A	N/A	N/A	
Benzidine	0	0	0	0.0001	0.0001	0.002	
Benz(a)Anthracene	0	0	0	0.001	0.001	0.024	
Benz(a)Pyrene	0	0	0	0.0001	0.0001	0.002	
3,4-Benzofluoranthene	0	0	0	0.001	0.001	0.024	
Benz(k)Fluoranthene	0	0	0	0.01	0.01	0.24	
Bis(2-Chloroethyl)Ether	0	0	0	0.03	0.03	0.72	
Bis(2-Chloroisopropyl)Ether	0	0	0	N/A	N/A	N/A	
Bis(2-Ethylhexyl)Phthalate	0	0	0	0.32	0.32	7.65	
4-Bromophenyl Phenyl Ether	0	0	0	N/A	N/A	N/A	
Buyl Benzyl Phthalate	0	0	0	N/A	N/A	N/A	
2-Chloronaphthalene	0	0	0	N/A	N/A	N/A	
Chrysene	0	0	0	0.12	0.12	2.87	
Dibenz(a,h)Anthracene	0	0	0	0.0001	0.0001	0.002	
1,2-Dichlorobenzene	0	0	0	N/A	N/A	N/A	
1,3-Dichlorobenzene	0	0	0	N/A	N/A	N/A	
Model Results	14-Dichlorobenzene	0	0	0	N/A/10/2022	N/A	N/A

## *Recommended WQBELs & Monitoring Requirements*

No Samples/Month:

### Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., < Target QL).

Model Results

Pollutants	Governing WQBEL	Units	Comments
Total Dissolved Solids (PWS)	N/A	N/A	PWS, Not Applicable
Chloride (PWS)	N/A	N/A	PWS, Not Applicable
Bromide	N/A	N/A	No WQS
Sulfate (PWS)	N/A	N/A	PWS, Not Applicable
Total Aluminum	1,416	µg/L	Discharge Conc ≤ 10% WQBEL
Total Antimony	N/A	N/A	Discharge Conc < TQL
Total Arsenic	N/A	N/A	Discharge Conc < TQL
Total Barium	12,682	µg/L	Discharge Conc ≤ 10% WQBEL
Total Beryllium	N/A	N/A	No WQS
Total Boron	8,435	µg/L	Discharge Conc ≤ 10% WQBEL
Total Cadmium	1.14	µg/L	Discharge Conc < TQL
Total Chromium (III)	354	µg/L	Discharge Conc ≤ 10% WQBEL
Hexavalent Chromium	30.8	µg/L	Discharge Conc < TQL
Total Cobalt	100	µg/L	Discharge Conc ≤ 10% WQBEL
Free Cyanide	21.1	µg/L	Discharge Conc ≤ 25% WQBEL
Total Cyanide	N/A	N/A	No WQS
Dissolved Iron	1,565	µg/L	Discharge Conc ≤ 10% WQBEL
Total Iron	7,926	µg/L	Discharge Conc ≤ 10% WQBEL
Total Lead	11.4	µg/L	Discharge Conc < TQL
Total Manganese	5,284	µg/L	Discharge Conc ≤ 10% WQBEL
Total Mercury	0.26	µg/L	Discharge Conc < TQL
Total Nickel	212	µg/L	Discharge Conc ≤ 10% WQBEL
Total Phenols (Phenolics) (PWS)			PWS, Not Applicable
Total Selenium	26.4	µg/L	Discharge Conc < TQL
Total Silver	5.23	µg/L	Discharge Conc ≤ 10% WQBEL
Total Thallium	1.27	µg/L	Discharge Conc < TQL
Total Molybdenum	N/A	N/A	No WQS
Acrolein	5.67	µg/L	Discharge Conc < TQL
Acrylamide	1.67	µg/L	Discharge Conc < TQL
Benzene	13.9	µg/L	Discharge Conc < TQL
Bromoform	167	µg/L	Discharge Conc < TQL
Carbon Tetrachloride	9.56	µg/L	Discharge Conc < TQL
Chlorobenzene	528	µg/L	Discharge Conc ≤ 25% WQBEL
Chlorodibromomethane	19.1	µg/L	Discharge Conc < TQL
Chloroethane	N/A	N/A	No WQS
2-Chloroethyl Vinyl Ether	18,495	µg/L	Discharge Conc < TQL
Chloroform	30.1	µg/L	Discharge Conc < TQL
Dichlorobromomethane	22.7	µg/L	Discharge Conc < TQL
1,1-Dichloroethane	N/A	N/A	No WQS
1,2-Dichloroethane	237	µg/L	Discharge Conc < TQL
1,1-Dichloroethylene	174	µg/L	Discharge Conc < TQL
1,2-Dichloropropane	21.5	µg/L	Discharge Conc < TQL
1,3-Dichloropropylene	6.46	µg/L	Discharge Conc < TQL
1,4-Dioxane	N/A	N/A	No WQS
Model Results	359	µg/L	Discharge Conc ≤ 10% WQBEL
Ethylbenzene			Page 15

Méthyl Bromide	528	µg/L	Discharge Conc < TQL
Methyl Chloride	29,063	µg/L	Discharge Conc < TQL
Methylene Chloride	478	µg/L	Discharge Conc < TQL
1,1,2,2-Tetrachloroethane	4.78	µg/L	Discharge Conc < TQL
Tetrachloroethylene	239	µg/L	Discharge Conc < TQL
Toluene	301	µg/L	Discharge Conc < TQL
1,2-trans-Dichloroethylene	528	µg/L	Discharge Conc < TQL
1,1,1-Trichloroethane	3,223	µg/L	Discharge Conc < TQL
1,1,2-Trichloroethane	13.2	µg/L	Discharge Conc < TQL
Trichloroethylene	14.3	µg/L	Discharge Conc < TQL
Vinyl Chloride	0.48	µg/L	Discharge Conc < TQL
2-Chlorophenol	159	µg/L	Discharge Conc < TQL
2,4-Dichlorophenol	52.8	µg/L	Discharge Conc < TQL
2,4-Dimethylphenol	528	µg/L	Discharge Conc < TQL
4,6-Dinitro- <i>o</i> -Cresol	10.6	µg/L	Discharge Conc < TQL
2,4-Dinitrophenol	52.8	µg/L	Discharge Conc < TQL
2-Nitrophenol	8,495	µg/L	Discharge Conc < TQL
4-Nitrophenol	2,484	µg/L	Discharge Conc < TQL
p-Chloro- <i>m</i> -Cresol	302	µg/L	Discharge Conc < TQL
Pentachlorophenol	0.72	µg/L	Discharge Conc < TQL
Phenol	21,137	µg/L	Discharge Conc < TQL
2,4,6-Trichlorophenol	35.9	µg/L	Discharge Conc < TQL
Acenaphthene	89.8	µg/L	Discharge Conc < TQL
Acenaphthylene	N/A	N/A	No WQS
Anthraene	1,565	µg/L	Discharge Conc < TQL
Benzidine	0.002	µg/L	Discharge Conc < TQL
Benz(a)Anthracene	0.024	µg/L	Discharge Conc < TQL
Benz(a)Pyrene	0.002	µg/L	Discharge Conc < TQL
3,4-Benzofluoranthene	0.024	µg/L	Discharge Conc < TQL
Benzo(ghi)Perylene	N/A	N/A	No WQS
Benzo(k)Fluoranthene	0.24	µg/L	Discharge Conc < TQL
Bis(2-Chloroethyl)Methane	N/A	N/A	No WQS
Bis(2-Chloroethyl)Ether	0.72	µg/L	Discharge Conc < TQL
Bis(2-Chloroisopropyl)Ether	1,057	µg/L	Discharge Conc < TQL
Bis(2-Ethylhexyl)Phthalate	7.65	µg/L	Discharge Conc ≤ 25% WQBEL
4-Bromophenyl Phenyl Ether	285	µg/L	Discharge Conc < TQL
Buyl Benzyl Phthalate	0.53	µg/L	Discharge Conc < TQL
2-Chloronaphthalene	4,227	µg/L	Discharge Conc < TQL
4-Chlorophenyl Phenyl Ether	N/A	N/A	No WQS
Chrysene	2.87	µg/L	Discharge Conc < TQL
Dibenz(a,h)Anthracene	0.002	µg/L	Discharge Conc < TQL
1,2-Dichlorobenzene	845	µg/L	Discharge Conc < TQL
1,3-Dichlorobenzene	37.0	µg/L	Discharge Conc < TQL
1,4-Dichlorobenzene	793	µg/L	Discharge Conc < TQL
3,3-Dichlorobenzidine	1.2	µg/L	Discharge Conc < TQL
Diethyl Phthalate	3,171	µg/L	Discharge Conc < TQL
Model Result Dimethyl Phthalate	2,642	µg/L	Discharge Conc ≤ 25% WQBEL

Di-n-Butyl Phthalate	106	µg/L	Discharge Conc < TQL
2,4-Dinitrotoluene	1.2	µg/L	Discharge Conc < TQL
2,6-Dinitrotoluene	1.2	µg/L	Discharge Conc < TQL
Di-n-Octyl Phthalate	N/A	N/A	No WQS
1,2-Diphenylhydrazine	0.72	µg/L	Discharge Conc < TQL
Fluoranthene	106	µg/L	Discharge Conc < TQL
Fluorene	264	µg/L	Discharge Conc < TQL
Hexachlorobenzene	0.002	µg/L	Discharge Conc < TQL
Hexachlorobutadiene	0.24	µg/L	Discharge Conc < TQL
Hexachlorocyclopentadiene	5.28	µg/L	Discharge Conc < TQL
Hexachloroethane	2.39	µg/L	Discharge Conc < TQL
Indeno(1,2,3- <i>cd</i> )Pyrene	0.024	µg/L	Discharge Conc < TQL
Isophorone	180	µg/L	Discharge Conc < TQL
Naphthalene	227	µg/L	Discharge Conc < TQL
Nitrobenzene	52.8	µg/L	Discharge Conc < TQL
<i>n</i> -Nitrosodimethylamine	0.017	µg/L	Discharge Conc < TQL
<i>n</i> -Nitrosodi- <i>n</i> -Propylamine	0.12	µg/L	Discharge Conc < TQL
<i>n</i> -Nitrosodiphenylamine	78.9	µg/L	Discharge Conc < TQL
Phenanthrene	5.28	µg/L	Discharge Conc < TQL
Pyrene	106	µg/L	Discharge Conc < TQL
1,2,4-Trichlorobenzene	0.37	µg/L	Discharge Conc < TQL

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet							
Type of Test	Chronic			Facility Name			
Species Tested	Ceriodaphnia			Saxonburg Area Authority			
Endpoint	Survival			Permit No.			
TIWC (decimal)	0.28			PA0029122			
No. Per Replicate	1						
TST b value	0.75						
TST alpha value	0.2						
Test Completion Date							
Replicate	6/28/2021			Replicate	7/4/2022		
No.	Control	TIWC		No.	Control	TIWC	
1	1	1		1	1	1	
2	1	1		2	1	1	
3	1	1		3	1	1	
4	1	1		4	1	1	
5	1	1		5	1	1	
6	1	1		6	1	1	
7	1	1		7	1	1	
8	1	1		8	1	1	
9	1	1		9	1	1	
10	1	1		10	1	1	
11				11			
12				12			
13				13			
14				14			
15				15			
Mean	1.000	1.000		Mean	1.000	1.000	
Std Dev.	0.000	0.000		Std Dev.	0.000	0.000	
# Replicates	10	10		# Replicates	10	10	
T-Test Result							
Deg. of Freedom				T-Test Result			
Critical T Value				Deg. of Freedom			
Pass or Fail	PASS			Critical T Value			
Test Completion Date							
Replicate	7/5/2023			Replicate	7/1/2024		
No.	Control	TIWC		No.	Control	TIWC	
1	1	1		1	1	1	
2	1	1		2	1	1	
3	1	1		3	1	1	
4	1	1		4	1	1	
5	1	1		5	1	1	
6	1	1		6	1	1	
7	1	1		7	1	1	
8	1	1		8	0	1	
9	1	1		9	1	0	
10	1	1		10	1	1	
11				11			
12				12			
13				13			
14				14			
15				15			
Mean	1.000	1.000		Mean	0.900	0.900	
Std Dev.	0.000	0.000		Std Dev.	0.316	0.316	
# Replicates	10	10		# Replicates	10	10	
T-Test Result							
Deg. of Freedom				T-Test Result	1.8000		
Critical T Value				Deg. of Freedom	18		
Pass or Fail	PASS			Critical T Value	0.8647		
Test Completion Date							
Replicate				Replicate			
No.	Control	TIWC		No.	Control	TIWC	
1				1			
2				2			
3				3			
4				4			
5				5			
6				6			
7				7			
8				8			
9				9			
10				10			
11				11			
12				12			
13				13			
14				14			
15				15			
Mean				Mean			
Std Dev.				Std Dev.			
# Replicates				# Replicates			
T-Test Result							
Deg. of Freedom				T-Test Result			
Critical T Value				Deg. of Freedom			
Pass or Fail	PASS			Critical T Value			

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet						
Type of Test	Chronic			Facility Name		
Species Tested	Ceriodaphnia			Saxonburg Area Authority		
Endpoint	Reproduction			Permit No.		
TIWC (decimal)	0.28			PA0029122		
No. Per Replicate	1					
TST b value	0.75					
TST alpha value	0.2					
Test Completion Date						
Replicate	6/28/2021			Replicate	7/4/2022	
No.	Control	TIWC		No.	Control	TIWC
1	33	33		1	26	22
2	30	23		2	14	8
3	33	23		3	22	20
4	22	22		4	26	23
5	24	33		5	22	24
6	22	29		6	19	23
7	26	29		7	21	22
8	22	26		8	25	7
9	25	29		9	25	23
10	26	31		10	23	20
11				11		
12				12		
13				13		
14				14		
15				15		
Mean	26.300	27.800		Mean	22.300	19.000
Std Dev.	4.286	4.104		Std Dev.	3.713	6.716
# Replicates	10	10		# Replicates	10	10
T-Test Result	4.8939			T-Test Result	0.8894	
Deg. of Freedom	16			Deg. of Freedom	14	
Critical T Value	0.8647			Critical T Value	0.8681	
Pass or Fail	PASS			Pass or Fail	PASS	
Test Completion Date						
Replicate	7/5/2023			Replicate	7/1/2024	
No.	Control	TIWC		No.	Control	TIWC
1	21	25		1	17	16
2	25	15		2	15	16
3	24	15		3	14	17
4	11	15		4	14	19
5	27	19		5	19	20
6	31	22		6	20	17
7	21	15		7	17	23
8	22	27		8	0	21
9	11	22		9	16	6
10	33	21		10	20	15
11				11		
12				12		
13				13		
14				14		
15				15		
Mean	22.600	19.600		Mean	15.200	17.000
Std Dev.	7.306	4.502		Std Dev.	5.789	4.819
# Replicates	10	10		# Replicates	10	10
T-Test Result	1.1817			T-Test Result	2.7936	
Deg. of Freedom	17			Deg. of Freedom	17	
Critical T Value	0.8633			Critical T Value	0.8633	
Pass or Fail	PASS			Pass or Fail	PASS	

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet							
Type of Test	Chronic			Facility Name			
Species Tested	Pimephales			Saxonburg Area Authority			
Endpoint	Survival			Permit No.			
TIWC (decimal)	0.28			PA0029122			
No. Per Replicate	10						
TST b value	0.75						
TST alpha value	0.25						
Test Completion Date							
Replicate	6/29/2021			Replicate	7/5/2022		
No.	Control	TIWC		No.	Control	TIWC	
1	1	0.8		1	1	1	
2	0.7	1		2	1	1	
3	0.7	0.7		3	1	1	
4	1	0.9		4	1	1	
5				5			
6				6			
7				7			
8				8			
9				9			
10				10			
11				11			
12				12			
13				13			
14				14			
15				15			
Mean	0.850	0.850		Mean	1.000	1.000	
Std Dev.	0.173	0.129		Std Dev.	0.000	0.000	
# Replicates	4	4		# Replicates	4	4	
T-Test Result	4.5011			T-Test Result			
Deg. of Freedom	5			Deg. of Freedom			
Critical T Value	0.7287			Critical T Value			
Pass or Fail	PASS			Pass or Fail	PASS		
Test Completion Date							
Replicate	7/4/2023			Replicate	7/2/2024		
No.	Control	TIWC		No.	Control	TIWC	
1	0.9	0.9		1	1	0.9	
2	0.9	0.5		2	1	1	
3	1	0.9		3	1	1	
4	1	1		4	1	1	
5				5			
6				6			
7				7			
8				8			
9				9			
10				10			
11				11			
12				12			
13				13			
14				14			
15				15			
Mean	0.950	0.825		Mean	1.000	0.975	
Std Dev.	0.058	0.222		Std Dev.	0.000	0.050	
# Replicates	4	4		# Replicates	4	4	
T-Test Result	2.4762			T-Test Result	17.8823		
Deg. of Freedom	3			Deg. of Freedom	3		
Critical T Value	0.7649			Critical T Value	0.7649		
Pass or Fail	PASS			Pass or Fail	PASS		

DEP Whole Effluent Toxicity (WET) Analysis Spreadsheet						
Type of Test	Chronic			Facility Name		
Species Tested	Pimephales			Saxonburg Area Authority		
Endpoint	Growth			Permit No.		
TIWC (decimal)	0.28			PA0029122		
No. Per Replicate	10					
TST b value	0.75					
TST alpha value	0.25					
Test Completion Date						
Replicate	6/29/2021			Replicate	7/4/2022	
No.	Control	TIWC		No.	Control	TIWC
1	0.256	0.259		1	0.356	0.383
2	0.285	0.246		2	0.35	0.399
3	0.3	0.31		3	0.373	0.378
4	0.31	0.301		4	0.345	0.358
5				5		
6				6		
7				7		
8				8		
9				9		
10				10		
11				11		
12				12		
13				13		
14				14		
15				15		
Mean	0.288	0.279		Mean	0.356	0.379
Std Dev.	0.024	0.031		Std Dev.	0.012	0.017
# Replicates	4	4		# Replicates	4	4
T-Test Result	3.5194			T-Test Result	11.6093	
Deg. of Freedom	5			Deg. of Freedom	5	
Critical T Value	0.7287			Critical T Value	0.7287	
Pass or Fail	PASS			Pass or Fail	PASS	
Test Completion Date						
Replicate	7/4/2023			Replicate	7/2/2024	
No.	Control	TIWC		No.	Control	TIWC
1	0.451	0.424		1	0.403	0.382
2	0.453	0.266		2	0.356	0.386
3	0.483	0.482		3	0.418	0.437
4	0.485	0.472		4	0.447	0.443
5				5		
6				6		
7				7		
8				8		
9				9		
10				10		
11				11		
12				12		
13				13		
14				14		
15				15		
Mean	0.463	0.406		Mean	0.406	0.410
Std Dev.	0.016	0.096		Std Dev.	0.038	0.038
# Replicates	4	4		# Replicates	4	4
T-Test Result	1.2200			T-Test Result	4.4256	
Deg. of Freedom	3			Deg. of Freedom	5	
Critical T Value	0.7649			Critical T Value	0.7287	
Pass or Fail	PASS			Pass or Fail	PASS	

**WET Summary and Evaluation**

Facility Name	Saxonburg Area Authority
Permit No.	PA0029122
Design Flow (MGD)	2.052
Q <sub>7-10</sub> Flow (cfs)	8.65
PMF <sub>a</sub>	0.454
PMF <sub>c</sub>	1

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Survival	PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Ceriodaphnia	Reproduction	PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Survival	PASS	PASS	PASS	PASS

Species	Endpoint	Test Results (Pass/Fail)			
		Test Date	Test Date	Test Date	Test Date
Pimephales	Growth	PASS	PASS	PASS	PASS

Reasonable Potential? NO

**Permit Recommendations**

Test Type Chronic  
 TIWC 27 % Effluent  
 Dilution Series 7, 14, 27, 64, 100 % Effluent  
 Permit Limit None  
 Permit Limit Species