

Application Type Renewal  
Facility Type Municipal  
Major / Minor Major

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0029289  
APS ID 723786  
Authorization ID 1279529

**Applicant and Facility Information**

Applicant Name	<u>Brodhead Creek Region Authority</u>	Facility Name	<u>Brodhead Creek Regional Authority STP</u>
Applicant Address	<u>410 Mill Creek Road</u> <u>East Stroudsburg, PA 18301-1126</u>	Facility Address	<u>20 South Fourth Street</u> <u>Stroudsburg, PA 18360</u>
Applicant Contact	<u>David Horton</u>	Facility Contact	<u>Michael Reisenwitz</u>
Applicant Phone	<u>(570) 421-3232</u>	Facility Phone	<u>(570) 421-2270</u>
Client ID	<u>87465</u>	Site ID	<u>238612</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Stroudsburg Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Monroe</u>
Date Application Received	<u>June 27, 2019</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>June 27, 2019</u>	If No, Reason	<u>Major Facility</u>
Purpose of Application	<u>Renewal of an existing NPDES Permit for treated Sewage</u>		

**Summary of Review**

This application is for the Stroudsburg Borough Sewage Treatment Plant's NPDES permit renewal for the discharge of 4.5 MGD of treated sewage and stormwater into McMichael Creek. McMichael Creek is a TSF-MF receiving stream in the Brodhead Creek watershed 1E and is classified for Migratory Fishes / Trout Stocking, aquatic life, water supply and recreation. Per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than their designated use. The discharge is not expected to affect public water supplies.

The Facility serves Stroudsburg Borough, Stroud Township, Pocono Township, Hamilton Borough, and Tobyhanna Township. The SBRs discharge through Outfall 001. Outfall 002 is for stormwater only and stormwater Outfalls 003 & 004 have been turned back to the Borough of Stroudsburg. The existing limits will be retained from the Present Permit including the Part C language concerning stream temperature:

- *The discharge of wastewater shall not increase the ambient temperatures of the receiving waters by more than 5°F, nor shall such discharge result in stream temperatures exceeding 87°F.*

Mercury limits will be introduced in year 4 of the permit. The limitations and monitoring requirements specified for the draft permit reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001) and/or BPJ.

The WMS Report query "Water Management System Inspections" was run. On 06/19/2019 a Compliance Evaluation was done with No Violations noted.

The WMS "Open Violations by Client Report" was run and there are No Open Violations.

The Existing Permit expires on January 31, 2020 and the renewal was submitted June 27, 2019.

Approve	Deny	Signatures	Date
X		Bernard Feist, P.E. / Environmental Engineer /s/	August 1, 2019
X		Amy M. Bellanca, P.E. / Environmental Engineer Manager /s/	August 1, 2019

**Summary of Review**

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	4.5
Latitude	40° 59' 14.72"	Longitude	-75° 11' 11.32"
Quad Name		Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	McMichael Creek (TSF, MF)	Stream Code	4778
NHD Com ID	26175214	RMI	0.2
Drainage Area	114 mi <sup>2</sup>	Yield (cfs/mi <sup>2</sup> )	0.197
Q <sub>7-10</sub> Flow (cfs)	22.5 cfs	Q <sub>7-10</sub> Basis	DFlow Gage 01442500
Elevation (ft)	376	Slope (ft/ft)	
Watershed No.	1-E	Chapter 93 Class.	TSF, MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	PATHOGENS		
Source(s) of Impairment	SOURCE UNKNOWN		
TMDL Status		Name	
Background/Ambient Data		Data Source	
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake	City of Easton		
PWS Waters		Flow at Intake (cfs)	
PWS RMI		Distance from Outfall (mi)	➤ 30 miles

McMichael Creek RMI 0.2 **WRDS: 4778** HUC 8 Code: **02040104**

USGS STATION.--01442500 BROADHEAD CREEK AT MINISINK HILLS, PA  
 LOCATION.--Lat 40° 59'55", long 75° 08'35", Monroe County, Hydrologic Unit 02040104, on left bank at Minisink Hills, 500 ft upstream from Marshall Creek, 0.8 mi upstream from mouth, and 3.0 mi southeast of East Stroudsburg.  
 DRAINAGE AREA.--259 square miles.  
 PERIOD OF RECORD.--November 1950 to current year.

DFLOW Results				
Gage	Period	Days in +	7Q10	Harmonic
01442500 - Brodhead Creek at Minisink Hills, PA	1994/04/01 - 2018/04/01	8,766	50.9	2.52E+02


Double-click on biological flow value for excursion analysis

Q<sub>7-10</sub> LowFlowYield (cfs/mi<sup>2</sup>)= 50.9 / 259 = 0.197

**RMI 0.2 Outfall 001 at 376 ft**

**StreamStats Report**

Region ID: PA  
 Workspace ID: PA201907251305083  
 Clicked Point (Latitude, Longitude): 40.98751, -75.18595  
 Time: 2019-07-25 09:05:24



Low-Flow Statistics Parameters: 8 Percent (8.9 square miles) Low Flow Region 2


Parameter Code	Parameter Name	Value	Units
DRNAREA	Drainage Area	114	square miles

Stream Q7-10 Flow (cfs) = 0.197 \* 114 = 22.5 cfs

**RMI 0.0 at 370 ft**

**StreamStats Report**

Region ID: PA  
 Workspace ID: PA20190725131708050  
 Clicked Point (Latitude, Longitude): 40.98733, -75.18380  
 Time: 2019-07-25 09:17:24 -0



Low-Flow Statistics Parameters: 5 Percent (12.1 square miles) Low Flow Region 2

Parameter Code	Parameter Name	Value	Units
DRNAREA	Drainage Area	258	square miles

Treatment Facility Summary				
Treatment Facility Name: Brodhead Creek Regional Authority WWTP				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia And Phosphorus	Sequencing Batch Reactor	Ultraviolet	4.5
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
4.5	11400	Not Overloaded	Combination	Landfill

Changes Since Last Permit Issuance: Construction Completion. WQM # 4509405.(SBRs).

**Development of Effluent Limitations**

Outfall No.	001	Design Flow (MGD)	4.5
Latitude	40° 59' 16.00"	Longitude	-75° 11' 10.00"
Wastewater Description:	Sewage Effluent		

**Technology-Based Limitations**


The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: UV disinfection

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):



**TOXICS SCREENING ANALYSIS  
 WATER QUALITY POLLUTANTS OF CONCERN  
 VERSION 2.6**

CLEAR FORM

Facility: **BCRA** NPDES Permit No.: **PA0029289** Outfall: **001**  
 Analysis Hardness (mg/L): **116** Discharge Flow (MGD): **4.5** Analysis pH (SU): **7**  
 Stream Flow, Q<sub>7-10</sub> (cfs): **22.5**

Parameter	Maximum Concentration in Application or DMRs (µg/L)	Most Stringent Criterion (µg/L)	Candidate for PENTOXSD Modeling?	Most Stringent WQBEL (µg/L)	Screening Recommendation
<b>Group 1</b> Total Dissolved Solids	693000	500000	Yes	na	#VALUE!
Chloride	118000	250000	No		#VALUE!
Bromide	< 1000	N/A	No		#VALUE!
Sulfate	64000	250000	No		#VALUE!
<b>Group 2</b> Total Aluminum	< 100	750	No		
Total Antimony	0.4	5.6	No		
Total Arsenic	< 1	10	No (Value < QL)		
Total Barium	12	2400	No		
Total Beryllium	< 0.4	N/A	No		
Total Boron	142	1600	No		
Total Cadmium	< 0.08	0.302	No (Value < QL)		
Total Chromium	< 1	N/A	No		
Hexavalent Chromium	< 0.047	10.4	No (Value < QL)		
Total Cobalt	< 1	19	No (Value < QL)		
Total Copper	4	10.6	No		
Free Available Cyanide	5	5.2	No		
Total Cyanide	< 5	N/A	No		
Dissolved Iron	87	300	No		
Total Iron	104	1500	No		
Total Lead	< 1	3.8	No (Value < QL)		
Total Manganese	23	1000	No		
Total Mercury	0.497	0.05	Yes	0.211	Establish Limits

Analysis Results

**Effluent Limits**

Hydrodynamics		Wasteload Allocations		Effluent Limits			
RMI	Name	Permit Number	Disc Flow (mgd)				
0.2	BCRA	0029289	4.5000				
Parameter	Effluent Limit (µg/L)	Governing Criterion	Max. Daily Limit (µg/L)	Most Stringent			
▶ 1,1-DICHLOROETHYLENE	0.5	INPUT	0.78	139.459	THH		
BIS(2-ETHYLHEXYL) PHTHALATE	1.29	INPUT	2.013	20.634	CRL		
MERCURY	0.211	THH	0.33	0.211	THH		
TOTAL DISSOLVED SOLIDS (PWS)	693000	INPUT	1080000	NA	NA		
VANADIUM	1	INPUT	1.56	422.603	CFC		



BCRA 2019 Models.pdf

Comments: 2019 Modelling pdf ->



BCRA 2008 Models.pdf

2008 Modelling ->

**Best Professional Judgment (BPJ) Limitations**

Comments: Delay Mercury limits for 3 years for the development of a TRE

**Anti-Backsliding**

**DOCKET NO. D-1986-011 CP-4  
 DELAWARE RIVER BASIN COMMISSION  
 EFFLUENT TABLE A-1: DRBC Parameters Included in NPDES permit**

OUTFALL 001 (McMichael Creek)		
PARAMETER	LIMIT	MONITORING
pH (Standard Units)	6 to 9 at all times	As required by NPDES permit
Total Suspended Solids	85% minimum removal 10 mg/l; 375 lbs/day	As required by NPDES permit
CBOD (5-Day at 20° C)	10 mg/l; 375 lbs/day 85% minimum removal*	As required by NPDES permit
Ammonia-Nitrogen (5/1 to 10/31)	1.5 mg/l, 56.3 lbs/day	As required by NPDES permit
Ammonia-Nitrogen (11/1 to 4/30)	4.5 mg/l; 169 lbs/day	As required by NPDES permit
Fecal Coliform	200 colonies per 100 ml	As required by NPDES permit
Dissolved Oxygen	7.0 mg/l (minimum at all times)	As required by NPDES permit
Nitrate-Nitrogen (5/1 - 10/31)	4.0 mg/l; 150 lbs/day	As required by NPDES permit
Total Phosphorous	1.0 mg/l; 37.5 lbs/day	As required by NPDES permit
Total Dissolved Solids**	1,000 mg/l	As required by NPDES permit

\* Per the NPDES permit, 85% minimum removal of CBOD5 or BOD5 \*\*

**EFFLUENT TABLE A-2: DRBC Parameters Not Included in NPDES permit**

OUTFALL 001 (McMichael Creek)		
PARAMETER	LIMIT	MONITORING
Total Kjeldahl Nitrogen (TKN)	Monitor & Report	Monthly
Nitrite+Nitrate-Nitrogen	Monitor & Report	Monthly

**Whole Effluent Toxicity (WET)**

For Outfall 001,  **Acute**  **Chronic** WET Testing was completed:

- For the permit renewal application (4 tests).
- Quarterly throughout the permit term.
- Quarterly throughout the permit term and a TIE/TRE was conducted.
- Other: Yearly

The dilution series used for the tests was:

Sub Fac

General TMDL Streams Location NHD Additives **WETT**

Q7-10 Flow\*  cfs PMFa\*  PMFc\*  WETT Required by Permit?   
 WETT Failure(s)?

IWCa  % Test Type  Test Type for Failures(s)

IWCc  % Test Type (Other)

TIWc  % Dilution Series      Comments

Species Type\* Species

CDUBI	Ceriodaphnia Dubia
PPROM	Pimephales Promelas

**Summary of Four Most Recent Test Results**

NOEC/LC50 Data Analysis

Test Date	Ceriodaphnia Results (% Effluent)			Pimephales Results (% Effluent)			Pass? *
	NOEC Survival	NOEC Reproduction	LC50	NOEC Survival	NOEC Growth	LC50	
8/21/2018	100	100	100	100	100	100	Pass
8/28/2017	100	100	100	100	100	100	Pass
7/19/2016	100	100	100	100	100	100	Pass
7/14/2015	100	100	100	100	100	100	Pass
7/7/2014	100	100	100	100	100	100	Pass
4/15/2014	100	100	100	100	100	100	Pass

\* A "passing" result is that which is greater than or equal to the TIWC value.

Is there reasonable potential for an excursion above water quality standards based on the results of these tests? (NOTE – In general, reasonable potential is determined anytime there is at least one test failure in the previous four tests).

YES  NO



**Evaluation of Test Type, IWC and Dilution Series for Renewed Permit**

**2019 update**

Sub Fac 204539 001 OUTFALL #001

General TMDL Streams Location NHD Additives **WETT**

Q7-10 Flow\* 22.5 cfs PMFa\* 0.491 PMFc\* 1.0 WETT Required by Permit?   
 WETT Failure(s)?

IWCa 38.66 % Test Type Chronic Test Type for Failures(s)   
 IWCC 23.63 % Test Type (Other)

TIWC 24 % Dilution Series 1st 2nd 3rd 4th 5th 6 12 24 62 100 Comments From 2019 Pollution Report; SBRs we

Species Type*	Species
CDUBI	Ceriodaphnia Dubia
PPROM	Pimephales Promelas

Acute Partial Mix Factor (PMFa): **0.491**

Chronic Partial Mix Factor (PMFc): **1.0**

**WET Limits**

Has reasonable potential been determined?  YES  NO

Will WET limits be established in the permit?  YES  NO

**Compliance History**

**DMR Data for Outfall 001 (from June 1, 2018 to May 31, 2019)**

Parameter	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18	OCT-18	SEP-18	AUG-18	JUL-18	JUN-18
Flow (MGD) Average Monthly	2.753	2.568	2.612	2.388	2.653	2.698	2.851	2.284	2.404	2.304	1.966	1.926
Flow (MGD) Daily Maximum	4.292	3.922	3.622	2.736	5.102	5.379	3.448	3.099	3.352	3.609	3.246	2.493
pH (S.U.) Minimum	6.9	6.8	6.8	6.7	6.7	6.8	6.8	6.9	7.0	7.4	6.9	7.0
pH (S.U.) Maximum	7.3	7.3	7.2	7.3	7.2	7.3	7.4	7.6	7.4	7.8	7.4	7.3
DO (mg/L) Instantaneous Minimum	7.8	8.0	9.1	9.3	9.3	9.2	8.6	7.9	7.5	7.4	7.5	7.5
CBOD5 (lbs/day) Average Monthly	< 47	< 48	< 44	< 50	< 42	54	< 99	< 59	63	58	< 50	< 51
CBOD5 (lbs/day) Weekly Average	< 62	< 77	47	< 83	< 49	57	< 194	< 74	86	66	66	61
CBOD5 (mg/L) Average Monthly	< 2.0	< 2.2	< 2.0	< 2.6	< 2.0	2.6	< 4.1	< 3.1	2.9	3.0	< 2.9	< 3.1
CBOD5 (mg/L) Weekly Average	< 2.0	< 2.8	< 2.0	< 4.2	< 2.0	3.2	< 8.6	< 3.7	3.6	3.0	< 3.0	3.6
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	8665	8473	5793	4974	3816	3877	4548	6317	4646	4052	1901	3095
BOD5 (mg/L) Raw Sewage Influent Average Monthly	340	364	260	232	172	177	179	301	206	197	102	171
TSS (lbs/day) Average Monthly	< 95	< 84	< 90	< 83	< 84	83	< 111	< 75	76	57	< 56	< 45

TSS (lbs/day) Raw Sewage Influent   Average Monthly	9640	9289	6332	5586	4954	4346	4616	5705	7069	5552	7111	9734
TSS (lbs/day) Weekly Average	< 123	< 108	< 101	< 92	< 98	96	< 140	< 91	117	99	90	< 51
TSS (mg/L) Average Monthly	< 4.0	< 4.0	< 4.1	< 4.2	< 4.0	3.9	< 4.5	< 4.1	3.5	3.0	< 3.3	< 2.8
TSS (mg/L) Raw Sewage Influent   Average Monthly	379	407	284	261	223	200	182	279	467	270	388	538
TSS (mg/L) Weekly Average	< 4.0	< 4.0	< 4.3	< 4.9	< 4.0	4.0	< 4.5	< 5.0	5.0	5.3	5.8	< 3.2
Total Dissolved Solids (lbs/day) Average Monthly	10619	9701	12480	9788	8134	8927	11083	9650	10103	9786	11335	9290
Total Dissolved Solids (mg/L) Average Monthly	452	467	563	493	390	426	454	500	474	511	693	576
Fecal Coliform (CFU/100 ml) Geometric Mean	< 2	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	5	3	3	2.0	4	2	< 2	1.5	< 1	2.0	1	1
Nitrate-Nitrite (lbs/day) Average Monthly	< 72	< 75	< 59	< 51	< 52	< 52	< 54	< 40	45	47	36	42
Nitrate-Nitrite (mg/L) Average Monthly	< 3.0	< 3.5	< 2.6	< 2.56	< 2.482	< 2.45	< 2.158	< 2.105	2.15	< 2.46	2.065	2.63
Total Nitrogen (lbs/day) Average Monthly	< 98	107	< 92	< 53	< 76	< 69	86	< 61	60	67	57	72
Total Nitrogen (mg/L) Average Monthly	< 4.1	5.0	< 4.1	< 2.7	< 3.638	< 3.27	3.453	< 3.24	2.877	3.47	3.367	4.48
Ammonia (lbs/day) Average Monthly	< 2.7	< 2.1	< 2.3	< 2.8	< 5.2	< 5.3	< 7.5	< 4.2	< 3.4	9.6	< 8.5	< 10.6
Ammonia (mg/L) Average Monthly	< 0.11	< 0.1	< 0.1	< 0.14	< 0.23	< 0.26	< 0.283	< 0.2	< 0.16	< 0.5	< 0.5	< 0.65
Nitrate (lbs/day) Average Monthly	69							< 37	44	46	35	41
Nitrate (mg/L) Average Monthly	2.9							< 1.93	2.1	< 2.41	2.04	2.6
TKN (lbs/day) Average Monthly	32	32	< 33	< 34	24	< 17	< 25	< 21	16	< 21	22	30
TKN (mg/L) Average Monthly	1.4	1.6	< 1.5	< 1.7	1.16	< 0.83	< 1.011	< 1.135	< 0.793	< 1.1	1.3	1.9
Total Phosphorus (lbs/day) Average Monthly	< 2.5	< 2.2	< 2.2	< 2.2	< 2.1	< 2.8	< 1.6	< 2.7	< 3.9	< 1.4	< 1.5	< 2.6
Total Phosphorus (mg/L) Average Monthly	< 0.1	< 0.11	< 0.1	< 0.11	< 0.1	< 0.14	< 0.07	< 0.14	< 0.18	< 0.07	< 0.09	< 0.16

**DMR Data for Outfall 002 (from June 1, 2018 to May 31, 2019)**

Parameter	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18	OCT-18	SEP-18	AUG-18	JUL-18	JUN-18
TSS (mg/L) Daily Maximum						44.2						
TKN (mg/L) Daily Maximum						< 1.00						
Total Iron (mg/L) Daily Maximum						0.758						