

Application Type Renewal
Facility Type Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0029726
APS ID 1021119
Authorization ID 1322789

Applicant and Facility Information

Applicant Name	<u>Jamestown Borough Municipal Authority</u>	Facility Name	<u>Jamestown Municipal STP</u>
Applicant Address	<u>406 Jackson Street</u> <u>Jamestown, PA 16134-0188</u>	Facility Address	<u>Main Street Extension</u> <u>Jamestown, PA 16134</u>
Applicant Contact	<u>Charles Swartz</u>	Facility Contact	<u>Michael Davidson</u>
Applicant Phone	<u>(724) 932-3644</u>	Facility Phone	<u>(724) 372-3339</u>
Client ID	<u>207</u>	Site ID	<u>261230</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Jamestown Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Mercer</u>
Date Application Received	<u>July 31, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>August 13, 2020</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of an NPDES Permit for an existing discharge of treated sewage from a POTW.</u>		

Summary of Review

This is a municipally owned sewage treatment plant serving the Borough of Jamestown, Mercer County. There are no commercial or industrial users and the facility is currently not accepting hauled in waste.

There are no proposed changes to the discharge quantity or quality as part of this permit renewal.

The plant discharges to a segment of the Shenango River, which is known to contain threatened and endangered mussel species. A summary of threatened and endangered mussel species concerns and considerations is included on Page 9 of this Fact Sheet. Additionally, the draft permit will be forwarded to the US Fish & Wildlife Service and PA Fish and Boat Commission.

There are currently no open violations listed in EFACTS for this permittee (10/21/2021).

Sludge use and disposal description and location(s): Sludge is hauled offsite and disposed of at Mahoning Landfill in Springfield, Ohio.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Adam J. Pesek Adam J. Pesek, E.I.T. / Environmental Engineer	October 21, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	October 22, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.26</u>
Latitude	<u>41° 28' 59"</u>	Longitude	<u>-80° 26' 30"</u>
Quad Name	<u>Greenville West</u>	Quad Code	<u>0702</u>
Wastewater Description: <u>Domestic Sewage</u>			
Receiving Waters	<u>Shenango River</u>	Stream Code	<u>35482</u>
NHD Com ID	<u>130027726</u>	RMI	<u>66.34</u>
Drainage Area	<u>170.8</u>	Yield (cfs/mi ²)	<u>0.023</u>
Q ₇₋₁₀ Flow (cfs)	<u>11.21 (Summer), 8.145 (winter)</u>	Q ₇₋₁₀ Basis	<u>USGS # 03101500, accrued flow #03100000</u>
Elevation (ft)	<u>968</u>	Slope (ft/ft)	<u>0.00083</u>
Watershed No.	<u>20-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.71</u>		<u>WQN 911 field samples (2005-2020)(June-September)</u>
	<u>20.24 (Sum),</u>		
Temperature (°C)	<u>4.71 (Win)</u>		<u>WQN 911 (2005-2020)</u>
Hardness (mg/L)	<u>70</u>		<u>WQN 911 (2005-2020)(90th %)</u>
NH ₃ -N	<u>0.11</u>		<u>WQN 911 field samples (2002-2011)</u>
CBOD	<u>2.2</u>		<u>2005 sampling for NIDR – Shenango River Watershed</u>
Nearest Downstream Public Water Supply Intake	<u>Greenville Municipal Authority</u>		
PWS Waters	<u>Shenango River</u>	Flow at Intake (cfs)	<u>35.7</u>
PWS RMI	<u>57</u>	Distance from Outfall (mi)	<u>9.34</u>

Changes Since Last Permit Issuance:

Other Comments:

Treatment Facility Summary				
Treatment Facility Name: Jamestown Municipal STP				
WQM Permit No.		Issuance Date		
4399407 A-1		10/03/2013		
4300404 A-2		3/25/2019		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	UV Light	0.26
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.26	266	Not Overloaded	Drying	Landfill

Changes Since Last Permit Issuance: WQM Permit 4300404 A-2 was issued which permitted the replacement of the Liberty street pump station, replacement of the influent interceptor sewer, a new mechanical bar screen and channel, a new influent pump station, improvements to the aeration tanks, addition of four new clarifiers, making repairs to the existing clarifiers, replacement of the disinfection system with UV disinfection equipment, removing of existing sludge holding tank, construction of two new sludge holding tanks

Other Comments: N/A

Compliance History	
Summary of DMRs:	One effluent violation (total phosphorus) reported in the last 5 years.
Summary of Inspections:	Last site inspection was conducted on 7/31/2020. The inspection report indicated the planned plant improvements have not started as of that date because bids were higher than expected. Issues noted were the comminutor was not operational and updated Lab Accreditation Form with current contract lab information and lab registration information for on-site analysis was necessary. A CACP was executed on 12/22/2020 for late submission of the NPDES Permit renewal application.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from September 1, 2020 to August 31, 2021)

Parameter	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20
Flow (MGD) Average Monthly	0.054	0.102	0.054	0.087	0.059	0.078	0.063	0.120	0.146	0.080	0.056	0.042
Flow (MGD) Daily Maximum	0.136	0.607	0.093	0.194	0.138	0.176	0.148	0.398	0.317	0.144	0.180	0.085
pH (S.U.) Minimum	7.0	7.0	7.0	6.8	6.9	6.8	6.9	6.5	6.6	6.7	6.7	6.7
pH (S.U.) Maximum	7.3	7.4	7.5	7.1	7.4	7.3	7.4	6.8	6.8	7.0	7.0	7.0
DO (mg/L) Minimum	5.7	4.4	6.9	7.4	7.1	4.9	4.5	4.4	5.5	6.5	4.5	5.1
TRC (mg/L) Average Monthly	0.2	0.2	0.3	0.2	0.3	0.3	0.3	0.3	0.3	0.2	0.3	0.2
TRC (mg/L) Instantaneous Maximum	0.4	0.5	0.7	0.5	0.5	0.6	0.4	0.4	0.7	0.4	0.5	0.3
CBOD5 (lbs/day) Average Monthly	2.5	4.4	< 1.8	< 2.6	< 1.1	2.8	1.6	< 2.8	< 3.5	< 2.1	< 1.5	< 1.3
CBOD5 (lbs/day) Weekly Average	5	7	2	< 5	2	5	2	< 5	< 5	3	< 2.1	< 2
CBOD5 (mg/L) Average Monthly	5	6	< 5	< 3	< 2	4	3	< 3	< 3	< 3	< 3	< 3
CBOD5 (mg/L) Weekly Average	7	9	10	< 6	4	4	5	< 3	< 3	4	4	< 5
BOD5 (lbs/day) Raw Sewage Influent Average Monthly	68	122	55	67	88	65	78	139	128	64	82	53
BOD5 (lbs/day) Raw Sewage Influent Daily Maximum	159	239	91	107	106	80	145	349	199	81	150	73
BOD5 (mg/L) Raw Sewage Influent Average Monthly	132	143	123	85	200	95	152	125	105	108	175	135
TSS (lbs/day) Average Monthly	< 2.3	< 4.3	< 2.0	< 4.8	< 2.3	< 3.6	< 2.5	< 4.7	< 7.3	< 3.2	< 2.4	< 2.0

**NPDES Permit Fact Sheet
Jamestown Municipal STP**

NPDES Permit No. PA0029726

TSS (lbs/day) Raw Sewage Influent Average Monthly	55	93	36	51	64	58	55	50	93	55	59	35
TSS (lbs/day) Raw Sewage Influent Daily Maximum	119	253	50	82	94	78	71	55	202	72	82	61
TSS (lbs/day) Weekly Average	< 4	< 8	< 3	10	< 3	< 6	< 3	9	11	< 4	3	< 3
TSS (mg/L) Average Monthly	< 5	< 5	< 5	< 5	< 5	< 5	< 5	< 5	< 6	< 5	< 5	< 5
TSS (mg/L) Raw Sewage Influent Average Monthly	111	112	79	81	144	90	110	69	73	94	135	90
TSS (mg/L) Weekly Average	< 5	< 5	5	6	< 5	< 5	< 5	< 5	7	< 5	6	< 5
Fecal Coliform (CFU/100 ml) Geometric Mean	31	38	59	9	3	17	108	22	13	27	34	24
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	208	99	411	59	10	210	866	121	23	33	76	228
Total Nitrogen (lbs/day) Average Monthly	5	10	6	8	5	5	5	5	7	7	6	5
Total Nitrogen (mg/L) Average Monthly	10.1	9.6	13.13	8.8	10.6	7.61	9.5	5.69	5.8	11.4	13.6	12.2
Ammonia (lbs/day) Average Monthly	< 1	< 2	< 1	< 1	< 1	< 1	< 2	< 1	< 1	< 1	< 1	< 1
Ammonia (mg/L) Average Monthly	< 3	< 3	< 3	< 1	< 1	< 1	< 3	< 2	< 1	< 1	< 1	< 1
Total Phosphorus (lbs/day) Average Monthly	0.2	0.4	0.5	0.2	0.1	0.1	0.1	0.2	0.4	0.2	0.2	0.2
Total Phosphorus (mg/L) Average Monthly	0.5	0.4	1.0	0.3	0.3	0.1	0.3	0.2	0.3	0.4	0.4	0.5

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.26</u>
Latitude <u>41° 28' 59"</u>	Longitude <u>-80° 26' 30"</u>
Wastewater Description: <u>Domestic Sewage</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report (No./100 ml)	IMAX		92a.61

Comments: Monitoring for E. coli is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

The technology-based limits for TRC are no longer applicable because the facility recently switched to UV disinfection.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen (5/01 – 10/31)	16.0	Average Monthly	WQM 7.0 Ver 1.1
Ammonia Nitrogen (11/01 – 4/30)	17.5	Average Monthly	WQM 7.0 Ver 1.1

Comments: Wintertime modeling was conducted for this discharge, although not current standard modeling procedure, due to the unique seasonal streamflow characteristics for this discharge and North and South Shenango Joint STP's discharge due to release rates of the Pymatuning Dam, operated by USACOE. The calculated limits are slightly more stringent than the current limits due primarily to new Chapter 93 water quality criteria for ammonia nitrogen which took effect early in 2021.

A phosphorus average monthly limit of 1.0 mg/l will be retained in the permit, based on the Shenango River Trophic State Index (TSI) Study.

Toxic modeling was not done because this is a minor sewage discharge and there are no industrial or commercial users.

Best Professional Judgment (BPJ) Limitations

A dissolved oxygen limit of 4.0 mg/l as a daily minimum is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Other Considerations

Comments: Monitoring for influent BOD₅ and influent TSS is placed in the permit in accordance with the Department's SOP entitled "New and Reissuance Individual Sewage NPDES Permit Applications."

Monitoring for total nitrogen and UV intensity is placed in the permit in accordance with the Department's SOP entitled "Establishing Effluent Limitations for Individual Sewage Permits."

Anti-Backsliding

N/A

Threatened and Endangered Mussel Species Concerns and Considerations

The main segment of the Shenango River from the Pymatuning Dam in Jamestown, Pennsylvania, downstream to the point of inundation by Shenango River Lake near Big Bend, Mercer County, Pennsylvania, is documented to contain federally and state listed threatened and endangered mussel species. Due to the discharge being directly to the Shenango River, potential impacts to endangered mussel species were evaluated.

The USFWS has indicated in comment letters on other NPDES permits that in order to protect threatened and endangered mussel species, wastewater discharges containing ammonia-nitrogen (NH₃-N), chloride (Cl⁻) and nickel, where mussels or their habitat exist, can be no more than 1.9 mg/l, 78 mg/l and 7.3 ug/l, respectively. The calculated site-specific criteria based on WQN Station 911 stream background pH and temperature data (pH of 7.71 and temperature of 20.24) results in NH₃-N criteria of 1.113 mg/l.

Ammonia-Nitrogen (NH₃-N) Evaluation:

The following is a summary of the Ammonia-Nitrogen eDMR average monthly reporting data:

Ammonia-Nitrogen (NH ₃ -N) Sampling Data (eDMR Reporting)														
Ammonia-Nitrogen (NH ₃ -N) 24-hour composite samples (mg/L)	Year	January	February	March	April	May	June	July	August	September	October	November	December	
	2018	<0.8	<0.8	<0.8	<0.8	<5.5	<0.8	<0.8	<1.2	<0.8	<0.8	<0.8	<0.8	<0.8
	2019	<0.8	<0.8	0.8	<0.8	<0.8	<0.8	<0.8	<0.8	<1.0	<1.0	<1.0	<1.0	<1.0
	2020	<1.0	<1.0	1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0	<1.0
	2021	<2.0	<3.0	<1.0	<1.0	<1.0	<3.0	<3.0	<3.0					

Note: Jamestown MA's current NPDES permit has 1/week NH₃-N monitoring with a year-round average monthly limit of 18.0 mg/L (36 mg/L IMAX).

The proposed permit limits for Ammonia-Nitrogen in the new permit cycle were as follows:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)			Minimum ⁽²⁾ Measurement Frequency	Required Sample Type	
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average			Instant. Maximum
Ammonia-Nitrogen May 1 - Oct 31	34.6	XXX	XXX	16.0	XXX	32	1/week 24-Hr Composite	
Ammonia-Nitrogen Nov 1 - Apr 30	37.9	XXX	XXX	17.5	XXX	35	1/week 24-Hr Composite	

The limits in the existing permit were calculated utilizing the Department DO model (WQM 7.0) which assumes a complete mix of the effluent with the receiving stream. The WQM 7.0 model was reevaluated as part of the subject permit renewal using the newly adopted ammonia-nitrogen water quality criteria (same as 2013 EPA CMG).

As can be seen from the eDMR data for the past three and a half years, the highest ammonia nitrogen concentration in the effluent was 1.0 mg/l, with most results being non-detect at MDLs ranging from 0.8 to 3.0 mg/l. This indicates that the facility is consistently denitrifying the municipal sewage to a high degree and easily meeting the calculated WQBELs in the permit. There is no perceived impact due to ammonia nitrogen with the max detectable concentration because it is less than the most stringent WQ criteria. The Endangered Mussel Species Impact Area Calculations Spreadsheet (attached) was completed using the maximum non-detect concentration of 3 mg/l to determine the potential impact area in this scenario which resulted in a maximum area of impact of 1.54 m² or 16.59 ft².

Due to this facility being a minor sewage facility (design flow less than 1.0 MGD), the application only required one effluent sample for chloride and no sampling for total nickel. The lone reported effluent chloride concentration was 61 mg/l, which is less than the concentration stated by the USFWS of being protective of mussels. Nickel is not expected to be present in the effluent at levels of concern due to this being a municipal sewage treatment plant with no commercial or industrial users and they do not accept hauled in waste.

Based on this sampling data, relatively small calculated areas of impact for this existing major sewage discharge and comparisons to characteristics of other similar minor sewage discharges, the existing discharge from the Jamestown Municipal STP facility is not believed to be having any measurable adverse effects on threatened or endangered mussel species in the Shenango River. However, the Department will establish quarterly effluent sampling for chloride and total nickel to develop a dataset as a means of further evaluating potential impacts in the upcoming permit term.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report Daily Min	Report	XXX	XXX	1/day	Measured
CBOD5	33.3	50	XXX	25	40	50	1/week	24-Hr Composite
BOD5 Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
TSS	25.5	56	XXX	30	45	60	1/week	24-Hr Composite
TSS Raw Sewage Influent	Report	Report Daily Max	XXX	Report	XXX	XXX	1/week	24-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	1/week	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	1/week	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/quarter	Grab
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/quarter	24-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	34.6	XXX	XXX	16.0	XXX	32	1/week	24-Hr Composite

Outfall 001 , Continued (from Permit Effective Date through Permit Expiration Date)

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Weekly Average	Minimum	Average Monthly	Weekly Average	Instant. Maximum		
Ammonia-Nitrogen Nov 1 - Apr 30	37.9	XXX	XXX	17.5	XXX	35	1/week	24-Hr Composite
Total Phosphorus	2.2	XXX	XXX	1.0	XXX	2	1/week	24-Hr Composite
Chloride	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite
Total Nickel	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	24-Hr Composite

Compliance Sampling Location: Outfall 001 (after disinfection)

Other Comments: Sampling frequency for total nitrogen was relaxed from 1/week to 1/quarter because there is not currently a local stream impairment for nutrients.

On September 20, 2004, the Department approved Jamestown's re-rating from 0.15 MGD to 0.26 MGD. This was a hydraulic re-rate and not an organic re-rating. To calculate the allowable CBOD₅ & TSS mass loadings, the federal definition of secondary treatment was applied (85% removal) to the influent loadings from the original design specifications. Since they were only granted a hydraulic re-rating, the base load from the Borough's customers should remain the same. Mass Loadings for NH₃-N and phosphorus were calculated using the higher, re-rated flow.

CBOD₅: BOD₅ influent = 266 lb/day x 0.15 x 25 (CBOD₅/30 (BOD₅) = **33.3 lb/day**

TSS: TSS influent = 170 lb/day x 0.15 = **25.5 lb/day**

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	68.200	978.00	167.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.023	11.21	0.00	0.000	0.000	0.0	0.00	0.00	20.24	7.71	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
NSSJMA STP	PA0100277	1.7000	0.0000	0.0000	0.000	20.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.20	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.11	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	66.340	968.00	170.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.023	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.24	7.71	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Jamestown STP	PA0029726	0.2600	0.0000	0.0000	0.000	20.00	7.10

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.20	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.11	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	62.000	949.00	183.60	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.023	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.24	7.71	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20A		35482				SHENANGO RIVER						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
68.200	11.21	0.00	11.21	2.6299	0.00102	.845	62.99	74.56	0.26	0.437	20.19	7.46
66.340	11.30	0.00	11.30	3.0321	0.00083	.855	64.64	75.64	0.26	1.022	20.19	7.44
Q1-10 Flow												
68.200	7.17	0.00	7.17	2.6299	0.00102	NA	NA	NA	0.21	0.530	20.18	7.39
66.340	7.23	0.00	7.23	3.0321	0.00083	NA	NA	NA	0.22	1.233	20.17	7.37
Q30-10 Flow												
68.200	15.25	0.00	15.25	2.6299	0.00102	NA	NA	NA	0.30	0.379	20.20	7.50
66.340	15.36	0.00	15.36	3.0321	0.00083	NA	NA	NA	0.30	0.889	20.20	7.49

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
 20A 35482 SHENANGO RIVER

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
68.200	NSSJMA STP	10.71	39.64	10.71	39.64	0	0
66.340	Jamestown STP	7.22	50	10.93	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
68.200	NSSJMA STP	1.37	8.68	1.37	7.52	2	13
66.340	Jamestown STP	1.15	25	1.39	21.67	2	13

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
68.20	NSSJMA STP	22.6	18.34	7.52	6.15	4	4	2	19
66.34	Jamestown STP	25	25	21.67	16.12	4	4	2	19

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>	
20A	35482	SHENANGO RIVER	

<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
68.200	1.700	20.194	7.458
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
62.992	0.845	74.563	0.260
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
5.27	0.666	1.26	0.711
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
7.437	1.815	Tsivoglou	5
<u>Reach Travel Time (days)</u>	Subreach Results		
0.437	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.044	5.11	1.22
	0.087	4.97	1.18
	0.131	4.82	1.15
	0.175	4.68	1.11
	0.219	4.55	1.08
	0.262	4.42	1.04
	0.306	4.29	1.01
	0.350	4.16	0.98
	0.393	4.04	0.95
	0.437	3.93	0.92

<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
66.340	1.960	20.189	7.444
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
64.641	0.855	75.644	0.259
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
4.51	0.552	1.34	0.710
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
5.922	1.474	Tsivoglou	5
<u>Reach Travel Time (days)</u>	Subreach Results		
1.022	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.102	4.26	1.25
	0.204	4.02	1.16
	0.307	3.80	1.08
	0.409	3.59	1.00
	0.511	3.39	0.93
	0.613	3.20	0.87
	0.716	3.03	0.81
	0.818	2.86	0.75
	0.920	2.70	0.70
	1.022	2.55	0.65

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20A	35482	SHENANGO RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
68.200	NSSJMA STP	PA0100277	1.700	CBOD5	18.34		
				NH3-N	6.15	12.3	
				Dissolved Oxygen			4
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
66.340	Jamestown STP	PA0029726	0.260	CBOD5	25		
				NH3-N	16.12	32.24	
				Dissolved Oxygen			4

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	68.200	978.00	167.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.023	8.15	0.00	0.000	0.000	0.0	0.00	0.00	4.71	7.71	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
NSSJMA STP	PA0100277	1.7000	0.0000	0.0000	0.000	15.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.20	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.11	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	66.340	968.00	170.80	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.023	0.00	0.00	0.000	0.000	0.0	0.00	0.00	4.71	7.71	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Jamestown STP	PA0029726	0.2600	0.0000	0.0000	0.000	15.00	7.10

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.20	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.11	0.00	0.70

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	35482	SHENANGO RIVER	62.000	949.00	183.60	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.023	0.00	0.00	0.000	0.000	0.0	0.00	0.00	4.71	7.71	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
20A		35482				SHENANGO RIVER						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
68.200	8.15	0.00	8.15	2.6299	0.00102	.826	57.75	69.95	0.23	0.503	7.22	7.41
66.340	8.24	0.00	8.24	3.0321	0.00083	.836	59.44	71.1	0.23	1.170	7.48	7.39
Q1-10 Flow												
68.200	5.22	0.00	5.22	2.6299	0.00102	NA	NA	NA	0.19	0.601	8.16	7.33
66.340	5.27	0.00	5.27	3.0321	0.00083	NA	NA	NA	0.19	1.388	8.47	7.32
Q30-10 Flow												
68.200	11.08	0.00	11.08	2.6299	0.00102	NA	NA	NA	0.26	0.439	6.68	7.46
66.340	11.20	0.00	11.20	3.0321	0.00083	NA	NA	NA	0.26	1.026	6.90	7.44

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input checked="" type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

SWP Basin **Stream Code** **Stream Name**
 20A 35482 SHENANGO RIVER

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
68.200	NSSJMA STP	16.79	49.87	16.79	49.87	0	0
66.340	Jamestown STP	10.94	50	17.07	50	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
68.200	NSSJMA STP	3.34	16.96	3.34	15.9	2	6
66.340	Jamestown STP	2.74	25	3.38	23.44	2	6

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
68.20	NSSJMA STP	25	25	14.7	10.45	4	4	2	19
66.34	Jamestown STP	25	25	23.44	17.57	4	4	2	19

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	35482	SHENANGO RIVER		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
68.200	1.700	7.220	7.407	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
57.748	0.826	69.949	0.226	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
7.76	1.121	2.63	0.262	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.208	1.160	Tsvoglou	5	
<u>Reach Travel Time (days)</u>				
0.503				
	Subreach Results			
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.050	7.52	2.60	6.98
	0.101	7.29	2.56	6.78
	0.151	7.07	2.53	6.60
	0.201	6.85	2.50	6.44
	0.251	6.64	2.46	6.31
	0.302	6.43	2.43	6.19
	0.352	6.23	2.40	6.09
	0.402	6.04	2.37	6.01
	0.452	5.85	2.34	5.94
	0.503	5.67	2.31	5.89
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
66.340	1.960	7.479	7.393	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
59.445	0.836	71.104	0.227	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
6.34	0.959	2.84	0.267	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.837	0.953	Tsvoglou	5	
<u>Reach Travel Time (days)</u>				
1.170				
	Subreach Results			
	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.117	5.95	2.75	5.56
	0.234	5.58	2.66	5.35
	0.351	5.24	2.58	5.21
	0.468	4.92	2.50	5.12
	0.585	4.62	2.43	5.08
	0.702	4.34	2.35	5.09
	0.819	4.07	2.28	5.12
	0.936	3.82	2.21	5.19
	1.053	3.59	2.14	5.28
	1.170	3.37	2.07	5.38

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20A	35482	SHENANGO RIVER					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
68.200	NSSJMA STP	PA0100277	1.700	CBOD5	25		
				NH3-N	10.45	20.9	
				Dissolved Oxygen			4
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
66.340	Jamestown STP	PA0029726	0.260	CBOD5	25		
				NH3-N	17.57	35.14	
				Dissolved Oxygen			4

10/21/2021

Facility:	Jamestown Municipal STP		
Permit Number:	PA0029726	Effective: Existing Discharge	Expiration:
Outfall No:	001		
Location:	Jamestown Borough, Mercer County		
Discharge to:	Shenango River		
Site Specific Mussel Survey Completed:	No		

Discharge and Stream Characteristics		Comments	
Q _s	Stream Flow	7.246 MGD / 11.21 cfs	USGS # 03101500, accrued flow #03100000
Q _D	Discharge Flow	0.26 MGD / 0.4023 cfs	
C _{S(Cl⁻)}	Instream chloride Concentration	9.47 mg/L	WQN 911 field samples (2010-2020)(June-Sept)
C _{E(Cl⁻)}	Discharge chloride (existing)	61 mg/L	Maximum concentration from renewal application
C _{P(Cl⁻)}	Discharge chloride (proposed)	61 mg/L	Maximum concentration from renewal application
C _{S(NH₃-N)}	Instream NH ₃ -N	0.11 mg/L	WQN 911 field samples (2002-2011)
C _{E(NH₃-N)}	Discharge NH ₃ -N (existing)	3 mg/L	Highest concentration reported on DMRs in last 5 years
C _{P(NH₃-N)}	Discharge NH ₃ -N (proposed)	3 mg/L	Highest concentration reported on DMRs in last 5 years
pH _s	Instream pH	7.71 S.U.	WQN #911
T _s	Instream Temp.	20.24 °C	WQN #911 Summertime Mean
C _{C(NH₃-N)}	Ammonia criteria	1.113 mg/L	From ammonia criteria comparison spreadsheet -using instream pH and Temp
C _{C(Cl⁻)}	Chloride criteria	78 mg/L	USFWS criteria
W _s	Stream width	26 meters	Google Earth - Approximate

Ammonia Criteria Calculations:			
pH _s	7.71	S.U.	(Default value is 7.0)
T _s	20.24	°C	(Default value is 20 °)
Acute Criteria			
	METHOD and UNITS	CRITERIA	Comments
	Current CMC (mg TAN/L) =	4.231	
	EPA 2013 CMC (mg TAN/L) =	6.463	Oncorhynchus present * formula on pg. 41 (plateaus at 15.7 C)
		6.463	Oncorhynchus absent * formula on pg. 42 (plateaus at 10.2 C)
Chronic Criteria			
	METHOD and UNITS	CRITERIA	COMMENTS
	Current CMC (mg TAN/L) =	1.231	
	EPA 2013 CMC (mg TAN/L) =	1.113	* formula on pg. 46 (plateaus at 7 C)

Endangered Mussel Species Impact Area Calculations:

Existing Area of Impact

N/A - No Site Specific Mussel Survey Completed for this Discharger

Approximate Area of Impact Determined from Survey =	N/A m ²	(Enter N/A if no site specific survey has been completed)
Existing Mussel Density within Area of Impact =		
Rabbitsfoot (<i>Quadrula cylindrical</i>)		per m ²
Northern Riffleshell (<i>Epioblasma torulosa rangiana</i>)		per m ²
Rayed Bean (<i>Villosa fabalis</i>)		per m ²
Clubshell (<i>Pleuroberma clava</i>)		per m ²
Sheepnose (<i>Plethobasus cyphus</i>)		per m ²
Snuffbox (<i>Epioblasma triquetra</i>)		per m ²
TOTAL		0 per m ²

Method 1 - Utilizing Site Specific Mussel Survey Information

N/A - No Site Specific Mussel Survey Completed for this Discharger

This method utilizes a simple comparison of the size of the existing area of impact as determined from a site specific mussel survey and the chlorides in the existing discharge compared to the chlorides in the proposed discharge after the facility upgrades treatment technologies. This method is only applicable to where the stream impairment is caused by TDS and/or chlorides as the plume has been delineated through conductivity measurements.

A. Area of Impact Determined from Survey:	N/A	m ²
B. Chlorides in Existing Discharge:		61 mg/L
C. Chlorides in Proposed Discharge after Treatment Facility Upgrades:		61 mg/L
D. Approximate Area of Impact after Treatment Facility Upgrades:		N/A m ²

A/B = D/C Therefore, D = (A*C)/B

10/21/2021

Facility:	Jamestown Municipal STP		
Permit Number:	PA0029726	Effective: Existing Discharge	Expiration: N/A
Outfall No:	001		
Location:	Jamestown Borough, Mercer County		
Discharge to:	Shenango River		
Site Specific Mussel Survey Completed:	No		

Endangered Mussel Species Impact Area Calculations: (continued...)

Method 2 - Mass Balance Relationship of Loading and Assimilative Capacity of Stream

Parameter	Calculation	Value
Chloride (Cl ⁻)	$L_{S(Cl^-)} = \text{Available Chloride Loading in Stream} = C_{C(Cl^-)} - C_{S(Cl^-)} \times Q_S(\text{MGD}) \times 8.34 =$	4,141 lbs/Day
	$L_{D-MAX(Cl^-)} = \text{Current Maximum Discharge Chloride Loading exceeding criteria} = (C_{E(Cl^-)} - C_{S(Cl^-)}) \times Q_D(\text{MGD}) \times 8.34 =$	-37 lbs/Day
	$\%_{Cl^-} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(Cl^-)} / L_{S(Cl^-)} =$	0% of Stream Capacity
	$L_{D(Cl^-)} = \text{Proposed Discharge Cl}^- \text{ Loading exceeding criteria after Treatment Facility Upgrades} = (C_{P(Cl^-)} - C_{S(Cl^-)}) \times Q_D(\text{MGD}) \times 8.34 =$	-36.8628 lbs/Day
	$\%_{P(Cl^-)} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(Cl^-)} / L_{S(Cl^-)} =$	-0.89% of Stream Capacity
	Proposed Area of Impact due to Chloride * = $(\%_{P(Cl^-)} \times W_S)^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	0.03 m ² 0.29 ft ²
Ammonia-Nitrogen (NH ₃ -N)	$L_{S(NH_3-N)} = \text{Available NH}_3\text{-N Loading in Stream} = C_{C(NH_3-N)} - C_{S(NH_3-N)} \times Q_S(\text{MGD}) \times 8.34 =$	61 lbs/Day
	$L_{D-MAX(NH_3-N)} = \text{Current Maximum Discharge NH}_3\text{-N Loading} = C_{E(NH_3-N)} \times Q_D(\text{MGD}) \times 8.34 =$	7 lbs/Day
	$\%_{E(NH_3-N)} = \text{Percent of Stream Capacity for Current Loading} = L_{D-MAX(NH_3-N)} / L_{S(NH_3-N)} =$	11% of Stream Capacity
	$L_{D(NH_3-N)} = \text{Proposed Discharge NH}_3\text{-N Loading after Treatment Facility Upgrades} = C_{P(NH_3-N)} - C_{S(NH_3-N)} \times Q_D(\text{MGD}) \times 8.34 =$	4 lbs/Day
	$\%_{P(NH_3-N)} = \text{Percent of Stream Capacity for Proposed Loading} = L_{D(NH_3-N)} / L_{S(NH_3-N)} =$	6.56% of Stream Capacity
	Proposed Area of Impact due to NH ₃ -N * = $(\%_{P(NH_3-N)} \times W_S)^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	1.45 m ² 15.64 ft ²

Method 3 - Mass Balance Relationship of Stream Flow, Proposed Effluent Quality, and Mussel Protection Criteria

Parameter	Calculation	Value	
Chloride (Cl ⁻)	$Q_A(Cl^-)C_{S(Cl^-)} + Q_D C_{P(Cl^-)} = Q_T C_{C(Cl^-)}$		
	$Q_A(Cl^-) = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$		
	$Q_T = Q_S + Q_D \text{ (cfs)}$		
	$Q_A(Cl^-)C_{S(Cl^-)} + Q_D C_{P(Cl^-)} = (Q_D + Q_S)C_{C(Cl^-)}$		
	SOLVING FOR $Q_A(Cl^-) = [(Q_D C_{P(Cl^-)} / C_{C(Cl^-)}) - Q_D] / (1 - C_{S(Cl^-)} / C_{C(Cl^-)}) =$	-0.099797 cfs	
	$\%_{P(Cl^-)} = \text{Percent of Stream Width Required to Assimilate Chlorides to Criteria Concentration} = Q_A(Cl^-) / Q_S \text{ (cfs)} =$	-0.8903%	
	$W_{I(Cl^-)} = \text{Proposed Width of Stream required to Assimilate Chlorides to Criteria Concentration} = W_S \times \%_{P(Cl^-)}$	-0.231465 meters	
	Proposed Area of Impact due to Chloride * = $(W_{I(Cl^-)})^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge	0.03 m ² 0.29 ft ²	
	Ammonia-Nitrogen (NH ₃ -N)	$Q_A(NH_3-N)C_{S(NH_3-N)} + Q_D C_{P(NH_3-N)} = Q_T C_{C(NH_3-N)}$	
		$Q_A(NH_3-N) = \text{Assimilative Stream Flow Required to Achieve Criteria (cfs)}$	
$Q_T = Q_S + Q_D \text{ (cfs)}$			
$Q_A(NH_3-N)C_{S(NH_3-N)} + Q_D C_{P(NH_3-N)} = (Q_D + Q_S)C_{C(NH_3-N)}$			
SOLVING FOR $Q_A(NH_3-N) = [(Q_D C_{P(NH_3-N)} / C_{C(NH_3-N)}) - Q_D] / (1 - C_{S(NH_3-N)} / C_{C(NH_3-N)}) =$		0.7569 cfs	
$\%_{P(NH_3-N)} = \text{Percent of Stream Width Required to Assimilate NH}_3\text{-N to Criteria Concentration} = Q_A(NH_3-N) / Q_S \text{ (cfs)} =$		6.7517%	
$W_{I(NH_3-N)} = \text{Proposed Width of Stream required to Assimilate NH}_3\text{-N to Criteria Concentration} = W_S \times \%_{P(NH_3-N)}$		1.755451 meters	
Proposed Area of Impact due to NH ₃ -N * = $(W_{I(NH_3-N)})^2 \times 0.5 =$ * assuming equal flow across transect and 90° spread at discharge		1.54 m ² 16.59 ft ²	

Jamestown Municipal STP
Jamestown Borough, Mercer County
NPDES# PA0029726

Date	pH min	pH max	Ave (10^pH min			
			10^-pH min	10^-pH max	& pH max)	-Log (Ave pH)
Jul-18	7.0	7.4	1E-07	3.98E-08	6.99E-08	7.2
Aug-18	7.1	7.3	7.94E-08	5.01E-08	6.48E-08	7.2
Sep-18	7.1	7.6	7.94E-08	2.51E-08	5.23E-08	7.3
Jul-19	6.7	7.3	2E-07	5.01E-08	1.25E-07	6.9
Aug-19	6.8	7.5	1.58E-07	3.16E-08	9.51E-08	7.0
Sep-19	7.2	7.6	6.31E-08	2.51E-08	4.41E-08	7.4
Jul-20	6.6	7.0	2.51E-07	1E-07	1.76E-07	6.8
Aug-20	6.7	7.0	2E-07	1E-07	1.5E-07	6.8
Sep-20	6.7	7.0	2E-07	1E-07	1.5E-07	6.8
Jul-21	7.0	7.4	1E-07	3.98E-08	6.99E-08	7.2
					Median:	7.1