

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0029831
 APS ID 1052473
 Authorization ID 1377626

Applicant and Facility Information

Applicant Name	<u>Sullivan County School District</u>	Facility Name	<u>Sullivan County School District Treatment Plant</u>
Applicant Address	<u>PO Box 240</u> <u>Laporte, PA 18626-0240</u>	Facility Address	<u>PO Box 240</u> <u>Laporte, PA 18626-0240</u>
Applicant Contact	<u>Douglas Linder, Business Manager</u>	Facility Contact	<u>Douglas Linder</u>
Applicant Phone	<u>(570) 928-8194</u>	Facility Phone	<u>(570) 928-8194</u>
Client ID	<u>41765</u>	Site ID	<u>519271</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Laporte Borough</u>
Connection Status	<u>No Limitations</u>	County	<u>Sullivan</u>
Date Application Received	<u>November 29, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 1, 2021</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of a NPDES Permit</u>		

Summary of Review

The subject facility is a wastewater treatment plant serving the school complex in Laporte Borough, Sullivan County.

A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's sludge is transferred to other WWTPs for further processing. Per the application 0.01 dry tons were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		<i>Keith C. Allison</i> Keith C. Allison / Project Manager	May 6, 2022
✓		<i>Nicholas W. Hartranft</i> Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	May 9, 2022

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.018</u>
Latitude	<u>41° 25' 24.79"</u>	Longitude	<u>-76° 30' 18.26"</u>
Quad Name	<u>Eagles Mere, PA</u>	Quad Code	<u>0733</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Mill Creek (EV (existing use))</u>	Stream Code	<u>20346</u>
NHD Com ID	<u>66909189</u>	RMI	<u>0.85 (@ discharge)</u>
Drainage Area	<u>0.19 (@ discharge)</u>		<u>0.73 (@POFU)</u>
Q7-10 Flow (cfs)	<u>0.41 (@POFU)</u>	Yield (cfs/mi ²)	<u>0.0504</u>
Elevation (ft)	<u>0.0207 (@POFU)</u>	Q7-10 Basis	<u>Gage 0155250, Muncy Creek @ Sonestown, PA</u>
Watershed No.	<u>1880 (@ discharge)</u>	Slope (ft/ft)	<u>0.003</u>
Existing Use	<u>1797 (@POFU)</u>	Chapter 93 Class.	<u>CWF</u>
Exceptions to Use	<u>10-B</u>	Existing Use Qualifier	<u>RBP - Antidegradation</u>
Assessment Status	<u>EV (EXCEPTIONAL VALUE)</u>	Exceptions to Criteria	<u>None</u>
	<u>None</u>		
Nearest Downstream Public Water Supply Intake	<u>PA American Water Co. @ Milton, PA</u>		
PWS Waters	<u>West Branch Susquehanna River</u>	Flow at Intake (cfs)	<u>682</u>
PWS RMI	<u>10.5</u>	Distance from Outfall (mi)	<u>63</u>

Changes Since Last Permit Issuance: None. The above stream and drainage characteristics were determined for the previous review and remain adequate.

Other Comments: The discharge is to an ephemeral stream. The point of first use (POFU) was previously determined to be 0.12 miles downstream in the same UNT to Mill Creek.

DEP has evaluated information indicating that the existing use of the receiving waters is different than the designated use under 25 Pa. Code § 93.9. In developing the draft NPDES permit, DEP is proposing to protect the existing use of the receiving waters. Following DEP's notice of the receipt of the application and the draft permit in the Pennsylvania Bulletin, DEP will accept written comments during the public comment period regarding DEP's tentative determination to protect the existing use. DEP will make a final determination on existing use protection for the receiving waters as part of the final permit action. The EV existing use has been in place since before the existing permit.

No downstream water supply is expected to be affected by the discharge at this time with the limitations and monitoring proposed.

Compliance History

DMR Data for Outfall 001 (from April 1, 2021 to March 31, 2022)

Parameter	MAR-22	FEB-22	JAN-22	DEC-21	NOV-21	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21
Flow (MGD) Average Monthly	0.0041	0.0034	0.0029	0.0024	0.0031	0.0020	0.0014	0.0012	0.0009	0.0009	0.0036	0.0018
Flow (MGD) Daily Maximum	0.0115	0.0091	0.0067	0.0080	0.0083	0.0068	0.0047	0.0042	0.0047	0.0046	0.0085	0.0063
pH (S.U.) Minimum	6.4	6.4	6.2	6.3	6.2	6.3	6.3	6.3	6.3	6.3	6.4	6.4
pH (S.U.) Instantaneous Maximum	7.2	7.5	7.5	7.4	7.5	7.1	7.4	7.4	7.5	7.4	7.1	7.4
DO (mg/L) Minimum	7.0	6.9	6.9	6.1	6.1	6.1	6.0	6.0	6.0	6.1	6.0	6.0
TRC (mg/L) Average Monthly	< 0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
TRC (mg/L) Instantaneous Maximum	0.02	0.04	0.03	0.03	0.04	0.05	0.04	0.03	0.01	0.03	0.03	0.04
CBOD5 (mg/L) Average Monthly	< 5.59	3.0	10.5	4.5	2.0	6.5	2.0	2.0	2.0	2.0	4.0	2.0
TSS (mg/L) Average Monthly	20.0	21.0	9.0	12.0	7.5	6.5	6.0	4.0	5.0	5.0	5.0	4.0
Fecal Coliform (No./100 ml) Geometric Mean	1087	2	1	8	1	1	1	1	1	1	1	1
Fecal Coliform (No./100 ml) Instantaneous Maximum	2419.6	3	1	60	1	1	1	3	1	1	1	1
Ammonia (mg/L) Average Monthly	1.507	2.3	5.4	7.56	2.1	0.26	0.33	0.12	0.28	0.10	0.10	0.06

Compliance History, Cont'd

Summary of Inspections:	The facility has been inspected approximately annually by the Department over the past permit term. The most recent inspection on February 2, 2022 identified no violations at the time of inspection.
Other Comments:	A query in WMS found no open violations in eFACTS for the Sullivan County School District.

Treatment Facility Summary

Treatment Facility Name: Sullivan County School District Treatment Plant

Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Chlorine With Dechlorination	0.018
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.018	38	Not Overloaded	None	Landfill

Changes Since Last Permit Issuance: None

Other Comments: Treatment consists of a comminutor, manual bar screen, one aeration tank, two clarifiers, hypochlorite disinfection with chlorine contact tank, erosion dechlorinator, and sludge holding tank.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	5/week	Grab
DO	XXX	XXX	Report	XXX	XXX	XXX	5/week	Grab
TRC	XXX	XXX	XXX	0.02	XXX	0.05	5/week	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.5	XXX	19	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6	2/month	8-Hr Composite

Development of Effluent Limitations

Outfall No.	001	Design Flow (MGD)	0.018
Latitude	41° 25' 24.80"	Longitude	-76° 30' 18.60"
Wastewater Description: Sewage Effluent			

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limitations are applicable and included in the existing permit except for a more stringent TRC limit as explained below.

Water Quality-Based Limitations

DO, CBOD₅ and NH₃-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. WQM7.0 modeling was performed for the previous review at the POFU showing the CBOD₅ technology-based limits noted above with a water quality-based limit of 3.0 mg/L for ammonia-nitrogen are adequate to protect the receiving stream. The previous modeling run is attached (Attachment B).

Total Residual Chlorine

A 0.2 mg/L monthly average was included in the last renewal and previously a 0.05 mg/L Instantaneous Maximum was established to protect the existing stream use consistent with 25 PA Code 93.4c and are more stringent than the tech-based limitation noted above. The existing limits will remain.

Discharge to Dry or Intermittent Stream

The existing permit does not contain any additional limitations established under the Department's *Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales and Storm Sewers* guidance document (391-2000-014). The current version of the guidance prescribes additional and more stringent limitations for new or expanded discharges that include a CBOD₅ limit of 10 mg/L, TSS limit of 10 mg/L, DO minimum of 6 mg/L, TN limit of 5 mg/L, and TP limit of 0.5 mg/L. These additional limitations will not be required at this time for this existing discharge.

Antidegradation

Because no new or increased discharges are proposed the antidegradation requirements of 25 PA Code 93.4c and the Antidegradation Best Available Combination of Technologies (ABACT) requirements as listed in the Department's Antidegradation Implementation Guidance (391-0300-002) are not applicable at this time.

Chesapeake Bay/Nutrient Requirements

According to the Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, this facility is an existing Phase 5 Chesapeake Bay sewage discharger that is not expanding, and therefore requires no nutrient loading limits but does require Total Nitrogen and Total Phosphorus monitoring. Nutrient monitoring has not been included in the previous couple of permit cycles based on regular nutrient monitoring conducted from 2007-2008. Because no recent regular monitoring has been performed annual monitoring for Total Nitrogen and Total Phosphorus will be included at this time consistent with the phase III WIP Wastewater Implementation Plan. Application sampling was at 26.4 mg/L and 4.1 mg/L for Total Nitrogen and Total Phosphorus, respectively.

Toxics Management

No further "Reasonable Potential Analysis" was performed for this minor sewage facility to determine additional parameters as possible candidates for limitations or monitoring.

Best Professional Judgment (BPJ) Limitations

Comments: None needed beyond the limitations mentioned above.

Anti-Backsliding

No proposed limitations have been made less stringent consistent with the anti-backsliding provisions of the Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the “NPDES Permit Writer’s Manual” (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Metered
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	5/week	Grab
Dissolved Oxygen	XXX	XXX	Report	XXX	XXX	XXX	5/week	Grab
Total Residual Chlorine (TRC)	XXX	XXX	XXX	0.02	XXX	0.05	5/week	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Total Nitrogen	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	9.5	XXX	19	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6	2/month	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	Report Daily Max	XXX	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001


Other Comments: The existing 5/week monitoring for pH, DO, and TRC is adequate for this facility serving a school complex with a satisfactory compliance history consistent with Footnote 3 of Table 6-3 of the Department's *Technical Guidance for the Development and Specifications of Effluent Limitations and Other Permit Conditions* document (362-0400-001) which states "For schools, flow, pH and D.O. should be monitored daily throughout the school year except for holidays and weekends unless public events are scheduled on holidays, weekends or during the summer." Annual Total Nitrogen and Total Phosphorus monitoring are now included as mentioned above. Annual E. Coli monitoring is also now included consistent with current Department policy and recent changes to Chapter 93 of the Department's regulations.

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment B)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input checked="" type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: Establishing Effluent Limitations for Individual Sewage Permits, rev. 3/24/21
<input type="checkbox"/>	Other: [redacted]

Attachments:

- A. Discharge Location Map
- B. WQM7.0 Modeling Run

Permit No. PA0029831



Permit No. PA0029831

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10B	20346	Trib 20346 to Mill Creek	0.730	1797.00	0.41	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfs)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.02	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Sullivan County	PA0029831	0.0180	0.0180	0.0180	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	4.00	0.00	0.00	0.70

Permit No. PA0029831

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
10B	20346	Trib 20346 to Mill Creek	0.001	1672.00	5.93	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfs)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.100	0.00	0.30	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	0.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name										
10B	20346	Trib 20346 to Mill Creek										
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
0.730	0.02	0.00	0.02	.0278	0.03247	.318	2.78	8.74	0.05	0.812	22.87	7.00
Q1-10 Flow												
0.730	0.01	0.00	0.01	.0278	0.03247	NA	NA	NA	0.05	0.891	23.39	7.00
Q30-10 Flow												
0.730	0.03	0.00	0.03	.0278	0.03247	NA	NA	NA	0.06	0.750	22.49	7.00

Permit No. PA0029831

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
10B	20346	Trib 20346 to Mill Creek

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.730	Sullivan County	7.58	8	7.58	8	0	0

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.730	Sullivan County	1.6	3.22	1.6	3.22	0	0

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.73	Sullivan County	25	25	3.22	3.22	3	3	0	0

Permit No. PA0029831

WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
10B	20346	Trib 20346 to Mill Creek		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.730	0.018	22.868		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
2.780	0.318	8.736		0.055
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
15.19	1.331	1.85		0.873
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
5.236	27.617	Owens		5
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.812	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.081	13.43	1.72	7.07
	0.162	11.87	1.60	7.40
	0.244	10.49	1.49	7.55
	0.325	9.28	1.39	7.68
	0.406	8.20	1.30	7.78
	0.487	7.25	1.21	7.82
	0.568	6.41	1.13	7.82
	0.650	5.66	1.05	7.82
	0.731	5.01	0.98	7.82
	0.812	4.43	0.91	7.82

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
10B	20346	Trib 20346 to Mill Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Eff. Limit 30-day Ave. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
0.730	Sullivan County	PA0029831	0.018	CBOD5	25		
				NH3-N	3.22	6.44	
				Dissolved Oxygen			3