

Application Type

**Renewal**

Facility Type

**Non-Municipal**

Major / Minor

**Minor**

Application No.

**PA0029866**

APS ID

**276037**

Authorization ID

**1451756**

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

**Applicant and Facility Information**

Applicant Name	<b>Cumberland Valley School District</b>	Facility Name	<b>Green Ridge Elementary School</b>
Applicant Address	6746 Carlisle Pike Mechanicsburg, PA 17050-1711	Facility Address	1 Green Ridge Road Mechanicsburg, PA 17050-1507
Applicant Contact	James Koontz	Facility Contact	Vincent Dirito
Applicant Phone	(717) 506-3374	Facility Phone	(717) 506-3324
Client ID	28228	Site ID	252089
Ch 94 Load Status	Not Overloaded	Municipality	Silver Spring Township
Connection Status	No Limitations	County	Cumberland
Date Application Received	August 22, 2023	EPA Waived?	Yes
Date Application Accepted	September 8, 2023	If No, Reason	
Purpose of Application	NPDES Renewal.		

**Summary of Review**

Cumberland Valley School District (CVSD) has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on February 22, 2019 and became effective on March 1, 2019. The permit was amended on July 25, 2019 to modify the UV output monitoring requirement. The permit expired on February 29, 2024. During the permit term, CVSD submitted an NPDES permit major amendment and WQM permit amendment applications on February 29, 2024 to upgrade the existing treatment plant and increase the flow from 0.0065 MGD to 0.01 MGD. The renewal, NPDES major amendment, and WQM amendment applications will be reviewed simultaneously.

Based on the review, it is recommended that the permit be drafted.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>Jinsu Kim</i> Jinsu Kim / Environmental Engineering Specialist	June 7, 2024
X		<i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	June 20, 2024
X		<i>Maria D. Bebenek</i> Maria D. Bebenek, P.E. / Program Manager	June 20, 2024

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.0065 (interim) 0.01 (final)
Latitude	40° 15' 57.71"	Longitude	-77° 3' 12.39"
Quad Name	Wertzville	Quad Code	1629
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Conodoguinet Creek (WWF, MF)	Stream Code	10236
NHD Com ID	56403869	RMI	0.76
Drainage Area	0.43 sq.mi.	Yield (cfs/mi <sup>2</sup> )	0.147
Q <sub>7-10</sub> Flow (cfs)	0.06	Q <sub>7-10</sub> Basis	USGS gage no. 01570000
Elevation (ft)		Slope (ft/ft)	
Watershed No.	7-B	Chapter 93 Class.	WWF, MF
Existing Use	None	Existing Use Qualifier	None
Exceptions to Use	None	Exceptions to Criteria	None
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment	N/A		
Source(s) of Impairment	N/A		
TMDL Status	N/A	Name	
Nearest Downstream Public Water Supply Intake	PA American		
PWS Waters	Conodoguinet Creek	Flow at Intake (cfs)	72.82
PWS RMI	18.38	Distance from Outfall (mi)	4.8

#### Drainage Area

The discharge is to Unnamed Tributary to Conodoguinet Creek at RMI 0.76 mi. A drainage area upstream of the point of discharge is estimated to be 0.43 sq.mi according to USGS StreamStats available at <https://streamstats.usgs.gov/ss/>.

#### Stream Flow

USGS StreamStats produced a Q<sub>7-10</sub> flow of 0.00886 cfs at the point of discharge. However, because the estimated drainage area is below the minimum value required to be used in regression equations to calculate the Q<sub>7-10</sub>, the produced Q<sub>7-10</sub> flow may not be entirely accurate. Because of this, flow data collected from the nearest downstream USGS gage station (i.e., USGS gage station no. 01570000 on Conodoguinet Creek near Hogestown, PA) has been correlated as follows:

$$\text{Low Flow Yield} = Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 69.3 \text{ cfs} / 470 \text{ sq.mi.} = 0.147 \text{ cfs/sq.mi.}$$

$$Q_{7-10\text{site}} = \text{Low Flow Yield} * \text{Drainage Area}_{\text{site}} = 0.147 \text{ cfs/sq.mi.} * 0.43 \text{ sq.mi.} = 0.06 \text{ cfs}$$

#### Unnamed Tributary 10236 of Conodoguinet Creek

Under Pa Code §93.9o, all unnamed tributaries of Conodoguinet Creek from PA 997 at Roxbury to Mouth of the Conodoguinet Creek are designated as warm water and migratory fishes and Conodoguinet Creek is a tributary of Susquehanna River. Consequently, no special protection water(s) is impacted by this discharge. No Class A Wild Trout Fishery is also impacted by this discharge. DEP's latest integrated water quality report finalized in 2024 indicates that the discharge is located in a stream segment listed as attaining use(s).

#### Public Water Supply Intake

The fact sheet prepared for the last permit renewal indicates that the nearest downstream water supply intake is PA American Water located on Conodoguinet Creek, approximately 4.8 miles from the discharge. Considering the quantity discharge from this facility and dilution available in Conodoguinet Creek, the discharge is not expected to significantly impact the water supply despite the relatively short-distance from the discharge point to the intake.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Green Ridge Elementary				
<b>WQM Permit No.</b>	<b>Issuance Date</b>			
2107401	04/16/2007			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Extended Aeration With Solids Removal	Ultraviolet	0.0065 (interim) 0.01 (final)
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0065 (interim) 0.01 (final)	13.5 (interim) 18.3 (final)	Not Overloaded	Aerobic Digestion	Other WWTP

CVSD owns and operates an on-site 0.0065 MGD wastewater treatment facility serving sanitary wastewater generated from Green Ridge Elementary School located at 1 Green Ridge Road, Mechanicsburg PA 17050. The facility utilizes an extended aeration activated sludge treatment process consisting of a comminutor, equalization basin, aeration tank, clarifier, dosing tank, sand filters (2), post aeration, UV disinfection and outfall structure.

The proposed upgrade to 0.01 MGD treatment plant will remove the equalization tank and install a new equalization tank, one additional aeration tank, and one additional UV disinfection system. The more details on this proposed upgrade will be discussed in the Internal Review and Recommendation for the WQM permit amendment.

A sludge holding tank is used for sludge handling. Any solids generated from this facility will be hauled off site via a local septic hauler to another WWTP for ultimate disposal.

Compliance History	
<b>Summary of DMRs:</b>	A summary of past 12-month DMR data is presented on the next page.
<b>Summary of Inspections:</b>	06/06/23: DEP conducted a routine inspection and noted that there was no significant issue identified at the time of inspection. 12/09/20: DEP conducted an administrative inspection in response to a data irregularity on the flow recording from 2019. No significant issues were found at the time of inspection.
<b>Other Comments:</b>	Since the last permit reissuance, the facility had a number of permit violations including effluent violations. These violations are listed on page 5 of this fact sheet.  DEP's database shows that there is no open violation associated with this facility or permittee.

Effluent Data

DMR Data for Outfall 001 (from May 1, 2023 to April 30, 2024)

Parameter	APR-24	MAR-24	FEB-24	JAN-24	DEC-23	NOV-23	OCT-23	SEP-23	AUG-23	JUL-23	JUN-23	MAY-23
Flow (MGD) Average Monthly	0.003653	0.002063	0.001814	0.014244	0.001592	0.001486	0.002239	0.002848	0.001471	0.001025	0.001214	0.002581
Flow (MGD) Daily Maximum	0.03566	0.005334	0.003952	0.341825	0.007487	0.004343	0.005272	0.00642	0.004535	0.002249	0.003351	0.006095
pH (S.U.) Daily Minimum	6.58	6.80	6.86	6.46	6.25	6.53	7.13	7.04	7.16	6.85	6.14	6.51
pH (S.U.) Daily Maximum	8.31	8.50	8.13	8.21	8.0	8.09	8.52	8.32	8.17	7.76	7.49	7.79
DO (mg/L) Daily Minimum	9.22	7.73	7.44	5.49	6.74	5.07	5.06	5.09	5.45	6.17	5.94	5.18
CBOD5 (mg/L) Average Monthly	2.9	< 2.4	2.5	< 3.4	3.3	< 2.5	< 2.5	< 2.4	< 2.4	< 2.4	< 2.4	< 3.1
TSS (mg/L) Average Monthly	3.0	2.0	3.0	2.0	6.0	2.0	2.0	4.0	8.0	5.0	3.0	5.0
Fecal Coliform (No./100 ml) Geometric Mean	< 1	< 1	< 1	< 2.0	< 1	< 1	< 1	< 1	< 1	< 2	< 13	< 5
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	1	< 1	4.0	1	1	< 1	< 1	< 1	4	172	23
Nitrate-Nitrite (lbs/day) Daily Maximum					< 57							
Nitrate-Nitrite (mg/L) Daily Maximum					< 55.4							
Total Nitrogen (lbs/day) Daily Maximum					57							
Total Nitrogen (mg/L) Daily Maximum					55							
Ammonia (mg/L) Average Monthly	0.74	0.87	< 0.1	< 0.15	3.7	< 4.5	0.21	1.1	< 0.1	< 0.1	< 1.9	4.48
TKN (lbs/day) Daily Maximum					< 0.5							
TKN (mg/L) Daily Maximum					< 0.5							
Total Phosphorus (lbs/day) Daily Maximum					5.0							
Total Phosphorus (mg/L) Daily Maximum					7.0							

Permit Violations

Permit Violations since last permit reissuance:

Date	Description	Parameters	Results	Limits	Units	SBC
2/25/2019	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	< 14	10	mg/L	Average Monthly
2/25/2019	Violation of permit condition	Fecal Coliform	17800	10000	CFU/100 ml	Instantaneous Maximum
2/25/2019	Violation of permit condition	Total Suspended Solids	16	10	mg/L	Average Monthly
3/25/2019	Violation of permit condition	Total Suspended Solids	< 41.5	10	mg/L	Average Monthly
6/24/2019	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	14	10	mg/L	Average Monthly
7/24/2019	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	20.1	10	mg/L	Average Monthly
7/24/2019	Violation of permit condition	Fecal Coliform	2300	1000	CFU/100 ml	Instantaneous Maximum
7/24/2019	Violation of permit condition	Fecal Coliform	757	200	CFU/100 ml	Geometric Mean
4/25/2020	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	16	10	mg/L	Average Monthly
4/25/2020	Violation of permit condition	Total Suspended Solids	20	10	mg/L	Average Monthly
10/20/2020	Violation of permit condition	Carbonaceous Biochemical Oxygen Demand (CBOD5)	14	10	mg/L	Average Monthly
10/20/2020	Violation of permit condition	Fecal Coliform	2420	1000	No./100 ml	Instantaneous Maximum
6/27/2021	Violation of permit condition	Total Suspended Solids	11	10	mg/L	Average Monthly
11/30/2021	Late DMR Submission					
3/28/2022	Violation of permit condition	Total Suspended Solids	11	10	mg/L	Average Monthly

**Existing Effluent Limits and Monitoring Requirements**

A table below summarizes effluent limits and monitoring requirements specified in the current permit:

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
Dissolved Oxygen	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5)	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
Total Suspended Solids	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Nitrate-Nitrite as N	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	Calculation
Ammonia-Nitrogen Oct 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia-Nitrogen May 1 - Sep 30	XXX	XXX	XXX	10.5	XXX	21	2/month	8-Hr Composite
Total Kjeldahl Nitrogen	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite
Total Phosphorus	XXX	Report Daily Max	XXX	XXX	Report Daily Max	XXX	1/year	8-Hr Composite

**Development of Effluent Limitations and Monitoring Requirements**

Outfall No. 001  
Latitude 40° 16' 0.00"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.0065 (interim) .01 (final)  
Longitude -77° 3' 16.00"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: Since the facility utilizes UV disinfection, TRC BAT effluent standard is not applicable.

**Water Quality-Based Limitations**

*CBOD5, NH3-N and Dissolved Oxygen (DO)*

WQM 7.0 version 1.0b is a water quality model designed to assist DEP to determine appropriate permit requirements for CBOD5, NH3-N and DO. DEP's guidance no. 391-2000-007 provides the technical methods contained in WQM 7.0 for conducting wasteload allocation and for determining recommended NPDES effluent limits for point source discharges. A multi-discharge analysis is necessary as Hodges MHP is located less than a mile upstream from this facility. Also, given the fact that there will be an upgrade from 0.0065 MGD to 0.01 MGD, the model was utilized for both interim (0.0065 MGD) and final (0.01 MGD) conditions as follows:

1. Interim (0.0065 MGD)

The model output indicates that all existing effluent limits are still protective of water quality. No change is therefore recommended.

2. Final (0.01 MGD)

The model output indicates that the existing effluent limit for CBOD5 is still protective of water quality; but more stringent limits are needed for NH3-N. This is consistent with a preliminary effluent limitation analysis based on 0.01 MGD sent to CVSD via email dated July 28, 2022 (see attachment).

Based on this, the upcoming renewal will contain interim and final effluent limits.

*Total Residual Chlorine*

Since the facility utilizes UV disinfection, the development of WQBELs for TRC is not necessary.

*Toxics*

DEP's NPDES permit application for minor sewages less than 0.1 MGD does not require sampling of toxics pollutants. As a result, no reasonable potential analysis for toxics pollutants has been performed for the upcoming permit renewal.

### **Best Professional Judgement Limitations**

#### ***CBOD5 & TSS***

The existing permit contains effluent limits of 10 mg/L (average monthly) and 20 mg/L (IMAX) for both CBOD5 and TSS. Based on the fact sheet developed during the last permit renewal, it appears these effluent limits were developed using DEP's best professional judgment (BPJ) to protect the receiving stream that was supposedly determined to be a dry/intermittent stream. While there has been a number of effluent violations associated with Total Suspended Solids previously, the facility should be able to meet the dry stream effluent limits if the existing tertiary treatment process is properly operated and maintained. In general, the tertiary treatment process which includes the additional filtration such as sand filters should be able to remove solids substantially. In the opinion of DEP, the existing effluent limits of 10 mg/L (average monthly) and 20 mg/L (IMAX) for both CBOD5 and TSS were appropriately developed and should remain unchanged for the upcoming permit renewal.

#### ***Dissolved Oxygen***

A minimum of 5.0 mg/L for DO is an existing effluent limit and is a current state water quality criterion found in 25 Pa. Code § 93.7(a). This effluent limit will remain unchanged for the upcoming permit renewal to ensure the protection of water quality standards. This approach is also consistent with DEP's guidance specified in the SOP no. BPNPSM-PMT-033. This requirement has also been assigned to other facilities throughout the state.

### **Additional Considerations**

#### ***Flow Monitoring***

The requirement to monitor the volume of effluent will remain in the draft permit per 40 CFR § 122.44(i)(1)(ii).

#### ***E. Coli Monitoring Requirement***

DEP's SOP no. BPNPSM-PMT-033 recommends an annual routine monitoring of E. Coli for all sewage facilities that have design flow less than 0.05 MGD but greater than 0.002 MGD. An annual monitoring for E. Coli will therefore be included in the permit.

#### ***UV Monitoring Requirement***

Initially the facility is not capable of monitoring for UV output; as a result, Part C condition was included as part of the NPDES amendment in 2019 to allow the facility to monitor relative percent irradiance of the UV system. Based on the review of the proposed UV system, the facility will continue to inspect the system on a daily basis to ensure the system is properly functional. The existing Part C condition will replace with the following Part C condition:

*The permittee shall report operation of the ultraviolet (UV) disinfection system on a daily basis using the Daily Effluent Monitoring Form (3800-FM-BCW0435) and the parameter named "UV Functional" The permittee shall report values of "1" for Yes (i.e., the UV system is functional) and "< 1" for No (i.e., the UV system is not functional). The UV system shall be considered functional when all components that are necessary for disinfection to achieve effluent limitations in Part A of this permit are operating properly.*

This condition has become DEP's standard Part C condition for those facilities that are not capable of reporting the UV output.

#### ***Chesapeake Bay TMDL***

DEP's Phase III Watershed Implementation Plan (WIP) categorizes this facility as a phase 5 non-significant sewage facility that has a design flow less than 0.2 MGD but greater than 0.002 MGD. The WIP recommends monitoring and reporting for Total Nitrogen and Total Phosphorus throughout the permit term at a frequency no less than annually. The requirement to monitor for these parameters is also recommended by DEP's SOP no. BPNPSM-PMT-033. The facility has therefore been monitoring for nutrients.

DEP's Phase III WIP has the following statements for those phase 5 facilities proposed to expand:

**If Phase 5 facilities choose to expand, the renewed or amended permits will contain Cap Loads based on the lesser of a) existing TN/TP concentrations at current design average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP.**

DEP has summarized the DMR data previously reported as follows:

	Annual Data (1/year)			
	TP (mg/L)	TP (lbs)	TN (mg/L)	TN (lbs)
2019	0.06	10	58	0.3
2020	0.02	8.2	57.2	0.1
2021	0.01	2.5	31.3	0.1
2022	0.0001	4.8	50	0.001
2023	5	7	55	57
Min	0.0001	2.5	31.3	0.001
Med	0.02	7	55	0.1
Avg	1.01802	6.5	50.3	11.5002
Max	5	10	58	57

Given the number of samples collected and largely inconsistent effluent values reported, DEP has determined not to use existing TN & TP effluent concentrations but to use default concentrations of 25 mg/L TN and 4.0 mg/L TP. The calculations are as follows:

**TP: 4.0 mg/L \* 0.0065 MGD (current design average annual flow) \* 8.34 (conversion factor) \* 365 days/year = 79.15 lbs/yr = 79 lbs TP/yr**

**TN: 25 mg/L \* 0.0065 MGD (current design average annual flow) \* 8.34 (conversion factor) \* 365 days/year = 494.67 lbs/yr = 495 lbs TN/yr**

These are Cap Loads (annual mass effluent limitations) that will be in effect upon completion of the proposed upgrade. With these Cap Loads (annual mass limits) to be applied, it is reasonable to increase the monitoring frequency for nutrients from 1/year to 2/month. DEP determines that it would be more effective to apply a monthly monitoring for these nutrients upon issuance of the renewal rather than upon completion of the proposed upgrade as this would provide more accurate data for the permittee to prepare to comply with the Cap Loads.

#### *Monitoring Frequency and Sample Type*

Unless otherwise specified throughout this fact sheet, existing monitoring frequencies and sample types will remain unchanged in the permit.

#### *Antidegradation Requirements*

All effluent limitations and monitoring requirements have been developed to ensure that existing instream water uses and the level of water quality necessary to protect the existing uses are maintained and protected.

#### *Anti-Backsliding Requirements*

All permit requirements proposed for the upcoming permit renewal have been developed at least as stringent as the existing permit requirements in accordance with 40 CFR §122.44(l)(1).

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Upon Completion of Construction.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)					
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum	Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 30	XXX	XXX	XXX	10.5	XXX	21	2/month	8-Hr Composite
E. Coli (no. / 100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

**Proposed Effluent Limitations and Monitoring Requirements (continued)**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Upon Completion of Construction through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	9.0 Daily Max	XXX	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	22.5	XXX	XXX	2/month	8-Hr Composite
Ammonia May 1 - Oct 30	XXX	XXX	XXX	7.5	XXX	15	2/month	8-Hr Composite
E. Coli (no. / 100 mL)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab

**Proposed Chesapeake Bay Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

**Outfall 001, Effective Period: Permit Effective Date through Upon Completion of Construction**

Parameter	Effluent Limitations					Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)			Minimum Measurement Frequency	Required Sample Type
	Monthly	Annual	Minimum	Monthly Average	Maximum		
Ammonia---N	Report	Report	XXX	Report	XXX	2/month	8-Hr Composite
Kjeldahl---N	Report	XXX	XXX	Report	XXX	2/month	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	2/month	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	2/month	8-Hr Composite
Net Total Nitrogen	XXX	Report	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	Report	XXX	XXX	XXX	1/year	Calculation

**Outfall 001, Effective Period: Upon Completion of Construction through Permit Expiration Date**

Parameter	Effluent Limitations					Monitoring Requirements	
	Mass Units (lbs/day)		Concentrations (mg/L)			Minimum Measurement Frequency	Required Sample Type
	Monthly	Annual	Minimum	Monthly Average	Maximum		
Ammonia---N	Report	Report	XXX	Report	XXX	2/month	8-Hr Composite
Kjeldahl---N	Report	XXX	XXX	Report	XXX	2/month	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	2/month	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	2/month	8-Hr Composite
Net Total Nitrogen	XXX	495	XXX	XXX	XXX	1/year	Calculation
Net Total Phosphorus	XXX	79	XXX	XXX	XXX	1/year	Calculation

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Attachments


## StreamStats Report

**Region ID:** PA

**Workspace ID:** PA20240607004706372000

**Clicked Point (Latitude, Longitude):** 40.26604, -77.05349

**Time:** 2024-06-06 20:47:25 -0400



[Collapse All](#)

### ➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	11	percent
DRNAREA	Area that drains to a point on a stream	0.43	square miles
PRECIP	Mean Annual Precipitation	39	inches
ROCKDEP	Depth to rock	3.3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	0.91	miles per square mile

## General Disclaimers

Parameter values have been edited, computed flows may not apply.

## ➤ Low-Flow Statistics

### Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.43	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	39	inches	35	50.4
STRDEN	Stream Density	0.91	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	3.3	feet	3.32	5.65
CARBON	Percent Carbonate	11	percent	0	99

### Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

### Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0318	ft^3/s
30 Day 2 Year Low Flow	0.0496	ft^3/s
7 Day 10 Year Low Flow	0.00886	ft^3/s
30 Day 10 Year Low Flow	0.015	ft^3/s
90 Day 10 Year Low Flow	0.032	ft^3/s

#### *Low-Flow Statistics Citations*

**Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-**

**5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)**

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.20.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

WQM 7.0 for Interim (0.0065 MGD) condition:

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name			RMI	Elevation	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
07B	10236	10236	Trib	Conodoguinet Creek	1.290	444.00	0.04	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>												
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)		
Q7-10 0.147 0.00 0.00 0.000 0.000 0.0 0.00 0.00 25.00 7.00 0.00 0.00 Q1-10 0.00 0.00 0.000 0.000 Q30-10 0.00 0.00 0.000 0.000												
<b>Discharge Data</b>												
		Name		Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
		Hodges MHP		PA0260967	0.0130	0.0130	0.0130	0.000	25.00	7.00		
<b>Parameter Data</b>												
				Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
				CBOD5		25.00	2.00	0.00	1.50			
				Dissolved Oxygen		5.00	8.24	0.00	0.00			
				NH3-N		2.00	0.00	0.00	0.70			

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
07B	10236	10236 to Conodoguinet Creek		0.760	396.00	0.43	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.147	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
<b>Discharge Data</b>											
	Name	Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Green Ridge	PA0029866		0.0065	0.0065	0.0065	0.000	25.00	7.00		
<b>Parameter Data</b>											
	Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5			10.00	2.00	0.00	1.50				
	Dissolved Oxygen			5.00	8.24	0.00	0.00				
	NH3-N			10.50	0.00	0.00	0.70				

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
07B	10236	10236 to Conodoguinet Creek		0.000	366.00	0.73	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.147	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
<b>Discharge Data</b>											
	Name	Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
				0.0000	0.0000	0.0000	0.000	0.00	7.00		
<b>Parameter Data</b>											
	Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5			25.00	2.00	0.00	1.50				
	Dissolved Oxygen			3.00	8.24	0.00	0.00				
	NH3-N			25.00	0.00	0.00	0.70				

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>		<u>Stream Name</u>								
07B			10236		Trib 10236 to Conodoguinet Creek								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
1.290	0.01	0.00	0.01	.0201	0.01715	.325	1.31	4.02	0.06	0.529	25.00	7.00	
0.760	0.06	0.00	0.06	.0302	0.00748	.353	3.82	10.83	0.07	0.670	25.00	7.00	
<b>Q1-10 Flow</b>													
1.290	0.01	0.00	0.01	.0201	0.01715	NA	NA	NA	0.06	0.535	25.00	7.00	
0.760	0.06	0.00	0.06	.0302	0.00748	NA	NA	NA	0.07	0.694	25.00	7.00	
<b>Q30-10 Flow</b>													
1.290	0.01	0.00	0.01	.0201	0.01715	NA	NA	NA	0.06	0.521	25.00	7.00	
0.760	0.07	0.00	0.07	.0302	0.00748	NA	NA	NA	0.07	0.639	25.00	7.00	

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.91	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.13	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07B	10236	Trib 10236 to Conodoguinet Creek		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
1.290	0.013	25.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
1.307	0.325	4.019	0.061	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
19.80	1.442	1.41	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.734	30.050	Owens	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.529	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.053	17.98	1.33	6.32
	0.106	16.34	1.26	6.58
	0.159	14.84	1.20	6.75
	0.212	13.48	1.13	6.89
	0.265	12.25	1.07	7.02
	0.318	11.13	1.02	7.14
	0.371	10.11	0.96	7.25
	0.423	9.18	0.91	7.34
	0.476	8.34	0.86	7.43
	0.529	7.58	0.82	7.51
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.760	0.020	25.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
3.819	0.353	10.830	0.069	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
4.41	0.816	1.36	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.691	28.101	Owens	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.670	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.067	4.12	1.27	7.54
	0.134	3.85	1.18	7.54
	0.201	3.59	1.10	7.54
	0.268	3.35	1.03	7.54
	0.335	3.13	0.96	7.54
	0.402	2.92	0.90	7.54
	0.469	2.73	0.84	7.54
	0.536	2.55	0.78	7.54
	0.603	2.38	0.73	7.54
	0.670	2.22	0.68	7.54

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>							
07B	10236	Trib 10236 to Conodoguinet Creek							
<b>NH3-N Acute Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.290	Hodges MHP	11.07	4	11.07	4	0	0		
0.760	Green Ridge	11.07	21	11.07	21	0	0		
<b>NH3-N Chronic Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.290	Hodges MHP	1.37	1.82	1.37	1.82	0	0		
0.760	Green Ridge	1.37	10.5	1.37	10.5	0	0		
<b>Dissolved Oxygen Allocations</b>									
RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.29	Hodges MHP	25	25	1.82	1.82	5	5	0	0
0.76	Green Ridge	10	10	10.5	10.5	5	5	0	0

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
	07B	10236	Trib 10236 to Conodoguinet Creek				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.290	Hodges MHP	PA0260967	0.013	CBOD5	25		
				NH3-N	1.82	3.64	
				Dissolved Oxygen			5
0.760	Green Ridge	PA0029866	0.007	CBOD5	10		
				NH3-N	10.5	21	
				Dissolved Oxygen			5

WQM 7.0 for Final (0.01 MGD) condition:

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10236	Trib 10236 to Conodoguinet Creek	1.290	444.00	0.04	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfs/m)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH	Temp (°C)	Stream pH
Q7-10	0.147	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Hodges MHP	PA0260967	0.0130	0.0130	0.0130	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)

CBOD5 25.00 2.00 0.00 1.50

Dissolved Oxygen 5.00 8.24 0.00 0.00

NH3-N 2.00 0.00 0.00 0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name		RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC		
07B	10236	10236 to Conodoguinet Creek		0.760	396.00	0.43	0.00000	0.00	<input checked="" type="checkbox"/>		
<b>Stream Data</b>											
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.147	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						
<b>Discharge Data</b>											
	Name	Permit Number		Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	Green Ridge	PA0029866		0.0100	0.0100	0.0100	0.000	25.00	7.00		
<b>Parameter Data</b>											
	Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5			10.00	2.00	0.00	1.50				
	Dissolved Oxygen			5.00	8.24	0.00	0.00				
	NH3-N			10.50	0.00	0.00	0.70				

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
07B	10236	Trib 10236 to Conodoguinet Creek			0.000	366.00	0.73	0.00000	0.00	<input checked="" type="checkbox"/>
<b>Stream Data</b>										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH
Q7-10	0.147	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
<b>Discharge Data</b>										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	0.00	7.00		
<b>Parameter Data</b>										
	Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)				
	CBOD5		25.00	2.00	0.00	1.50				
	Dissolved Oxygen		3.00	8.24	0.00	0.00				
	NH3-N		25.00	0.00	0.00	0.70				

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>			<u>Stream Code</u>		<u>Stream Name</u>								
07B			10236		Trib 10236 to Conodoguinet Creek								
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH	
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)		
<b>Q7-10 Flow</b>													
1.290	0.01	0.00	0.01	.0201	0.01715	.325	1.31	4.02	0.06	0.529	25.00	7.00	
0.760	0.06	0.00	0.06	.0356	0.00748	.356	3.88	10.89	0.07	0.649	25.00	7.00	
<b>Q1-10 Flow</b>													
1.290	0.01	0.00	0.01	.0201	0.01715	NA	NA	NA	0.06	0.535	25.00	7.00	
0.760	0.06	0.00	0.06	.0356	0.00748	NA	NA	NA	0.07	0.671	25.00	7.00	
<b>Q30-10 Flow</b>													
1.290	0.01	0.00	0.01	.0201	0.01715	NA	NA	NA	0.06	0.521	25.00	7.00	
0.760	0.07	0.00	0.07	.0356	0.00748	NA	NA	NA	0.07	0.621	25.00	7.00	

## WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.91	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.13	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
07B	10236	Trib 10236 to Conodoguinet Creek		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
1.290	0.013	25.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
1.307	0.325	4.019	0.061	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
19.80	1.442	1.41	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
5.734	30.050	Owens	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.529	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.053	17.98	1.33	6.32
	0.106	16.34	1.26	6.58
	0.159	14.84	1.20	6.75
	0.212	13.48	1.13	6.89
	0.265	12.25	1.07	7.02
	0.318	11.13	1.02	7.14
	0.371	10.11	0.96	7.25
	0.423	9.18	0.91	7.34
	0.476	8.34	0.86	7.43
	0.529	7.58	0.82	7.51
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
0.760	0.023	25.000	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
3.878	0.356	10.890	0.072	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
4.72	0.885	1.42	1.029	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.543	28.195	Owens	5	
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.649	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.065	4.39	1.33	7.54
	0.130	4.08	1.24	7.54
	0.195	3.80	1.16	7.54
	0.260	3.53	1.09	7.54
	0.325	3.29	1.01	7.54
	0.389	3.06	0.95	7.54
	0.454	2.85	0.89	7.54
	0.519	2.65	0.83	7.54
	0.584	2.46	0.78	7.54
	0.649	2.29	0.73	7.54

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>							
07B	10236	Trib 10236 to Conodoguinet Creek							
<b>NH3-N Acute Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.290	Hodges MHP	11.07	4	11.07	4	0	0		
0.760	Green Ridge	11.07	21	11.07	21	0	0		
<b>NH3-N Chronic Allocations</b>									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.290	Hodges MHP	1.37	1.82	1.37	1.82	0	0		
0.760	Green Ridge	1.37	7.68	1.37	7.68	0	0		
<b>Dissolved Oxygen Allocations</b>									
RMI	Discharge Name	CBOD5		NH3-N		Dissolved Oxygen		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.29	Hodges MHP	25	25	1.82	1.82	5	5	0	0
0.76	Green Ridge	10	10	7.68	7.68	5	5	0	0

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
	07B	10236	Trib 10236 to Conodoguinet Creek				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.290	Hodges MHP	PA0260967	0.013	CBOD5	25		
				NH3-N	1.82	3.64	
				Dissolved Oxygen			5
0.760	Green Ridge	PA0029866	0.010	CBOD5	10		
				NH3-N	7.68	15.36	
				Dissolved Oxygen			5

**Kim, Jin Su**

---

**From:** Kim, Jin Su  
**Sent:** Thursday, July 28, 2022 8:41 AM  
**To:** Bridges,James  
**Cc:** Martin, Daniel  
**Subject:** Cumberland Valley School District - Green Ridge Elementary School Preliminary Effluent Limitations  
**Attachments:** PEL - Green Ridge Elementary School.pdf

Good Morning Jim,

As requested, attached is a Preliminary Effluent Limitations Analysis (PEL) for the subject facility based on the increased flow of 0.01 MGD (from 0.0065 MGD). Most of the existing requirements are expected to remain the same, except for NH3-N and Chesapeake Bay Cap Loads. A further discussion would be needed for Cap Loads and please note that a review of the actual permit application package may result in different requirements or additional requirements based on the information provided in the application package.

Please let me know if you have any questions.

Thanks,  
Jinsu

Jinsu Kim | Permits Section  
Department of Environmental Protection | Clean Water Program  
Southcentral Regional Office  
909 Elmerton Avenue | Harrisburg, Pa 17110-8200  
Phone: 717.705.4825 | Fax 717.705.4760  
[www.dep.state.pa.us](http://www.dep.state.pa.us)

**Phase 3 WIP Wastewater Supplement**  
**Revised, July 29, 2022**

Unless DEP has specifically authorized to do so in a permit or other agreement, Offsets may not be sold as Credits.

Once approval for Offsets is obtained, the permittee must report the Offsets on the Nitrogen Budget worksheet of DEP's Annual Chesapeake Bay Spreadsheet to apply the Offsets toward compliance with the Cap Loads.

**C. Connection of Facilities**

If Facility A has a permitted discharge and decides to eliminate the discharge through connection to Facility B, the lesser of the existing annual TN and TP loads or Cap Loads of Facility A may be transferred to Facility B's Cap Load. The transferred loads are not considered Offsets and can be used for nutrient trading purposes.

If Facility A is an indirect discharger to Facility B and decides to remove its flow, opting to obtain an NPDES permit for its own discharge, Facility A will receive zero (0) for Cap Loads and Facility B will retain its original Cap Loads.

**D. Non-Significant Facilities**

Non-Significant Sewage Facilities

For Phase 4 sewage facilities (average annual design flow on August 29, 2005  $\geq$  0.2 MGD and  $<$  0.4 MGD), a future decision may be made as to the establishment of Cap Loads in permits. Until then, DEP will permit Phase 4 sewage facilities as follows:

1. Renewed or amended permits for facilities that do not increase design flow (compared to the date of the latest prior permit action) will contain monitoring and reporting for TN and TP throughout the permit term at a frequency no less than monthly.
2. Renewed or amended permits that include an increase in design flow will contain Cap Loads based on the lesser of a) existing TN and TP concentrations at current design average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP.

For Phase 5 sewage facilities with individual permits (average annual design flow on August 29, 2005  $>$  0.002 MGD and  $<$  0.2 MGD), DEP will issue individual permits with monitoring and reporting for TN and TP throughout the permit term at a frequency no less than annually, unless 1) the facility has already conducted at least two years of nutrient monitoring and 2) a summary of the monitoring results are included in the next permit's fact sheet. If, however, Phase 5 facilities choose to expand, the renewed or amended permits will contain Cap Loads based on the lesser of a) existing TN/TP concentrations at current design average annual flow or b) 7,306 lbs/yr TN and 974 lbs/yr TP.

If no data are available to determine existing concentrations for expanding Phase 4 or 5 facilities, default concentrations of 25 mg/l TN and 4 mg/l TP may be used (these are the average estimated concentrations of all non-significant sewage facilities).

DEP will not issue permits to existing Phase 4 and 5 facilities containing Cap Loads unless it is done on a broad scale or unless the facilities are expanding.

For new Phase 4 and 5 sewage discharges, in general DEP will issue new permits containing Cap Loads of "0" and new facilities will be expected to purchase credits and/or apply offsets to achieve compliance, with the exception of small flow and single residence facilities.

Non-Significant IW Facilities

For non-significant IW facilities, monitoring and reporting of TN and TP will be required throughout the permit term in renewed or amended permits anytime the facility has the potential to introduce a net TN or TP increase to the load contained within the intake water used in processing. In general, facilities that discharge