

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0029947
APS ID 2372
Authorization ID 1427630

Applicant and Facility Information

Applicant Name	<u>Southern Huntingdon County School District</u>	Facility Name	<u>Spring Farms Elementary School</u>
Applicant Address	<u>10339 Pogue Road</u> <u>Three Springs, PA 17264-8537</u>	Facility Address	<u>12075 Old Plank Road</u> <u>Three Springs, PA 17264-8013</u>
Applicant Contact	<u>Stanley Hall</u>	Facility Contact	<u>Stanley Hall</u>
Applicant Phone	<u>(814) 447-5529</u>	Facility Phone	<u>(814) 447-5529</u>
Client ID	<u>42725</u>	Site ID	<u>450363</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Clay Township</u>
Connection Status		County	<u>Huntingdon</u>
Date Application Received	<u>February 10, 2023</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>February 22, 2023</u>	If No, Reason	
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

Southern Huntingdon County School District (Permittee) has applied to the Pennsylvania Department of Environmental Protection (DEP or Department) for reissuance of its National Pollutant Discharge Elimination System (NPDES) permit for Spring Farms Elementary School STP. This permit renewal application was received on February 10, 2022. The permit was last reissued on June 15, 2018, authorizing discharge of treated sewage from the existing treatment plant located in Clay Township, Huntingdon County into UNT to Spring Creek. The permit will expire on June 30, 2023.

The facility has average annual design flow and hydraulic design capacity of 0.00533 MGD. The flow contribution to the treatment plant is 100% from the elementary school. The school is closed during the summer months so flow to the plant is significantly less except for summer sports and activities.

Sludge use and disposal description and location(s): N/A due to disposed at other facilities such as Shade Gap WWTP.

Changes in this renewal: The E. Coli. monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this report, it is recommended that the permit be drafted and published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilary H. Le / Environmental Engineering Specialist	April 21, 2023
X		Maria D. Bebenek for Daniel W. Martin, P.E. / Environmental Engineer Manager	May 22, 2023

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.00533
Latitude	40° 11' 47.46"	Longitude	-78° 0' 30.91"
Quad Name	Saltillo	Quad Code	1721
Wastewater Description: Sewage Effluent			
Receiving Waters	Unnamed Tributary to Spring Creek	Stream Code	12882
NHD Com ID	66212073	RMI	0.28 mile
Drainage Area	0.83 mi. ²	Yield (cfs/mi ²)	See comment below
Q ₇₋₁₀ Flow (cfs)	See comment below	Q ₇₋₁₀ Basis	See comment below
Elevation (ft)	775.86	Slope (ft/ft)	
Watershed No.	12-C	Chapter 93 Class.	CWF & MF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Impaired		
Cause(s) of Impairment	Nutrients, Siltation		
Source(s) of Impairment	Crop Production (Crop Related Agriculture)		
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Mifflintown Water System, Juniata County		
PWS Waters	Juniata River	Flow at Intake (cfs)	
PWS RMI	37.32 miles	Distance from Outfall (mi)	Approximate 63.0 miles

Changes Since Last Permit Issuance: none

Drainage Area

The discharges are to Unnamed Tributary to Spring Creek at RMI 0.28 miles. A drainage area upstream of the discharge is estimated to be 0.83 mi.², according to USGS PA StreamStats available at: <https://streamstats.usgs.gov/ss/>.

Streamflow

Streamflow data was collected from the nearest upstream USGS stream gage 01564500 located in Aughwick Creek Three Springs, PA. Q₇₋₁₀ values at this gage are 5.81 cfs respectively for the reporting. The drainage area was found to be 172 mi.².

$$\text{Low Flow Yield} = 5.81 \text{ cfs} / 172 \text{ mi.}^2 = 0.03 \text{ cfs/mi.}^2$$

$$Q_{7-10} \text{ at discharge} = 0.03 \text{ cfs/mi.}^2 * 0.83 \text{ mi.}^2 = 0.025 \text{ cfs}$$

303d Listed Streams

The discharge from this facility is to UNT to Spring Creek which is assessed impaired for Aquatic Life due to nutrients and siltation from crop related agriculture. Two aquatic surveys were conducted in 1986 and 2002. In April 2013, another survey took place for the whole watershed. The first two survey indicated a low flow status in the stream with approximately 2 to 3 inches of water depth. A review of 2013 survey report by Regional Water Pollution Biologist indicated that the stream is a perennial stream with apparently no distinguishable contribution of pollutants to the existing impairment. No TMDL is proposed for the watershed.

PWS Intake

The nearest downstream public water supply intake is the Mifflintown Borough Municipal Authority Juniata County on Juniata River. It is approximately 63.0 miles downstream of the discharge. Due to the distance, dilution, and effluent limits the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Spring Farms Elementary School				
WQM Permit No.		Issuance Date		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Hypochlorite	0.00533
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.00533		Not Overloaded	Anaerobic Digestion	Other WWTP

Changes Since Last Permit Issuance: none

Other Comments:

Per DEP’s recent visit to the site on May 4, 2022, the treatment facility consists of the following units:

- One comminutor
- One aeration tank
- One settling tank
- Two sand filters
- One chlorine contact tank
- Two blowers

The plant uses liquid chlorine and soda ash as needed. The stream to design flow ratio is 3.03:1 (0.025 cfs / [0.00533 MGD * (1.547 cfs/MGD)]) which qualifies the treatment plant to receive dry stream limits. However, since the facility is not a new or expanding, the dry stream limits are not applicable.

Industrial/Commercial Users:

There are no industrial/commercial users contributing to this treatment plant.

Biosolids Management:

The treatment plant doesn’t have a sludge wasting tank. Solids are usually removed by septic hauler.

Compliance History	
Summary of DMRs:	A summary of past 12-month DMRs is presented on page 4 & 5.
Summary of Inspections:	5/04/2022: Mr. Clark, DEP’s WQS, conducted a compliance evaluation inspection. No violation identified during inspection. Recommendation was to submit a NPDES permit renewal application by January 1, 2023. The effluent was clear, and all field test results were within the permit limits.
Other Comments:	There are no open violations against the permittee or applicant.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from March 1, 2022 to February 28, 2023)

Parameter	FEB-23	JAN-23	DEC-22	NOV-22	OCT-22	SEP-22	AUG-22	JUL-22	JUN-22	MAY-22	APR-22	MAR-22
Flow (MGD) Average Monthly		0.0008	0.0009	0.001	0.0013	0.0012	0.0007	0.0004	0.0006	0.0011	0.0011	0.0013
Flow (MGD) Daily Maximum		0.00223	0.00265	0.00452	0.00381	0.00287	0.00236	0.00201	0.00159	0.00267	0.00242	0.00267
pH (S.U.) Daily Minimum		7.0	7.0	7.0	7.0	6.9	7.0	7.0	7.0	7.2	6.9	6.9
pH (S.U.) Instantaneous Maximum		7.3	7.4	7.4	7.3	7.5	7.6	7.4	7.7	7.9	7.2	8.3
DO (mg/L) Daily Minimum		7.3	7.3	7.1	7.3	7.3	7.7	8.0	8.0	7.1	7.7	7.7
TRC (mg/L) Average Monthly		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
TRC (mg/L) Instantaneous Maximum		0.4	0.4	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
CBOD5 (mg/L) Average Monthly		< 3.00	7.85	3.87	5.89	< 3.00	4.125	< 3.00	< 3.00	< 3.00	3.88	< 3.00
TSS (mg/L) Average Monthly		< 1.60	2.2	< 1.60	< 1.60	2.0	< 1.60	4.6	21.8	< 1.6	2.4	< 1.60
Fecal Coliform (No./100 ml) Geometric Mean		< 1.000	2.02484 6	< 1.000	1.41421 4	5.42217 7	1.76068 2	< 1.00	< 1.00	15.2823 4	2.02484 6	2.50998
Fecal Coliform (No./100 ml) IMAX		< 1.000	4.1	< 1.000	2.0	9.8	3.1	< 1.00	< 1.00	17.3	4.1	6.3
Nitrate-Nitrite (mg/L) Average Monthly		8.572	10.06	9.7535	8.1	6.069	7.396	14.9245	8.8525	9.272	10.121	7.563
Nitrate-Nitrite (lbs) Total Monthly		2.86083 5	6.05792 7	4.6755	5.61453 4	3.07881 3	3.38817 6	3.09296 3	2.85552	5.19308 9	4.11102	3.08756 9
Total Nitrogen (mg/L) Average Monthly		9.072	10.56	10.2535	8.6	6.40233 3	7.896	15.4245	9.3525	9.772	10.621	8.063
Total Nitrogen (lbs) Total Monthly		3.02888 6	6.36299 8	4.91508	5.96226 1	3.2427	3.62408 6	3.20347 8	3.01752	5.47230 6	4.31742	3.28987 5
Total Nitrogen (lbs) Total Annual						< 52						
Ammonia (mg/L) Average Monthly		< 0.1000	< 0.1000	< 0.1000	< 0.1000	< 0.1000	< 0.1000	< 0.1000	< 0.1000	< 0.1000	< 0.1000	< 0.1000
Ammonia (lbs) Total Monthly		0.0341	0.062	0.048	0.0682	0.048	0.0465	0.217	0.033	0.558	0.042	0.0403

NPDES Permit Fact Sheet
Spring Farms Elementary School

NPDES Permit No. PA0029947

Ammonia (lbs) Total Annual						< 2						
TKN (mg/L) Average Monthly		< 0.5000	< 0.5000	< 0.5000	< 0.5000	< 0.5000	< 0.5000	< 0.5000	< 0.500	< 0.5000	< 0.5000	< 0.5000
TKN (lbs) Total Monthly		0.16805 1	0.30507 1	0.23958	0.34772 7	0.16389	0.23591	0.11051 5	0.162	0.27921 7	0.20643	0.20230 6
Total Phosphorus (mg/L) Average Monthly		0.3365	0.4635	0.4565	0.382	0.5375	0.395	1.1825	0.551	0.548	0.494	0.229
Total Phosphorus (lbs) Total Monthly		0.11144 5	0.27766 7	0.21885	0.26195	0.2796	0.17294 9	0.22971	0.17823	0.31815 3	0.18429	0.09603 8
Total Phosphorus (lbs) Total Annual						2						

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.00533</u>
Latitude <u>40° 11' 47.25"</u>	Longitude <u>-78° 0' 30.99"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: These standards apply, subject to Water Quality Analysis and BPJ where applicable.

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃-N calculations were based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

- * Discharge pH 7.0 (Default)
- * Discharge Temperature 20°C (Default)
- * Stream pH 7.0 (Default)
- * Stream Temperature 20°C (Default)
- * Background NH₃-N 0 mg/L (Assumed since no nearby upstream WWTPs)

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 9.68 mg/L NH₃-N as a monthly average (AML) and 19.36 mg/L NH₃-N instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects. However, the existing limits of 7.5 mg/L AML & 15.0 mg/L IMAX were more stringent and will remain in the proposed permit. The AML and IMAX winter limit will be 22.5 mg/L and 45.0 mg/L, respectively which is derived by multiplying the summer limits by a factor of 3. Winter season IMAX limit is not needed since it is more than 25.0 mg/L. Recent DMRs and inspection reports indicate that the facility has been consistently achieving these limits.

CBOD₅:

The attached computer printout of the WQM 7.0 stream model (ver. 1.1) indicates that a monthly average limit (AML) of 25.0 mg/L, & 50.0 mg/L will remain in the proposed permit. Recent DMRs and inspection reports show that the facility has typically been achieving concentrations below this limit. The minimum monitoring frequency will remain the same as 2/month.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(1).

Dissolved Oxygen (D.O.):

The D.O. goal is 6.0 mg/L. However, a minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. It is recommended that this limit be maintained in the proposed permit to ensure the protection of water quality standards. This approach is consistent with DEP's current Standard Operating Procedure (SOP) No. BCW-PMT-033, version 1.9 revised March 22, 2021, and has been applied to other point source dischargers throughout the state.

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100ml as a geometric mean and an instantaneous maximum not greater than 10,000/100ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 1.9 revised March 22, 2021, a routine monitoring for E. Coli will be included in the permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

Total Suspended Solids (TSS):

The existing limits of 30.0 mg/L average monthly (AML), and 60.0 mg/L instantaneous maximum (IMAX) will remain in the permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Past DMRs and inspection reports show that the facility has been consistently achieving these limits.

Total Residual Chlorine (TRC):

The attached computer printout utilizes the equation and calculations as presented in the Department's 2003 Implementation Guidance for Total Residual Chlorine (TRC) (ID#391-2000-015) for developing chlorine limitations. The attached printout indicates that a water quality limit of 0.45 mg/L would be needed to prevent toxicity concerns at the discharge point. The Instantaneous Maximum (IMAX) limit is 1.5 mg/L. However, the existing limits of 0.3 mg/L AML & 1.0 mg/L IMAX were more stringent and will remain in the proposed permit. Minimum monitoring frequency will be 1/day.

Toxics:

There is no toxicity concern from this facility. Minor facilities are not required to report toxics if there is no industrial or commercial contribution per DEP's application form 3800-PM-BCW0342b revised 10/2017.

Total Phosphorus:

This facility is not located in Lower Susquehanna Sub-basin and the receiving stream doesn't have phosphorus related impairment. Local phosphorus limit is not warranted at this time. The facility, however, will be monitoring Total Phosphorus as part of Chesapeake Bay Tributary Strategy.

Stormwater:

There is no known stormwater outfall associated with this facility.

Chesapeake Bay Strategy:

According to DEP's Chesapeake Bay Phase II Watershed Implementation Plan (WIP) Wastewater Supplement, this facility is considered a phase 5 non-significant sewage discharger with design flow less than 0.2 MGD but greater than 0.002 MGD. In general, DEP will issue permits for all phase 5 facilities with monitoring and reporting for Total Nitrogen (TN) and Total Phosphorus (TP) throughout the permit term at a frequency no less than annually. Furthermore, DEP's SOP No. BPNPSM-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 GPD. At this time, the Department is not requiring a total maximum annual nitrogen or phosphorus loading cap. Ammonia-Nitrogen, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, TN, and TP monitoring is already included in the existing permit and will remain in the proposed renewal.

The monthly "Monitor & Report" requirements for Ammonia-Nitrogen, Nitrate-Nitrite as N, and Total Kjeldahl Nitrogen; and quarterly calculation "Monitor & Report" for TN will remain in the proposed permit. The yearly calculation "report" for TP & TN will remain in the proposed permit.

Total Dissolved Solids (TDS):

Minor facilities with design flow of <0.1 MGD are not required to report effluent TDS concentration/load.

WETT:

Minor facilities and facilities without a formal EPA approved pretreatment program are exempted from WETT.

Anti-Backsliding:

The proposed limits are at least as stringent as are in existing permit; therefore, anti-backsliding is not applicable.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

WQM 7.0:

The following data were used in the attached computer model (WQM 7.0) of the stream:

- Discharge pH 7.0 (Default)
- Discharge Temperature 20°C (Default per 391-2000-013)
- Stream pH 7.0 (Default per 391-2000-013)
- Stream Temperature 20°C (Default per 391-2000-013)

The following two nodes were used in modeling:

Node 1: Outfall 001 at UNT to Spring Creek (12882)
 Elevation: 775.86 ft (USGS)
 Drainage Area: 0.83 mi² (USGS StreamStats)
 River Mile Index: 0.28 (PA DEP eMapPA)
 Low Flow Yield: 0.03 cfs/mi² (calculated)
 Discharge Flow: 0.00533 MGD

Node 2: At the confluence with Spring Creek (12879)
 Elevation: 752.57 ft (USGS)
 Drainage Area: 7.15 mi² (StreamStats)
 River Mile Index: 0.001 (PA DEP eMapPA)
 Low Flow Yield: 0.03 cfs/mi²
 Discharge Flow: 0.00 MGD

The screenshot displays the USGS StreamStats web application interface. On the left is a navigation sidebar with options like 'SELECT A STATE / REGION', 'IDENTIFY A STUDY AREA', and 'BUILD A REPORT'. The main content area shows a map of the study area and two data tables.

Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	6.67	percent
DRNAREA	Area that drains to a point on a stream	0.83	square miles
PRECIP	Mean Annual Precipitation	37	inches
ROCKDEP	Depth to rock	3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.47	miles per square mile

Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.83	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	37	inches	35	50.4
STRDEN	Stream Density	2.47	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	3	feet	3.32	5.65
CARBON	Percent Carbonate	6.67	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0171	ft ³ /s
30 Day 2 Year Low Flow	0.0295	ft ³ /s
7 Day 10 Year Low Flow	0.0039	ft ³ /s
30 Day 10 Year Low Flow	0.00738	ft ³ /s
90 Day 10 Year Low Flow	0.0173	ft ³ /s

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	4.39	percent
DRNAREA	Area that drains to a point on a stream	172	square miles
PRECIP	Mean Annual Precipitation	38	inches
ROCKDEP	Depth to rock	4	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.15	miles per square mile

> Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	172	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	38	inches	35	50.4
STRDEN	Stream Density	2.15	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	4	feet	3.32	5.65
CARBON	Percent Carbonate	4.39	percent	0	99

Low-Flow Statistics Flow Report [Low Flow Region 2]

PI: Prediction Interval-Lower, PIu: Prediction Interval-Upper, ASEp: Average Standard Error of Prediction, SE: Standard Error (other -- see report)

Statistic	Value	Unit	SE	ASEp
7 Day 2 Year Low Flow	12.7	ft ³ /s	38	38
30 Day 2 Year Low Flow	17.6	ft ³ /s	33	33
7 Day 10 Year Low Flow	5.81	ft ³ /s	51	51
30 Day 10 Year Low Flow	8.27	ft ³ /s	46	46
90 Day 10 Year Low Flow	13.5	ft ³ /s	36	36

Low-Flow Statistics Citations

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
CARBON	Percentage of area of carbonate rock	3.06	percent
DRNAREA	Area that drains to a point on a stream	7.15	square miles
PRECIP	Mean Annual Precipitation	37	inches
ROCKDEP	Depth to rock	3.3	feet
STRDEN	Stream Density -- total length of streams divided by drainage area	2.16	miles per square mile

> Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	7.15	square miles	4.93	1280
PRECIP	Mean Annual Precipitation	37	inches	35	50.4
STRDEN	Stream Density	2.16	miles per square mile	0.51	3.1
ROCKDEP	Depth to Rock	3.3	feet	3.32	5.65
CARBON	Percent Carbonate	3.06	percent	0	99

Low-Flow Statistics Disclaimers [Low Flow Region 2]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 2]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.235	ft ³ /s
30 Day 2 Year Low Flow	0.377	ft ³ /s
7 Day 10 Year Low Flow	0.0692	ft ³ /s
30 Day 10 Year Low Flow	0.119	ft ³ /s
90 Day 10 Year Low Flow	0.248	ft ³ /s

Analysis Results WQM 7.0

Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | Effluent Limitations

RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.28	Southern School	PA0029947	0.0053

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	9.68	19.36	
Dissolved Oxygen			5

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel

rptEffLimits

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name	Disc. Flow (mgd)	Parameter	Eff. Limit 30-Day Avg. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
12C	12892	Tri 12892 to Spring Creek					
104		Name	Permit Number	Parameter	Eff. Limit 30-Day Avg. (mg/L)	Eff. Limit Maximum (mg/L)	Eff. Limit Minimum (mg/L)
0.280	Southern School	PA0029947	0.0053	CBOD5	25		
				NH3-N	9.68	19.36	
				Dissolved Oxygen			5

Wednesday, April 10, 2023 | Version 1.1 | Page 1 of 1

Page: 1 of 1 | No Filter

rpt_WLA

WQM 7.0 Wasteload Allocations

SWP Basin	Stream Code	Stream Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
12C	12892	Tri 12892 to Spring Creek						
NH3-N Acute Allocations								
104	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction	
0.280	Southern School	16.76	49.34	16.76	49.34	0	0	
NH3-N Chronic Allocations								
104	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction	
0.280	Southern School	1.89	9.68	1.89	9.68	0	0	
Dissolved Oxygen Allocations								
104	Discharge Name	CBOD5 (mg/L)	NH3-N (mg/L)	Dissolved Oxygen (mg/L)	Critical Reach	Percent Reduction		
0.280	Southern School	25	9.68	5	0	0		

Wednesday, April 10, 2023 | Version 1.1 | Page 1 of 1

Page: 1 of 1 | No Filter

rptDOSim

WQM 7.0 D.O. Simulation

SWP Basin	Stream Code	Stream Name
12C	1288.2	Trib 12882 to Spring Creek

Rate	Total Discharge Flow (mgd)	Analysis Temperature (°C)	Analysis pH
0.280	0.025	20.000	7.000

Reach Width (ft)	Reach Depth (ft)	Reach Velocity (ft/s)	Reach Velocity (ft/s)
3.500	0.291	10.367	0.038

Reach CSODs (mg/L)	Reach K1 (1/day)	Reach NPL4N (mg/L)	Reach NPL4N (1/day)
7.70	1.170	2.40	0.700

Reach DDO (mg/L)	Reach K2 (1/day)	K0 Equation	Reach DDO Goal (mg/L)
7.440	22.950	Const	0

Reach Travel Time (days)	Subreach Results	D.O.
0.477	Travel Time CSODs (mg/L)	NPL4N (mg/L)
		(mg/L)
	0.048	7.30
	0.095	6.92
	0.143	6.57
	0.191	6.23
	0.239	5.91
	0.286	5.60
	0.334	5.31
	0.382	5.04
	0.430	4.78
	0.477	4.53

Wednesday, April 19, 2023 Version 1.1 Page 1 of 1

rptModelSpecs

WQM 7.0 Modeling Specifications

Parameters	Units	Use Inputted Q1-10 and Q25-10 Flows
WLA Method	EMF94	<input type="checkbox"/>
Q1-10/Q1-10 Ratio	0.64	<input type="checkbox"/>
Q25-10/Q1-10 Ratio	1.36	<input type="checkbox"/>
D.O. Saturation	90.00%	<input type="checkbox"/>
D.O. Goal	0	<input type="checkbox"/>

Use Inputted WLD Ratio
Use Inputted Reach Travel Times
Temperature Adjust Kr
Use Balanced Technology

Wednesday, April 19, 2023 Version 1.1 Page 1 of 1

rptHydro

WQM 7.0 Hydrodynamic Outputs

SWP Basin	Stream Code	Stream Name
12C	1288.2	Trib 12882 to Spring Creek

RM	Stream Flow (cfs)	PWS WLD Stream Flow (cfs)	Net Stream Flow (cfs)	Disc. Slope (ft/ft)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	WLD Rate (ft/s)	Velocity (ft/s)	Reach Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow	0.280	0.02	0.02	0.002	0.01581	291	3.19	10.97	0.04	0.477	20.00	7.00
Q1-10 Flow	0.280	0.02	0.02	0.002	0.01581	NA	NA	NA	0.03	0.570	20.00	7.00
Q25-10 Flow	0.280	0.02	0.02	0.002	0.01581	NA	NA	NA	0.04	0.417	20.00	7.00

Wednesday, April 19, 2023 Version 1.1 Page 1 of 1

rptGeneral

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RM	Elevation (ft)	Drainage Area (acres)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply PC
12C	1288.2	Trib 12882 to Spring Creek	0.280	775.86	0.83	0.00000	0.00	<input checked="" type="checkbox"/>

Design Cond.	L/FY	Inb Flow (cfs)	Stream Flow (cfs)	Rich Flow (cfs)	Rich Velocity (ft/s)	WLD Rate (ft/s)	Rich Width (ft)	Rich Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	pH
Q7-10	0.020	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00
Q1-10	0.00	0.00	0.00	0.000	0.000						
Q25-10	0.00	0.00	0.00	0.000	0.000						

Discharge Data	Existing Disc. Flow (mgd)	Permitted Disc. Flow (mgd)	Design Disc. Flow (mgd)	Reserve Factor	Disc. Temp (°C)	Disc. pH
Southern School	0.0253	0.0253	0.0253	0.000	20.00	7.00


Parameter Data	Disc. Conc. (mg/L)	Inb Conc. (mg/L)	Stream Conc. (mg/L)	File Goal (1/day)
CSODs	25.00	2.00	0.00	1.50
Dissolved Oxygen	5.00	8.24	0.00	0.00
NPL4N	25.00	0.00	0.00	0.70

Wednesday, April 19, 2023 Version 1.1 Page 1 of 2

Input Data WQM 7.0										
SWP#	Stream Code	Stream Name	F04	Elevation	Discharge Area (sqft)	Slope (ft/ft)	FWQS Withdrawal (mgd)	Apply F.C.		
TRC	12852	Trb 12852 to Spring Creek	0.001	752.57	7.75	0.00010	0.00	<input checked="" type="checkbox"/>		
Services Data										
Design Cond.	LFY	Trb Flow (cfs)	Stream Flow (cfs)	Rich Flow Time (days)	Rich Velocity (ft/s)	WQ Rich Rate	Rich Width (ft)	Rich Depth (ft)	Temperature (°C)	Stream Temp (°C)
GP-10	0.030	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
GS-10	0.00	0.00	0.00	0.000	0.000					0.00
CS-10	0.00	0.00	0.00	0.000	0.000					0.00
Discharge Data										
Name	Permit Number	Discharge Flow (mgd)	Permitted Discharge Flow (mgd)	Design Discharge Flow (mgd)	Reserve Factor	Discharge Temp (°C)	Discharge pH			
Southern School	PA0029947	0.0000	0.0000	0.0000	0.000	20.00	7.00			
Parameter Data										
Parameter Name	Discharge Conc. (mg/L)	Trb Conc. (mg/L)	Stream Conc. (mg/L)	File Coef. (1/days)						
CSOD5	25.00	2.00	0.00	1.50						
Dissolved Oxygen	5.00	8.24	0.00	0.00						
NPC-N	25.00	0.00	0.00	0.70						

Wednesday, April 10, 2023 Version 1.1 Page 2 of 2

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.025	= Q stream (cfs)	0.5	= CV Daily		
0.00533	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BJP Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)	= Decay Coefficient (K)			
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.986		1.3.2.iii	WLA_cfc = 0.954
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.367		5.1d	LTA_cfc = 0.555
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.452		AFC	
		INST_MAX_LIMIT (mg/l) = 1.479			
WLA_afc	(.019/e ^{-k*AFC_tc}) + [(AFC_Yc*Qs*.019/Qd*e ^{-k*AFC_tc})]... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_afc	EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)				
LTA_afc	wla_afc*LTAMULT_afc				
WLA_cfc	(.011/e ^{-k*CFC_tc}) + [(CFC_Yc*Qs*.011/Qd*e ^{-k*CFC_tc})]... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)				
LTAMULT_cfc	EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)				
LTA_cfc	wla_cfc*LTAMULT_cfc				
AML_MULT	EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))				
AVG_MON_LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)				
INST_MAX_LIMIT	1.5*(av_mon_limit/AML_MULT)/LTAMULT_afc				



Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.3	XXX	1.0	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	7.5	XXX	15	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	22.5	XXX	XXX	2/month	8-Hr Composite

Existing Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, to comply with Pennsylvania's Chesapeake Bay Tributary Strategy.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/month	8-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)			Minimum ⁽²⁾ Measurement Frequency	Required Sample Type	
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum			Instant. Maximum
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.3	XXX	1.0	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	7.5	XXX	15.0	2/month	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	22.5	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Monthly	Annual	Monthly	Monthly Average	Maximum	Instant. Maximum		
Ammonia--N	Report	Report	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Kjeldahl--N	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Nitrate-Nitrite as N	Report	XXX	XXX	Report	XXX	XXX	1/month	8-Hr Composite
Total Nitrogen	Report	Report	XXX	Report	XXX	XXX	1/month	Calculation
Total Phosphorus	Report	Report	XXX	Report	XXX	XXX	1/month	8-Hr Composite

Compliance Sampling Location:

Other Comments:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input checked="" type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]