

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0030082
APS ID 1115445
Authorization ID 1488214

Applicant and Facility Information

Applicant Name	<u>Best Fayette Medical Center LP</u>	Facility Name	<u>Brownsville Gen Hospital</u>
Applicant Address	125 Simpson Road	Facility Address	125 Simpson Road
	Brownsville, PA 15417-9624		Brownsville, PA 15417-9624
Applicant Contact	<u>Belinda Strongosky</u>	Facility Contact	<u>Thomas Bibby</u>
Applicant Phone	<u>(412) 999-1050</u>	Facility Phone	<u>(724)-366-5184</u>
Client ID	<u>294938</u>	Site ID	<u>271378</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Redstone Township</u>
Connection Status	<u>Dept. Imposed Connection Prohibitions</u>	County	<u>Fayette</u>
Date Application Received	<u>May 31, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>June 24, 2024</u>	If No, Reason	
Purpose of Application	<u>Application for a renewal of an NPDES permit for discharge of treated Sewage</u>		

Approve	Deny	Signatures	Date
X		<i>Fahmida Amin</i> Fahmida Amin / Environmental Engineering Trainee	April 30, 2025
X		<i>Mahbuba Iasmin</i> Mahbuba Iasmin, Ph.D., P.E. / Environmental Engineering Manager	May 5, 2025

Summary of Review

The applicant has applied for a renewal of NPDES Permit No. PA0030082. NPDES Permit No. PA0030082 was previously issued by the PA Department of Environmental Protection (DEP) on September 01, 2017. That permit expired on August 31, 2022.

WQM Permit No. 463S59, issued on August 14, 1963, authorized the construction of the plant to treat an average design flow of 0.045 MGD. The existing treatment process consists of extended aeration, final clarification and chlorination.

The receiving stream, Tributary 40161 to Dunlap Creek to Dunlap Creek, is currently classified as a WWF and is located in State Watershed No. 19-C.

The permittee has complied with Act 14 notifications as evidenced by updated letters sent to Redstone Township and Fayette County.

Changes since the last permit include:

- New Ammonia-Nitrogen Winter limits
- Addition of *E.Coli* monitoring
- New water quality-based effluent limitation for Total Residual Chlorine (TRC) with two years compliance schedule. First 24 months old TRC limits. New TRC limits from 25th month. Part C.IV condition - TRC Effluent Limitations Below Quantitation Limits has also been added.

Anti-Backsliding

Section 402(o) of the Clean Water Act (CWA), enacted in the Water Quality Act of 1987, establishes anti-backsliding rules governing two situations. The first situation occurs when a permittee seeks to revise a Technology-Based effluent limitation based on BPJ to reflect a subsequently promulgated effluent guideline which is less stringent. The second situation addressed by Section 402(o) arises when a permittee seeks relaxation of an effluent limitation which is based upon a State treatment standard of water quality standard.

Previous limits can be used pursuant to EPA's anti-backsliding regulation 40 CFR 122.44 (l) Reissued permits. (1) Except as provided in paragraph (l)(2) of this section when a permit is renewed or reissued. Interim effluent limitations, standards or conditions must be at least as stringent as the final effluent limitations, standards, or conditions in the previous permit (unless the circumstances on which the previous permit was based have materially and substantially changed since the time the permit was issued and would constitute cause for permit modification or revocation and reissuance under §122.62). (2) In the case of effluent limitations established on the basis of Section 402(a)(1)(B) of the CWA, a permit may not be renewed, reissued, or modified on the basis of effluent guidelines promulgated under section 304(b) subsequent to the original issuance of such permit, to contain effluent limitations which are less stringent than the comparable effluent limitations in the previous permit.

This facility is not seeking to revise the previously permitted effluent limits.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	.045
Latitude	40° 0' 14"	Longitude	-79° 52' 23"
Quad Name	Fayette City	Quad Code	40079A7
Wastewater Description: Sewage Effluent			
Receiving Waters	Tributary 40161 to Dunlap Creek (WWF)		
NHD Com ID	99411870	Stream Code	40161
Drainage Area	0.069	RMI	1.11
Q ₇₋₁₀ Flow (cfs)	0.000299	Yield (cfs/mi ²)	0.00433
Elevation (ft)	1168	Q ₇₋₁₀ Basis	USGS StreamStats
Watershed No.	19-C	Slope (ft/ft)	
Existing Use		Chapter 93 Class.	WWF
Exceptions to Use		Existing Use Qualifier	
Assessment Status	Attaining Use(s); Supports Aquatic Life		
Cause(s) of Impairment	N/A		
Source(s) of Impairment	N/A		
TMDL Status	None	Name	N/A
Background/Ambient Data	Data Source		
pH (SU)			
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake	Newell Municipal Authority		
PWS Waters	Monongahela River	Flow at Intake (cfs)	0.6 MGD
PWS RMI	50.94	Distance from Outfall (mi)	12.5

Changes Since Last Permit Issuance:

- New ammonia-nitrogen winter limits. Winter limit is more stringent due to water quality modeling.
- New TRC limits, a two-years compliance schedule.

Other Comments: None

Treatment Facility Summary				
Treatment Facility Name: Brownsville Gen Hospital STP				
WQM Permit No.		Issuance Date		
463S59		08/14/1963		
463S59-T1		01/15/2013		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Chlorine With Dechlorination	0.001
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.045		Not Overloaded	Dewatering	

Changes Since Last Permit Issuance: None

Other Comments:

Operations Compliance Check Summary Report

Facility: BROWNSVILLE GEN HOSP

NPDES Permit No.: PA0030082

Compliance Review Period: 3/1/20-2/28/25

Inspection Summary:

INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC
07/09/2021	Administrative/File Review	PA Dept of Environmental Protection	No Violations Noted
07/09/2021	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted

Violation Summary:

No violations noted during review period

Open Violations by Client ID:

No open violations for Client ID 294938

Enforcement Summary:

No enforcements executed during review period

Effluent Violation Summary:

MON PD	PARAMETER	REPORTED		UNIT	STAT BASE CODE
		VALUE	PERMIT LIMIT		
May-22	Ammonia-Nitrogen	2.35	1.5	mg/L	Average Monthly
Sep-21	Ammonia-Nitrogen	2.3	1.5	mg/L	Average Monthly

Compliance Status: Facility is generally in compliance with no open violations or pending enforcements.

Completed by: Amanda Illar Completed date: 3/17/25

Compliance History

DMR Data for Outfall 001 (from March 1, 2024 to February 28, 2025)

Parameter	FEB-25	JAN-25	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24
Flow (MGD) Average Monthly	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001	0.001
pH (S.U.) Minimum	6.9	6.9	7.0	6.9	7.0	7.0	7.0	7.1	6.9	7.1	7.1	6.9
pH (S.U.) Maximum	7.0	7.0	7.0	7.0	7.0	7.0	7.1	7.2	7.0	7.2	7.2	7.0
DO (mg/L) Minimum	6.1	6.1	5.6	5.6	5.8	5.7	5.7	5.3	5.5	6.1	5.7	5.9
TRC (mg/L) Average Monthly	0.22	0.16	0.21	0.12	0.34	0.2	0.21	0.26	0.35	0.15	0.18	0.13
TRC (mg/L) Instantaneous Maximum	0.28	0.23	0.47	0.29	0.51	0.2	0.36	0.41	0.58	0.31	0.37	0.28
CBOD5 (mg/L) Average Monthly	2.65	2.7	< 2.0	< 2.0	< 2.0	2.6	< 2.0	< 2.0	4.35	5.6	2.25	< 2.0
CBOD5 (mg/L) Instantaneous Maximum	3.8	3.4	< 2.0	< 2.0	< 2.0	3.2	< 2.0	< 2.0	6.7	6.6	2.5	< 2.0
TSS (mg/L) Average Monthly	< 5.0	13.5	11.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	15.5	8.5	5.5	< 5.0
TSS (mg/L) Instantaneous Maximum	< 5.0	22.0	17.0	< 5.0	< 5.0	< 5.0	< 5.0	< 5.0	26.0	11.0	6.0	< 5.0
Fecal Coliform (No./100 ml) Geometric Mean	5	4	28	15	2	2	37	45	21	5	12	12
Fecal Coliform (No./100 ml) Instantaneous Maximum	24	19	47	217	2	2	191	103	147	24	137	146
Total Nitrogen (mg/L) Daily Maximum			18.4									
Ammonia (mg/L) Average Monthly	0.15	1.1	0.8	0.15	0.15	0.2	0.25	0.15	0.15	0.25	0.65	0.1
Ammonia (mg/L) Instantaneous Maximum	0.2	2.1	1.3	0.2	0.2	0.3	0.4	0.2	0.2	0.3	1.2	0.1

NPDES Permit Fact Sheet
Brownsville Gen Hospital

NPDES Permit No. PA0030082

Total Phosphorus (mg/L) Daily Maximum												
---	--	--	--	--	--	--	--	--	--	--	--	--

Development of Effluent Limitations

Outfall No. 001
Latitude 40° 0' 14.00"
Wastewater Description: Sewage Effluent

Design Flow (MGD) .045
Longitude -79° 52' 23.00"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations (WQBELs)

Pursuant to EPA's approval of Pennsylvania's 2017 Triennial Review of Water Quality Standards and corresponding regulatory changes published in the *Pennsylvania Bulletin* on July 11, 2020, new water quality criteria for ammonia-nitrogen apply to waters of the commonwealth. Therefore, WQBELs for Outfall 001 are being re-evaluated even though there have been no changes to the treatment plant.

WQM 7.0 Water Quality Modeling

DEP's WQM 7.0 version 1.1 model is a Microsoft Access Program used for sewage dischargers to determine whether TBELs are sufficient to meet in-stream water quality criteria for ammonia-nitrogen, carbonaceous biochemical oxygen demand (CBOD₅), and dissolved oxygen (DO). To accomplish this, the model simultaneously simulates mixing and degradation of ammonia-nitrogen and mixing and consumption of DO through CBOD₅ and ammonia-nitrogen degradation. WQM 7.0 determines the highest pollutant loadings that the stream can assimilate while still meeting water quality criteria under design conditions.

The model is a two-step process. The discharge is first modeled for the summer period (May through October) because warm temperatures are more likely to result in critical loading conditions. Reduced DO levels likely also play a role in ammonia toxicity and solubility of DO decreases at increased water temperature. If summer modeling determines that WQBELs are appropriate for the summer period, then modeling is completed for the winter period (November through April). This is in accordance with DEP's *Implementation Guidance of Section 93.7 Ammonia Criteria* [Do. No. 391-2000-013] (Ammonia Guidance).

River Mile Index (RMI) was measured in eMAP PA as the distance from the facility's outfall to Tributary 40161 to Dunlap Creek. Elevation was read by applying a topo map in eMAP PA. Discharge point and downstream drainage areas as well as Q₇₋₁₀ were generated by USGS Stream Stats. USGS Stream Stats output files are included in Attachment 1. In the absence of site-specific data, discharge temperature, stream temperature, and stream pH were assumed to be 20, 25, and 7 in accordance with the Ammonia Guidance. Stream width to depth was assumed to be 10 in accordance with DEP's *Technical Reference Guide (TRG) WQM 7.0 for Windows Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen Version 1* [Doc. No. 391-2000-007]. The previous effluent limitations for ammonia-nitrogen, dissolved oxygen, and CBOD₅ were used as the discharge concentrations.

WQM 7.0 modeling inputs are documented in the table below:

Discharge Characteristics		Basin/Stream Characteristics	
Parameter	Value	Parameter	Value
River Mile Index (RMI)	1.11	Drainage Area	0.069
Discharge Flow (MGD)	.045	Q ₇₋₁₀ (cfs)	0.000299
Discharge Temp (°C)	20	Low-flow yield (cfs/mi ²)	0.00433
Summer Ammonia-Nitrogen (mg/L)	1.5	Elevation (ft)	1168
Winter Ammonia-Nitrogen (mg/L)	2.65	Stream Width/Depth	10
CBOD ₅ (mg/L)	25	Stream Temp (°C)	25
		Stream pH (s.u.)	7

The discharge was modeled using WQM 7.0 to evaluate the ammonia-nitrogen, CBOD₅, and DO parameters. The modeling confirmed that water quality-based effluent limits are necessary for ammonia-nitrogen, CBOD₅, and DO. In accordance with DEP's SOP for *Establishing Effluent Limitations for Individual Sewage Permits* [SOP No. BCW-PMT-033 revised March 24, 2021, Version 1.9], winter ammonia-nitrogen limits are assessed by comparing winter WQM 7.0 output value with one calculated by multiplying the summer limit by a multiplier of three. The more restrictive limit is then imposed. For this facility, the more restrictive limit comes from the winter model. WQM 7.0 output files are included in Attachments 2 and 3.

Water Quality-Based Limitations

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
CBOD5	25.0	Average Monthly	WQM 7.0 Version 1.1
Ammonia Nitrogen (May 1 to Oct 31)	1.89	Average Monthly	WQM 7.0 Version 1.1
Ammonia Nitrogen (Nov 1 to Apr 30)	2.65	Average Monthly	WQM 7.0 Version 1.1
Dissolved Oxygen	5.0 (Minimum)	Average Monthly	WQM 7.0 Version 1.1
TRC	0.009	Average Monthly	TRC Calculation

Comments: Due to anti-backsliding, the previously permitted seasonal WQBEL for CBOD5 of 10 mg/L and Summer Ammonia Nitrogen of 1.5 mg/L will be re-imposed.

Additional Considerations

Monitoring frequency for the proposed effluent limits are based upon Table 6-3, Self-Monitoring Requirements for Sewage Dischargers, from the Departments Technical Guidance for the Development and Specification of Effluent Limitations and Other Permit Conditions in NPDES Permits (Document No. 386-0400-001).

Sewage dischargers will include monitoring, at a minimum, for E. Coli, in new and reissued permits, with a monitoring frequency of 1/year for design flows 0.002 – 0.05 MGD per 25 Pa. Code § 92a.061, and Section I.A, Note 12, SOP No. BCW-PMT-033, Establishing Effluent Limitations for Individual Sewage Permits.

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.045	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX	1/day	Grab
DO	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
TSS	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia-Nitrogen Nov 1 - Apr 30	XXX	XXX	XXX	2.65	XXX	5.3	2/month	Grab
Ammonia-Nitrogen May 1 - Oct 31	XXX	XXX	XXX	1.5	XXX	3.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through 24 month.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab

Compliance Sampling Location:

Other Comments:

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: 25th Month through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
TRC	XXX	XXX	XXX	0.009	XXX	0.029	1/day	Grab

Compliance Sampling Location:

Other Comments:

Attachment 1 – USGS StreamStats Report

StreamStats Report

Region ID: PA

Workspace ID: PA20250409172225550000

Clicked Point (Latitude, Longitude): 40.00394, -79.86815

Time: 2025-04-09 13:22:56 -0400



[Collapse All](#)

► Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	0.069	square miles
ELEV	Mean Basin Elevation	1168	feet

► Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 4]

Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	0.069	square miles	2.26	1400
ELEV	Mean Basin Elevation	1168	feet	1050	2580

Low-Flow Statistics Disclaimers [Low Flow Region 4]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 4]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.00131	ft^3/s
30 Day 2 Year Low Flow	0.00285	ft^3/s
7 Day 10 Year Low Flow	0.000299	ft^3/s
30 Day 10 Year Low Flow	0.000782	ft^3/s
90 Day 10 Year Low Flow	0.00181	ft^3/s

Low-Flow Statistics Citations

Stuckey, M.H., 2006, Low-flow, base-flow, and mean-flow regression equations for Pennsylvania streams: U.S. Geological Survey Scientific Investigations Report 2006-5130, 84 p. (<http://pubs.usgs.gov/sir/2006/5130/>)

USGS Data Disclaimer: Unless otherwise stated, all data, metadata and related materials are considered to satisfy the quality standards relative to the purpose for which the data were collected. Although these data and associated metadata have been reviewed for accuracy and completeness and approved for release by the U.S. Geological Survey (USGS), no warranty expressed or implied is made regarding the display or utility of the data for other purposes, nor on all computer systems, nor shall the act of distribution constitute any such warranty.

USGS Software Disclaimer: This software has been approved for release by the U.S. Geological Survey (USGS). Although the software has been subjected to rigorous review, the USGS reserves the right to update the software as needed pursuant to further analysis and review. No warranty, expressed or implied, is made by the USGS or the U.S. Government as to the functionality of the software and related material nor shall the fact of release constitute any such warranty. Furthermore, the software is released on condition that neither the USGS nor the U.S. Government shall be held liable for any damages resulting from its authorized or unauthorized use.

USGS Product Names Disclaimer: Any use of trade, firm, or product names is for descriptive purposes only and does not imply endorsement by the U.S. Government.

Application Version: 4.28.1

StreamStats Services Version: 1.2.22

NSS Services Version: 2.2.1

Attachment 2 – WQM 7.0 Version 1.1 – Summer Period

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19C	40161	Trib 40161 to Dunlap Creek	1.110	1093.29	0.07	0.04900	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.004	0.00	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Brownsville STP	PA0030082	0.0450	0.0450	0.0450	0.000	20.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		4.00	8.38	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19C	40161	Trib 40161 to Dunlap Creek	0.730	993.35	0.07	0.04900	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream Temp (°C)	Stream pH
Q7-10	0.004	0.00	0.00	0.000	0.000	10.0	0.00	0.00	25.00	7.00	0.00
Q1-10		0.00	0.00	0.000	0.000						
Q30-10		0.00	0.00	0.000	0.000						

Discharge Data							
Name		Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)
			0.0000	0.0000	0.0000	0.000	25.00
Parameter Data							
Parameter Name			Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)	
CBOD5			25.00	2.00	0.00	1.50	
Dissolved Oxygen			3.00	8.38	0.00	0.00	
NH3-N			25.00	0.00	0.00	0.70	

WQM 7.0 Hydrodynamic Outputs

SWP Basin			Stream Code		Stream Name							
19C			40161		Trib 40161 to Dunlap Creek							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)		(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
1.110	0.00	0.00	0.00	.0696 0.04900	.378	1.79	4.74	0.10	0.225	20.02	7.00	
Q1-10 Flow												
1.110	0.00	0.00	0.00	.0696 0.04900	NA	NA	NA	0.10	0.226	20.01	7.00	
Q30-10 Flow												
1.110	0.00	0.00	0.00	.0696 0.04900	NA	NA	NA	0.10	0.225	20.03	7.00	

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>						
19C	40161	Trib 40161 to Dunlap Creek							
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.110	Brownsville STP	16.74	16.79	16.74	16.79	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
1.110	Brownsville STP	1.88	1.89	1.88	1.89	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
1.11	Brownsville STP	25	25	1.89	1.89	5	5	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19C	40161	Trib 40161 to Dunlap Creek		
<u>RMI</u> 1.110	<u>Total Discharge Flow (mgd)</u> 0.045	<u>Analysis Temperature (°C)</u> 20.021	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 1.794	<u>Reach Depth (ft)</u> 0.378	<u>Reach WDRatio</u> 4.742	<u>Reach Velocity (fps)</u> 0.103	
<u>Reach CBOD5 (mg/L)</u> 24.90	<u>Reach Kc (1/days)</u> 1.499	<u>Reach NH3-N (mg/L)</u> 1.89	<u>Reach Kn (1/days)</u> 0.701	
<u>Reach DO (mg/L)</u> 5.014	<u>Reach Kr (1/days)</u> 28.617	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 5	
<u>Reach Travel Time (days)</u> 0.225	Subreach Results			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.023	24.07	1.86	5.97
	0.045	23.27	1.83	6.50
	0.068	22.50	1.80	6.81
	0.090	21.75	1.77	7.01
	0.113	21.03	1.74	7.14
	0.135	20.33	1.72	7.23
	0.158	19.65	1.69	7.31
	0.180	19.00	1.66	7.38
	0.203	18.37	1.64	7.44
	0.225	17.76	1.61	7.49

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
		19C	40161	Trib 40161 to Dunlap Creek			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.110	Brownsville STP	PA0030082	0.045	CBOD5	25		
				NH3-N	1.89	3.78	
				Dissolved Oxygen			5

Attachment 3 – WQM 7.0 Version 1.1 – Winter Period

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
				(ft)	(sq mi)	(ft/ft)	(mgd)	
19C	40161	Trib 40161 to Dunlap Creek	1.110	1093.29	0.07	0.04900	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Stream pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.009	0.00	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Brownsville STP	PA0030082	0.0450	0.0450	0.0450	0.000	15.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	4.00	12.80	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation	Drainage Area	Slope	PWS Withdrawal	Apply FC
				(ft)	(sq mi)	(ft/ft)	(mgd)	
19C	40161 Trib 40161 to Dunlap Creek		0.730	993.35	0.07	0.04900	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.009	0.00	0.00	0.000	0.000	10.0	0.00	0.00	5.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name		Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)		
CBOD5		25.00	2.00	0.00	1.50		
Dissolved Oxygen		3.00	12.80	0.00	0.00		
NH3-N		25.00	0.00	0.00	0.70		

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>		<u>Stream Name</u>							
19C			40161		Trib 40161 to Dunlap Creek							
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
1.110	0.00	0.00	0.00	.0696	0.04900	.379	1.8	4.74	0.10	0.225	14.91	7.00
Q1-10 Flow												
1.110	0.00	0.00	0.00	.0696	0.04900	NA	NA	NA	0.10	0.225	14.95	7.00
Q30-10 Flow												
1.110	0.00	0.00	0.00	.0696	0.04900	NA	NA	NA	0.10	0.224	14.88	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>					
19C	40161	Trib 40161 to Dunlap Creek						
NH3-N Acute Allocations								
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction	
1.110	Brownsville STP	24.1	24.24	24.1	24.24	0	0	
NH3-N Chronic Allocations								
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction	
1.110	Brownsville STP	2.62	2.65	2.62	2.65	0	0	
Dissolved Oxygen Allocations								
RMI	Discharge Name	CBOD5 Baseline (mg/L)	NH3-N Multiple (mg/L)	NH3-N Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Critical Reach	Percent Reduction
1.11	Brownsville STP	25	25	2.65	2.65	5	0	0

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19C	40161	Trib 40161 to Dunlap Creek		
<u>RMI</u> 1.110	<u>Total Discharge Flow (mgd)</u> 0.045	<u>Analysis Temperature (°C)</u> 14.915	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 1.795	<u>Reach Depth (ft)</u> 0.379	<u>Reach WDRatio</u> 4.743	<u>Reach Velocity (fps)</u> 0.103	
<u>Reach CBOD5 (mg/L)</u> 24.80	<u>Reach Kc (1/days)</u> 1.499	<u>Reach NH3-N (mg/L)</u> 2.63	<u>Reach Kn (1/days)</u> 0.473	
<u>Reach DO (mg/L)</u> 5.066	<u>Reach Kr (1/days)</u> 25.355	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 5	
<u>Reach Travel Time (days)</u> 0.225	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.022	24.15	2.60	6.42
	0.045	23.52	2.58	7.21
	0.067	22.90	2.55	7.67
	0.090	22.29	2.52	7.95
	0.112	21.71	2.50	8.13
	0.135	21.14	2.47	8.25
	0.157	20.58	2.44	8.34
	0.180	20.04	2.42	8.40
	0.202	19.51	2.39	8.46
	0.225	19.00	2.37	8.51

WQM 7.0 Effluent Limits

SWP Basin	Stream Code	Stream Name					
		19C	40161	Trib 40161 to Dunlap Creek			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.110	Brownsville STP	PA0030082	0.045	CBOD5	25		
				NH3-N	2.65	5.3	
				Dissolved Oxygen			5

Attachment 4 – TRC_CALC

TRC EVALUATION									
Input appropriate values in A3:A9 and D3:D9									
0.000299	= Q stream (cfs)				0.5	= CV Daily			
0.045	= Q discharge (MGD)				0.5	= CV Hourly			
30	= no. samples				1	= AFC_Partial Mix Factor			
0.3	= Chlorine Demand of Stream				1	= CFC_Partial Mix Factor			
0	= Chlorine Demand of Discharge				15	= AFC_Criteria Compliance Time (min)			
0.5	= BAT/BPJ Value				720	= CFC_Criteria Compliance Time (min)			
0	= % Factor of Safety (FOS)					= Decay Coefficient (K)			
Source	Reference	AFC Calculations			Reference	CFC Calculations			
TRC	1.3.2.III	WLA_afc = 0.020			1.3.2.III	WLA_cfc = 0.012			
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373			5.1c	LTAMULT_cfc = 0.581			
PENTOXSD TRG	5.1b	LTA_afc= 0.008			5.1d	LTA_cfc = 0.007			
Effluent Limit Calculations									
PENTOXSD TRG	5.1f	AML MULT = 1.231							
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.009				CFC			
		INST MAX LIMIT (mg/l) = 0.029							
WLA_afc		$(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd)*e(-k*AFC_tc)]...\\ ... + Xd + (AFC_Yc*Qs*Xa/Qd)]*(1-FOS/100)$							
LTAMULT_afc		$\text{EXP}((0.5*\text{LN}(cvh^2+1))-2.326*\text{LN}(cvh^2+1)^0.5)$							
LTA_afc		wla_afc*LTAMULT_afc							
WLA_cfc		$(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd)*e(-k*CFC_tc)]...\\ ... + Xd + (CFC_Yc*Qs*Xa/Qd)]*(1-FOS/100)$							
LTAMULT_cfc		$\text{EXP}((0.5*\text{LN}(cvd^2/no_samples+1))-2.326*\text{LN}(cvd^2/no_samples+1)^0.5)$							
LTA_cfc		wla_cfc*LTAMULT_cfc							
AML MULT		$\text{EXP}(2.326*\text{LN}(cvd^2/no_samples+1)^0.5)-0.5*\text{LN}(cvd^2/no_samples+1)$							
AVG MON LIMIT		$\text{MIN}(\text{BAT_BPJ},\text{MIN}(\text{LTA_afc},\text{LTA_cfc})*\text{AML_MULT})$							
INST MAX LIMIT		$1.5*((\text{av_mon_limit}/\text{AML_MULT})/\text{LTAMULT_afc})$							