

Application Type Renewal  
Facility Type Non-Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0030139  
APS ID 523154  
Authorization ID 1085672

**Applicant and Facility Information**

Applicant Name	<u>PA Department Of Corr</u>	Facility Name	<u>PA Department Of Corr Dallas Sci</u>
Applicant Address	<u>1000 Folies Road Dallas Sci</u> <u>Dallas, PA 18612</u>	Facility Address	<u>Department Of Corrections Dallas Sci -</u> <u>1000 Follies Road</u> <u>Dallas, PA 18612</u>
Applicant Contact	<u>Dave Popek</u>	Facility Contact	<u>Robert Selert</u>
Applicant Phone	<u>(570) 675-2727</u>	Facility Phone	<u>(570) 675-1101</u>
Client ID	<u>43607</u>	Site ID	<u>516545</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Jackson Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Luzerne</u>
Date Application Received	<u>August 4, 2015</u>	EPA Waived?	<u>No</u>
Date Application Accepted	<u>August 19, 2015</u>	If No, Reason	<u>Significant CB Discharge</u>
Purpose of Application	<u>RENEWAL OF EXISTING NPDES PERMIT.</u>		

**Summary of Review**

The applicant is requesting the renewal of a NPDES Permit to discharge up to 0.5 MGD of treated sewage into East Fork Harveys Creek , a Cold Water Fishes (CWF) designated stream in State Watershed 05B (Toby-Wapwallopen Creeks). The stream at this location is designated for the following uses: aquatic life, water supply, CWF and recreation. Per the Department's current existing use list, the receiving stream does not have an existing use classification that is more protective than the designated use. The discharge is not expected to affect public water supplies.

The effluent limits for CBOD5, TSS, Fecal Coliform, and pH are technology based. The limits for DO, TRC and NH3-N are water quality based. No changes to site operations were proposed in the application submittal.

Section 7 of Pennsylvania's Phase 3 Chesapeake Bay Watershed Implementation Plan describes Pennsylvania's strategy for reducing nutrients to the Chesapeake Bay from wastewater facilities. The Phase 2 nutrient monitoring limits required by the Chesapeake Bay strategy will be continued. An update is that the minimum monitoring frequency for TN species and TP for renewing NPDES permits for Significant Sewage dischargers is increase to 2/week and 24hr composite monitoring is preferred.

Facilities with NPDES permits must use DEP's eDMR system for reporting, except small flow treatment facilities. An Annual DMR must be submitted by the end of the Truing Period, November 28. As attachments to the Annual DMR a facility must submit a completed Annual Chesapeake Bay Spreadsheet, available through DEP's Supplemental Reports website, which contains an Annual Nutrient Monitoring worksheet and an Annual Nutrient Budget worksheet. This Spreadsheet will be submitted once per Compliance Year only, and reflect all nutrient sample results (for the period October 1 – September 30), Credit transactions (including the Truing Period) and Offsets applied during the Compliance Year.

Appendix Q of the Chesapeake Bay TMDL segregates Pennsylvania's point sources into four sectors – significant sewage

Approve	Deny	Signatures	Date
X		Bernard Feist, P.E. / Environmental Engineer /s/	July 16, 2019
X		Amy M. Bellanca, P.E. / Environmental Engineer Manager /s/	July 22, 2019

**Summary of Review**

dischargers, significant industrial waste (IW) dischargers, combined sewer overflows (CSOs) and non-significant dischargers (both sewage and IW facilities). All sectors contain a listing of individual facilities with NPDES permits that were believed to be discharging at the time the TMDL was published (2010). All sectors with the exception of the non-significant dischargers have individual wasteload allocations (WLAs) for TN and TP assigned to specific facilities. Non-significant dischargers have a bulk or aggregate allocation for TN and TP based on the facilities in that sector that were believed to be discharging at that time and their estimated nutrient loads.

The Chesapeake Bay TMDL specifies individual WLAs for 183 significant sewage treatment facilities. A sewage facility is considered significant if it has a design flow of at least 0.4 MGD. For rollout of its permitting strategy, DEP classified these facilities into three phases.

Table 7-1: Significant Chesapeake Bay Sewage NPDES Permits Issued

Phase 2 WIP Wastewater Supplement  
Revised, November 9, 2018

Previous

NPDES Permit No.	Phase	Facility	Latest Permit Issuance Date	Permit Expiration Date	Cap Load Compliance Start Date	TN Cap Load (lbs/yr)	TN Offsets Included in Cap Load (lbs/yr)	TP Cap Load (lbs/yr)	TN Delivery Ratio	TP Delivery Ratio
PA0030139	3	Dallas State Correctional Institution	1/25/2011	1/31/2016	10/1/2009	9,741	-	1,218	0.871	0.436

DEP will continue to use an adaptive management philosophy to guide decision-making for TMDL implementation. DEP may deviate from the guidelines stated herein where warranted to ensure that total aggregate loads remain at or below the WLAs prescribed by the TMDL. Where DEP deviates from these guidelines, it will be done in a systematic, centralized manner, and will be documented through the submission of status/milestone reports to EPA.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.45</u>
Latitude	<u>41° 16' 42.74"</u>	Longitude	<u>-76° 0' 36.09"</u>
Quad Name	<u></u>	Quad Code	<u></u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>East Fork Harveys Creek (CWF, MF)</u>	Stream Code	<u>28318</u>
NHD Com ID	<u>65633837</u>	RMI	<u>2.0</u>
Drainage Area	<u>3.14</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.1</u>
Q <sub>7-10</sub> Flow (cfs)	<u>.314</u>	Q <sub>7-10</sub> Basis	<u>DFlow USGS 01536500</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>5-B</u>	Chapter 93 Class.	<u>CWF, MF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Impaired</u>		
Cause(s) of Impairment	<u>Organic Enrichment/Low D.O., TURBIDITY</u>		
Source(s) of Impairment	<u>NATURAL SOURCES, Other</u>		
TMDL Status	<u></u>	Name	<u></u>
Nearest Downstream Public Water Supply Intake	<u>Danville Municipal Water</u>		
PWS Waters	<u></u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u>&gt; 50 Miles</u>

Gage	Period	Days in +	7Q10	Harmonic
01536500 - Susquehanna River at Wilkes-Barre, PA	1993/04/01 - 2018/04/01	9,131	9.77E+02	5.48E+03

$$LFY = Q_{7-10} \text{ LowFlowYield (cfs/mi}^2\text{)} = 977 / 9,960 = 0.1$$

USGS STATION.--01536500 SUSQUEHANNA RIVER AT WILKES-BARRE, PA  
 LOCATION.--Lat 41° 15'03", long 75° 52'52", Luzerne County, Hydrologic Unit 02050107, on left bank at downstream side of North Street bridge in Wilkes-Barre, and 1.8 mi upstream from Toby Creek.  
 DRAINAGE AREA.--9,960 square miles.  
 PERIOD OF RECORD.--April 1899 to current year. Gage-height records collected at same site since November 1890, contained in reports of U.S. Weather Bureau.  
 GAGE.--Water-stage recorder and crest-stage gage. Datum of gage is 510.86 ft above North American Vertical Datum of 1988.


**Outfall 001 at RMI 2.0 @ 1076 elevation**

Clicked Point (Latitude, Longitude):

41.27844, -76.00975

Time:

2019-07-12 15:38:18 -0400



Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units
DRNAREA	Drainage Area	3.14	square miles

Stream Q<sub>7-10</sub> Flow (cfs) = 3.14 \* 0.1 = .314 cfs


**RMI 0.0 @ Elevation 865 ft**

Clicked Point (Latitude, Longitude):

41.25655, -75.99539

Time:

2019-07-12 15:46:52



Low-Flow Statistics Parameters [Low Flow Region 2]

Parameter Code	Parameter Name	Value	Units
DRNAREA	Drainage Area	7.08	square miles

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) .45  
 Latitude 41° 16' 42.64" Longitude -76° 0' 36.26"  
 Wastewater Description: Sewage Effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

<b>TRC EVALUATION</b>					
Input appropriate values in A3:A9 and D3:D9			PA SCI Dallas		
0.314	= Q stream (cfs)		0.5	= CV Daily	
0.45	= Q discharge (MGD)		0.5	= CV Hourly	
4	= no. samples		1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA afc = 0.163		1.3.2.iii	WLA cfc = 0.151
PENTOXSD TRG	5.1a	LTAMULT afc = 0.373		5.1c	LTAMULT cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.061		5.1d	LTA_cfc = 0.088
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML MULT = 1.720			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.104		AFC	
		INST MAX LIMIT (mg/l) = 0.244			



### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
05B	28318	EAST FORK HARVEYS CREEK					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.000	PA Dallas SCI	pa 0030139	0.450	CBOD5	25		
				NH3-N	2.47	4.94	
				Dissolved Oxygen			5



PA Dallas WQM.pdf

#### Pentox Toxic Analysis

Parameter	Effluent Limit (µg/L)	Governing Criterion	Max. Daily Limit (µg/L)	Most Stringent	
				WQBEL (µg/L)	WQBEL Criterion
▶ COPPER	11.4	INPUT	17.786	13.02	AFC
LEAD	4.617	CFC	7.203	4.617	CFC
ZINC	76.5	INPUT	119.352	111.437	AFC



PA Dallas Pentox.pdf

### Best Professional Judgment (BPJ) Limitations

Limits are recommended for Copper, Lead, and Zinc. Due to the small sampling set, quarterly Monitor & Report will be incorporated into this Permit Cycle for more robust data, analysis, and corrections.



PA Dallas Renewal Application.pdf

Compliance History

DMR Data for Outfall 001 (from June 1, 2018 to May 31, 2019)

Parameter	MAY-19	APR-19	MAR-19	FEB-19	JAN-19	DEC-18	NOV-18	OCT-18	SEP-18	AUG-18	JUL-18	JUN-18
Flow (MGD) Average Monthly	0.29	0.27	0.25	0.25	0.27	0.49	0.53	0.45	0.46	0.26	0.25	0.18
Flow (MGD) Daily Maximum	0.53	0.50	0.44	0.38	0.76	0.68	0.70	0.65	0.96	0.61	0.71	0.30
pH (S.U.) Minimum	6.8	6.5	6.2	6.3	6.2	6.2	6.4	6.5	6.7	6.2	6.2	6.2
pH (S.U.) Maximum	7.3	7.2	7.1	7.1	7.9	6.9	7.0	7.1	7.2	6.9	6.8	6.8
DO (mg/L) Minimum	5.0	5.1	3.8	5.9	4.6	4.7	6.2	6.0	5.3	6.0	7.4	6.7
TRC (mg/L) Average Monthly	0.04	0.052	0.056	0.0525	0.052	0.086	0.061	0.06	0.07	0.07	0.05	0.05
TRC (mg/L) Instantaneous Maximum	0.07	0.12	0.11	0.08	0.13	0.15	0.16	0.11	0.18	0.32	0.17	0.08
CBOD5 (lbs/day) Average Monthly	5.4	6.8	9.3	7.8	6.0	11.4	12.3	10.8	12.7	12.7	5.3	7.1
CBOD5 (mg/L) Average Monthly	2.4	3.78	4.33	4.0	< 3.0	< 3.0	3.0	3.0	3.0	4.8	3.25	5.0
TSS (lbs/day) Average Monthly	13.4	9.36	47.82	12.35	10.02	19.04	20.54	18.07	21.15	12.49	8.18	7.0
TSS (mg/L) Average Monthly	6.2	5.0	22.0	6.25	< 5.0	< 5.0	< 5.0	< 5.0	5.0	< 5.0	< 5.0	< 5.0
Fecal Coliform (CFU/100 ml) Geometric Mean	1.58	5.0	2	11	4	4	2	9	3	10	9	30
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	9.8	13.5	6	29	43	10	8	72	9	24	96	334
Nitrate-Nitrite (mg/L) Average Monthly	0.51	0.36	0.568	0.2575	0.8	0.82	1.14	0.64	1.19	1.3	0.98	1.2
Nitrate-Nitrite (lbs) Total Monthly	35.75	20.89	39	13.36	49.94	90.35	133.47	72	135.53	91.94	47.72	51.2
Total Nitrogen (mg/L) Average Monthly	1.91	5.48	2.593	1.9325	2.70	2.34	3.12	1.87	2.33	2.42	1.86	2.3
Total Nitrogen (lbs) Effluent Net   Total Monthly	132.52	276.52	188	103	168.32	259.11	368.80	211.1	268.58	182	91.86	97
Total Nitrogen (lbs) Total Monthly	132.52	276.52	188	103	168.32	259	368.80	211	268.58	182	91.86	97.1
Total Nitrogen (lbs) Effluent Net   Total Annual									< 1878			
Total Nitrogen (lbs) Total Annual									< 1878			
Ammonia (lbs/day) Average Monthly	0.62	4.11	2.14	0.33	1.57	3.14	4.32	2.0	2.37	1.62	0.93	0.89
Ammonia (mg/L) Average Monthly	0.28	2.46	0.885	0.1725	0.778	0.84	1.07	0.56	0.56	0.623	0.57	0.64
Ammonia (lbs) Total Monthly	19.25	119.05	64.34	9.03	48.64	94.1	125.25	63.2	68.81	50.24	27.95	26.6
Ammonia (lbs) Total Annual									< 509			
TKN (mg/L) Average Monthly	1.4	5.13	2.025	1.675	1.91	1.52	1.97	1.23	1.14	1.12	1.02	1.31
TKN (lbs) Total Monthly	96.76	255.66	149.32	89.38	118.63	168.8	235.24	138.7	133.03	89.68	50.51	54.3
Total Phosphorus (mg/L) Average Monthly	2.76	2.7	1.558	1.0475	3.08	1.97	2.73	2.2	2.47	2.55	3.03	4.5

Total Phosphorus (lbs) Effluent Net   Total Monthly	190.22	146.82	95	55	192.46	225.64	320.02	245	266.11	190	144.1	188
Total Phosphorus (lbs) Total Monthly	190.22	146.82	95.42	55.11	192.46	225.6	320.02	245	266.11	190.25	144.10	187.8
Total Phosphorus (lbs) Effluent Net   Total Annual									1761			
Total Phosphorus (lbs) Total Annual									1761			