

Application Type Renewal
Facility Type Sewage
Major / Minor Minor

NPDES PERMIT FACT SHEET

Application No. PA0030287
APS ID 812909
Authorization ID 1266490

Applicant and Facility Information

Applicant Name	<u>Allegheny Country Club</u>	Facility Name	<u>Allegheny Country Club STP</u>
Applicant Address	<u>250 Country Club Road</u> <u>Sewickley, PA 15143-9449</u>	Facility Address	<u>250 Country Club Road</u> <u>Sewickley, PA 15143-9449</u>
Applicant Contact	<u>Justin Kolanz</u>	Facility Contact	<u>Justin Kolanz</u>
Applicant Phone	<u>(412) 741-7500</u>	Facility Phone	<u>(412) 741-7500</u>
Client ID	<u>1101</u>	Site ID	<u>257720</u>
SIC Code	<u>7322</u>	Municipality	<u>Sewickley Heights Borough</u>
SIC Description	<u>Services - Adjustment and Collection Services</u>	County	<u>Allegheny</u>
Date Application Received	<u>March 25, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>March 25, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renewal of NPDES Permit.</u>		

Summary of Review

This application is for a renewal which was previously issued on January 17, 2014. The existing discharge is to a dry swale that leads to an unnamed tributary of Little Sewickley Creek. Little Sewickley Creek is classified as a HQ-CWF.

The treatment process consists of flow equalization, extended aeration, final clarification, chlorination and dechlorination.

Since there have been no changes to the receiving stream, the discharge, or Department Modeling Programs, the limitations are based on the previously approved pollution report (copy attached below as a pdf file).



Pollution Report

This permit has been updated to conform with the Standard Operating Procedure (SOP)1 for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits SOP No. BCW-PMT-033 Final, November 9, 2012 Revised, January 10, 2019 Version 1.6

Approve	Return	Deny	Signatures	Date
X			Raymond E. Lattner / Environmental Application Mngr. /S/	2/23/20
X			Donald J. Leone, P.E. / Environmental Engineer Manager /S/	2/24/20