

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

NPDES PERMIT FACT SHEET INDIVIDUAL SEWAGE

Application No. PA0030511
APS ID 276001
Authorization ID 1487643

Applicant and Facility Information

Applicant Name <u>Bermudian Springs School District</u>	Facility Name <u>Bermudian Springs High School</u>
Applicant Address <u>7335 Carlisle Pike</u> <u>York Springs, PA 17372-8807</u>	Facility Address <u>7335 Carlisle Pike</u> <u>York Springs, PA 17372-8807</u>
Applicant Contact <u>Marlin Ensor</u>	Facility Contact <u>Marlin Ensor</u>
Applicant Phone <u>(717) 528-4113</u>	Facility Phone <u>(717) 528-4113</u>
Client ID <u>64940</u>	Site ID <u>451521</u>
Ch 94 Load Status <u>Not Overloaded</u>	Municipality <u>Huntington Township</u>
Connection Status <u></u>	County <u>Adams</u>
Date Application Received <u>June 6, 2024</u>	EPA Waived? <u>Yes</u>
Date Application Accepted <u>June 7, 2024</u>	If No, Reason <u></u>
Purpose of Application <u>NPDES permit renewal.</u>	

Summary of Review

Keller Engineers, Inc., on behalf of Bermudian Springs School District, has applied to the Pennsylvania Department of Environmental Protection (DEP) for issuance of the NPDES permit. The permit was issued on February 24, 2020, became effective on March 1, 2020, and expires on February 28, 2025.

The average annual design flow and hydraulic design capacity is 0.03 MGD, and the organic loading capacity is 66.7 lbs BOD₅/day. The NPDES PA0030511 major amendment was issued on 4/8/2021 to replace the chlorine monitor & report requirement with UV light intensity (mW/cm²) disinfection monitor & report requirement.

The original WQM Part II 0189403 was issued on September 28, 1989. The WQM Part II 0120404 was issued on November 13, 2020, as a project for, among other things, to replace chlorine disinfection with UV disinfection, with the following attributes to remain unchanged: average design flow and hydraulic capacity of 0.03 MGD with 66.7 lbs of organic BOD₅ per day.

Sludge use and disposal description and location(s): N/A because of sludge hauling, by Peck's Septic Service.

Changes from the previous permit: The E. Coli monitoring and report requirements will add to the proposed permit.

Based on the review outlined in this fact sheet, it is recommended that the permit be drafted. A public notice of the draft permit will be published in the *Pennsylvania Bulletin* for public comments for 30 days.

Approve	Deny	Signatures	Date
X		<i>Hilaryle</i> Hilary H. Le / Environmental Engineering Specialist	January 3, 2025
X		<i>Maria D. Bebenek for</i> Daniel W. Martin, P.E. / Environmental Engineer Manager	January 27, 2025

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.03
Latitude	39° 58' 42.87"	Longitude	-77° 4' 52.88"
Quad Name	Hampton	Quad Code	
Wastewater Description:		Sewage Effluent	
Receiving Waters	Unnamed Tributary to North Branch Mud Run (WWF)	Stream Code	NA (Dry Stream to 08635)
NHD Com ID	57469385	RMI	0.58
Drainage Area	See comments below	Yield (cfs/mi ²)	See comments below
Q ₇₋₁₀ Flow (cfs)	See comments below	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)		Slope (ft/ft)	
Watershed No.	7-F	Chapter 93 Class.	WWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Not Assessed		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status	Name		
Nearest Downstream Public Water Supply Intake	Wrightsville Borough Municipal Authority, York County		
PWS Waters	Susquehanna River	Flow at Intake (cfs)	
PWS RMI	28.51 miles	Distance from Outfall (mi)	Approximate 54.32 miles

Changes Since Last Permit Issuance:

Other Comments: No Stream code exists for the dry stream on which the discharge is located. The drainage area at the discharge point is 0.076 mi.². The length of the dry stream from the discharge point to its confluence with UNT 08635 is 0.58 mile.

Drainage Area

The discharge is to Unnamed Tributary 08635 to North Branch Mud Run at RMI 0.30 mile. A drainage area upstream of the discharge is estimated to be 2.68 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

The nearby small watershed within the Conewago drainage basin (with an exit point on UNT 09045 just before its confluence with Conewago Creek) was chosen as a proper representative watershed. The Q₇₋₁₀ is 0.26 cfs and the drainage area is 4.89 mi.² (according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>) which results in a Q₇₋₁₀ low flow yield of 0.05 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 \text{Low Flow Yield} &= Q_{7-10\text{gage}} / \text{Drainage Area}_{\text{gage}} = 0.26 \text{ cfs} / 4.89 \text{ mi.}^2 = 0.05 \text{ cfs/mi.}^2 \\
 Q_{7-10\text{discharge}} &= 0.05 \text{ cfs/mi.}^2 * \text{Drainage Area}_{\text{discharge}} = 0.05 \text{ cfs/mi.}^2 * 2.68 \text{ mi.}^2 = 0.13 \text{ cfs} \\
 Q_{30-10} &= 1.36 * Q_{7-10\text{discharge}} = 1.36 * 0.13 \text{ cfs} = 0.18 \text{ cfs} \\
 Q_{1-10} &= 0.64 * Q_{7-10\text{discharge}} = 0.64 * 0.13 \text{ cfs} = 0.08 \text{ cfs}
 \end{aligned}$$

The resulting dilution ratio (under Q₇₋₁₀ conditions) is $Q_{\text{stream}}/Q_{\text{discharge}} = 0.13 \text{ cfs}/[0.03 \text{ MGD} * (1.55 \text{ cfs/MGD})] = 2.8:1$

Potable Water Supply Intake

The nearest downstream public water supply intake is the Wrightsville Borough Municipal Authority, York County intake on the Susquehanna River, approximately 54.32 miles from the point of discharge. Given the nature and dilution, the discharge is not expected to significantly impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Bermudian Springs Hs				
WQM Permit No.	Issuance Date			
0120404	11/13/2020			
0189403	9/28/1989			
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Primary	Sedimentation Tanks	Ultraviolet	0.03
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.03	66.7	Not Overloaded		

Changes Since Last Permit Issuance:

Other Comments:

The WWTP train is as follows:

Comminutor / Bar Screen (1) ⇒ EQ Tank (1) ⇒ Aeration Tank (1) ⇒ Settling Tank (1) ⇒ Sand Filters (2) ⇒ UV Disinfection ⇒ Sludge Holding Tanks (2) ⇒ Discharge to Dry Stream

Compliance History	
Summary of DMRs:	DMRs reported last 12 months are summarized in the next page.
Summary of Inspections:	1/25/2024: Mr. Hoy, DEP WQS, conducted a compliance evaluation inspection. The discharge was clear. The field test results indicated in permit limits. There were no violations indicate during inspection. DEP's requests: 1. Filling in the "Municipality" and "Dry Tons applied/Disposed" beneficial use information on future sludge hauling supplemental reports. 2. The date, time, initials of collector, and volume of individual grab samples for an 8-hour composite sample must be recorded and maintained with other sampling records. DEP's recommendations: 1. Determining the sludge storage capacity. 2. The facility utilizes as electronic composite sampler to satisfy sampling requirements as outlined in Part A of NPDES Permit PA0030511. 3. Recording the date, time, temperature, and initials of collector when samples are collected from the sample refrigerator for transportation for lab analysis.
Other Comments:	There are no open violations associated with this facility or permittee.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from December 1, 2023 to November 30, 2024)

Parameter	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24	DEC-23
Flow (MGD) Average Monthly	0.01567	0.02361	0.01579	0.01635	0.00851	0.0103	0.01652	0.01796	0.02027	0.01556	0.01745	0.01669
Flow (MGD) Daily Maximum	0.02409	0.01934	0.02563	0.02711	0.02181	0.02183	0.02817	0.02548	0.05371	0.02623	0.02932	0.0293
pH (S.U.) Instantaneous Minimum	6.8	6.8	6.4	6.7	7.2	6.5	6.5	6.7	6.9	6.6	6.6	6.7
pH (S.U.) Instantaneous Maximum	7.1	7.1	7.0	7.6	7.5	7.3	7.1	7.2	7.3	7.2	7.3	7.1
DO (mg/L) Instantaneous Minimum	9.3	8.2	6.6	6.1	8.0	8.2	7.4	8.4	8.1	6.5	9.9	10.0
CBOD5 (mg/L) Average Monthly	< 2	< 2	< 2	< 2	< 2.0	< 2	< 2	< 3.0	< 3.0	< 2	< 4	< 3
TSS (mg/L) Average Monthly	4	2.0	3	6	11.0	4	2	1.0	2	1	1	2
Fecal Coliform (No./100 ml) Geometric Mean	18	8	3	2	< 11.0	5	7	< 1	13	1.0	4	< 11
Fecal Coliform (No./100 ml) Instantaneous Maximum	28	10	3	4	118	6	11	< 1	162	2.0	17	129
UV Intensity (mW/cm ²) Instantaneous Minimum	4.6	4.7	5	5.9	8.1	4.4	5.4	5.3	5.0	4.4	3.5	5.3
Nitrate-Nitrite (lbs/day) Total Annual												264
Nitrate-Nitrite (mg/L) Annual Average												70.9
Total Nitrogen (lbs/day) Total Annual												264
Total Nitrogen (mg/L) Annual Average												70.9
Ammonia (mg/L) Average Monthly	< 0.1	< 0.1	< 0.1	1.2	< 0.1	< 0.1	< 0.2	< 0.1	< 0.1	< 0.1	< 3.1	< 0.1

NPDES Permit Fact Sheet
Bermudian Springs High School

NPDES Permit No. PA0030511

TKN (lbs/day) Total Annual												< 2
TKN (mg/L) Annual Average												< 0.5
Total Phosphorus (lbs/day) Total Annual												26
Total Phosphorus (mg/L) Annual Average												7

Existing Effluent Limitations and Monitoring Requirements

Outfall 001,

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
CBOD ₅	XXX	XXX	XXX	10	XXX	20	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10	XXX	20	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6	2/month	8-Hr Composite
TKN	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Nitrate-Nitrite	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Nitrogen	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Development of Effluent Limitations

Outfall No. 001
Latitude 39° 58' 42.87"
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.03
Longitude -77° 4' 52.88"

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: TRC is not applied to this facility because the UV is for disinfection.

Water Quality-Based Limitations

Ammonia (NH₃-N):

NH₃-N calculations were first based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The following data is necessary to determine the in-stream NH₃-N criteria used in the attached computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 25°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 25°C (Default for WWF)
- Background NH₃-N = 0 (Default)

The screenshot shows the 'Effluent Limitations' tab in the 'Analysis Results WQM 7.0' software. The interface includes a table for effluent limits for parameters like CBOD₅, NH₃-N, and Dissolved Oxygen. The table has columns for 'Parameter', 'Effluent Limit 30 Day Average (mg/L)', 'Effluent Limit Maximum (mg/L)', and 'Effluent Limit Minimum (mg/L)'. The values are: CBOD₅ (25), NH₃-N (6.73), and Dissolved Oxygen (5). The interface also includes a 'Record: 1 of 1' indicator and a 'Search' button.

Regarding NH₃-N limits, the attached computer printout of the WQM 7.0 stream model (version 1.1) indicates that a limit of 6.73 mg/L as a monthly average and 13.46 mg/L instantaneous maximum (IMAX) are necessary to protect the aquatic life from toxicity effects at the point of discharge. However, the existing limits of 3.0 mg/L monthly average & 6.0 mg/L IMAX are slightly high and will remain in the proposed permit. Per anti-backsliding policy, the existing winter average monthly limit of 9.0 mg/L & IMAX limit of 18.0 mg/L will remain in place. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

Carbonaceous Biochemical Oxygen Demand (CBOD₅):

The attached computer printout of the WQM 7.0 stream model indicates that a monthly average limit of 25.0 mg/L, or secondary treatment, is adequate to protect the water quality of the stream. However, the existing limits of 10.0 mg/L monthly average and 20.0 mg/L instantaneous maximum will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

Dissolved Oxygen (D.O.):

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. This is consistent with the previous permit and current Department criteria.

Total Suspended Solids (TSS):

The existing dry stream limits of 10.0 mg/L monthly average and 20.0 mg/L instantaneous maximum will remain in the proposed permit as per guidance document 391-2000-014. Recent DMRs and inspection reports show that the facility has been consistently achieving these limits.

pH:

The effluent discharge pH should remain above 6.0 and below 9.0 standard units according to 25 Pa. Code § 95.2(2).

Fecal Coliform:

The recent coliform guidance in 25 Pa. Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa. Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

E. Coli:

As recommended by DEP's SOP No. BCW-PMT-033, version 2.0 revised February 5, 2024, a routine monitoring for E. Coli will be included in the proposed permit under 25 Pa. Code § 92a.61. This requirement applies to all sewage dischargers greater than 0.002 MGD in their new and reissued permits. A monitoring frequency of 1/year will be included in the permit to be consistent with the recommendation from this SOP.

UV:

The UV system daily monitor and report the UV light intensity (mW/cm²) will remain in the proposed permit.

Chesapeake Bay Strategy:

The Department formulated a strategy to comply with the EPA and Chesapeake Bay Foundation requirements by reducing point source loadings of Total Nitrogen (TN) and Total Phosphorus (TP). Sewage discharges have been prioritized by Central Office based on their delivered TN loadings to the Bay. The highest priority (Phases I, II, and III) dischargers will receive annual loading caps based on their design flow on August 29, 2005 and concentrations of 6 mg/L TN and 0.8 mg/L TP. These limits may be achieved through a combination of treatment technology, credits, or offsets. Phase IV (0.2 - 0.4 MGD) will be required to monitor and report TN and TP during permit renewal monthly and Phase V (below 0.2 MGD) will monitor during current permit renewal once a year. However, any facility in Phases IV and V that undergoes expansion is subjected to cap load right away.

The discharge of TN and TP from this facility is consistent with and covered under the Chesapeake Bay TMDL aggregate WLA for non-significant wastewater discharges. Therefore, a 1/year "Monitor & Report" for Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, TN, and TP requirements will be added to the proposed permit.

Antidegradation (93.4):

The effluent limits for this discharge have been developed to ensure that existing in-stream water uses and the level of water quality necessary to protect the existing uses are maintained and protected. No High-Quality Waters are impacted by this discharge. No Exceptional Value Waters are impacted by this discharge.

Class A Wild Trout Fisheries:

No Class A Wild Trout Fisheries are impacted by this discharge.

303d Listed Streams:

eMap PA lists the dry stream as tentatively impaired at the discharge point for excessive algal growth and siltation due to agriculture. UNT 08635 also has a tentative impairment for the same items. A TMDL has not yet been developed.

Additional Consideration

Flow Monitoring

The requirement to monitor the volume of effluent will remain in the proposed permit per 40 CFR § 122.44(i)(1)(ii).

Monitoring Frequency and Sample Type

The facility currently is required to collect daily effluent grab samples for D.O., UV light intensity, and pH; bi-monthly effluent 8-hr composite samples of CBOD₅, TSS, and Ammonia-Nitrogen; bi-monthly effluent grab samples of Fecal Coliform; annually effluent 8-hr composite samples of TP, Nitrate-Nitrite as N, and total Kjeldahl Nitrogen; and annually effluent calculation samples of TN. Based on the best professional judgement of the author, the existing monitoring frequencies are sufficient and necessary. Therefore, the renewal permit monitoring frequencies will remain the same as those specified in the existing permit.

WQM 7.0 Data


*	Discharge pH	=	7.0	(Default)
*	Discharge Temperature	=	25°C	(Default)
*	Stream pH	=	7.0	(Default)
*	Stream Temperature	=	25°C	(Default for WWF)
*	Background NH ₃ -N	=	0	(Default)



Node 1: Point of First Use on UNT Mud Run (08635) (0.58 mi downstream of Outfall 001)

Elevation:	528 ft (USGS National Map Viewer)
Drainage Area:	2.68 mi. ² (USGS PA StreamStats)
River Mile Index:	0.30 (PA DEP eMapPA)
Low Flow Yield:	0.05 cfs/mi. ²
Discharge Flow:	0.03 MGD

Node 2: Just before confluence with Mud Run

Elevation:	517 ft (USGS National Map Viewer)
Drainage Area:	3.04 mi. ² (USGS PA StreamStats)
River Mile Index:	0.001 (PA DEP eMapPA)
Low Flow Yield:	0.05 cfs/mi. ²
Discharge Flow:	0.000 MGD





NPDES Permit Fact Sheet
Bermudian Springs High School

NPDES Permit No. PA0030511

> Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
BSLOPD	Mean basin slope measured in degrees	0.9956	degrees
DRNAREA	Area that drains to a point on a stream	3.04	square miles
ROCKDEP	Depth to rock	4.4	feet
URBAN	Percentage of basin with urban development	0.6297	percent

> Low-Flow Statistics

Low-Flow Statistics Parameters [Low Flow Region 1]


Parameter Code	Parameter Name	Value	Units	Min Limit	Max Limit
DRNAREA	Drainage Area	3.04	square miles	4.78	1150
BSLOPD	Mean Basin Slope degrees	0.9956	degrees	1.7	6.4
ROCKDEP	Depth to Rock	4.4	feet	4.13	5.21
URBAN	Percent Urban	0.6297	percent	0	89

Low-Flow Statistics Disclaimers [Low Flow Region 1]

One or more of the parameters is outside the suggested range. Estimates were extrapolated with unknown errors.

Low-Flow Statistics Flow Report [Low Flow Region 1]

Statistic	Value	Unit
7 Day 2 Year Low Flow	0.0621	ft ³ /s
30 Day 2 Year Low Flow	0.12	ft ³ /s
7 Day 10 Year Low Flow	0.0146	ft ³ /s
30 Day 10 Year Low Flow	0.0303	ft ³ /s
90 Day 10 Year Low Flow	0.107	ft ³ /s



Analysis Results WQM 7.0


Hydrodynamics | **NH3-N Allocations** | D.O. Allocations | D.O. Simulation | Effluent Limitations



RMI	Discharge Name	Permit Number	Disc Flow (mgd)
0.30	Bermudian SSD	PA0030511	0.0300

Parameter	Effluent Limit 30 Day Average (mg/L)	Effluent Limit Maximum (mg/L)	Effluent Limit Minimum (mg/L)
CBOD5	25		
NH3-N	6.73	13.46	
Dissolved Oxygen			5

Record: 1 of 1 | No Filter | Search

Print | < Back | Next > | Archive | Cancel





Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Daily Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	Continuous	Measured
pH (S.U.)	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
D.O.	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
UV Intensity (mW/cm ²)	XXX	XXX	Report	XXX	XXX	XXX	1/day	Measured
CBOD ₅	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	10.0	XXX	20.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	8-Hr Composite
TKN	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Nitrate-Nitrite	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite
Total Nitrogen	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	Calculation
Total Phosphorus	XXX	Report Total Annual	XXX	Report Annl Avg	XXX	XXX	1/year	8-Hr Composite

Compliance Sampling Location:

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [REDACTED])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input checked="" type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input checked="" type="checkbox"/>	SOP: BCW-PMT-033
<input type="checkbox"/>	Other: [REDACTED]