

**Development of Effluent Limitations**

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	50	IMax	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	60	IMax	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	IMin – IMax	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(1) & TRC Implementation Guidance
	1.4	IMAX	-	
Total Nitrogen	Report	Daily Max	-	92a.61
Total Phosphorous	Report	Daily Max	-	92a.61

Comments: For TRC limits, consideration is given to the length of swale to Unnamed Tributary to Wolf Run. From swale to Unnamed Tributary, it is approximately 800 feet for the discharge to travel before it reaches the confluence. It is considered enough distance of a swale for TRC in the discharge to dissipate before it reaches the stream. Also, the given limits are acceptable based on the Regulation in Chapter 92.48(b)(1), TRC Implementation Guidance 391-2000-015/ May 1, 2003 and an internal memo on TRC Implementation for Sewage Facilities dated June 20, 1995.

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia-Nitrogen	2.1	Average Monthly	WQM6.3
	4.2	IMAX	
	4.4	Average Monthly	
Nov 1 to Apr 30	8.8	IMAX	
Dissolved Oxygen	5.0	Instant. Minimum	WQM6.3

**Compliance History**

<b>Summary of DMRs:</b>	A review of the Discharge Monitoring Report indicates general compliance with some minor effluent excursions.
<b>Summary of Inspections:</b>	A review of the inspection reports indicates general compliance with plant being maintained.

**Discharge, Receiving Waters and Water Supply Information**

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.032</u>
Latitude	<u>40° 40' 8.00"</u>	Longitude	<u>80° 25' 25.00"</u>
Quad Name	<u>Midland</u>	Quad Code	<u>1302</u>
Wastewater Description: <u>Treated sanitary sewage from a High School</u>			
Receiving Waters	<u>Swale to Unnamed Tributary of Wolf Run</u>	Stream Code	<u>None for swale For UNT 33532</u>
NHD Com ID	<u>99680454</u>	RMI	<u>UNT 0.53</u>
Drainage Area (sq.mi.)	<u>0.1 for swale, 0.2 for UT</u>	Yield (cfs/mi <sup>2</sup> )	<u>0 for swale, 0.027 for UT</u>
Q7-10 Flow (cfs)	<u>0 for swale, 0.0054 for UT</u>	Q7-10 Basis	<u>Previous Pollution Report</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u></u>
Watershed No.	<u>20-B</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u></u>	Exceptions to Criteria	<u></u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>

**Treatment Facility Summary**

**Treatment Facility Name:** Western Beaver Jr/Sr High School STP

WQM Permit No.	Issuance Date
9113-S	8/25/1958

Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary with Ammonia Removal	Extended Aeration	Chlorination	0.004
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.032	54	Not Overloaded	Aerobic Holding Tank	Landfill

