

Southwest Regional Office CLEAN WATER PROGRAM

| Application Type | Renewal | | Application No. | PA0030856 |
|------------------|---------|-------------------------|------------------|-----------|
| Facility Type | Sewage | NPDES PERMIT FACT SHEET | APS ID | 815033 |
| Major / Minor | Minor | | Authorization ID | 1263702 |

| Applicant and Facility Information | | | | | | | | |
|---|-----------------|----------------------------------|------------------|---|--|--|--|--|
| Applicant Name | | ern Beaver County ol District | Facility Name | Western Beaver Jr/Sr High School STP | | | | |
| Applicant Address 34 | | idgemont Drive | Facility Address | 343 Ridgemont Drive | | | | |
| | Midla | nd, PA 15059-2219 | | Industry, PA 15052-1602 | | | | |
| Applicant Contact | Robert Postupac | | Facility Contact | Same | | | | |
| Applicant Phone | _(724) 643-9310 | | Facility Phone | Same | | | | |
| Client ID | _1103 | | Site ID | 251936 | | | | |
| SIC Code | 8211 | | Municipality | Industry Borough | | | | |
| Services – Elementary SIC Description and Secondary Schools | | County | Beaver | | | | | |
| Date Application Received | | March 1, 2019 | EPA Waived? | Yes | | | | |
| Date Application Accepted | | March 5, 2019 | If No, Reason | | | | | |
| Purpose of Application | | Renewal of NPDES Permit | | | | | | |

Summary of Review

This application is for a renewal which was previously issued on August 15, 2014.

The existing treatment process consists of extended aeration, final clarification, and chlorination.

The discharge is to an unnamed tributary of Wolf Run. Wolf Run is classified as a warm water fishery.

Since there have been no changes to the receiving stream, the discharge, or Department Modeling Programs, the limitations are based on the previously approved pollution report (copy attached as a pdf file).



Pollution Report

Monitoring Frequencies

Department policy allows Daily when Discharging for the parameters pH, D.O. and TRC from a school discharge. This monitoring frequency will be implemented

This permit has been established in accordance with the Standard Operating Procedure (SOP)1 for Clean Water Program Establishing Effluent Limitations for Individual Sewage Permits SOP No. BCW-PMT-033 Final, November 9, 2012 Revised, January 10, 2019 Version 1.6

| Approve | Return | Deny | Signatures | Date |
|---------|--------|------|--|-----------|
| X | | | Raymond E. Lattner / Environmental Application Mngr. | 2/11/2020 |
| Х | | | Donald J. Leone, P.E. / Environmental Engineer Manager | 2/12/2020 |