

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0030970
 APS ID 1032016
 Authorization ID 1342661

Applicant and Facility Information

| | | | |
|---------------------------|---|------------------|---|
| Applicant Name | <u>PA State System Of Higher Ed Cheyney University</u> | Facility Name | <u>Cheyney University Of PA</u> |
| Applicant Address | <u>PO Box 200 1837 University Circle Cheyney, PA 19319-0200</u> | Facility Address | <u>1837 University Circle Creek Road & Cheyney Road Cheyney, PA 19319</u> |
| Applicant Contact | <u>James Lewis</u> | Facility Contact | <u>James Lewis</u> |
| Applicant Phone | <u>(610) 399-2092</u> | Facility Phone | <u>(610) 399-2092</u> |
| Client ID | <u>209276</u> | Site ID | <u>452780</u> |
| Ch 94 Load Status | <u>Not Overloaded</u> | Municipality | <u>Thornbury Township</u> |
| Connection Status | <u>No Limitations</u> | County | <u>Delaware</u> |
| Date Application Received | <u>February 10, 2021</u> | EPA Waived? | <u>Yes</u> |
| Date Application Accepted | <u>Not Applicable</u> | If No, Reason | <u></u> |
| Purpose of Application | <u>Permit Renewal.</u> | | |

Summary of Review

The permittee submitted a renewal NPDES permit application for their treated effluent sewage discharge to Chester Creek through Outfall 001. The facility is a sewage treatment plant serving Cheyney University campus and a portion of a residential neighborhood. The previous Fact Sheet noted that 95 % of flow was from the University and 5% from Thornbury Township.

The facility consists of Influent Screening followed by the Influent Flow Equalization, which is then pumped to, and treated by, two parallel Sequencing Batch Reactors (SBR), Equalization, Effluent Filtration, Ultraviolet Disinfection, and finally discharge through the outfall. The SBR solids are wasted to an aerobic digester and two sludge holding tanks.

The limitations from the current permit are retained in this permit, as are the monitoring frequencies and sample type. Monitoring of E. coli was added to this renewal based on an updated SOP and code. E. coli will be monitored quarterly and will be grab sample which is already instituted at the facility. The influent sampling was continued in this permit as the facility serves part of a municipality. UV monitoring is continued in the permit as the facility is using UV disinfection (it was noted in the last Fact Sheet the facility switched from chlorine to UV prior to May 6, 2016).

Sludge use and disposal description and location(s): Hauled off-site

Act 14 Notifications:

Delaware County Received February 18, 2021
 Thornbury Township Received February 6, 2021

Proposed Part C Conditions:

- No Stormwater

| Approve | Deny | Signatures | Date |
|---------|------|--|-------------|
| X | | Harmonie Hawley, PhD, PE / Environmental Engineering Specialist /s/ | May 3, 2021 |
| X | | Pravin C. Patel, P.E. / Environmental Engineer Manager /s/ | 05/04/2021 |

Summary of Review

- Acquire Necessary Property Rights
- Proper Sludge Disposal
- Abandon STP When Municipal Sewers Available
- Notification of Designation of the Responsible Operator
- Remedial Measures if Unsatisfactory Effluent
- I-Max Requirements
- Solids Management

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

| Discharge, Receiving Waters and Water Supply Information | | | |
|--|---|-------------------------------------|------------------------|
| Outfall No. | <u>001</u> | Design Flow (MGD) | <u>.27</u> |
| Latitude | <u>39° 55' 45.78"</u> | Longitude | <u>-75° 31' 30.52"</u> |
| Quad Name | <u>West Chester</u> | Quad Code | <u>1941</u> |
| Wastewater Description: <u>Sewage Effluent</u> | | | |
| Receiving Waters | <u>Chester Creek (TSF, MF)</u> | Stream Code | <u>00604</u> |
| NHD Com ID | <u>25621342</u> | RMI | <u>14.7</u> |
| Drainage Area | <u>21</u> | Yield (cfs/mi ²) | <u>0.23</u> |
| Q ₇₋₁₀ Flow (cfs) | <u>4.74</u> | Q ₇₋₁₀ Basis | <u>PA StreamStats</u> |
| Elevation (ft) | <u>248</u> | Slope (ft/ft) | <u>0.00296</u> |
| Watershed No. | <u>3-G</u> | Chapter 93 Class. | <u>TSF, MF</u> |
| Existing Use | <u>Recreational/ Aquatic Life</u> | Existing Use Qualifier | <u>N/A</u> |
| Exceptions to Use | <u>None</u> | Exceptions to Criteria | <u>N/A</u> |
| Assessment Status | <u>Impaired</u> | | |
| Cause(s) of Impairment | <u>Cause Unknown, Flow Regime Modification, Siltation</u> | | |
| Source(s) of Impairment | <u>Urban Runoff/Storm Sewers</u> | | |
| TMDL Status | <u>None</u> | Name | <u>None</u> |
| Background/Ambient Data | | Data Source | |
| pH (SU) | <u>7</u> | TRG WQM (391-2000-007 default data) | |
| Temperature (°F) | <u>68 (20 °C)</u> | TRG WQM (391-2000-007 default data) | |
| Hardness (mg/L) | <u>100</u> | Toxics Analysis Spreadsheet default | |
| Other: | <u>N/A</u> | None | |
| Nearest Downstream Public Water Supply Intake | <u>Aqua PA Main Stem Crum Creek</u> | | |
| PWS Waters | <u>Chester Creek</u> | Flow at Intake (cfs) | <u>30.9</u> |
| PWS RMI | <u>7.1</u> | Distance from Outfall (mi) | <u>7.7</u> |

Changes Since Last Permit Issuance: None

Other Comments: None

| Treatment Facility Summary | | | | |
|--|----------------------------|--|---------------------|------------------------|
| Treatment Facility Name: Cheyney University STP | | | | |
| WQM Permit No. | | Issuance Date | | |
| 2312403 | | June 28, 2012 | | |
| Waste Type | Degree of Treatment | Process Type | Disinfection | Avg Annual Flow (MGD) |
| Sewage | Tertiary | Sequencing Batch Reactor W/Sol Removal | Ultraviolet | 0.27 |
| Hydraulic Capacity (MGD) | Organic Capacity (lbs/day) | Load Status | Biosolids Treatment | Biosolids Use/Disposal |
| 0.27 | 540 | Not Overloaded | Aerobic Digestion | Landfill |

Changes Since Last Permit Issuance: None

Other Comments: None

Compliance History

DMR Data for Outfall 001 (from March 1, 2020 to February 28, 2021)

| Parameter | FEB-21 | JAN-21 | DEC-20 | NOV-20 | OCT-20 | SEP-20 | AUG-20 | JUL-20 | JUN-20 | MAY-20 | APR-20 | MAR-20 |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD) Average Monthly | 0.065 | 0.047 | 0.043 | 0.049 | 0.046 | 0.045 | 0.047 | 0.028 | 0.032 | 0.0423 | 0.0443 | 0.0432 |
| pH (S.U.) Instantaneous Minimum | 6.9 | 7.5 | 7.2 | 7.3 | 7.1 | 7.2 | 7.2 | 7.2 | 7.1 | 6.6 | 6.43 | 6.19 |
| pH (S.U.) Instantaneous Maximum | 7.8 | 7.8 | 7.9 | 7.7 | 7.7 | 7.9 | 8.0 | 7.9 | 8.4 | 7.7 | 7.01 | 7.24 |
| DO (mg/L) Instantaneous Minimum | 8.6 | 9.4 | 7.2 | 7.1 | 6.9 | 5.9 | 4.4 | 6.4 | 7.0 | 7.4 | 7.27 | 8.18 |
| CBOD5 (lbs/day) Average Monthly | < 1.2 | < 0.8 | < 1.5 | < 0.9 | < 1.0 | < 1.2 | < 3.5 | < 0.5 | < 0.6 | < 0.9 | 1.1 | 1.0 |
| CBOD5 (mg/L) Average Monthly | < 2 | < 2 | < 4 | < 2 | < 2 | < 3 | < 8 | < 2 | < 2.0 | < 2 | 3.1 | 2.2 |
| CBOD5 (mg/L) Influent Average Monthly | 65.4 | 50.8 | 34 | 46.1 | 50.3 | 53.9 | 273.4 | 10.7 | 13.1 | 10 | 19.2 | 38.6 |
| CBOD5 (mg/L) Influent Instantaneous Maximum | 119 | 140 | 66.7 | 87.1 | 69.3 | 78.2 | 771.0 | 12.9 | 27.2 | 15 | 44.4 | 98.2 |
| TSS (lbs/day) Average Monthly | < 0.9 | < 0.5 | < 0.6 | 0.4 | < 1.1 | 0.8 | < 0.5 | < 2.0 | < 1.0 | 2.4 | 2.4 | 4.7 |
| TSS (mg/L) Average Monthly | < 1.5 | < 1.3 | < 1.6 | 1.0 | < 2.8 | 2.2 | < 1.0 | < 1.0 | < 4.6 | 6 | 6.7 | 10.9 |
| TSS (mg/L) Influent Average Monthly | 86.8 | 39.5 | 45.4 | 115 | 109.3 | 106.2 | 46.0 | 16.8 | 16.2 | 26 | 87.3 | 105 |
| TSS (mg/L) Influent Instantaneous Maximum | 99.0 | 60 | 64 | 187 | 116 | 123.0 | 100.0 | 37 | 25.0 | 41 | 130 | 230 |
| Fecal Coliform (No./100 ml) Geometric Mean | < 3 | < 2 | < 2 | < 2 | < 2 | < 2 | < 10 | < 2 | < 2.0 | < 2 | 1 | < 1 |

| | | | | | | | | | | | | |
|---|---------|----------|----------|----------|----------|----------|----------|----------|----------|--------|-------|--------|
| Fecal Coliform (No./100 ml) Instantaneous Maximum | 18 | < 2 | < 2 | < 2 | < 2 | < 2 | 700 | < 2 | < 2.0 | < 2 | 1 | < 1 |
| UV Intensity (mW/cm²) Average Monthly | 474.6 | 532.5 | 584.5 | 352.7 | 239.4 | 354.0 | 299 | 401.5 | 447.5 | 352.4 | 385.6 | 224.24 |
| Total Nitrogen (mg/L) Average Monthly | < 12.15 | < 5.0 | < 5.58 | < 14.32 | 17.45 | < 17.78 | < 9.59 | < 9.04 | < 8.30 | < 10.0 | 12.5 | 15.36 |
| Total Nitrogen (mg/L) Instantaneous Maximum | 13.54 | < 6.12 | < 7.06 | 16.00 | 19.04 | 20.14 | < 16.70 | < 10.50 | < 8.62 | 12.9 | 12.7 | 18.83 |
| Ammonia (lbs/day) Average Monthly | < 0.56 | < 0.04 | < 0.06 | < 0.04 | < 0.21 | < 0.04 | < 0.05 | < 0.02 | < 0.04 | < 0.04 | 0.2 | 0.2 |
| Ammonia (mg/L) Average Monthly | < 1.0 | < 0.10 | < 0.2 | < 0.1 | < 0.3 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.1 | < 0.5 | < 0.5 |
| Total Phosphorus (lbs/day) Average Monthly | 0.19 | < 0.04 | 0.08 | 0.43 | 0.35 | 0.06 | 0.04 | < 0.01 | < 0.02 | 0.06 | 0.03 | 0.06 |
| Total Phosphorus (mg/L) Average Monthly | 0.3 | < 0.10 | 0.2 | 1.0 | 0.7 | 0.2 | 0.1 | < 0.1 | < 0.10 | 0.12 | 0.1 | 0.13 |
| Total Copper (mg/L) Average Monthly | 0.0165 | < 0.0323 | < 0.0100 | < 0.0110 | < 0.0100 | < 0.0102 | < 0.01 | < 0.0100 | < 0.0106 | 0.011 | 0.01 | 0.01 |
| Total Copper (mg/L) Instantaneous Maximum | 0.0190 | 0.0800 | < 0.0100 | 0.0130 | < 0.0100 | 0.0110 | < 0.0100 | < 0.0100 | 0.0130 | 0.011 | 0.01 | 0.02 |

Compliance History

Effluent Violations for Outfall 001, from: April 1, 2020 To: February 28, 2021

| Parameter | Date | SBC | DMR Value | Units | Limit Value | Units |
|-----------|----------|----------|-----------|-------|-------------|-------|
| DO | 08/31/20 | Inst Min | 4.4 | mg/L | 5.0 | mg/L |

Summary of Inspections: The most recent Inspection was on 11/05/2020 with Violations noted (failure to use NIST thermometer; failure to maintain proper sample temperature).

Other Comments: No Open Violations were found for the site on April 27, 2021; an Open Violation for the client was found for failure to submit PAG130025 renewal application.

Development of Effluent Limitations

| | |
|---|---|
| Outfall No. <u>001</u> | Design Flow (MGD) <u>.27</u> |
| Latitude <u>39° 55' 45.78"</u> | Longitude <u>-75° 31' 30.52"</u> |
| Wastewater Description: <u>Sewage Effluent</u> | |

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant | Limit (mg/l) | SBC | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD ₅ | 25 | Average Monthly | 133.102(a)(4)(i) | 92a.47(a)(1) |
| | 40 | Average Weekly | 133.102(a)(4)(ii) | 92a.47(a)(2) |
| Total Suspended Solids | 30 | Average Monthly | 133.102(b)(1) | 92a.47(a)(1) |
| | 45 | Average Weekly | 133.102(b)(2) | 92a.47(a)(2) |
| pH | 6.0 – 9.0 S.U. | Min – Max | 133.102(c) | 95.2(1) |
| Fecal Coliform (5/1 – 9/30) | 200 / 100 ml | Geo Mean | - | 92a.47(a)(4) |
| Fecal Coliform (5/1 – 9/30) | 1,000 / 100 ml | IMAX | - | 92a.47(a)(4) |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml | Geo Mean | - | 92a.47(a)(5) |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX | - | 92a.47(a)(5) |
| Total Residual Chlorine | 0.5 | Average Monthly | - | 92a.48(b)(2) |

Comments: TSS, pH, and fecal coliform are retained from the current permit and are consistent with the above references. Chlorine is not used for disinfection so there are no limitations for TRC; however, monitoring of the UV system is retained in this renewal. In addition to the above listed parameters, monitoring for Total Nitrogen is standard practice and is retained in this permit (SOP No. BCW-PMT-033 based on Chapter 92a.61). The facility has no industrial users.

E. coli was added to the permit with a sampling frequency of once per quarter per SOP No. BCW-PMT-033 based on Chapter 92a.61.

Water Quality-Based Limitations

A "Reasonable Potential Analysis" (Attachment A) determined the following parameters were candidates for limitations: Total Copper

The following limitations were determined through water quality modeling (output files attached):

| Parameter | Limit (mg/l) | SBC | Model |
|--------------|--------------|--------|-------|
| Total Copper | Report | 1/week | TMS |

Comments: The WQM model was run and the results are shown in Attachment B. The limitations for CBOD₅, NH₃-N, and DO were the same as the current permit and will be retained in this permit. Seasonal limits for ammonia-nitrogen are continued in the renewal. The Total Dissolved Solids are under 1,000 mg/l so monitoring is not added to this permit. The limits for Total Phosphorus are retained in this permit. There is a DRBC docket, number D-78-43CP, however it does not provide any effluent limitations.

Best Professional Judgment (BPJ) Limitations

Comments: Total Phosphorous limits are retained in the permit.

Anti-Backsliding

None

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------------------|-------------------------------------|-------------------|-----------------------|---------------------|---------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Flow (MGD) | Report | XXX | XXX | XXX | XXX | XXX | Continuous | Recorded |
| pH (S.U.) | XXX | XXX | 6.0 Inst Min | XXX | XXX | 9.0 | 1/day | Grab |
| DO | XXX | XXX | 5.0 Inst Min | XXX | XXX | XXX | 1/day | Grab |
| CBOD5 Influent | XXX | XXX | XXX | Report | XXX | Report | 1/week | 24-Hr Composite |
| CBOD5 | 56.3 | XXX | XXX | 25 | XXX | 50 | 1/week | 24-Hr Composite |
| TSS Influent | XXX | XXX | XXX | Report | XXX | Report | 1/week | 24-Hr Composite |
| TSS | 67.6 | XXX | XXX | 30 | XXX | 60 | 1/week | 24-Hr Composite |
| Fecal Coliform (No./100 ml) | XXX | XXX | XXX | 200 Geo Mean | XXX | 1000 | 1/week | Grab |
| E. Coli (No./100 ml) | XXX | XXX | XXX | Report Avg Qrtly | XXX | XXX | 1/quarter | Grab |
| UV Intensity (mW/cm ²) | XXX | XXX | XXX | Report | XXX | XXX | 1/day | Metered |
| Total Nitrogen | XXX | XXX | XXX | Report | XXX | Report | 1/week | 24-Hr Composite |
| Ammonia Nov 1 - Apr 30 | 16.8 | XXX | XXX | 7.5 | XXX | 15 | 1/week | 24-Hr Composite |
| Ammonia May 1 - Oct 31 | 5.6 | XXX | XXX | 2.5 | XXX | 5 | 1/week | 24-Hr Composite |

Outfall001 , Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter | Effluent Limitations | | | | | | Monitoring Requirements | |
|------------------------------------|-------------------------------------|-------------------|-----------------------|--------------------|---------|---------------------|--|----------------------------|
| | Mass Units (lbs/day) ⁽¹⁾ | | Concentrations (mg/L) | | | | Minimum ⁽²⁾ Measurement Frequency | Required Sample Type |
| | Average Monthly | Average Weekly | Minimum | Average Monthly | Maximum | Instant. Maximum | | |
| Total Phosphorus Nov 1 - Mar 31 | 4.5 | XXX | XXX | 2.0 | XXX | 4 | 1/week | 24-Hr Composite |
| Total Phosphorus Apr 1 - Oct 31 | 2.3 | XXX | XXX | 1.0 | XXX | 2 | 1/week | 24-Hr Composite |
| Total Copper | XXX | XXX | XXX | Report | XXX | Report | 1/week | 24-Hr Composite |

Compliance Sampling Location: Outfall 001

Other Comments: None

Attachment A: TMS



Toxic Management Spreadsheet
Version 1.3, March 2021

Discharge Information

Instructions Discharge Stream

Facility: Cheyney University NPDES Permit No.: PA0030970 Outfall No.: 001

Evaluation Type: Major Sewage / Industrial Waste Wastewater Description: Municipal

| Discharge Characteristics | | | | | | | | |
|---------------------------|------------------|----------|----------------------------|-----|-----|-----|--------------------------|----------------|
| Design Flow (MGD)* | Hardness (mg/l)* | pH (SU)* | Partial Mix Factors (PMFs) | | | | Complete Mix Times (min) | |
| | | | AFC | CFC | THH | CRL | Q _{T-10} | Q ₁ |
| 0.27 | 100 | 7 | | | | | | |

| Discharge Pollutant | Units | Max Discharge Conc | 0 if left blank | | 0.5 if left blank | | 0 if left blank | | 1 if left blank | | |
|---------------------|---------------------------------|--------------------|-----------------|-------------|-------------------|-----------|-----------------|------------|-----------------|--------------|-------------|
| | | | Trib Conc | Stream Conc | Daily CV | Hourly CV | Stream CV | Fate Coeff | FOS | Criteria Mod | Chem Transl |
| Group 1 | Total Dissolved Solids (PWS) | mg/L | 337 | | | | | | | | |
| | Chloride (PWS) | mg/L | 97.4 | | | | | | | | |
| | Bromide | mg/L | < 0.12 | | | | | | | | |
| | Sulfate (PWS) | mg/L | 42.7 | | | | | | | | |
| | Fluoride (PWS) | mg/L | | | | | | | | | |
| Group 2 | Total Aluminum | µg/L | | | | | | | | | |
| | Total Antimony | µg/L | | | | | | | | | |
| | Total Arsenic | µg/L | | | | | | | | | |
| | Total Barium | µg/L | | | | | | | | | |
| | Total Beryllium | µg/L | | | | | | | | | |
| | Total Boron | µg/L | | | | | | | | | |
| | Total Cadmium | µg/L | | | | | | | | | |
| | Total Chromium (III) | µg/L | | | | | | | | | |
| | Hexavalent Chromium | µg/L | | | | | | | | | |
| | Total Cobalt | µg/L | | | | | | | | | |
| | Total Copper | µg/L | 20 | | | | | | | | |
| | Free Cyanide | µg/L | | | | | | | | | |
| | Total Cyanide | µg/L | | | | | | | | | |
| | Dissolved Iron | µg/L | | | | | | | | | |
| | Total Iron | µg/L | | | | | | | | | |
| | Total Lead | µg/L | < 1 | | | | | | | | |
| | Total Manganese | µg/L | | | | | | | | | |
| | Total Mercury | µg/L | | | | | | | | | |
| | Total Nickel | µg/L | | | | | | | | | |
| | Total Phenols (Phenolics) (PWS) | µg/L | | | | | | | | | |
| | Total Selenium | µg/L | | | | | | | | | |
| | Total Silver | µg/L | | | | | | | | | |
| | Total Thallium | µg/L | | | | | | | | | |
| Total Zinc | µg/L | 15 | | | | | | | | | |
| Total Molybdenum | µg/L | | | | | | | | | | |
| Acrolein | µg/L | < | | | | | | | | | |
| Acrylamide | µg/L | < | | | | | | | | | |
| Acrylonitrile | µg/L | < | | | | | | | | | |
| Benzene | µg/L | < | | | | | | | | | |
| Bromoform | µg/L | < | | | | | | | | | |



Stream / Surface Water Information

Cheyney University, NPDES Permit No. PA0030970, Outfall 001

Instructions Discharge **Stream**

Receiving Surface Water Name: Chester Creek

No. Reaches to Model: 1

- Statewide Criteria
- Great Lakes Criteria
- ORSANCO Criteria

| Location | Stream Code* | RMI* | Elevation (ft)* | DA (mi ²)* | Slope (ft/ft) | PWS Withdrawal (MGD) | Apply Fish Criteria* |
|--------------------|--------------|------|-----------------|------------------------|---------------|----------------------|----------------------|
| Point of Discharge | 000604 | 14.7 | 248 | 21 | | | Yes |
| End of Reach 1 | 000604 | 13.1 | 223 | 24.3 | | | Yes |

Q₇₋₁₀

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|-----|-----------|-----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness* | pH* | Hardness | pH |
| Point of Discharge | 14.7 | 0.1 | 4.74 | | | | | | | | 100 | 7 | | | |
| End of Reach 1 | 13.1 | 0.1 | 5.71 | | | | | | | | | | | | |

Q_n

| Location | RMI | LFY (cfs/mi ²)* | Flow (cfs) | | W/D Ratio | Width (ft) | Depth (ft) | Velocity (fps) | Travel Time (days) | Tributary | | Stream | | Analysis | |
|--------------------|------|-----------------------------|------------|-----------|-----------|------------|------------|----------------|--------------------|-----------|----|----------|----|----------|----|
| | | | Stream | Tributary | | | | | | Hardness | pH | Hardness | pH | Hardness | pH |
| Point of Discharge | 14.7 | | | | | | | | | | | | | | |
| End of Reach 1 | 13.1 | | | | | | | | | | | | | | |



Model Results

Cheyney University, NPDES Permit No. PA0030970, Outfall 001

All
 Inputs
 Results
 Limits

Hydrodynamics

Wasteload Allocations

AFC
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | 13.439 | 14.0 | 116 | Chem Translator of 0.96 applied |
| Total Lead | 0 | 0 | | 0 | 64.581 | 81.6 | 676 | Chem Translator of 0.791 applied |
| Total Zinc | 0 | 0 | | 0 | 117.180 | 120 | 992 | Chem Translator of 0.978 applied |

CFC
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------------------------------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | 8.956 | 9.33 | 115 | Chem Translator of 0.96 applied |
| Total Lead | 0 | 0 | | 0 | 2.517 | 3.18 | 39.3 | Chem Translator of 0.791 applied |
| Total Zinc | 0 | 0 | | 0 | 118.139 | 120 | 1,480 | Chem Translator of 0.986 applied |

THW
 CCT (min):
 PMF:
 Analysis Hardness (mg/l):
 Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | 500,000 | 500,000 | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | 250,000 | 250,000 | N/A | |

| | | | | | | | | |
|--------------|---|---|--|---|-----|-----|-----|--|
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |

CRL CCT (min): PMF: Analysis Hardness (mg/l): Analysis pH:

| Pollutants | Stream Conc (µg/L) | Stream CV | Trib Conc (µg/L) | Fate Coef | WQC (µg/L) | WQ Obj (µg/L) | WLA (µg/L) | Comments |
|------------------------------|--------------------|-----------|------------------|-----------|------------|---------------|------------|----------|
| Total Dissolved Solids (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Chloride (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Sulfate (PWS) | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Copper | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Lead | 0 | 0 | | 0 | N/A | N/A | N/A | |
| Total Zinc | 0 | 0 | | 0 | N/A | N/A | N/A | |

Recommended WQBELs & Monitoring Requirements

No. Samples/Month:

| Pollutants | Mass Limits | | Concentration Limits | | | | Governing WQBEL | WQBEL Basis | Comments |
|--------------|---------------|---------------|----------------------|--------|--------|-------|-----------------|-------------|------------------------------------|
| | AML (lbs/day) | MDL (lbs/day) | AML | MDL | IMAX | Units | | | |
| Total Copper | Report | Report | Report | Report | Report | µg/L | 74.3 | AFC | Discharge Conc > 10% WQBEL (no RP) |

Other Pollutants without Limits or Monitoring

The following pollutants do not require effluent limits or monitoring based on water quality because reasonable potential to exceed water quality criteria was not determined and the discharge concentration was less than thresholds for monitoring, or the pollutant was not detected and a sufficiently sensitive analytical method was used (e.g., <= Target QL).

| Pollutants | Governing WQBEL | Units | Comments |
|------------------------------|-----------------|-------|----------------------------|
| Total Dissolved Solids (PWS) | N/A | N/A | PWS Not Applicable |
| Chloride (PWS) | N/A | N/A | PWS Not Applicable |
| Bromide | N/A | N/A | No WQS |
| Sulfate (PWS) | N/A | N/A | PWS Not Applicable |
| Total Lead | N/A | N/A | Discharge Conc < TGL |
| Total Zinc | 636 | µg/L | Discharge Conc ≤ 10% WQBEL |

Attachment B: WQM

WQM 7.0 Effluent Limits

| <u>SWP Basin</u> | | <u>Stream Code</u> | | <u>Stream Name</u> | | | |
|------------------|-----------------|--------------------|-----------------|---------------------------|--------------------------------|----------------------------|----------------------------|
| 03G | | 604 | | EAST BRANCH CHESTER CREEK | | | |
| RMI | Name | Permit Number | Disc Flow (mgd) | Parameter | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 14.700 | Cheyney Univers | PA0030970 | 0.270 | CBOD5 | 25 | | |
| | | | | NH3-N | 2.5 | 5 | |
| | | | | Dissolved Oxygen | | | 5 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|---------------------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 03G | 604 | EAST BRANCH CHESTER CREEK | 14.700 | 248.00 | 21.00 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | Tributary pH | Stream Temp | Stream pH |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|--------------|-------------|-----------|
| | (cfsm) | (cfs) | (cfs) | (days) | (fps) | | (ft) | (ft) | (°C) | | (°C) | |
| Q7-10 | 0.100 | 4.74 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

Discharge Data

| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
|-----------------|---------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Cheyney Univers | PA0030970 | 0.2700 | 0.2700 | 0.2700 | 0.000 | 25.00 | 7.00 |

Parameter Data

| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) |
|------------------|------------------|------------------|--------------------|--------------------|
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 |
| Dissolved Oxygen | 5.00 | 8.24 | 0.00 | 0.00 |
| NH3-N | 2.50 | 0.00 | 0.00 | 0.70 |

Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name | RMI | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC |
|-----------|-------------|---------------------------|--------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 03G | 604 | EAST BRANCH CHESTER CREEK | 13.100 | 223.00 | 24.30 | 0.00000 | 0.00 | <input checked="" type="checkbox"/> |

Stream Data

| Design Cond. | LFY | Trib Flow | Stream Flow | Rch Trav Time (days) | Rch Velocity (fps) | WD Ratio | Rch Width (ft) | Rch Depth (ft) | Tributary Temp (°C) | Tributary pH | Stream Temp (°C) | Stream pH |
|--------------|--------|-----------|-------------|----------------------|--------------------|----------|----------------|----------------|---------------------|--------------|------------------|-----------|
| | (cfsm) | (cfs) | (cfs) | | | | | | | | | |
| Q7-10 | 0.100 | 5.71 | 0.00 | 0.000 | 0.000 | 0.0 | 0.00 | 0.00 | 20.00 | 7.00 | 0.00 | 0.00 |
| Q1-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |
| Q30-10 | | 0.00 | 0.00 | 0.000 | 0.000 | | | | | | | |

| Discharge Data | | | | | | | |
|------------------|------------------|--------------------------|---------------------------|------------------------|----------------|----------------|---------|
| Name | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor | Disc Temp (°C) | Disc pH |
| | | 0.0000 | 0.0000 | 0.0000 | 0.000 | 25.00 | 7.00 |
| Parameter Data | | | | | | | |
| Parameter Name | Disc Conc (mg/L) | Trib Conc (mg/L) | Stream Conc (mg/L) | Fate Coef (1/days) | | | |
| CBOD5 | 25.00 | 2.00 | 0.00 | 1.50 | | | |
| Dissolved Oxygen | 3.00 | 8.24 | 0.00 | 0.00 | | | |
| NH3-N | 25.00 | 0.00 | 0.00 | 0.70 | | | |

WQM 7.0 Modeling Specifications

| | | | |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters | Both | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method | EMPR | Use Inputted W/D Ratio | <input type="checkbox"/> |
| Q1-10/Q7-10 Ratio | 0.64 | Use Inputted Reach Travel Times | <input type="checkbox"/> |
| Q30-10/Q7-10 Ratio | 1.36 | Temperature Adjust Kr | <input checked="" type="checkbox"/> |
| D.O. Saturation | 90.00% | Use Balanced Technology | <input checked="" type="checkbox"/> |
| D.O. Goal | 6 | | |

WQM 7.0 Hydrodynamic Outputs

| <u>SWP Basin</u> | | <u>Stream Code</u> | | | <u>Stream Name</u> | | | | | | | |
|--------------------|-------------|--------------------|-----------------|--------------------|---------------------------|-------|-------|-----------|----------|-----------------|---------------|-------------|
| 03G | | 604 | | | EAST BRANCH CHESTER CREEK | | | | | | | |
| RMI | Stream Flow | PWS With | Net Stream Flow | Disc Analysis Flow | Reach Slope | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
| | (cfs) | (cfs) | (cfs) | (cfs) | (ft/ft) | (ft) | (ft) | | (fps) | (days) | (°C) | |
| Q7-10 Flow | | | | | | | | | | | | |
| 14.700 | 4.74 | 0.00 | 4.74 | .4177 | 0.00298 | .68 | 30.31 | 45.95 | 0.26 | 0.379 | 20.40 | 7.00 |
| Q1-10 Flow | | | | | | | | | | | | |
| 14.700 | 3.03 | 0.00 | 3.03 | .4177 | 0.00298 | NA | NA | NA | 0.21 | 0.475 | 20.61 | 7.00 |
| Q30-10 Flow | | | | | | | | | | | | |
| 14.700 | 6.45 | 0.00 | 6.45 | .4177 | 0.00298 | NA | NA | NA | 0.30 | 0.323 | 20.30 | 7.00 |

WQM 7.0 D.O.Simulation

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> | | | |
|---------------------------------|-----------------------------------|----------------------------------|---------------------|-----------------------------|--|
| 03G | 604 | EAST BRANCH CHESTER CREEK | | | |
| <u>RMI</u> | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> | | <u>Analysis pH</u> | |
| 14.700 | 0.270 | 20.405 | | 7.000 | |
| <u>Reach Width (ft)</u> | <u>Reach Depth (ft)</u> | <u>Reach WDRatio</u> | | <u>Reach Velocity (fps)</u> | |
| 30.309 | 0.680 | 45.949 | | 0.258 | |
| <u>Reach CBOD5 (mg/L)</u> | <u>Reach Kc (1/days)</u> | <u>Reach NH3-N (mg/L)</u> | | <u>Reach Kn (1/days)</u> | |
| 3.88 | 0.678 | 0.20 | | 0.722 | |
| <u>Reach DO (mg/L)</u> | <u>Reach Kr (1/days)</u> | <u>Kr Equation</u> | | <u>Reach DO Goal (mg/L)</u> | |
| 7.980 | 7.324 | Tsivoglou | | 6 | |
| <u>Reach Travel Time (days)</u> | <u>Subreach Results</u> | | | | |
| 0.379 | <u>TravTime (days)</u> | <u>CBOD5 (mg/L)</u> | <u>NH3-N (mg/L)</u> | <u>D.O. (mg/L)</u> | |
| | 0.038 | 3.76 | 0.20 | 8.10 | |
| | 0.076 | 3.67 | 0.19 | 8.18 | |
| | 0.114 | 3.57 | 0.19 | 8.18 | |
| | 0.152 | 3.48 | 0.18 | 8.18 | |
| | 0.190 | 3.39 | 0.18 | 8.18 | |
| | 0.227 | 3.30 | 0.17 | 8.18 | |
| | 0.265 | 3.22 | 0.17 | 8.18 | |
| | 0.303 | 3.13 | 0.16 | 8.18 | |
| | 0.341 | 3.05 | 0.16 | 8.18 | |
| | 0.379 | 2.97 | 0.15 | 8.18 | |

WQM 7.0 Wasteload Allocations

| | | |
|------------------|--------------------|---------------------------|
| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |
| 03G | 604 | EAST BRANCH CHESTER CREEK |

NH3-N Acute Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 14.700 | Cheyney Unvers | 9.26 | 5 | 9.26 | 5 | 0 | 0 |

NH3-N Chronic Allocations

| RMI | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|--------|----------------|---------------------------------|---------------------------|---------------------------------|---------------------------|-------------------|----------------------|
| 14.700 | Cheyney Unvers | 1.88 | 2.5 | 1.88 | 2.5 | 0 | 0 |

Dissolved Oxygen Allocations

| RMI | Discharge Name | <u>CBOD5</u> | | <u>NH3-N</u> | | <u>Dissolved Oxygen</u> | | Critical Reach | Percent Reduction |
|-------|----------------|--------------------|--------------------|--------------------|--------------------|-------------------------|--------------------|-------------------|----------------------|
| | | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | | |
| 14.70 | Cheyney Unvers | 25 | 25 | 2.5 | 2.5 | 5 | 5 | 0 | 0 |