

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0031313  
 APS ID 1024395  
 Authorization ID 1328996

**Applicant and Facility Information**

Applicant Name	<u>Intermediate Unit 1</u>	Facility Name	<u>Colonial Elementary School</u>
Applicant Address	<u>1 Intermediate Unit Drive</u> <u>Coal Center, PA 15423-1000</u>	Facility Address	<u>6353 National Pike</u> <u>Grindstone, PA 15442-1114</u>
Applicant Contact	<u>Richard Staley</u>	Facility Contact	<u>Richard Staley</u>
Applicant Phone	<u>(724) 938-3241</u>	Facility Phone	<u>(724) 938-3241</u>
Client ID	<u>227656</u>	Site ID	<u>242082</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Redstone Township</u>
Connection Status		County	<u>Fayette</u>
Date Application Received	<u>September 30, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 3, 2021</u>	If No, Reason	
Purpose of Application	<u>NPDES permit renewal for a minor treatment facility.</u>		

**Summary of Review**

This application is for a renewal of an NPDES permit, for an existing Minor discharge of treated sewage from a Non-Municipal STP.

Act 14 – Proof of Notification was submitted and received.

There is one open violation for subject client ID (227656) for an NPDES permit Part A effluent violation on 2/26/2021.

There has been no change to the discharge or the receiving stream since the last permit issuance.

A part 2 WQM permit is not required at this time.

Treatment consist of (WQM Permit No. 463S48): The existing treatment process consists of comminution, flow equalization, extended aeration, clarification, and chlorination. The treated sewage then discharges to Unnamed Tributary 39947 to Colvin Run (WWF) through outfall 001.

Sludge use and disposal description and location(s): Septage must be pumped and hauled off-site by a septage hauler for land application under a general permit authorized by DEP or disposal at an STP.

The EPA waiver is in effect.

Approve	Deny	Signatures	Date
X		Jon Bucha Jonathan F. Bucha / Civil Engineer General	May 20, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	May 25, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0105</u>
Latitude	<u>39° 59' 32"</u>	Longitude	<u>-79° 50' 19"</u>
Quad Name	<u>New Salem</u>	Quad Code	<u>1907</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary to Colvin Run (WWF)</u>	Stream Code	<u>39947</u>
NHD Com ID	<u>99412006</u>	RMI	<u>1.8</u>
Drainage Area	<u>0.125 mi<sup>2</sup> (Pollution Report)</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.8</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.1</u>	Q <sub>7-10</sub> Basis	<u>Default</u>
Elevation (ft)	<u>1170 (Google Earth)</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>19-C</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u>Final</u>	Name	<u>Redstone Creek Watershed</u>
Background/Ambient Data		Data Source	
pH (SU)	<u></u>		<u></u>
Temperature (°F)	<u></u>		<u></u>
Hardness (mg/L)	<u></u>		<u></u>
Other:	<u></u>		<u></u>
Nearest Downstream Public Water Supply Intake	<u>PA American Water Company</u>		
PWS Waters	<u>Monongahela River</u>	Flow at Intake (cfs)	<u></u>
PWS RMI	<u></u>	Distance from Outfall (mi)	<u></u>

Changes Since Last Permit Issuance: No Changes.

Other Comments: This treatment system is capable of meeting effluent limits.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Colonial Elementary School				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
463S48		8/12/1963		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Chlorine With Dechlorination	
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0105		Not Overloaded	Dewatering	Other WWTP

Compliance History

DMR Data for Outfall 001 (from April 1, 2020 to March 31, 2021)

Parameter	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20	APR-20
Flow (MGD) Average Monthly	0.00004	0.00010	0.00015		0.00006	0.00012						
pH (S.U.) Minimum	7.8	6.0	6.7		6.0	6.9						
pH (S.U.) Maximum	8.9	7.2	7.2		7.5	7.7						
DO (mg/L) Minimum	12.0	11.6	11.9		9.0	6.0						
TRC (mg/L) Average Monthly	< 0.02	< 0.02	< 0.02		< 0.02	< 0.02						
TRC (mg/L) Instantaneous Maximum	0.02	0.02	0.22		0.02	0.02						
CBOD5 (mg/L) Average Monthly	2.4	2.5	2.0		2.1	2.7						
CBOD5 (mg/L) Instantaneous Maximum	2.8	2.5	2.0		2.1	3.1						
TSS (mg/L) Average Monthly	5.0	5.5	5.5		5.0	5.0						
TSS (mg/L) Instantaneous Maximum	5.0	6.0	6.0		5.0	5.0						
Fecal Coliform (CFU/100 ml) Geometric Mean	3	5	49		1	1						
Fecal Coliform (CFU/100 ml) Instantaneous Maximum	7	6	58		2	1						
Total Nitrogen (mg/L) Daily Maximum				36.8								
Ammonia (mg/L) Average Monthly	0.3	0.8	1.1		0.6	2.6						

Ammonia (mg/L) Instantaneous Maximum	0.3	1.2	1.7		0.6	4.8						
Total Phosphorus (mg/L) Daily Maximum				1.0								

Compliance History	
<b>Summary of DMRs:</b>	Review of the past 3 years of DMR reports indicates one effluent violation for minimum pH. No other effluent violations were indicated on the DMRs.
<b>Summary of Inspections:</b>	An inspection occurred on 2/15/2018, where the plant was determined to be in good operating condition. Jan – Apr 2017 TRC violations were due to incorrect meter readings and are not an ongoing issue.

**Development of Effluent Limitations**

<b>Outfall No.</b> <u>001</u>	<b>Design Flow (MGD)</b> <u>.0105</u>
<b>Latitude</b> <u>39° 59' 32.00"</u>	<b>Longitude</b> <u>-79° 50' 19.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>	

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report	IMAX	-	92a.61(11)(12)

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (Attachment C):

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen (May 1 – October 31)	3.0	Average Monthly	WQM 7.0
Ammonia Nitrogen (November 1 – April 30)	9.0	Average Monthly	WQM 7.0
Dissolved Oxygen	4.0	Average Monthly	WQM 7.0
Total Residual Chlorine	0.127	Average Monthly	TRC Calc Spreadsheet
Total Residual Chlorine	0.397	Instantaneous Maximum	TRC Calc Spreadsheet

Comments: The winter seasonal ammonia nitrogen limit of 9.0 mg/L is based upon 3 times the summer seasonal limit, which is based upon the Department's Implementation Guidance of Section 93.7 Ammonia Criteria. Based on the facilities eDMR data, this treatment system should be able to meet the more stringent TRC limits and no compliance schedule should be necessary.

**Best Professional Judgment (BPJ) Limitations**

Comments: Total Nitrogen and Total Phosphorus monitoring will remain at the 1/year sampling frequency on the current permit renewal, based on the Department's SOP for Establishing Effluent Limitations for Individual Sewage Permits. Monitoring for D.O., pH, and TRC will remain at 5/week.

**Anti-Backsliding**

Anti-backsliding is not applicable since the permit limits are not being relaxed.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.


**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	2/month	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	5/week	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	5/week	Grab
TRC	XXX	XXX	XXX	0.12	XXX	0.39	5/week	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001 after disinfection.

# ATTACHMENT A


## eMAP – Stream Designation





# ATTACHMENT B

## StreamStats REPORT – RMI 0.001 On Unnamed Trib 39947



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	1.12	square miles
ELEV	Mean Basin Elevation	1076	feet

## ATTACHMENT C WQM 7.0 MODEL OUTPUT FILE

### WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>				
19C		39947	Trib 39947 to Colvin Run				
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
1.800	Unnamed Trib	PA0031313	0.000	CBOD5	25		
				NH3-N	3.26	6.52	
				Dissolved Oxygen			4

## WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
19C	39947	Trib 39947 to Colvin Run		
<hr/>				
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
1.800	0.011	22.174		7.000
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
1.802	0.302	5.962		0.053
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
15.00	0.875	1.84		0.828
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
5.845	29.100	Owens		5
<u>Reach Travel Time (days)</u>				
2.084				
	<b>Subreach Results</b>			
	<u>TravTime</u>	<u>CBOD5</u>	<u>NH3-N</u>	<u>D.O.</u>
	(days)	(mg/L)	(mg/L)	(mg/L)
	0.208	12.26	1.55	7.92
	0.417	10.02	1.31	7.92
	0.625	8.19	1.10	7.92
	0.834	6.70	0.92	7.92
	1.042	5.48	0.78	7.92
	1.251	4.48	0.66	7.92
	1.459	3.66	0.55	7.92
	1.667	2.99	0.46	7.92
	1.876	2.45	0.39	7.92
	2.084	2.00	0.33	7.92

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19C	39947	Trib 39947 to Colvin Run	1.800	1170.00	0.13	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Unnamed Trib	PA0031313	0.0000	0.0000	0.0105	0.000	20.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	4.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
19C	39947	Trib 39947 to Colvin Run	0.001	887.00	1.12	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.100	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

### WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>								
19C		39947		Trib 39947 to Colvin Run								
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
1.800	0.01	0.00	0.01	.0162	0.02979	.302	1.8	5.96	0.05	2.084	22.17	7.00
<b>Q1-10 Flow</b>												
1.800	0.01	0.00	0.01	.0162	0.02979	NA	NA	NA	0.05	2.293	21.65	7.00
<b>Q30-10 Flow</b>												
1.800	0.02	0.00	0.02	.0162	0.02979	NA	NA	NA	0.06	1.921	22.56	7.00

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
19C	39947	Trib 39947 to Colvin Run

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.800	Unnamed Trib	8.58	12.81	8.58	12.81	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
1.800	Unnamed Trib	1.59	3.26	1.59	3.26	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
1.80	Unnamed Trib	25	25	3.26	3.26	4	4	0	0

## ATTACHMENT D TRC SPREADSHEET

<b>TRC EVALUATION</b>					
Input appropriate values in A3:A9 and D3:D9					
<b>0.0125</b>	= <b>Q stream (cfs)</b>	<b>0.5</b>	= <b>CV Daily</b>		
<b>0.0105</b>	= <b>Q discharge (MGD)</b>	<b>0.5</b>	= <b>CV Hourly</b>		
<b>20</b>	= <b>no. samples</b>	<b>1</b>	= <b>AFC_Partial Mix Factor</b>		
<b>0.3</b>	= <b>Chlorine Demand of Stream</b>	<b>1</b>	= <b>CFC_Partial Mix Factor</b>		
<b>0</b>	= <b>Chlorine Demand of Discharge</b>	<b>15</b>	= <b>AFC_Criteria Compliance Time (min)</b>		
<b>0.5</b>	= <b>BAT/BPJ Value</b>	<b>720</b>	= <b>CFC_Criteria Compliance Time (min)</b>		
<b>0</b>	= <b>% Factor of Safety (FOS)</b>		= <b>Decay Coefficient (K)</b>		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 0.264		1.3.2.iii	WLA_cfc = 0.250
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 0.099		5.1d	LTA_cfc = 0.146
Source	Effluent Limit Calculations				
PENTOXSD TRG	5.1f	AML_MULT = 1.288			
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.127		AFC	
		INST MAX LIMIT (mg/l) = 0.397			
<b>WLA_afc</b>	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
<b>LTAMULT_afc</b>	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
<b>LTA_afc</b>	wla_afc * LTAMULT_afc				
<b>WLA_cfc</b>	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
<b>LTAMULT_cfc</b>	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$				
<b>LTA_cfc</b>	wla_cfc * LTAMULT_cfc				
<b>AML_MULT</b>	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$				
<b>AVG MON LIMIT</b>	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
<b>INST MAX LIMIT</b>	$1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$				
$(0.011 / EXP(-K \cdot CFC\_tc / 1440)) + (((CFC\_Yc \cdot Qs \cdot 0.011) / (1.547 \cdot Qd)) \dots$					
$\dots \cdot EXP(-K \cdot CFC\_tc / 1440)) + Xd + (CFC\_Yc \cdot Qs \cdot Xs / 1.547 \cdot Qd) \cdot (1 - FOS / 100)$					