

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0031330  
 APS ID 994134  
 Authorization ID 1274813

**Applicant and Facility Information**

Applicant Name	<u>Calvary Chapel of Fredericktown</u>	Facility Name	<u>Cox Donahey Elementary School</u>
Applicant Address	<u>112 Thornton Road</u> <u>Brownsville, PA 15417</u>	Facility Address	<u>Republic Road (0.25 mi from Route 40)</u> <u>Brownsville, PA 15333</u>
Applicant Contact	<u>John Thomas</u>	Facility Contact	<u>Edgar Harris</u>
Applicant Phone	<u>724-377-2522</u>	Facility Phone	<u>(724) 966-2278</u>
Client ID	<u>337039</u>	Site ID	<u>241990</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Redstone Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Fayette</u>
Date Application Received	<u>May 28, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>May 29, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>Renew NPDES application.</u>		

**Summary of Review**

The permittee has applied for a renewal of NPDES Permit No. PA0031330. NPDES Permit No. PA0031330 was previously issued by the PA Department of Environmental Protection (DEP) to the Brownsville Area School District on December 4, 2014. The NPDES permit and WQM Permit No 466S111 were transferred to the current permittee on January 24, 2019. The NPDES permit expired on December 31, 2019.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>David R. Ponchione</i> David R. Ponchione / Project Manager	April 21, 2020
X		<i>Christopher Kriley</i> Christopher Kriley, P.E. / Program Manager for Donald J. Leone, P.E. / Environmental Engineer Manager	April 21, 2020

**NPDES Permit Fact Sheet**  
**NPDES Permit No. PA0031330**  
**Cox Donahey Elementary School**

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0088</u>
Latitude	<u>40° 00' 28"</u>	Longitude	<u>-79° 52' 24"</u>
Quad Name	<u>Fayette City</u>	Quad Code	<u>1807</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Unnamed Tributary of Dunlap Creek (WWF)</u>	Stream Code	<u>40140</u>
NHD Com ID	<u>99411744</u>	RMI	<u>0.28</u>
Drainage Area	<u>0.02</u>	Yield (cfs/mi <sup>2</sup> )	<u>0</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0</u>	Q <sub>7-10</sub> Basis	<u>No flow shown on USGS topographic map- appears to be a dry swale</u>
Watershed No.	<u>19-C</u>	Chapter 93 Class.	<u>WWF</u>
Exceptions to Use	<u>None</u>	Exceptions to Criteria	<u>None</u>
Assessment Status	<u>Attaining Use(s)</u>		
Nearest Downstream Public Water Supply Intake		<u>California Water Company on the Monongahela River</u>	

Changes Since Last Permit Issuance: None

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Cox Donahey Elementary School WWTP				
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Extended Aeration	Chlorine With Dechlorination	0.00004
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.0088	14.7	Not Overloaded	Dewatering	Other WWTP

Changes Since Last Permit Issuance: None

Part II Permit No. 466S111 authorized construction of a treatment process consisting of extended aeration, final clarification, and chlorination.

Other Comments: Organic capacity listed in NPDES application is 1.47 lbs./day. This appears to be a typo error. An assumed influent BOD5 concentration of 200 mg/l x 0.0088 mgd x 8.345 = 14.7 lbs./day.

Compliance History

DMR Data for Outfall 001 (from March 1, 2019 to February 29, 2020)

Parameter	FEB-20	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19
Flow (MGD) Average Monthly	0.00004	0.00005	0.00004	0.00006	0.00005	0.00007	0.00004	0.00001	0.00002	0.00004	0.0004	0.00004
pH (S.U.) Instantaneous Minimum	6.1	6.3	6.6	6.0	6.2	6.3	6.4	6.8	6.6	6.6	6.4	6.2
pH (S.U.) Instantaneous Maximum	6.9	6.9	6.8	7.1	6.6	6.9	6.5	6.9	6.8	6.8	7.0	6.8
DO (mg/L) Instantaneous Minimum	8.3	8.0	4.2	7.0	6.2	4.8	5.4	5.4	6.4	6.5	6.0	8.4
TRC (mg/L) Average Monthly	0.25	0.27	0.20	0.25	0.23	0.23	0.25	0.24	0.26	0.24	0.29	0.26
TRC (mg/L) Instantaneous Maximum	0.30	0.31	0.29	0.29	0.28	0.31	0.28	0.25	0.30	0.30	0.36	0.35
CBOD5 (mg/L) Average Monthly	2.1	2.7	2.6	7.5	2.3	2.0	3.8	2.5	2.1	2.0	2.0	2.0
CBOD5 (mg/L) Instantaneous Maximum	2.2	3.4	3.0	9.3	2.6	2.0	5.5	2.7	2.2	2.0	2.0	2.0
TSS (mg/L) Average Monthly	5.0	6.5	5.5	13.0	11.5	10.0	7.5	6.0	5.0	5.0	5.0	5.0
TSS (mg/L) Instantaneous Maximum	5.0	8.0	6.0	16.0	15.0	13.0	8.0	7.0	5.0	5.0	5.0	5.0
Fecal Coliform (No./100 ml) Geometric Mean	1	1	2	4	1	1	1	1	2	10	1	1
Fecal Coliform (No./100 ml) Instantaneous Maximum	1	1	4	9	1	1	1	1	2	102	2	1
Total Nitrogen (mg/L) Daily Maximum			37.3									

Ammonia (mg/L) Average Monthly	0.9	0.9	2.4	0.7	0.5	0.8	0.4	0.7	0.7	0.8	3.8	2.1
Ammonia (mg/L) Instantaneous Maximum	1.0	1.3	3.0	0.7	0.5	0.9	0.5	1.2	1.9	0.9	5.6	2.6
Total Phosphorus (mg/L) Daily Maximum			9.0									

**Compliance History**

**Operations Compliance Check Summary Report**

**Facility:** Cox\_Donahey\_School\_STP

**NPDES Permit No.:** PA0031330

**Compliance Review Period:** 04/15/2015 – 04/15/2020:

**Open Violations by Client Summary:** None.

**Inspection Summary**

INSP ID	INSPECTED DATE	INSP TYPE	AGENCY	INSPECTION RESULT DESC	# OF VIOLATIONS
2694536	02/14/2018	Administrative/File Review	PA Dept of Environmental Protection	Violation(s) Noted	<u>1</u>
2533121	11/01/2016	Administrative/File Review	PA Dept of Environmental Protection	Violation(s) Noted	<u>1</u>
2504154	06/09/2016	Compliance Evaluation	PA Dept of Environmental Protection	No Violations Noted	<u>0</u>

**Violation Summary**

VIOL ID	VIOLATION DATE	VIOLATION TYPE	VIOLATION TYPE DESC	RESOLVED DATE
808424	02/14/2018	92A.62	NPDES - Failure to pay annual fee	03/12/2018
771462	11/01/2016	302.202	Operator Certification - Failure to submit annual system fee	11/15/2016

**Enforcement Summary**

ENF ID	ENF TYPE DESC	EXECUTED DATE	ENF FINALSTATUS	ENF CLOSED DATE
<a href="#">361602</a>	Notice of Violation	02/14/2018	Comply/Closed	03/12/2018
348337	Notice of Violation	11/01/2016	Comply/Closed	11/15/2016

**DMR Violation Summary**

Current eDMR user.

Effluent limit violation summary 4/15/2018 – 4/15/2020:

No violations reported in eDMR

**Compliance Status:**

Facility has no compliance issues.

**Completed by:** David Roote

**Completed date:** 4/15/2020

**Development of Effluent Limitations**

<b>Outfall No.</b>	<u>001</u>	<b>Design Flow (MGD)</b>	<u>.0088</u>
<b>Latitude</b>	<u>40° 00' 28.00"</u>	<b>Longitude</b>	<u>-79° 52' 24.00"</u>
<b>Wastewater Description:</b> <u>Sewage Effluent</u>			

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

<b>Pollutant</b>	<b>Limit (mg/l)</b>	<b>SBC</b>	<b>Federal Regulation</b>	<b>State Regulation</b>
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above effluent limitations are consistent with the previous NPDES permit.

The effluent limitations and monitoring requirements imposed in this renewal permit are consistent with the previous permit and are explained in the attached pollution report. Because there have been no changes to the discharge or the receiving stream, it was unnecessary to re-evaluate these parameters.

The previous limits take into consideration the discharge is to a dry stream and the area is accessible.

The Implementation Guidance for Evaluating Wastewater Discharges to Drainage Swales and Ditches (Revised May 1987) is the basis for the Ammonia-Nitrogen (NH3-N) limitations. That guidance considers BAT NH3-N limits to be 3.0/6.0 mg/l for the period of May 1 to Oct 31 and 9.0/18.0 mg/l for the period of Nov 1 to Apr 30. An NH3-N toxicity evaluation was conducted with an assumed point of first use (full flow) at the unnamed tributary and water quality-based limitations more stringent than BAT are not necessary.

A monthly average BOD<sub>5</sub> limitation of 10 mg/l is consistent with the above guidance, however it was previously changed to CBOD<sub>5</sub> to be consistent with DEP policy. Although the guidance requires TSS limitations of 10/20 mg/l, it was procedure to re-impose an existing TSS effluent limit if the discharge was in existence prior to 1987, the date of the guidance. Therefore, an average monthly TSS limit of 25 mg/l will be re-imposed.

That guidance requires a minimum Dissolved Oxygen concentration in the effluent of 3.0 mg/l. A more stringent Dissolved Oxygen minimum limitation of 4.0 mg/L however, was previously implemented based on the standard in 25 PA Code Chapter 93 and best professional judgment for activated sludge plants and will be re-imposed.

The following are consistent with current DEP policy:

- A once per year Monitor and Report requirement for Total N and Total P was incorporated into the previous permit as per Chapter 92.a.61 and will be continued.
- Mass loading limits and influent monitoring are not applicable for non-publicly owned treatment works.
- The design flow of the sewage treatment plant is less than 0.1 mgd. For this reason, the permittee is not required to report influent and effluent concentrations for various parameters as listed in the NPDES application. Total Dissolved Solids and its major constituents are therefore not a concern at this time.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	0.0088	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	10.0	XXX	20.0	2/month	Grab
TSS	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	9.0	XXX	18.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	3.0	XXX	6.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001



Pollution Report

