



Application Type Renewal  
Facility Type Municipal  
Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. **PA0031771**  
APS ID **1140750**  
Authorization ID **1532837**

**Applicant and Facility Information**

|                           |   |                  |   |
|---------------------------|---|------------------|---|
| Applicant Name            | <b>Westtown Township Chester County</b> | Facility Name    | <b>Westtown Township Sewer STP &amp; Sewer System</b> |
| Applicant Address         | PO Box 79                               | Facility Address | 950 Westtown Road                                     |
|                           | Westtown, PA 19395-0079                 |                  | West Chester, PA 19382-7648                           |
| Applicant Contact         | Mark Gross                              | Facility Contact | Mark Gross  |
| Applicant Phone           | (610) 692-1930                          | Facility Phone   | (610) 692-1930  |
| Client ID                 | 42451                                   | Site ID          | 451677  |
| Ch 94 Load Status         | Not Overloaded                          | Municipality     | Westtown Township                                     |
| Connection Status         | No Limitations                          | County           | Chester   |
| Date Application Received | <u>July 3, 2025</u>                     | EPA Waived?      | Yes   |
| Date Application Accepted |   | If No, Reason    |   |
| Purpose of Application    | Permit renewal                          |                  |   |

**Summary of Review**

A renewal request is received for a NPDES Permit to discharge treated sewage to East Branch Chester Creek.

The STP consists of a bar screen, grit chambers, equalization tank, aeration tanks, clarifiers, filter unit, UV disinfection and sludge digester. A phosphorus reduction system was added in 2013 in accordance with WQM permit No. 1512416.

Magnesium Hydroxide is used for pH control and Aluminum Chloride Hydroxide Sulfate is used for Phosphorus control at the facility.

The existing limits from the current permit being carried over to this renewal. WQM 7.0 was ran to verify and there isn't any significant concern from compliance end.

Influent monitoring for BOD5, CBOD5 and TSS are continued in the permit based on Chapter 94 requirement and to check compliance with the 85% removal requirement for secondary treatment.

Sludge use and disposal description and location(s): hauled away to DELCORA for disposal  
100 East Fifth Street, Chester, PA 19013.

Facility is not accepting any hauled-in wastes.

| Approve | Deny | Signatures  | Date              |
|---------|------|---|-------------------|
| X       |      | <i>Charley Yang</i><br>Charley Yang / Environmental Engineering Specialist    | December 24, 2025 |
| X       |      | <i>Pravin Patel</i><br>Pravin C. Patel, P.E. / Environmental Engineer Manager | 12/24/2025        |

### Summary of Review

#### Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

**Discharge, Receiving Waters and Water Supply Information**

|                              |  |  |                 |
|------------------------------|--|--|-----------------|
| Outfall No.                  | 001  | Design Flow (MGD)  | .495            |
| Latitude                     | 39° 57' 1.56"  | Longitude  | -75° 32' 49.29" |
| Quad Name                    |  | Quad Code  |                 |
| Wastewater Description:      | Sewage Effluent  |  |                 |
| Receiving Waters             | East Branch Chester Creek (TSF,<br>MF)   | Stream Code  | 00604           |
| NHD Com ID                   | 25621280   | RMI  | 11.668          |
| Drainage Area                | 8.64   | Yield (cfs/mi <sup>2</sup> )   |                 |
| Q <sub>7-10</sub> Flow (cfs) | 1.82   | Q <sub>7-10</sub> Basis  | StreamStats     |
| Elevation (ft)               | 263.88   | Slope (ft/ft)  |                 |
| Watershed No.                | 3-G  | Chapter 93 Class.  | TSF, MF         |
| Existing Use                 |  | Existing Use Qualifier   |                 |
| Exceptions to Use            |  | Exceptions to Criteria   |                 |
| Assessment Status            | Impaired   | CAUSE UNKNOWN, FLOW REGIME MODIFICATION, HABITAT ALTERATIONS,<br>SILTATION |                 |
| Cause(s) of Impairment       | HABITAT MODIFICATION - OTHER THAN HYDROMODIFICATION, URBAN<br>RUNOFF/STORM SEWERS, URBAN RUNOFF/STORM SEWERS, URBAN<br>RUNOFF/STORM SEWERS |  |                 |
| Source(s) of Impairment      |  |  |                 |
| TMDL Status                  | Name _____   |  |                 |

Changes Since Last Permit Issuance: Minor updates on receiving water information; RMI, DA, Q7-10, Elevation.

Other Comments:

| Treatment Facility Summary                                 |                                   |                      |                            |                               |
|--|-----------------------------------|----------------------|----------------------------|-------------------------------|
| <b>Treatment Facility Name:</b> Westtown-Chester Creek STP |                                   |                      |                            |                               |
| <b>WQM Permit No.</b>                                      |                                   | <b>Issuance Date</b> |                            |                               |
| 1512416  |                                   | 12/24/2012           |                            |                               |
| 1500407  |                                   | 02/01/2001           |                            |                               |
| <b>Waste Type</b>  | <b>Degree of Treatment</b>        | <b>Process Type</b>  | <b>Disinfection</b>        | <b>Avg Annual Flow (MGD)</b>  |
| Sewage   | Tertiary                          | Extended Aeration    | Ultraviolet                | 0.495                         |
| <b>Hydraulic Capacity (MGD)</b>                            | <b>Organic Capacity (lbs/day)</b> | <b>Load Status</b>   | <b>Biosolids Treatment</b> | <b>Biosolids Use/Disposal</b> |
| 0.495  | 1030                              | Not Overloaded       | Aerobic Digestion          | Other WWTP                    |

Changes Since Last Permit Issuance: None

Other Comments: N/A

| Compliance History             |  |
|--------------------------------|--|
| <b>Summary of DMRs:</b>        | No issues  |
| <b>Summary of Inspections:</b> | No violations were noted. The site seems to be in good condition per the inspection on 12/31/2025. |

Other Comments: 

Compliance History

DMR Data for Outfall 001 (from November 1, 2024 to October 31, 2025)

| Parameter  | OCT-25 | SEP-25 | AUG-25 | JUL-25 | JUN-25 | MAY-25 | APR-25 | MAR-25 | FEB-25 | JAN-25 | DEC-24 | NOV-24 |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| Flow (MGD)<br>Average Monthly                                      | 0.216  | 0.241  | 0.21   | 0.241  | 0.246  | 0.264  | 0.256  | 0.229  | 0.23   | 0.225  | 0.227  | 0.216  |
| Flow (MGD)<br>Daily Maximum  | 0.281  | 0.371  | 0.301  | 0.371  | 0.321  | 0.393  | 0.389  | 0.328  | 0.307  | 0.352  | 0.331  | 0.296  |
| pH (S.U.)<br>Instantaneous<br>Minimum                              | 6.2    | 6.3    | 6.4    | 6.3    | 6.4    | 6.4    | 6.4    | 6.4    | 6.2    | 6.4    | 6.6    | 6.4    |
| pH (S.U.)<br>Instantaneous<br>Maximum                              | 7.4    | 7.4    | 7.5    | 7.4    | 7.4    | 7.4    | 7.4    | 7.5    | 7.8    | 7.5    | 7.8    | 7.3    |
| DO (mg/L)<br>Instantaneous<br>Minimum                              | 7.6    | 7.7    | 7.5    | 7.7    | 8.4    | 9.1    | 9.7    | 10.2   | 11.2   | 10.9   | 10.4   | 9.2    |
| CBOD5 (lbs/day)<br>Average Monthly                                 | < 4    | < 5    | < 3    | < 5    | < 4    | < 5    | < 4    | < 4    | < 4    | < 4    | < 4    | < 4    |
| CBOD5 (lbs/day)<br>Raw Sewage Influent<br><br/> Average<br>Monthly | 401    | < 412  | 255    | 317    | 353    | 464    | 404    | 327    | 413    | 380    | 239    | 255    |
| CBOD5 (lbs/day)<br>Weekly Average                                  | < 5    | 6      | < 4    | 6      | < 4    | < 6    | < 5    | < 4    | < 5    | < 6    | < 4    | < 4    |
| CBOD5 (mg/L)<br>Average Monthly                                    | < 2    | < 3    | < 2    | < 3    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    |
| CBOD5 (mg/L)<br>Raw Sewage Influent<br><br/> Average<br>Monthly    | 189    | < 214  | 147    | 160    | 173    | 202    | 191    | 176    | 189    | 203    | 119.7  | 137    |
| CBOD5 (mg/L)<br>Weekly Average                                     | < 2    | 3      | < 2    | 3      | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    |
| BOD5 (lbs/day)<br>Raw Sewage Influent<br><br/> Average<br>Monthly  | 276    | 203    | 275    | 312    | 393    | 438    | 352    | 267    | 360    | 325    | 322    | 136    |
| BOD5 (mg/L)<br>Raw Sewage Influent<br><br/> Average<br>Monthly     | 147    | 117    | 153    | 134    | 187    | 215    | 145    | 141    | 189    | 172    | 169    | 73     |

NPDES Permit Fact Sheet  
Westtown Township Sewer STP & Sewer System

NPDES Permit No. PA0031771

|  |        |        |        |        |        |        |        |        |        |        |        |        |
|--|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|
| TSS (lbs/day)<br>Average Monthly                                 | 29     | 41     | 21     | 41     | 20     | 20     | 21     | < 3    | 17     | 27     | 34     | 39     |
| TSS (lbs/day)<br>Raw Sewage Influent<br><br/> Average<br>Monthly | 207    | 259    | 65     | 78     | 136    | 96     | 84     | 180    | 101    | 149    | 79     | 93     |
| TSS (lbs/day)<br>Weekly Average                                  | 35     | 68     | 25     | 68     | 25     | 30     | 28     | 8      | 31     | 75     | 35     | 46     |
| TSS (mg/L)<br>Average Monthly                                    | 14     | 20     | 12     | 20     | 10     | 8      | 10     | < 2    | 8      | 15     | 16     | 21     |
| TSS (mg/L)<br>Raw Sewage Influent<br><br/> Average<br>Monthly    | 113    | 131    | 37     | 37     | 66     | 41     | 39     | 98     | 47     | 80     | 40     | 51     |
| TSS (mg/L)<br>Weekly Average                                     | 16     | 34     | 15     | 34     | 12     | 11     | 14     | 4      | 14     | 27     | 19     | 24     |
| Total Dissolved Solids<br>(lbs/day)<br>Daily Maximum             |        | 1280   |        |        | 1292   |        |        | 1831   |        |        | 1477   |        |
| Total Dissolved Solids<br>(mg/L)<br>Daily Maximum                |        | 642    |        |        | 635    |        |        | 715    |        |        | 757    |        |
| Fecal Coliform<br>(No./100 ml)<br>Geometric Mean                 | < 9    | < 2    | < 2    | < 2    | < 2    | < 3    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    |
| Fecal Coliform<br>(No./100 ml)<br>Instantaneous<br>Maximum       | 122    | 3      | < 2    | 3      | < 2    | < 5    | < 2    | < 2    | < 2    | < 2    | < 2    | < 2    |
| UV Intensity ( $\mu$ w/cm <sup>2</sup> )<br>Daily Minimum        | 6.8    | 8      | 8.2    | 8      | 6.8    | 8      | 6.6    | 6.3    | 6.2    | 5.3    | 5.9    | 7      |
| Total Nitrogen<br>(lbs/day)<br>Average Monthly                   | < 85   | < 66   | < 58   | < 66   | < 63   | < 79   | < 73   | < 70   | < 75   | < 67   | < 63   | < 55   |
| Total Nitrogen (mg/L)<br>Average Monthly                         | < 41.4 | < 31.9 | < 33.4 | < 31.9 | < 30.9 | < 33.9 | < 33.5 | < 37.2 | < 34.7 | < 35.9 | < 32.1 | < 29.7 |
| Ammonia (lbs/day)<br>Average Monthly                             | < 0.05 | < 0.07 | < 0.04 | < 0.07 | < 0.04 | < 0.09 | < 0.08 | 0.2    | < 0.04 | < 0.05 | < 0.06 | < 0.1  |
| Ammonia (mg/L)<br>Average Monthly                                | < 0.02 | < 0.03 | < 0.02 | < 0.03 | < 0.02 | < 0.04 | < 0.04 | 0.1    | < 0.02 | < 0.03 | < 0.03 | < 0.1  |
| Total Phosphorus<br>(lbs/day)<br>Average Monthly                 | 1.8    | 1.4    | 0.9    | 1.4    | 1.2    | 1.2    | 1.4    | 0.9    | 1.1    | 0.9    | 1.0    | 2.2    |

**NPDES Permit Fact Sheet**  
**Westtown Township Sewer STP & Sewer System**

**NPDES Permit No. PA0031771**

|                         |       |       |         |       |         |       |       |       |       |         |         |
|-------------------------|-------|-------|---------|-------|---------|-------|-------|-------|-------|---------|---------|
| Total Phosphorus (mg/L) |       |       |         |       |         |       |       |       |       |         |         |
| Average Monthly         | 0.9   | 0.7   | 0.5     | 0.7   | 0.6     | 0.5   | 0.7   | 1.7   | 0.5   | 0.5     | 0.5     |
| Total Copper (lbs/day)  |       |       |         |       |         |       |       |       |       |         |         |
| Average Monthly         | 0.03  | 0.04  | < 0.02  | 0.04  | < 0.02  | 0.02  | 0.04  | 0.03  | 0.02  | < 0.02  | < 0.02  |
| Total Copper (lbs/day)  |       |       |         |       |         |       |       |       |       |         |         |
| Daily Maximum           | 0.03  | 0.04  | < 0.02  | 0.04  | < 0.02  | 0.02  | 0.04  | 0.03  | 0.02  | < 0.02  | < 0.02  |
| Total Copper (mg/L)     |       |       |         |       |         |       |       |       |       |         |         |
| Average Monthly         | 0.020 | 0.020 | < 0.010 | 0.020 | < 0.010 | 0.010 | 0.010 | 0.020 | 0.010 | < 0.010 | < 0.010 |
| Total Copper (mg/L)     |       |       |         |       |         |       |       |       |       |         |         |
| Daily Maximum           | 0.015 | 0.015 | < 0.010 | 0.015 | < 0.010 | 0.012 | 0.014 | 0.015 | 0.010 | < 0.010 | < 0.010 |
|                         |       |       |         |       |         |       |       |       |       |         | 0.016   |

**Development of Effluent Limitations**

Outfall No. 001  
Latitude 39° 57' 1.61"  
Wastewater Description: Sewage Effluent

Design Flow (MGD) .495  
Longitude -75° 32' 49.26"

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

| Pollutant                    | Limit (mg/l)    | SBC             | Federal Regulation | State Regulation |
|------------------------------|-----------------|-----------------|--------------------|------------------|
| CBOD <sub>5</sub>            | 25              | Average Monthly | 133.102(a)(4)(i)   | 92a.47(a)(1)     |
|                              | 40              | Average Weekly  | 133.102(a)(4)(ii)  | 92a.47(a)(2)     |
| Total Suspended Solids       | 30              | Average Monthly | 133.102(b)(1)      | 92a.47(a)(1)     |
|                              | 45              | Average Weekly  | 133.102(b)(2)      | 92a.47(a)(2)     |
| pH                           | 6.0 – 9.0 S.U.  | Min – Max       | 133.102(c)         | 95.2(1)          |
| Fecal Coliform (5/1 – 9/30)  | 200 / 100 ml    | Geo Mean        | -                  | 92a.47(a)(4)     |
| Fecal Coliform (5/1 – 9/30)  | 1,000 / 100 ml  | IMAX            | -                  | 92a.47(a)(4)     |
| Fecal Coliform (10/1 – 4/30) | 2,000 / 100 ml  | Geo Mean        | -                  | 92a.47(a)(5)     |
| Fecal Coliform (10/1 – 4/30) | 10,000 / 100 ml | IMAX            | -                  | 92a.47(a)(5)     |
| Total Residual Chlorine      | 0.5             | Average Monthly | -                  | 92a.48(b)(2)     |

**Water Quality-Based Limitations**

A "Reasonable Potential Analysis" (Attachment █) determined the following parameters were candidates for limitations: █

The following limitations were determined through water quality modeling (output files attached):

| Parameter                       | Limit (mg/l)                       | SBC                | Model           |
|---------------------------------|------------------------------------|--------------------|-----------------|
| CBOD5 (5/1 to 10/31)            | 15                                 | Average Monthly    | WQM 7.0 model   |
| CBOD5 (11/1 to 4/30)            | 25                                 | Average Monthly    | Seasonal limit  |
| TSS                             | 30                                 | Average Monthly    | DRBC            |
| NH3-N (5/1 to 10/31)            | 2.5                                | Average Monthly    | WQM 7.0 model   |
| NH3-N (11/1 to 4/30)            | 7.5                                | Average Monthly    | Seasonal limit  |
| Total Phosphorus (5/1 to 10/31) | 1.0                                | Average Monthly    | BPJ             |
| Total Phosphorus (11/1 to 4/30) | 2.0                                | Average Monthly    | Seasonal limit  |
| Dissolved Oxygen                | 5.0                                | Inst. Min.         | WQM 7.0 model   |
| Fecal Coliform (CFU/100ml)      | 200/1000                           | Ave.Mon./Inst.Max. | DRBC&Chap. 93   |
| pH                              | 6.0 to 9.0 STD units all the times | Chap. 93           |                 |
| Total Nitrogen                  | Report                             | Average Monthly    | Data Collection |
| TDS*                            | Report                             | Average Monthly    | DRBC            |
| UV intensity                    | Report                             | Minimum            | Data collection |
| Total Copper **                 | 0.028                              | Average Monthly    | Existing        |

\*Based on the consistently low TDS concentration , monitoring is recommended to continue.

\*\*Total Copper limit is based on the previous modeling which is protective of the water quality.

Comments: All limits are being carried over from the existing permit. WQM 7.0 was run to verify.

**Best Professional Judgment (BPJ) Limitations**

Comments: N/A

**Anti-Backsliding**

**N/A**

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**

| Parameter                                     | Effluent Limitations                |                  |                       |                 |                  |                  | Monitoring Requirements                         |                      |
|---|-------------------------------------|------------------|-----------------------|-----------------|------------------|------------------|---|----------------------|
|   | Mass Units (lbs/day) <sup>(1)</sup> |                  | Concentrations (mg/L) |                 |                  |                  | Minimum <sup>(2)</sup><br>Measurement Frequency | Required Sample Type |
|   | Average Monthly                     | Weekly Average   | Daily Minimum         | Average Monthly | Weekly Average   | Instant. Maximum |   |                      |
| Flow (MGD)                                    | Report                              | Report Daily Max | XXX                   | XXX             | XXX              | XXX              | Continuous                                      | Metered              |
| pH (S.U.)                                     | XXX                                 | XXX              | 6.0<br>Inst Min       | XXX             | XXX              | 9.0              | 1/day   | Grab                 |
| DO  | XXX                                 | XXX              | 5.0<br>Inst Min       | XXX             | XXX              | XXX              | 1/day   | Grab                 |
| CBOD5<br>Raw Sewage Influent                  | Report                              | XXX              | XXX                   | Report          | XXX              | XXX              | 1/week  | 24-Hr Composite      |
| CBOD5<br>Nov 1 - Apr 30                       | 103                                 | 165              | XXX                   | 25              | 40               | 50               | 1/week  | 24-Hr Composite      |
| CBOD5<br>May 1 - Oct 31                       | 62                                  | 95               | XXX                   | 15              | 23               | 30               | 1/week  | 24-Hr Composite      |
| BOD5<br>Raw Sewage Influent                   | Report                              | XXX              | XXX                   | Report          | XXX              | XXX              | 2/month   | 24-Hr Composite      |
| TSS   | 124                                 | 186              | XXX                   | 30              | 45               | 60               | 1/week  | 24-Hr Composite      |
| TSS<br>Raw Sewage Influent                    | Report                              | XXX              | XXX                   | Report          | XXX              | XXX              | 1/week  | 24-Hr Composite      |
| Total Dissolved Solids                        | XXX                                 | Report Daily Max | XXX                   | XXX             | Report Daily Max | XXX              | 1/quarter                                       | 24-Hr Composite      |
| Fecal Coliform (No./100 ml)<br>Oct 1 - Apr 30 | XXX                                 | XXX              | XXX                   | 200<br>Geo Mean | XXX              | 1000             | 1/week  | Grab                 |
| Fecal Coliform (No./100 ml)<br>May 1 - Sep 30 | XXX                                 | XXX              | XXX                   | 200<br>Geo Mean | XXX              | 1000             | 1/week  | Grab                 |

Outfall 001, Continued (from Permit Effective Date through Permit Expiration Date)

| Parameter                                  | Effluent Limitations                |                   |                       |                 |                    |                  | Monitoring Requirements                         |                      |
|--|-------------------------------------|-------------------|-----------------------|-----------------|--------------------|------------------|---|----------------------|
|  | Mass Units (lbs/day) <sup>(1)</sup> |                   | Concentrations (mg/L) |                 |                    |                  | Minimum <sup>(2)</sup><br>Measurement Frequency | Required Sample Type |
|  | Average Monthly                     | Weekly Average    | Daily Minimum         | Average Monthly | Weekly Average     | Instant. Maximum |   |                      |
| UV Intensity ( $\mu\text{w}/\text{cm}^2$ ) | XXX                                 | XXX               | Report                | XXX             | XXX                | XXX              | 1/day   | Measured             |
| Total Nitrogen                             | Report                              | XXX               | XXX                   | Report          | XXX                | XXX              | 1/week  | 24-Hr Composite      |
| Ammonia<br>Nov 1 - Apr 30                  | 31                                  | XXX               | XXX                   | 7.5             | XXX                | 15               | 1/week  | 24-Hr Composite      |
| Ammonia<br>May 1 - Oct 31                  | 10                                  | XXX               | XXX                   | 2.5             | XXX                | 5                | 1/week  | 24-Hr Composite      |
| Total Phosphorus<br>Nov 1 - Apr 30         | 8.2                                 | XXX               | XXX                   | 2.0             | XXX                | 4                | 1/week  | 24-Hr Composite      |
| Total Phosphorus<br>May 1 - Oct 31         | 4.1                                 | XXX               | XXX                   | 1.0             | XXX                | 2                | 1/week  | 24-Hr Composite      |
| Total Copper                               | 0.12                                | 0.23<br>Daily Max | XXX                   | 0.028           | 0.056<br>Daily Max | 0.07             | 1/month   | 24-Hr Composite      |

Compliance Sampling Location: 

Other Comments: 

| Tools and References Used to Develop Permit |  |
|---|--|
| <input checked="" type="checkbox"/>         | WQM for Windows Model (see Attachment [REDACTED])  |
| <input type="checkbox"/>                    | Toxics Management Spreadsheet (see Attachment [REDACTED])  |
| <input type="checkbox"/>                    | TRC Model Spreadsheet (see Attachment [REDACTED])  |
| <input type="checkbox"/>                    | Temperature Model Spreadsheet (see Attachment [REDACTED])  |
| <input type="checkbox"/>                    | Water Quality Toxics Management Strategy, 361-0100-003, 4/06.  |
| <input type="checkbox"/>                    | Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.   |
| <input type="checkbox"/>                    | Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.  |
| <input type="checkbox"/>                    | Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.  |
| <input type="checkbox"/>                    | Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.   |
| <input type="checkbox"/>                    | Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.  |
| <input type="checkbox"/>                    | Pennsylvania CSO Policy, 386-2000-002, 9/08.   |
| <input type="checkbox"/>                    | Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.  |
| <input type="checkbox"/>                    | Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.   |
| <input type="checkbox"/>                    | Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.  |
| <input type="checkbox"/>                    | Implementation Guidance Design Conditions, 386-2000-007, 9/97.   |
| <input type="checkbox"/>                    | Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.  |
| <input type="checkbox"/>                    | Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.   |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.   |
| <input type="checkbox"/>                    | Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.  |
| <input type="checkbox"/>                    | Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.  |
| <input type="checkbox"/>                    | Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.   |
| <input type="checkbox"/>                    | Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.   |
| <input type="checkbox"/>                    | Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.  |
| <input type="checkbox"/>                    | Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.   |
| <input type="checkbox"/>                    | Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.       |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.   |
| <input type="checkbox"/>                    | Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999. |
| <input type="checkbox"/>                    | Design Stream Flows, 386-2000-003, 9/98.   |
| <input type="checkbox"/>                    | Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.                                     |
| <input type="checkbox"/>                    | Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.   |
| <input type="checkbox"/>                    | Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.   |
| <input type="checkbox"/>                    | SOP: [REDACTED]  |
| <input type="checkbox"/>                    | Other: [REDACTED]  |

## Input Data WQM 7.0

| SWP Basin | Stream Code | Stream Name               | RMI   | Elevation<br>(ft) | Drainage Area<br>(sq mi) | Slope<br>(ft/ft) | PWS Withdrawal<br>(mgd) | Apply FC                            |
|-----------|-------------|---------------------------|-------|-------------------|--------------------------|------------------|-------------------------|-------------------------------------|
| 03G       | 604         | EAST BRANCH CHESTER CREEK | 1.680 | 263.88            | 8.64                     | 0.00000          | 0.00                    | <input checked="" type="checkbox"/> |

## Stream Data

| Design Cond. | LFY    | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | pH   | Stream Temp | pH   |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|------|-------------|------|
|              | (cfsm) | (cfs)     | (cfs)       | (days)        | (fps)        |          | (ft)      | (ft)      | (°C)           |      | (°C)        |      |
| Q7-10        | 0.100  | 0.00      | 0.00        | 0.000         | 0.000        | 0.0      | 0.00      | 0.00      | 20.00          | 7.00 | 0.00        | 0.00 |
| Q1-10        |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |      |             |      |
| Q30-10       |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |      |             |      |

## Discharge Data

| Name                  | Permit Number | Existing Disc Flow | Permitted Disc Flow | Design Disc Flow   | Reserve Factor     | Disc Temp (°C) | Disc pH |
|-----------------------|---------------|--------------------|---------------------|--------------------|--------------------|----------------|---------|
|                       |               | (mgd)              | (mgd)               | (mgd)              |                    |                |         |
| Westtown Chest        | PA0031771     | 0.0000             | 0.0000              | 0.4950             | 0.000              | 25.00          | 7.00    |
| <b>Parameter Data</b> |               |                    |                     |                    |                    |                |         |
| Parameter Name        |               | Disc Conc (mg/L)   | Trib Conc (mg/L)    | Stream Conc (mg/L) | Fate Coef (1/days) |                |         |
| CBOD5                 |               | 15.00              | 2.00                | 0.00               | 1.50               |                |         |
| Dissolved Oxygen      |               | 5.00               | 8.24                | 0.00               | 0.00               |                |         |
| NH3-N                 |               | 2.50               | 0.00                | 0.00               | 0.70               |                |         |

## Input Data WQM 7.0

| SWP Basin | Stream Code                   | Stream Name | RMI   | Elevation (ft) | Drainage Area (sq mi) | Slope (ft/ft) | PWS Withdrawal (mgd) | Apply FC                            |
|-----------|-------------------------------|-------------|-------|----------------|-----------------------|---------------|----------------------|-------------------------------------|
| 03G       | 604 EAST BRANCH CHESTER CREEK |             | 1.490 | 262.04         | 9.99                  | 0.00000       | 0.00                 | <input checked="" type="checkbox"/> |

## Stream Data

| Design Cond. | LFY    | Trib Flow | Stream Flow | Rch Trav Time | Rch Velocity | WD Ratio | Rch Width | Rch Depth | Tributary Temp | pH   | Stream Temp | pH   |
|--------------|--------|-----------|-------------|---------------|--------------|----------|-----------|-----------|----------------|------|-------------|------|
|              | (cfsm) | (cfs)     | (cfs)       | (days)        | (fps)        |          | (ft)      | (ft)      | (°C)           |      | (°C)        |      |
| Q7-10        | 0.100  | 0.00      | 0.00        | 0.000         | 0.000        | 0.0      | 0.00      | 0.00      | 20.00          | 7.00 | 0.00        | 0.00 |
| Q1-10        |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |      |             |      |
| Q30-10       |        | 0.00      | 0.00        | 0.000         | 0.000        |          |           |           |                |      |             |      |

## Discharge Data

| Name                  | Permit Number | Existing Disc Flow (mgd) | Permitted Disc Flow (mgd) | Design Disc Flow (mgd) | Reserve Factor     | Disc Temp (°C) | Disc pH |
|-----------------------|---------------|--------------------------|---------------------------|------------------------|--------------------|----------------|---------|
| down stream           |               | 0.0000                   | 0.0000                    | 0.0000                 | 0.000              | 25.00          | 7.00    |
| <b>Parameter Data</b> |               |                          |                           |                        |                    |                |         |
|                       |               |                          |                           |                        |                    |                |         |
| Parameter Name        |               | Disc Conc (mg/L)         | Trib Conc (mg/L)          | Stream Conc (mg/L)     | Fate Coef (1/days) |                |         |
| CBOD5                 |               | 25.00                    | 2.00                      | 0.00                   | 1.50               |                |         |
| Dissolved Oxygen      |               | 3.00                     | 8.24                      | 0.00                   | 0.00               |                |         |
| NH3-N                 |               | 25.00                    | 0.00                      | 0.00                   | 0.70               |                |         |

**WQM 7.0 Wasteload Allocations**

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u>        |
|------------------|--------------------|---------------------------|
| 03G              | 604                | EAST BRANCH CHESTER CREEK |

**NH3-N Acute Allocations**

| RMI                  | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|----------------------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 1.680 Westtown Chest |                | 13.18                     | 5                   | 13.18                     | 5                   | 0              | 0                 |

**NH3-N Chronic Allocations**

| RMI                  | Discharge Name | Baseline Criterion (mg/L) | Baseline WLA (mg/L) | Multiple Criterion (mg/L) | Multiple WLA (mg/L) | Critical Reach | Percent Reduction |
|----------------------|----------------|---------------------------|---------------------|---------------------------|---------------------|----------------|-------------------|
| 1.680 Westtown Chest |                | 1.66                      | 2.5                 | 1.66                      | 2.5                 | 0              | 0                 |

**Dissolved Oxygen Allocations**

| RMI                 | Discharge Name | CBOD5           |                 | NH3-N           |                 | Dissolved Oxygen |                 | Critical Reach | Percent Reduction |
|---------------------|----------------|-----------------|-----------------|-----------------|-----------------|------------------|-----------------|----------------|-------------------|
|                     |                | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L) | Multiple (mg/L) | Baseline (mg/L)  | Multiple (mg/L) |                |                   |
| 1.68 Westtown Chest |                | 15              | 15              | 2.5             | 2.5             | 5                | 5               | 0              | 0                 |

**WQM 7.0 D.O.Simulation**

| <u>SWP Basin</u>                | <u>Stream Code</u> | <u>Stream Name</u> |                                   |                                  |
|---------------------------------|--------------------|--------------------|-----------------------------------|----------------------------------|
|                                 |                    | 03G                | 604                               | EAST BRANCH CHESTER CREEK        |
| <u>RMI</u>                      |                    |                    | <u>Total Discharge Flow (mgd)</u> | <u>Analysis Temperature (°C)</u> |
| 1.680                           |                    | 0.495              |                                   | 22.349                           |
| <u>Reach Width (ft)</u>         |                    |                    | <u>Reach Depth (ft)</u>           | <u>Reach WDRatio</u>             |
| 18.388                          |                    | 0.560              |                                   | 32.806                           |
| <u>Reach CBOD5 (mg/L)</u>       |                    |                    | <u>Reach Kc (1/days)</u>          | <u>Reach NH3-N (mg/L)</u>        |
| 8.11                            |                    | 1.293              |                                   | 1.17                             |
| <u>Reach DO (mg/L)</u>          |                    |                    | <u>Reach Kr (1/days)</u>          | <u>Kr Equation</u>               |
| 6.719                           |                    | 2.914              |                                   | Tsivoglou                        |
| <u>Reach Travel Time (days)</u> | 0.073              |                    | <b>Subreach Results</b>           |                                  |
|                                 |                    | TravTime<br>(days) | CBOD5<br>(mg/L)                   | NH3-N<br>(mg/L)                  |
|                                 |                    |                    |                                   | D.O.<br>(mg/L)                   |
|                                 |                    | 0.007              | 8.02                              | 1.17                             |
|                                 |                    | 0.015              | 7.94                              | 1.16                             |
|                                 |                    | 0.022              | 7.85                              | 1.15                             |
|                                 |                    | 0.029              | 7.77                              | 1.15                             |
|                                 |                    | 0.037              | 7.69                              | 1.14                             |
|                                 |                    | 0.044              | 7.61                              | 1.13                             |
|                                 |                    | 0.051              | 7.53                              | 1.13                             |
|                                 |                    | 0.059              | 7.45                              | 1.12                             |
|                                 |                    | 0.066              | 7.37                              | 1.11                             |
|                                 |                    | 0.073              | 7.29                              | 1.10                             |
|                                 |                    |                    |                                   | 5.73                             |

**WQM 7.0 Effluent Limits**

| <u>SWP Basin</u> | <u>Stream Code</u> | <u>Stream Name</u> |                 |                           |                                |                            |                            |
|------------------|--------------------|--------------------|-----------------|---------------------------|--------------------------------|----------------------------|----------------------------|
|                  |                    | 03G                | 604             | EAST BRANCH CHESTER CREEK |                                |                            |                            |
| RMI              | Name               | Permit Number      | Disc Flow (mgd) | Parameter                 | Effl. Limit 30-day Ave. (mg/L) | Effl. Limit Maximum (mg/L) | Effl. Limit Minimum (mg/L) |
| 1.680            | Westtown Chest     | PA0031771          | 0.000           | CBOD5                     | 15                             |                            |                            |
|                  |                    |                    |                 | NH3-N                     | 2.5                            | 5                          |                            |
|                  |                    |                    |                 | Dissolved Oxygen          |                                |                            | 5                          |

**WQM 7.0 Hydrodynamic Outputs**

| <u>SWP Basin</u>   |             |          | <u>Stream Code</u> |               | <u>Stream Name</u>        |       |       |           |          |                 |               |             |
|--------------------|-------------|----------|--------------------|---------------|---------------------------|-------|-------|-----------|----------|-----------------|---------------|-------------|
| 03G                |             |          | 604                |               | EAST BRANCH CHESTER CREEK |       |       |           |          |                 |               |             |
| RMI                | Stream Flow | PWS With | Net Stream Flow    | Disc Analysis | Reach Slope               | Depth | Width | W/D Ratio | Velocity | Reach Trav Time | Analysis Temp | Analysis pH |
|                    | (cfs)       | (cfs)    | (cfs)              | (cfs)         | (ft/ft)                   | (ft)  | (ft)  |           | (fps)    | (days)          | (°C)          |             |
| <b>Q7-10 Flow</b>  |             |          |                    |               |                           |       |       |           |          |                 |               |             |
| 1.680              | 0.86        | 0.00     | 0.86               | .7658         | 0.00183                   | .56   | 18.39 | 32.81     | 0.16     | 0.073           | 22.35         | 7.00        |
| <b>Q1-10 Flow</b>  |             |          |                    |               |                           |       |       |           |          |                 |               |             |
| 1.680              | 0.55        | 0.00     | 0.55               | .7658         | 0.00183                   | NA    | NA    | NA        | 0.14     | 0.083           | 22.90         | 7.00        |
| <b>Q30-10 Flow</b> |             |          |                    |               |                           |       |       |           |          |                 |               |             |
| 1.680              | 1.18        | 0.00     | 1.18               | .7658         | 0.00183                   | NA    | NA    | NA        | 0.17     | 0.067           | 21.97         | 7.00        |

## WQM 7.0 Modeling Specifications

|                    |        |                                     |                                     |
|--------------------|--------|-------------------------------------|-------------------------------------|
| Parameters         | Both   | Use Inputted Q1-10 and Q30-10 Flows | <input checked="" type="checkbox"/> |
| WLA Method         | EMPR   | Use Inputted W/D Ratio              | <input type="checkbox"/>            |
| Q1-10/Q7-10 Ratio  | 0.64   | Use Inputted Reach Travel Times     | <input type="checkbox"/>            |
| Q30-10/Q7-10 Ratio | 1.36   | Temperature Adjust Kr               | <input checked="" type="checkbox"/> |
| D.O. Saturation    | 90.00% | Use Balanced Technology             | <input checked="" type="checkbox"/> |
| D.O. Goal          | 5      |                                     |                                     |