

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0031992
 APS ID 369894
 Authorization ID 1293490

Applicant and Facility Information

Applicant Name	<u>PA DCNR State Parks Bureau</u>	Facility Name	<u>Greenwood Furnace State Park</u>
Applicant Address	<u>15795 Greenwood Road</u> <u>Huntingdon, PA 16652-5831</u>	Facility Address	<u>Standing Stone Creek</u> <u>Huntingdon, PA 16652</u>
Applicant Contact	<u>James Dinsmore</u>	Facility Contact	<u>Michael Dinsmore</u>
Applicant Phone	<u>(814) 667-1800</u>	Facility Phone	<u>(814) 667-1800</u>
Client ID	<u>64584</u>	Site ID	<u>453106</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Jackson Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Huntingdon</u>
Date Application Received	<u>October 24, 2019</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>October 30, 2019</u>	If No, Reason	<u></u>
Purpose of Application	<u>NPDES permit renewal.</u>		

Summary of Review

The Greenwood Furnace State Park's WWTP is located in Jackson Borough, Huntingdon County. The WWTP is owned and operated by the Pennsylvania Department of Conservation & Natural Resources (PA DCNR) – State Parks Bureau. The park and the treatment plant operate from May through September and is closed during the remainder of the year. During operation there is little or no discharge from the polishing pond due to evaporation, trans-evaporation, the possibility of some seepage and due to low flow through the plant, about 3,000 gpd.

The WWTP has a design capacity of 0.059 MGD but is permitted for 0.015 MGD to prevent anti-degradation of the stream, and discharges to the East Branch Standing Stone Creek (HQ-CWF). The discharge to a HQ stream is justified, since the outfall pre-dates the HQ classification of the stream.

PA DCNR – State Parks Bureau has applied to the Pennsylvania Department of Environmental Protection (DEP) for reissuance of its NPDES permit. The permit was last reissued on February 9, 2015 and became effective on March 1, 2015. The permit expired on February 29, 2020.

WQM No. 3169401 original was issued on June 23, 1969.

Changes from the previous permit: Unit of Fecal Coliform changed from CFU/100 ml to No./100 ml.

Based on the review outline in this fact sheet, it is recommended that the permit be drafted and published in the Pennsylvania Bulletin for public comments for 30 days.

Approve	Deny	Signatures	Date
X		Hilary H. Le / Environmental Engineering Specialist	March 4, 2020
		Daniel W. Martin, P.E. / Environmental Engineer Manager	
		Maria D. Bebenek, P.E. / Clean Water Program Manager	

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	001	Design Flow (MGD)	0.015
Latitude	40° 38' 55.79"	Longitude	-77° 45' 32.32"
Quad Name	McAlevys Fort	Quad Code	
Wastewater Description: Sewage Effluent			
Receiving Waters	East Branch Standing Stone Creek (HQ-CWF)	Stream Code	15411
NHD Com ID	65603674	RMI	8.6 miles
Drainage Area	6.95 mi. ²	Yield (cfs/mi ²)	0.07
Q ₇₋₁₀ Flow (cfs)	0.51	Q ₇₋₁₀ Basis	USGS StreamStats
Elevation (ft)	900.0	Slope (ft/ft)	
Watershed No.	11-B	Chapter 93 Class.	HQ-CWF
Existing Use		Existing Use Qualifier	
Exceptions to Use		Exceptions to Criteria	
Assessment Status	Attaining Use(s)		
Cause(s) of Impairment			
Source(s) of Impairment			
TMDL Status		Name	
Nearest Downstream Public Water Supply Intake	Huntingdon Borough Water Department, Huntingdon County		
PWS Waters	Standing Stone Creek	Flow at Intake (cfs)	
PWS RMI	0.3 mile	Distance from Outfall (mi)	Approximate 24 miles

Changes Since Last Permit Issuance: none

Drainage Area

The discharge is to East Branch Standing Stone Creek at RMI 8.6 miles. A drainage area upstream of the discharge is estimated to be 6.95 mi.², according to USGS PA StreamStats available at <https://streamstats.usgs.gov/ss/>.

Streamflow

According to StreamStats, the discharge point on East Branch Standing Stone Creek has a Q₇₋₁₀ of 0.51 cfs and a drainage area of 6.95 mi.², which results in a Q₇₋₁₀ low flow yield of 0.07 cfs/mi.². This information is used to obtain a chronic or 30-day (Q₃₀₋₁₀), and an acute or 1-day (Q₁₋₁₀) exposure stream flow for the discharge point as follows (Guidance No. 391-2000-023):

$$\begin{aligned}
 Q_{7-10} &= 0.51 \text{ cfs} \\
 \text{Low Flow Yield} &= 0.51 \text{ cfs} / 6.95 \text{ mi.}^2 \approx 0.07 \text{ cfs/mi.}^2 \\
 Q_{30-10} &= 1.36 * 0.51 \text{ cfs} \approx 0.69 \text{ cfs} \\
 Q_{1-10} &= 0.64 * 0.51 \text{ cfs} \approx 0.33 \text{ cfs}
 \end{aligned}$$

Standing Stone Creek

25 Pa Code § 93.9n classifies Standing Stone Creek as High Quality-Cold Water Fishes (HQ-CWF) surface water. Based on the 2018 Integrated Report, Standing Stone Creek, assessment unit ID 21691, is not impaired. A TMDL currently does not exist for this stream segment, therefore, no TMDL has been taken into consideration during this review.

Public Water Supply:

The nearest downstream public water supply intake is the Huntingdon Borough Water Department on the Standing Stone Creek in Huntingdon Borough, approximately 24 miles downstream of this discharge. Considering distance and dilution, the discharge is not expected to impact the water supply.

Treatment Facility Summary				
Treatment Facility Name: Greenwood Furnace St Pk				
WQM Permit No.		Issuance Date		
3169401		6/23/1969		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Tertiary	Activated Sludge With Solids Removal	Hypochlorite	0.015
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.015		Not Overloaded	Aerobic Digestion	Combination of methods

Changes Since Last Permit Issuance: none

The WWTP train is as follows:

Comminutor (1) ⇒ Aeration Tanks (2) ⇒ Clarifiers (4) ⇒ Polishing Ponds (2) ⇒ Chlorine Contact Tank (1) ⇒ Sludge Holding Tanks (2) ⇒ Discharge (Outfall 001)

Calcium Hypochlorite is used for disinfection. Soda Ash is used for neutralizing pH.

Compliance History	
Summary of DMRs:	The DMRs reported from February 1, 2019 to January 31, 2020 is summarized in the Table below (Page # 5).
Summary of Inspections:	<p>9/14/2019: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. The recommendations were to attach missing effluent supplemental forms for September 2018 through July 2019 eDMRs, and submit NPDES renewal application. Treatment plant is operating approximately from May through September. Treatment plant was operating properly. There were no violations noted during inspection.</p> <p>8/24/2018: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. There was a recommendation such as replace D.O. meter sensor cap. There were no violations noted during inspection. Treatment plant appeared to be operating properly. Discharge occurred about 4 times per year. Sludge hauled by Lake septic and disposed of at the Shade Gap STP. Solids were removed, clarifier and aeration tank maintained periodically during the camping season.</p> <p>8/14/2017: Mr. Clark, DEP WQS, conducted compliance evaluation inspection. The treatment plant was in operation from May through September. There were no violations noted during inspection.</p>
Other Comments:	There are currently no open violations associated with the permittee or the facility.

Other Comments:

Compliance History

DMR Data for Outfall 001 (from February 1, 2019 to January 31, 2020)

Parameter	JAN-20	DEC-19	NOV-19	OCT-19	SEP-19	AUG-19	JUL-19	JUN-19	MAY-19	APR-19	MAR-19	FEB-19
Flow (MGD) Average Monthly			0.0313				0.028			0.037		
Flow (MGD) Daily Maximum			0.0432				0.0432			0.0432		
pH (S.U.) Instantaneous Minimum			6.68									
pH (S.U.) Minimum							6.86			6.89		
pH (mg/L) Minimum							6.86			6.89		
pH (S.U.) Instantaneous Maximum			6.89									
pH (S.U.) Maximum							7.28			7.29		
pH (mg/L) Maximum							7.28			7.29		
DO (mg/L) Minimum			7.83				6.07			8.57		
TRC (mg/L) Average Monthly			0.37				0.44			0.49		
TRC (mg/L) Instantaneous Maximum			0.65				0.78			0.78		
CBOD5 (mg/L) Average Monthly			< 0.20				2.33			10.88		
TSS (mg/L) Average Monthly			< 5.5				7			6.5		
Fecal Coliform (CFU/100 ml) Geometric Mean			< 10				< 10			< 15.8		
Fecal Coliform (CFU/100 ml) Instantaneous Maximum			< 10				< 10			< 25		
Nitrate-Nitrite (mg/L) Average Quarterly		0.81			1.43			< 0.05				
Total Nitrogen (mg/L) Average Quarterly		2.92			4.82			1.64				
Ammonia (mg/L) Average Quarterly		0.65			1.49			0.04				
TKN (mg/L) Average Quarterly		2.58			4.10			1.92				
Total Phosphorus (mg/L) Average Quarterly		2.100			1.548			1.574				

Development of Effluent Limitations

Outfall No. <u>001</u>	Design Flow (MGD) <u>0.015</u>
Latitude <u>40° 38' 39.92"</u>	Longitude <u>-77° 46' 5.59"</u>
Wastewater Description: <u>Sewage Effluent</u>	

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Water Quality-Based Limitations

Carbonaceous Biochemical Oxygen Demand (CBOD₅)

Only the minimum treatment requirements of secondary treatment will be necessary to protect water quality. The existing limits of 25 mg/L average monthly, and 50 mg/L instantaneous maximum will remain in the proposed permit. The facility has consistently achieved CBOD₅ levels well below these limits.

Ammonia (NH₃-N)

NH₃-N calculations are based on the Department's Implementation Guidance of Section 93.7 Ammonia Criteria, dated 11/4/97 (ID No. 391-2000-013). The attached printout of the WQM 7.0 data indicates that at a discharge of 0.015 MGD, limits (rounded according to the NPDES Technical Guidance 362-0400-001) of 25 mg/L NH₃-N as a monthly average and 50 mg/L NH₃-N instantaneous maximum are necessary to protect the aquatic life from toxicity effects.

The following data is necessary to determine the in-stream NH₃-N criteria used in the attached WQM 7.0 computer model of the stream:

- Discharge pH = 7.0 (Default)
- Discharge Temperature = 20°C (Default)
- Stream pH = 7.0 (Default)
- Stream Temperature = 20°C (Default)
- Background NH₃-N = 0 (Default)

There are no NH₃-N effluent limits in this permit. However, the "Monitor & Report" once per quarter for average quarter will remain in the proposed permit.

Total Suspended Solids (TSS)

The existing limits of 30 mg/L average monthly, and 60 mg/L instantaneous maximum will remain in the proposed permit based on the minimum level of effluent quality attainable by secondary treatment based on 25 Pa. Code § 92a.47. Past DMRs and inspection reports show that the facility has been consistently achieving these limits.

Dissolved Oxygen (D.O.)

A minimum D.O. of 5.0 mg/L is required per 25 Pa. Code § 93.7. The agreement between DEP and DCNR requires that D.O. be sampled 1/day (May - Sep) and 3/week (Oct – Apr). These monitoring requirements will remain in the proposed permit.

pH

The effluent discharge pH should remain above 6 and below 9 standard units according to 25 Pa Code § 95.2(2). Additionally, the DEP has an agreement with DCNR that necessitates seasonal monitoring requirements for certain parameters, including pH. For Greenwood Furnace State Park, pH must be sampled 1/day (May - Sep) and 3/week (Oct - Apr). These monitoring requirements will remain in the proposed permit.

Fecal Coliform

The recent coliform guidance in 25 Pa Code § 92a.47.(a)(4) requires a summer technology limit of 200/100 ml as a geometric mean and an instantaneous maximum not greater than 1,000/100 ml and 25 Pa Code § 92a.47.(a)(5) requires a winter limit of 2,000/100 ml as a geometric mean and an instantaneous maximum not greater than 10,000/100 ml.

Toxics

No toxic parameters of concern associated with this discharge.

Total Residual Chlorine

The attached computer printout (Page # 8) utilizes the equations and calculations as presented in the Department's 2003 Implementation Guidance for Residual Chlorine (TRC) (ID # 391-2000-015) for developing chlorine limitations. The attached printout indicates that an average monthly water quality limit of 0.5 mg/L and 1.6 mg/L max daily would be needed to prevent toxicity concerns. This is consistent with the existing permit. The treatment facility is meeting this limit. The agreement between DEP and DCNR requires that TRC be sampled 1/day (May - Sep) and 3/week (Oct - Apr). These monitoring requirements will remain in the proposed permit.

Biosolids Management

Sludge is periodically dredged from the lagoon and the polishing pond, and then disposed of by a certified hauler.

Chesapeake Bay Strategy

According to DEP's Chesapeake Bay Phase II Watershed Implementation Plan (WIP) Wastewater Supplement, this facility is considered a phase 5 non-significant sewage discharger with design flow less than 0.2 MGD but greater than 0.002 MGD. In general, DEP will issue permits for all phase 5 facilities with monitoring and reporting for Total Nitrogen (TN) and Total Phosphorus (TP) throughout the permit term at a frequency no less than annually. Furthermore, DEP's SOP No. BPNPSM-PMT-033 states that in general, at a minimum, monitoring for TN and TP should be included in new and reissued permits for sewage discharges with design flows > 2,000 gpd. At this time, the Department is not requiring a total maximum annual nitrogen or phosphorus loading cap. Ammonia-Nitrogen, Nitrate-Nitrite as N, Total Kjeldahl Nitrogen, TN, and TP monitoring is already included in the existing permit and will remain in the proposed permit.

The Chesapeake Bay parameters monitoring frequency for this facility will match that of the conventional pollutants monitoring frequency of one sample per quarter.

Stormwater

There is no known stormwater outfall associated with this facility.

Anti-Degradation (93.4)

The effluent limits for this discharge have been developed to ensure that the existing in-stream water used and the level of water quality necessary to protect the existing uses are maintained and protected. No new or additional discharge is proposed. The discharge pre-dates the Chapter 93 designation of HQ-CWF, and is not expected to impact the stream.

Class A Wild Trout Fisheries

No Class A Wild Trout Fisheries are impacted by this discharge.

The discharge is located on the following Class A Wild Trout Stream:

- East Branch Standing Stone Creek
 - o Sub-Basin: 11B, Trout Biomass: A, Section Number: 02, Fishery: Brown
 - o Upper Limits Description: Dam at Greenwood Furnace State Park, Lower Limit Description: Mouth
 - o Upper Limit River: 9.22 miles

303d Listed Streams:

The discharge is not located on a 303d listed stream segment.

WQM 7.0 input:

Node 1: Outfall 001 on East Branch Standing Stone Creek (15411)
Elevation: 900.00 ft (USGS National Map Viewer)
Drainage Area: 6.95 mi.² (USGS PA StreamStats)
River Mile Index: 8.6 (PA DEP eMapPA)
Low Flow Yield: 0.07 cfs/mi.²(0.51 cfs/6.95 mi.2)
Discharge Flow: 0.015 MGD (NPDES Application)

Node 2: Just before conjunction East Branch Standing Stone Creek & Trib. 15426
Elevation: 805.00 ft (USGS National Map Viewer)
Drainage Area: 9.06 mi.² (USGS PA StreamStats)
River Mile Index: 6.4 (PA DEP eMapPA)
Low Flow Yield: 0.07 cfs/mi.²
Discharge Flow: 0.000 MGD

WQM 7.0 data is attached.



Greenwood WQM
7.0 data.pdf

TRC results

TRC EVALUATION					
Input appropriate values in A3:A9 and D3:D9					
0.51	= Q stream (cfs)	0.5	= CV Daily		
0.015	= Q discharge (MGD)	0.5	= CV Hourly		
30	= no. samples	1	= AFC_Partial Mix Factor		
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor		
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)		
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)		
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)		
Source	Reference	AFC Calculations		Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 7.030		1.3.2.iii	WLA_cfc = 6.846
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 2.620		5.1d	LTA_cfc = 3.980
Source		Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231			
PENTOXSD TRG	5.1g	AVG_MON_LIMIT (mg/l) = 0.500		BAT/BPJ	
		INST_MAX_LIMIT (mg/l) = 1.635			
WLA_afc	$(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$				
LTA_afc	wla_afc * LTAMULT_afc				
WLA_cfc	$(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$				
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1)^{0.5})$				
LTA_cfc	wla_cfc * LTAMULT_cfc				
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$				
AVG_MON_LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)				
INST_MAX_LIMIT	1.5 * ((av_mon_limit / AML_MULT) / LTAMULT_afc)				

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)			Minimum ⁽²⁾ Measurement Frequency	Required Sample Type	
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum			Instant. Maximum
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.) May 1 - Sep 30	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
pH (S.U.) Oct 1 - Apr 30	XXX	XXX	6.0	XXX	XXX	9.0	3/week	Grab
DO May 1 - Sep 30	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
DO Oct 1 - Apr 30	XXX	XXX	5.0	XXX	XXX	XXX	3/week	Grab
TRC May 1 - Sep 30	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
TRC Oct 1 - Apr 30	XXX	XXX	XXX	0.5	XXX	1.6	3/week	Grab
CBOD ₅	XXX	XXX	XXX	25	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Nitrate-Nitrite	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
TKN	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

Proposed Effluent Limitations and Monitoring Requirements
--

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Daily Maximum	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.) May 1 - Sep 30	XXX	XXX	6.0	XXX	XXX	9.0	1/day	Grab
pH (S.U.) Oct 1 - Apr 30	XXX	XXX	6.0	XXX	XXX	9.0	3/week	Grab
DO May 1 - Sep 30	XXX	XXX	5.0	XXX	XXX	XXX	1/day	Grab
DO Oct 1 - Apr 30	XXX	XXX	5.0	XXX	XXX	XXX	3/week	Grab
TRC May 1 - Sep 30	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
TRC Oct 1 - Apr 30	XXX	XXX	XXX	0.5	XXX	1.6	3/week	Grab
CBOD ₅	XXX	XXX	XXX	25.0	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1,000	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2,000 Geo Mean	XXX	10,000	2/month	Grab
Ammonia	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Nitrate-Nitrite	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
TKN	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	1/quarter	8-Hr Composite

Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	PENTOXSD for Windows Model (see Attachment [redacted])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Toxics Screening Analysis Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 362-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 362-2000-003, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 362-2000-008, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 362-2183-003, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 362-2183-004, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 385-2000-011, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 391-2000-002, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 391-2000-003, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 391-2000-006, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 391-2000-007, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 391-2000-008, 10/1997.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 391-2000-010, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 391-2000-011, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 391-2000-013, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 391-2000-014, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 391-2000-015, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 391-2000-017, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 391-2000-018, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 391-2000-019, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 391-2000-021, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 391-2000-022, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 391-2000-023, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 391-2000-024, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 391-3200-013, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]