

Application Type Renewal
Facility Type Sewage
Major / Minor Minor

**NPDES PERMIT FACT SHEET
SECOND DRAFT**

Application No. PA0032115
APS ID 509177
Authorization ID 1300231

Applicant and Facility Information

Applicant Name	<u>PA DCNR Ricketts Glen State Park</u>	Facility Name	<u>Ricketts Glen State Park Sewage Treatment Plant</u>
Applicant Address	<u>695 State Route 487</u> <u>Benton, PA 17814</u>	Facility Address	<u>695 State Route 487</u> <u>Benton, PA 17814-7505</u>
Applicant Contact	<u>Scott Wilson, Park Manager</u>	Facility Contact	<u>Scott Wilson, Park Manager</u>
Applicant Phone	<u>(570) 477-5675</u>	Facility Phone	<u>(570) 477-5675</u>
Client ID	<u>52524</u>	Site ID	<u>244081</u>
SIC Code	<u>4952,8412</u>	Municipality	<u>Fairmount Township</u>
SIC Description	<u>Services - Museums and Art Galleries, Trans. & Utilities - Sewerage Systems</u>	County	<u>Luzerne</u>
Date Published in PA Bulletin	<u>June 27, 2020</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>July 27, 2020</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES permit for discharge of treated sewage.</u>		

Internal Review and Recommendations

The first draft of this application appeared in the PA Bulletin on Saturday, June 27, 2020. The final NPDES permit could not be issued due to open violations.

There are still 45 open violations for this client, including two in the Clean Water Program for this facility.

A second draft of the NPDES permit is being issued because 6 months (or 180 days) have elapsed since the draft has been issued.

An updated permit application was received on October 8, 2024. Re-modeling was not performed. Limitations and monitoring frequencies have been carried over from the first draft.

Sewage discharges now require monitoring and reporting for E. Coli. A monitoring frequency of 1/month for design flows >= 1 MGD, 1/quarter for design flows >= 0.05 and < 1 MGD, 1/year for design flows of 0.002 – 0.05 MGD will be utilized.

All the permit documents have been updated to the newest format.

Approve	Return	Deny	Signatures	Date
X			/s/ Allison Seyfried Zukosky / Project Manager	January 17, 2025
X			/s/ Amy M. Bellanca, P.E. / Acting Engineer Manager	1-22-25