

Application Type Renewal
Facility Type Industrial
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL INDUSTRIAL WASTE (IW)
AND IW STORMWATER**

Application No. PA0032409
APS ID 1049313
Authorization ID 1372221

Applicant and Facility Information

Applicant Name	<u>PA DCNR</u>	Facility Name	<u>Hyner Run State Park</u>
Applicant Address	<u>4205 Little Pine Creek Road</u> <u>Waterville, PA 17776-9608</u>	Facility Address	<u>86 Hyner Park Road</u> <u>North Bend, PA 17760-9525</u>
Applicant Contact	<u>Tracy Zupich</u>	Facility Contact	<u>Michael Winters</u>
Applicant Phone	<u>(570) 753-6000</u>	Facility Phone	<u>(570) 753-6000</u>
Client ID	<u>52524</u>	Site ID	<u>269791</u>
SIC Code	<u>8412</u>	Municipality	<u>Chapman Township</u>
SIC Description	<u>Services - Museums And Art Galleries</u>	County	<u>Clinton</u>
Date Application Received	<u>October 4, 2021</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u></u>	If No, Reason	<u></u>
Purpose of Application	<u>.</u>		

Summary of Review

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
		Chad A. Fabian / Project Manager	August 17, 2022
		Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	

Discharge, Receiving Waters and Water Supply Information

Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.00017</u>
Latitude	<u>41° 21' 33.76"</u>	Longitude	<u>-77° 37' 29.69"</u>
Quad Name	_____	Quad Code	_____
Wastewater Description: <u>IW Process Effluent without ELG</u>			

Receiving Waters	<u>Hyner Run (HQ-CWF)</u>	Stream Code	_____
NHD Com ID	<u>61114835</u>	RMI	_____
Drainage Area	_____	Yield (cfs/mi ²)	_____
Q ₇₋₁₀ Flow (cfs)	_____	Q ₇₋₁₀ Basis	_____
Elevation (ft)	_____	Slope (ft/ft)	_____
Watershed No.	<u>9-B</u>	Chapter 93 Class.	<u>HQ-CWF</u>
Existing Use	_____	Existing Use Qualifier	_____
Exceptions to Use	_____	Exceptions to Criteria	_____
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	_____		
Source(s) of Impairment	_____		
TMDL Status	_____	Name	_____

Background/Ambient Data	Data Source
pH (SU)	_____
Temperature (°F)	_____
Hardness (mg/L)	_____
Other:	_____

Nearest Downstream Public Water Supply Intake	
PWS Waters	<u>_____</u>
PWS RMI	<u>_____</u>
Flow at Intake (cfs)	<u>_____</u>
Distance from Outfall (mi)	<u>_____</u>

Changes Since Last Permit Issuance:

Other Comments:

Compliance History	
Summary of DMRs:	[REDACTED]
Summary of Inspections:	[REDACTED]

Other Comments: [REDACTED]

Compliance History

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations					
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)			
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX
pH (S.U.)	XXX	XXX	6.0	XXX	9.0	XXX
TRC	XXX	XXX	XXX	Report	XXX	0.05
TSS	XXX	XXX	XXX	30.0	XXX	60.0

Compliance Sampling Location:

Other Comments: