

Application Type Renewal
Facility Type Sewage
Major / Minor Minor

**NPDES PERMIT FACT SHEET
SECOND DRAFT**

Application No. PA0032433
APS ID 520176
Authorization ID 1313557

Applicant and Facility Information

Applicant Name	<u>PA DCNR, Frances Slocum State Park</u>	Facility Name	<u>Frances Slocum State Park</u>
Applicant Address	<u>565 Mount Olivet Road</u>	Facility Address	<u>565 Mount Olivet Road</u>
	<u>Wyoming, PA 18644-9333</u>		<u>Wyoming, PA 18644-9333</u>
Applicant Contact	<u>Kevin Koflanovich, Park Manager</u>	Facility Contact	<u>Kevin Koflanovich, Park Manager</u>
Applicant Phone	<u>(570) 696-3525</u>	Facility Phone	<u>(570) 696-3525</u>
Client ID	<u>52524</u>	Site ID	<u>448218</u>
SIC Code	<u>8412</u>	Municipality	<u>Kingston Township</u>
SIC Description	<u>Services - Museums and Art Galleries</u>	County	<u>Luzerne</u>
Date Published in PA Bulletin	<u>January 5, 2020</u>	EPA Waived?	<u>Yes</u>
Comment Period End Date	<u>February 5, 2020</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal of NPDES permit for discharge of treated sewage.</u>		

Internal Review and Recommendations

The first draft of this application appeared in the PA Bulletin on Saturday, January 5, 2020. The final NPDES permit could not be issued due to open violations.

There are still 45 open violations for this client; however, there are currently no open violations for this facility.

A second draft of the NPDES permit is being issued because 6 months (or 180 days) have elapsed since the draft has been issued.

Sewage discharges now require monitoring and reporting for E. Coli. A monitoring frequency of 1/month for design flows >= 1 MGD, 1/quarter for design flows >= 0.05 and < 1 MGD, 1/year for design flows of 0.002 – 0.05 MGD will be utilized.

All the permit documents have been updated to the newest format.

Approve	Return	Deny	Signatures	Date
X			/s/ Allison Seyfried Zukosky / Project Manager	January 21, 2025
X			/s/ Amy M. Bellanca, P.E. / Acting Engineer Manager	1-22-25