

Application Type Renewal
Facility Type Non-Municipal
Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0032468
APS ID 1038026
Authorization ID 1353328

Applicant and Facility Information

Applicant Name	<u>PA DCNR</u>	Facility Name	<u>Cook Forest State Park</u>
Applicant Address	<u>PO Box 120 113 River Road</u> <u>Cooksburg, PA 16217-0120</u>	Facility Address	<u>Park Road</u> <u>Cooksburg, PA 16217-0120</u>
Applicant Contact	<u>Ryan Borcz, Park Manager</u>	Facility Contact	<u>Ryan Borcz, Park Manager</u>
Applicant Phone	<u>(814) 744-8407</u>	Facility Phone	<u>(814) 744-8407</u>
Applicant E Mail	<u>cookforestsp@pa.gov</u>	Facility E Mail	<u>cookforestsp@pa.gov</u>
Client ID	<u>52524</u>	Site ID	<u>264209</u>
Municipality	<u>Barnett Township</u>	County	<u>Forest</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Connection Status	<u>No Limitations</u>
SIC Code	<u>4952</u>		<u>9512</u>
SIC Description	<u>Trans. & Utilities - Sewerage Systems</u>		<u>Pub Admin-Land, Mineral, Wildlife Cons</u>
Application Received	<u>April 8, 2021</u>	EPA Waived?	<u>No</u>
Application Accepted	<u>June 9, 2021</u>	If No, Reason	<u>DEP Discretion</u>
Application Purpose	<u>NPDES renewal</u>		

Summary of Review

This is an activated sludge treatment facility without dedicated sludge holding or treatment facilities. Except for the new parameter, E Coli, the permit requirements are from the existing permit and allow reduced winter monitoring as proposed by DCNR. Low DO and pH reported.

The discharge is to the upper reach of the Lower Clarion River TMDL. TMDL background data was taken downstream at the Route 36 bridge. As the Clarion River above the Route 36 bridge is attaining all uses no water-quality based requirements to achieve the TMDL requirements should be necessary. The TMDL incorporation is necessary to accurately assess background conditions.

Sludge use and disposal description and location(s): 35.9 dry tons hauled of site by Buerk's Septic.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		<i>William H. Mentzer</i> William H. Mentzer, P.E. Environmental Engineering Specialist	January 4, 2022
X		Justin C. Dickey Justin C. Dickey, P.E. Environmental Engineer Manager	January 6, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>0.079</u>
Latitude DP	<u>41° 19' 54.50"</u>	Longitude DP	<u>-79° 12' 27.10"</u>
Latitude NHD	<u>41° 19' 53.23"</u>	Longitude NHD	<u>-79° 12' 28.23"</u>
Quad Name	<u>Cooksburg</u>	Quad Code	<u>0812</u>
Wastewater:	<u>Treated campground domestic wastes</u>		
Receiving Waters	<u>Clarion River</u>	Stream Code	<u>49224</u>
NHD Com ID	<u>102668457</u>	RMI	<u>49.28</u>
Drainage Area	<u>806.6</u>	Yield (cfs/mi ²)	<u>0.119</u>
Q7-10 Flow (cfs)	<u>87.1</u>	Q7-10 Basis	<u>Clarion River</u>
Elevation (ft)	<u>1145.49</u>	Slope (ft/ft)	<u>0.0009</u>
Watershed No.	<u>17-B</u>	Chapter 93 Class.	<u>CWF</u>
Existing Use	<u>statewide</u>	Existing Use Qualifier	<u>none</u>
Use Exceptions	<u>none</u>	Exceptions to Criteria	<u>none</u>
Comments	<u>The NHD outfall is 1.02 miles above an unnamed Clarion River tributary</u>		
Low Flow	<u>Clarion River</u>	USGS St	<u>03029500</u>
		RMI	<u>48.33</u>
	Low Flow (cfs) <u>96</u>	Drainage (sq mi) <u>806.644</u>	Yield (cfs/sq mi) <u>0.119</u>
	Period <u>1940-96</u>	Elevation (ft) <u>1141.15</u>	Slope (ft/ft) <u>0.00111</u>
Comments	<u>The Clarion River is regulated through the East Branch Dam as of 1952 and upstream paper mill water use.</u>		
Assessment Status	<u>Attaining Use(s)</u>		
Impairment Cause	<u>Mine drainage</u>		
Impairment Source	<u>Abandoned mines</u>		
TMDL Status	<u>Final</u>	Name	<u>Lower Clarion River Watershed</u>
Comments	<u>This segment of the Lower Clarion River TMDL is attaining its uses and serves as the TMDL background and starting point.</u>		
Impoundment	<u>Piney Dam</u>	Retention (d)	<u>8.57</u>
		RMI	<u>26.15</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.2</u>	TMDL	
Temperature (°F)			
Hardness (mg/L)			
Other:			
Nearest Downstream Public Water Supply Intake	<u>Pa American Clarion District</u>		
PWS Waters	<u>Clarion River</u>	Flow at Intake (cfs)	<u>NA</u>
PWS RMI	<u>33.47</u>	Distance from Outfall (mi)	<u>16.37</u>

Changes Since Last Permit Issuance: none
Other Comments: none

Treatment Facility Summary				
Treatment Facility Name: Cook Forest State Park				
WQM Permit No.		Issuance Date		
2769401		January 1, 1970		
2769401 A-1		Nov 2016		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Activated Sludge	Sodium Hypochlorite	0.079
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.079	83	Not Overloaded	None	Other WWTP

Changes Since Permit Issuance: Amendment A1 is for influent control and disinfection replacement.

Other Comments:

The original treatment: comminution, extended aeration, and disinfection without a sludge production estimate or any sludge treatment and liquid sodium hypochlorite disinfection. The original permit was issued to the Bureau of State Parks which was then part of the Department of Forests and Waters. In 1975 the permit was transferred to DER.

The application is dated September 30, 1969, notarized on October 2, 1969, and received on October 6, 1969. The permit was issued to Forest and Waters on January 1, 1970 and transferred to DEP on September 18, 1974. Any further transfer is optional as the owner operator is the Commonwealth of Pennsylvania.

The application addresses two flow based 0.0745 and 0.079-MGD designs. The modules generally support the 0.0745-MGD design, but the chemical data tabulation supports a 0.079-MGD design. Also there is two campground populations at 1000 and 1100 people. The design organic load is 255-ppd with a 1100 campground population. During the application review a peak holiday weekend basis was proposed but never required. Aeration design has changed significantly since this facility was designed and built but the facility still should perform adequately.

Design is for an activated sludge facility using extended aeration. Treatment is comminution including a bar screen bypass, wet well/dry well pump station with two 140-gpm pumps (0.2016-MGD pumps), parallel aeration tanks followed by dedicated clarifiers and common liquid sodium hypochlorite disinfection.

The design inorganic load is 83-PPD based 6900 people at 0.012-ppcd. The waste description used a 150-mg/L concentration with a 0.079-MGD design flow. Similarly, the organic load is 255-PPD based 6900 people at 0.037-ppcd. The waste description does not specify a concentration and refers to the design report.

The applicant is the
Telephone
Fax
E Mail
The application is

Ryan Borcz. Cook Forest park manager
814-744-8407
814-744-8253
cookforest@pa.gov
Daniel A. Kauffman, Senior Civil
Engineer Western Engineering Office
Bureau of Facility Design and Construction 195
Park Road
Prospect, Pa 16052-9387
724 865-2131 ext 851
724-865-9075
daakauffma@pa.gov

Telephone
Fax
E Mail

Compliance History

DMR Data for Outfall 001 (from May 1, 2020 to April 30, 2021)

Parameter	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20	OCT-20	SEP-20	AUG-20	JUL-20	JUN-20	MAY-20
Flow (MGD) Average Monthly	0.019	0.027	0.010	0.018	13714	11300	0.010	0.0125	0.0153	0.0173	0.0188	0.0232
Flow (MGD) Daily Maximum	0.077	0.047	0.013	0.032	48800	58000	0.015	0.0218	0.0203	0.0257	0.0287	0.053
pH (S.U.) Minimum	7.13	6.99	6.75	6.70	7.0	7.39	5.7	5.5	5.5	5.8	6.0	6.5
pH (S.U.) Instant Maximum	7.60	7.48	8.80	7.40	8.8	7.5	7.03	6.9	6.7	6.9	6.9	7.0
DO (mg/L) Minimum	5.24	9.20	11.57	10.14	9.27	8.2	3.42	3.65	3.02	3.63	3.38	2.7
TRC (mg/L) Average Monthly	0.36	0.37	0.44	0.37	0.4	0.4	0.20	0.1	0.1	0.1	0.2	0.2
CBOD5 (mg/L) Average Monthly	2.30	0.30	0.75	1.65	1.7	0.14	1.8	2	3.0	2	3.0	21
TSS (mg/L) Average Monthly	6.5	4	6	4.0	6	0.63	11.5	8	9	6	5.0	9
F Coliform (#/100 ml) Geometric Mean	9	9	< 10	9	4.5	209.76	104	60	58	122	13	245
Total Nitrogen (mg/L) Average Monthly	3.32	1.31	1.75	1.43	2.6	0.48	40.08	50.22	52.56	51.24	28.42	17.51
Ammonia (mg/L) Average Monthly	1.85	0.09	0.16	0.22	0.05	0.16	15.35	0.24	0.2	0.15	4.02	14.72
Total Phosphorus (mg/L) Ave Monthly	0.158	0.122	0.17	0.065	0.37	0.033	9.97	2.192	4.062	2.941	0.948	0.524

Compliance History

Effluent Violations for Outfall 001, from: June 1, 2020 To: April 30, 2021

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
DO	06/30/20	Min	3.38	mg/L	4.0	mg/L
pH	07/31/20	Min	5.8	S.U.	6.0	S.U.
DO	07/31/20	Min	3.63	mg/L	4.0	mg/L
DO	08/31/20	Min	3.02	mg/L	4.0	mg/L
pH	08/31/20	Min	5.5	S.U.	6.0	S.U.
DO	09/30/20	Min	3.65	mg/L	4.0	mg/L
pH	09/30/20	Min	5.5	S.U.	6.0	S.U.
DO	10/31/20	Min	3.42	mg/L	4.0	mg/L
pH	10/31/20	Min	5.7	S.U.	6.0	S.U.

Summary of Inspections by Clint Stonesifer dated February 15, 2018 no problems noted.

Other Comments: Nov and Dec 2020 flow apparently entered as gpd not mgd
 Short summer flow averaging 0.0150-MGD is 19.0% of design
 Short summer maximum flow is 0.0257-MGD and 32.5% of design
 Short summer effluent BOD5 averages 3.3 with a 21-mg/L maximum
 Short summer effluent TSS averages 7.7 with a 11.5-mg/L maximum
 Short summer TSS/BOD5 ratio 3.3

Low DO and pH correlate to with a high TSS/CBOD5 ratio implying a low CBOD5 load and excessive aeration which led to the NPDES permit DO and pH goals not being achieved. The permit requirements should be achievable without additional treatment.

	Influent							Effluent	
	Mean	Mean	Max	Min	Mean	Max	Min	Mean	Max
	MGD	PPD	PPD	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
Design	0.079								
Hydraulic Design	0.079								
Organic Design									
Annual average									
	2018	0.031							
	2019	0.027							
	2020	0.019							
Peak Monthly Ave									
pH				6.7		7.0	6.7		7.0
TRC							0.05	0.22	0.47
BOD5		1	1	7.4		7.4	4.2	5.0	6.5
TSS		1	1	8		8	8	10	12
P		0	0	0.309		0.309	0.592	0.755	0.952
Ammonia		0	0	3.09		0.309	0.09	4.38	12.96
Coliform				9		9	10	10	2100
NO2NOS				0.61		0.61	0.49	0.49	0.49
DO							4	4	4

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.079
 Latitude 41° 19' 54.68" Longitude -79° 12' 28.60"
 Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
DO	4.0	Daily Minimum		BPJ
E Coli	126	Geo Mean		92a.47(a)

Comments: secondary treatment is the minimum treatment required. E coli is a new parameter for which monitoring is proposed.

Water Quality-Based Limitations

A Sewerage Program based “Reasonable Potential Analysis” determined the following parameters were candidates for limitations: Flow, BOD5 or CBOD5, TSS, nitrogen (N), phosphorus (P), ammonia-nitrogen, total residual chlorine (TRC), dissolved oxygen (DO), fecal coliform, e coli and pH.

TRC is spreadsheet evaluated. BOD5, CBOD5 and DO are evaluated with WQM 7.1.

The following limitations were determined through water quality modeling (output files attached):

Parameter		Limit (mg/l)			SBC	Model		
Parameter	Period	Minimum	Average	Maximum		Minimum	Average	Maximum
CBOD5			25	50	NAS		25	50
Ammonia	summer		25	50	NA		25	50
DO		4.0			NA	4.0		

Comments: Secondary treatment requirements are controlling. No ammonia requirements are necessary.

Best Professional Judgment (BPJ) Limitations

Comments: is the DO limitation basis.

Anti-Backsliding

Backsliding is not appropriate for violation corrections

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.) Oct 1 - Apr 30	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	3/week	Grab
pH (S.U.) May 1 - Sep 30	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO Oct 1 - Apr 30	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	3/week	Grab
DO May 1 - Sep 30	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC Oct 1 - Apr 30	XXX	XXX	XXX	0.5	XXX	1.6	3/week	Grab
TRC May 1 - Sep 30	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25	XXX	50.0	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30	XXX	60.0	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	2/month	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	1/quarter	8-Hr Composite
Ammonia	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report	XXX	XXX	2/month	8-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection

Discharger Site	Cook Forest	Revised	Saturday, May 14, 2016
Municipality	Cook Forest STP		Tuesday, January 4, 2022
County	Barnett Township		
NPDES Permit	Forest		
0.5	PA0034268		

TRC EVALUATION

Input appropriate values in B4:B8 and E4:E7

95.9998	= Q stream (cfs)	0.5	= CV Daily
0.0790	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		= Decay Coefficient (K)

Source	Reference	AFC Calculations	Reference	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 250.597	1.3.2.iii	WLA_cfc = 244.305
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c	LTAMULT_cfc = 0.581
PENTOXSD TRG	5.1b	LTA_afc = 93.379	5.1d	LTA_cfc = 142.028

Source	Reference	Effluent Limit Calculations
PENTOXSD TRG	5.1f	AML_MULT = 1.231
PENTOXSD TRG	5.1g	LIMIT (mg/l) = 0.500
		X LIMIT (mg/l) = 1.635

WLA_afc $(.019/e^{-k \cdot AFC_tc}) + [(AFC_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC_tc}) \dots + Xd + (AFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$

LTAMULT_afc $EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1) \cdot 0.5)$

LTA_afc $wla_afc \cdot LTAMULT_afc$

WLA_cfc $(.011/e^{-k \cdot CFC_tc}) + [(CFC_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC_tc}) \dots + Xd + (CFC_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$

LTAMULT_cfc $EXP((0.5 \cdot LN(cvd^2 / no_samples + 1)) - 2.326 \cdot LN(cvd^2 / no_samples + 1) \cdot 0.5)$

LTA_cfc $wla_cfc \cdot LTAMULT_cfc$

AML_MULT $EXP(2.326 \cdot LN((cvd^2 / no_samples + 1) \cdot 0.5) - 0.5 \cdot LN(cvd^2 / no_samples + 1))$

AVG MON LIMIT $MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) \cdot AML_MULT)$

INST MAX LIMIT $1.5 \cdot ((av_mon_limit / AML_MULT) / LTAMULT_afc)$

$(0.011 / EXP(-K \cdot CFC_tc / 1440)) + ((CFC_Yc \cdot Qs \cdot 0.011) / (1.547 \cdot Qd)) \dots$

$\dots \cdot EXP(-K \cdot CFC_tc / 1440)) + Xd + (CFC_Yc \cdot Qs \cdot Xs / 1.547 \cdot Qd) \cdot (1 - FOS / 100)$

Stream	Chlorine Required	=	perennial	Chlorine Demand	+	Chlorine Residual
Stream	Reach/Node	1	1			
Stream	Flow	Conditions	perennial			
Stream	Code		49224			
Stream	Function					
Samples			30			
reach	outfall	RMI	49.29			
reach	Reach End	RMI	47.75			
reach		feet	8131.2			
drainage		sq miles	806.642			
TRC	limitation	average	mg/L	0.500		
		maximum	mg/L	1.600		
elevation	modelled	feet	1145.49			
elevation	modelled	feet	1142.61			
slope	modelled	foot/foot	0.000			
low flow		cfs/sq mi	0.119			
discharge		mgd	0.0790			
Runoff	Period	hours	24.000			

No chlorine requirements indicated for the Clarion River

stream	flow	cfs	95.99976
stream	flow	MGD	62.046278
stream	flow	total	MGD
stream	chlorine	demand	mg/L
discharge	discharge	demand	mg/L
stream	Total Stream/Waste	ratio	786.4
permitted	TRC	mean	BAT
permitted	TRC	maximum	BAT

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	49224	CLARION RIVER	49.290	1145.49	806.64	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.077	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.20	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Cook Forest SP	PA0034268	0.0790	0.0790	0.0790	0.000	25.00	6.60

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.10	0.00	0.70

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	49224	CLARION RIVER	47.760	1142.61	806.64	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.077	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.20	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

Input Data WQM 7.0

	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
	49224	CLARION RIVER	37.770	1098.17	851.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary		Stream	
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.077	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.20	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
17B		49224				CLARION RIVER						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
Q7-10 Flow												
49.290	62.03	0.00	62.03	.1222	0.00036	1.108	146.05	131.82	0.38	0.243	20.01	7.20
47.760	62.03	0.00	62.03	.1222	0.00084	1.089	141.72	130.12	0.40	1.516	20.01	7.20
Q1-10 Flow												
49.290	39.70	0.00	39.70	.1222	0.00036	NA	NA	NA	0.30	0.312	20.02	7.20
47.760	39.70	0.00	39.70	.1222	0.00084	NA	NA	NA	0.31	1.945	20.02	7.20
Q30-10 Flow												
49.290	84.36	0.00	84.36	.1222	0.00036	NA	NA	NA	0.46	0.205	20.01	7.20
47.760	84.36	0.00	84.36	.1222	0.00084	NA	NA	NA	0.48	1.277	20.01	7.20

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	95.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17B	49224	CLARION RIVER

NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
49.290	Cook Forest SP	13.76	50	13.76	50	0	0
47.760		NA	NA	13.76	NA	NA	NA

NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
49.290	Cook Forest SP	1.72	25	1.72	25	0	0
47.760		NA	NA	1.72	NA	NA	NA

Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
49.29	Cook Forest SP	25	25	25	25	4	4	0	0
47.76		NA	NA	NA	NA	NA	NA	NA	NA

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
17B	49224	CLARION RIVER

<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
49.290	0.079	20.010	7.197
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
146.055	1.108	131.820	0.384
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.05	0.030	0.15	0.701
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.235	0.639	Tsivoglou	5
<u>Reach Travel Time (days)</u>	Subreach Results		
0.243	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.024	2.04	0.15
	0.049	2.04	0.14
	0.073	2.04	0.14
	0.097	2.04	0.14
	0.122	2.04	0.14
	0.146	2.04	0.13
	0.170	2.03	0.13
	0.195	2.03	0.13
	0.219	2.03	0.13
	0.243	2.03	0.13

<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>
47.760	0.079	20.010	7.197
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>
141.717	1.089	130.117	0.403
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>
2.03	0.010	0.03	0.701
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>
8.243	1.583	Tsivoglou	5
<u>Reach Travel Time (days)</u>	Subreach Results		
1.516	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>
			<u>D.O. (mg/L)</u>
	0.152	2.03	0.02
	0.303	2.02	0.02
	0.455	2.02	0.02
	0.606	2.02	0.02
	0.758	2.02	0.02
	0.910	2.01	0.01
	1.061	2.01	0.01
	1.213	2.01	0.01
	1.365	2.00	0.01
	1.516	2.00	0.01

WQM 7.0 Effluent Limits

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
17B		49224		CLARION RIVER			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
49.290	Cook Forest SP	PA0034268	0.079	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4