

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0032751  
 APS ID 1152915  
 Authorization ID 1553282

**Applicant and Facility Information**

Applicant Name	<u>PA DOT Maintenance &amp; Operations Bureau</u>	Facility Name	<u>PA DOT Rest Area 18</u>
Applicant Address	<u>400 North Street 6th Floor Harrisburg, PA 17120-0206</u>	Facility Address	<u>Safety Rest Area Site #18 Hadley, PA 16130</u>
Applicant Contact	<u>Nicholaus Sahd</u>	Facility Contact	<u></u>
Applicant Phone	<u>(717) 951-8685</u>	Facility Phone	<u></u>
Client ID	<u>189304</u>	Site ID	<u>451603</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Deer Creek Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Mercer</u>
Date Application Received	<u>December 23, 2025</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>January 6, 2026</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Renewal Application for a Minor Sewage Facility</u>		

**Summary of Review**

The permittee is applying for reissuance of Individual Permit No. **PA0032751**. The facility consists of a Comminutor w/ a bypass bar screen, Equalization Tank (aerated), (2) Extended Aeration Tanks, Final Clarifier, Aerated Sludge Holding Tank, Chlorine Contact (w/ tablet chlorination/dechlorination)/Post-Aeration Tank and an Effluent Tank.

This is an existing discharge with a design hydraulic capacity of 0.0087-MGD – Black Run.

DMRs have been submitted for the past five years. Only one inspection was conducted on November 20, 2024. During this inspection, an administrative review of the facility was performed, and no violations were identified.

Act 14 – Notifications were submitted and received.

There are 13 open violations in WMS for the subject Client ID (189304) as of 01/06/26. These violations fall within the categories below and are under Storage Tanks and WPC NPDES Inspection program.

- Failure to meet underground storage tank system operational requirements,
- Failure to meet aboveground storage tank protective coating requirements,
- Failure to meet aboveground storage tank secondary and/or emergency containment requirements,
- Failure to meet performance standards for new and/or upgraded underground storage tank systems,
- NPDES - Violation of effluent limits in Part A of permit
- NPDES - Failure to properly operate and maintain all facilities which are installed or used by the permittee to achieve compliance.

Sludge use and disposal description and location(s): 1.76 dry tons of sewage were disposed of at Municipal WWTP for treatment.

Approve	Deny	Signatures	Date
x		Adebayo Olude Adebayo Olude / Civil Engineer Trainee	January 6, 2026
X		Adam Olesnanik Adam Olesnanik, P.E. / Environmental Engineer Manager	March 4, 2026

**Summary of Review**

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.0087</u>
Latitude	<u>41° 28' 20.58"</u>	Longitude	<u>-80° 10' 3.31"</u>
Quad Name	<u>Hadley</u>	Quad Code	<u>41080D2</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Black Run (WWF)</u>	Stream Code	<u>58656</u>
NHD Com ID	<u>100476397</u>	RMI	<u></u>
Drainage Area	<u>3.81</u>	Yield (cfs/mi <sup>2</sup> )	<u>0.0396</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.151</u>	Q <sub>7-10</sub> Basis	<u>USGS StreamStats</u>
Elevation (ft)	<u></u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>16-G</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u></u>	Existing Use Qualifier	<u></u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u></u>		
Source(s) of Impairment	<u></u>		
TMDL Status	<u></u>	Name	<u></u>
Background/Ambient Data			
pH (SU)	<u>7</u>	Data Source	<u>Default - WWF</u>
Temperature (°F)	<u>25</u>		<u>Default</u>
Hardness (mg/L)	<u>100</u>		<u>Default</u>
Other:	<u>-</u>		<u>-</u>
Nearest Downstream Public Water Supply Intake		<u>Aqua Pennsylvania, Inc. - Emlenton</u>	
PWS Waters	<u>Allegheny River</u>	Flow at Intake (cfs)	<u>1,376</u>
PWS RMI	<u>90.0</u>	Distance from Outfall (mi)	<u>&gt;10miles</u>

Changes Since Last Permit Issuance: Elevation was revised using Google Earth. Drainage Area and Q<sub>7-10</sub> Flow were revised using USGS StreamStats.

Other Comments: The streamflow value used for the receiving stream in this renewal is different from the previous permit. According to USGS Stream Stats, the anticipated low-flow (Q<sub>7-10</sub>) for the stream is 0.151cfs, whereas the previous model assumed a low-flow of 0.000258 cfs. The basis for the earlier flow value is due to a default low flow yield of 0.1.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> PA DOT Rest Area 18				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
4317402		05/18/2017		
-		-		
<b>Waste Type</b>	<b>Degree of Treatment</b>	<b>Process Type</b>	<b>Disinfection</b>	<b>Avg Annual Flow (MGD)</b>
Sewage	Secondary	Extended Aeration	Chlorine With Dechlorination	0.0087
<b>Hydraulic Capacity (MGD)</b>				
0.0087	<b>Organic Capacity (lbs/day)</b>	<b>Load Status</b>	<b>Biosolids Treatment</b>	<b>Biosolids Use/Disposal</b>
	17.5	Not Overloaded		

Changes Since Last Permit Issuance: None

Other Comments: None

<b>Compliance History</b>	
<b>Summary of DMRs:</b>	DMRs were submitted for the past five years. Only one inspection was conducted on November 20, 2024. During this inspection, an administrative review of the facility was performed, and no violations were identified.
<b>Summary of Inspections:</b>	Only one inspection was conducted on November 20, 2024. During this inspection, an administrative review of the facility was performed, and no violations were identified.

Other Comments: None

Compliance History

DMR Data for Outfall 001 (from December 1, 2024 to November 30, 2025)

Parameter	NOV-25	OCT-25	SEP-25	AUG-25	JUL-25	JUN-25	MAY-25	APR-25	MAR-25	FEB-25	JAN-25	DEC-24
Flow (MGD) Average Monthly	0.0016	0.0014	0.0026	0.0029	0.0028	0.0025	0.0019	0.0013	0.0014	0.0015	0.0014	0.0018
Flow (MGD) Daily Maximum	0.0019	0.0015	0.0029	0.0032	0.0030	0.0027	0.0025	0.0014	0.0016	0.0017	0.0016	0.0021
pH (S.U.) Daily Minimum	6.9	6.8	6.9	6.8	6.9	6.7	6.9	6.7	6.9	6.9	6.7	6.7
pH (S.U.) Instantaneous Maximum	7.4	7.4	7.4	7.4	7.4	7.4	7.5	7.4	7.4	7.4	7.4	7.4
DO (mg/L) Daily Minimum	6.9	6.8	6.8	6.9	6.9	6.7	6.8	6.7	6.8	6.7	6.7	6.8
TRC (mg/L) Average Monthly	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
TRC (mg/L) Instantaneous Maximum	0.2	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.1
CBOD5 (mg/L) Average Monthly	3.4	4.3	4.0	4.4	3.8	4.1	3.8	4.8	4.1	4.5	4.8	4.6
CBOD5 (mg/L) Instantaneous Maximum	3.4	4.7	4.1	4.6	3.9	4.8	4.6	4.9	4.6	4.9	4.8	4.8
TSS (mg/L) Average Monthly	11.0	11.0	11.0	9.5	10.5	10.5	10.0	11.0	10.5	10.5	11.0	11.0
TSS (mg/L) Instantaneous Maximum	12.0	12.0	12.0	10.0	12.0	11.0	10.0	12.0	12.0	11.0	12.0	12.0
Fecal Coliform (No./100 ml) Average Monthly	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1	< 1
E. Coli (No./100 ml) Instantaneous Maximum												< 1

**NPDES Permit Fact Sheet  
PA DOT Rest Area 18**

**NPDES Permit No. PA0032751**

Total Nitrogen (mg/L) Average Monthly	19.2	19.4	24.1	18.8	19.1	18.5	18.8	19.3	18.7	19.7	19.2	18.7
Ammonia (mg/L) Average Monthly	7.7	7.7	7.6	7.5	7.4	7.5	7.7	7.1	7.4	7.8	7.5	6.8
Ammonia (mg/L) Instantaneous Maximum	7.9	7.9	7.7	7.5	7.8	8.0	7.8	7.2	7.7	7.8	7.8	7.7
Total Phosphorus (mg/L) Average Monthly	0.680	0.580	0.650	0.915	0.730	0.955	0.910	0.695	0.905	0.935	0.950	0.940
Total Phosphorus (mg/L) Instantaneous Maximum	0.910	0.680	0.660	0.990	0.850	0.990	0.980	0.980	0.910	0.970	0.960	0.990

**Development of Effluent Limitations**

<b>Outfall No.</b>	001	<b>Design Flow (MGD)</b>	.0087
<b>Latitude</b>	41° 28' 15.00"	<b>Longitude</b>	-80° 10' 4.00"
<b>Wastewater Description:</b> Sewage Effluent			

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)
E. Coli	Report	IMAX	-	92a.61

Comments: The limits for pH are technology-based on Chapter 93.7. The limits for Total Suspended Solids and Fecal Coliforms are technology-based on Chapter 92a.47. The limit for TRC is applicable under chapter 92a.48. E. Coli was placed in the previous permit in accordance with the Department’s SOP entitled “Establishing Effluent Limitations for Individual Sewage Permits.” With a design flow between 0.002 – 0.05 MGD, a sample frequency of 1/year is being carried forward.

**Water Quality-Based Limitations**

CBOD<sub>5</sub>, Ammonia, and Dissolved oxygen are evaluated using WQM 7.0 (Attachment 3). TRC is evaluated using the Department’s TRC evaluation spreadsheet (Attachment 4).

The following limitations were determined through water quality modeling:

Parameter	Limit (mg/l)	SBC	Model
CBOD <sub>5</sub>	25	Average Monthly	WQM 7.0
	50	IMAX	
NH <sub>3</sub> -N May 1 – Oct 31	8.5	Average Monthly	WQM 7.0
	17.0	IMAX	
NH <sub>3</sub> -N Nov 1 – Apr 30	25.5	Average Monthly	WQM 7.0
	51.0	IMAX	
Dissolved Oxygen	4.0	Daily minimum	WQM 7.0
TRC	0.5	Average Monthly	TRC Spreadsheet Model
	1.6	IMAX	

Comments: This discharge was evaluated using the WQM 7.0 model to determine appropriate effluent limitations for CBOD<sub>5</sub>, Ammonia-Nitrogen, and Dissolved Oxygen. The modeling results confirmed that the current CBOD<sub>5</sub> limitations remain appropriate, and existing Dissolved Oxygen limits are also adequate for the facility. Outfall 001 discharges to a dry stream, thus a dry stream degradation analysis was performed. The modeling results show that the output of the perennial model is equal to the highlighted inputs found in the dry stream model. As a result, the current permit limits are protective. Therefore, more stringent limits are not proposed in this renewal.

The Department's TRC model was performed. The model indicated an average monthly limit of 0.5 mg/L and an IMAX limit of 1.635 mg/L. The average monthly limit from the model is the same as the current limit. Therefore, the limits will be retained and no compliance schedule for TRC will be imposed.

**Best Professional Judgment (BPJ) Limitations**

Comments: None

**Anti-Backsliding**

The previous limits can be used pursuant to EPA's anti-backsliding regulation, 40 CFR 122.44(l). The previous permit limitations, monitoring requirements, and conditions will be retained.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	25.5	XXX	51.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	8.5	XXX	17.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	1.0	XXX	2.0	2/month	Grab

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	Report Daily Max	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report	XXX	XXX	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	25.5	XXX	51.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	8.5	XXX	17.0	2/month	Grab
Total Phosphorus	XXX	XXX	XXX	1.0	XXX	2.0	2/month	Grab

Compliance Sampling Location: Outfall 001 after disinfection


Other Comments: The limits in this renewal are being carried forward from previous permit and therefore retained.

Tools and References Used to Develop Permit	
<input type="checkbox"/>	WQM for Windows Model (see Attachment [redacted])
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	TRC Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [redacted])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [redacted]
<input type="checkbox"/>	Other: [redacted]

**Attachment 1**  
**eMAP – Receiving stream location and Designation**



Attachment 2  
Google Earth Aerial Site View



StreamStats Report

Region ID:


PA

Clicked Point (Latitude, Longitude):

41.47243, -80.16782

Time:

2026-01-06 15:32:56 -0500



StreamStats Update

Starting with version 4.30.0, the StreamStats application uses services that were redeveloped with open-source software components. Users may observe minor variations in computed results when compared to those from previous versions. These differences are expected and do not reflect errors in the underlying data or analytical methods. Users are advised to consider these potential variations when interpreting or comparing results generated across different versions of StreamStats. Please email [streamstats@usgs.gov](mailto:streamstats@usgs.gov) with any questions or concerns. A full list of changes can be found at <https://www.usgs.gov/streamstats/news/streamstats-data-updates-open-source-code-release>.

Collapse All


Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	3.81	square miles
ELEV	Mean Basin Elevation	1406.2	feet
PRECIP	Mean Annual Precipitation	43	inches

StreamStats Report

Region ID:  
Clicked Point (Latitude, Longitude):  
Time:

PA  
41.47310, -80.17026  
2026-01-06 15:30:46 -0500



StreamStats Update

Starting with version 4.30.0, the StreamStats application uses services that were redeveloped with open-source software components. Users may observe minor variations in computed results when compared to those from previous versions. These differences are expected and do not reflect errors in the underlying data or analytical methods. Users are advised to consider these potential variations when interpreting or comparing results generated across different versions of StreamStats. Please email [streamstats@usgs.gov](mailto:streamstats@usgs.gov) with any questions or concerns. A full list of changes can be found at <https://www.usgs.gov/streamstats/news/streamstats-data-updates-open-source-code-release>.

⊕ Collapse All

➤ Basin Characteristics

Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	3.84	square miles
ELEV	Mean Basin Elevation	1405.8	feet
PRECIP	Mean Annual Precipitation	43	inches

**Attachment 3**  
**WQM 7.0 Modeling Output files (dry stream)**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18G	58856	BLACK RUN	2.730	1334.00	3.81	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.040	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
PA Rest Area18	PA0032751	0.0087	0.0087	0.0087	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
COD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	4.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
16G	58656	BLACK RUN	2.560	1328.00	3.84	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	pH	Stream Temp	pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.040	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	2.00	0.00	1.50
Dissolved Oxygen	3.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>			<u>Stream Name</u>							
16G		58656			BLACK RUN							
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
2.730	0.15	0.00	0.15	.0135	0.00668	.384	7.34	19.14	0.06	0.178	20.41	7.00
<b>Q1-10 Flow</b>												
2.730	0.10	0.00	0.10	.0135	0.00668	NA	NA	NA	0.05	0.223	20.61	7.00
<b>Q30-10 Flow</b>												
2.730	0.21	0.00	0.21	.0135	0.00668	NA	NA	NA	0.07	0.152	20.31	7.00

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.38	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 Wasteload Allocations**

**SWP Basin**    **Stream Code**                      **Stream Name**  
16G              58656    BLACK RUN

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	2.730 PA Rest Area18	15.93	50	15.93	50	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
	2.730 PA Rest Area18	1.85	25	1.85	25	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
	2.73 PA Rest Area18	25	25	25	25	4	4	0	0

**WQM 7.0 D.O. Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16G	58656	BLACK RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.730	0.009	20.409	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
7.344	0.384	19.142	0.058	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
3.88	0.740	2.05	0.722	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
7.895	19.211	Owens	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.178	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.018	3.83	2.02	8.07
	0.036	3.78	2.00	8.18
	0.053	3.73	1.97	8.18
	0.071	3.68	1.94	8.18
	0.089	3.63	1.92	8.18
	0.107	3.58	1.90	8.18
	0.125	3.54	1.87	8.18
	0.142	3.49	1.85	8.18
	0.160	3.44	1.82	8.18
	0.178	<b>3.40</b>	<b>1.80</b>	<b>8.18</b>

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16G		58656		BLACK RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.730	PA Rest Area 18	PA0032751	0.009	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			4

**Attachment 3**  
**WQM 7.0 Modeling Output files (Perennial)**

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
18G	58656	BLACK RUN	2.730	1334.00	3.81	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time	Rch Velocity	WD Ratio	Rch Width	Rch Depth	Tributary Temp	Tributary pH	Stream Temp	Stream pH
	(cfsm)	(cfs)	(cfs)	(days)	(fps)		(ft)	(ft)	(°C)		(°C)	
Q7-10	0.040	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

**Discharge Data**

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
PA DOT Area 18	PA0032751	0.0087	0.0087	0.0087	0.000	25.00	7.00

**Parameter Data**

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	3.40	2.00	0.00	1.50
Dissolved Oxygen	8.18	8.24	0.00	0.00
NH3-N	1.80	0.00	0.00	0.70

**WQM 7.0 Hydrodynamic Outputs**

<u>SWP Basin</u>		<u>Stream Code</u>				<u>Stream Name</u>						
16G		58656				BLACK RUN						
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
2.730	0.15	0.00	0.15	.0135	0.00172	.398	7.92	19.93	0.05	0.129	20.41	7.00
<b>Q1-10 Flow</b>												
2.730	0.10	0.00	0.10	.0135	0.00172	NA	NA	NA	0.04	0.162	20.61	7.00
<b>Q30-10 Flow</b>												
2.730	0.20	0.00	0.20	.0135	0.00172	NA	NA	NA	0.06	0.110	20.31	7.00

**WQM 7.0 Modeling Specifications**

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

**WQM 7.0 D.O. Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
16G	58656	BLACK RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>	
2.730	0.009	20.410	7.000	
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>	
7.922	0.398	19.925	0.052	
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>	
2.11	0.182	0.15	0.722	
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>	
8.238	16.662	Owens	5	
<u>Reach Travel Time (days)</u>	<b>Subreach Results</b>			
0.129	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.013	2.11	0.15	8.18
	0.026	2.10	0.15	8.18
	0.039	2.10	0.14	8.18
	0.052	2.09	0.14	8.18
	0.065	2.09	0.14	8.18
	0.077	2.08	0.14	8.18
	0.090	2.08	0.14	8.18
	0.103	2.07	0.14	8.18
	0.116	2.07	0.14	8.18
	0.129	2.06	0.13	8.18

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
16G	58656	BLACK RUN

**NH3-N Acute Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.730	PA DOT Area 18	15.93	3.6	15.93	3.6	0	0

**NH3-N Chronic Allocations**

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
2.730	PA DOT Area 18	1.85	1.8	1.85	1.8	0	0

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
2.73	PA DOT Area 18	3.4	3.4	1.8	1.8	8.18	8.18	0	0

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>		<u>Stream Code</u>		<u>Stream Name</u>			
16G		58656		BLACK RUN			
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.730	PA DOT Area 18	PA0032751	0.009	CBOD5	3.4		
				NH3-N	1.8	3.6	
				Dissolved Oxygen			8.18

Attachment 4

TRC\_CALC

TRC EVALUATION				
Input appropriate values in A3:A9 and D3:D9				
0.151	= Q stream (cfs)	0.5	= CV Daily	
0.0087	= Q discharge (MGD)	0.5	= CV Hourly	
30	= no. samples	1	= AFC_Partial Mix Factor	
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor	
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)	
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)	
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)	
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 3.598		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 1.341		5.1d
				WLA_cfc = 3.500
				LTAMULT_cfc = 0.581
				LTA_cfc = 2.035
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500		BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635		
WLA_afc	(.019/e <sup>-k*AFC_tc</sup> ) + [(AFC_Yc*Qs*.019/Qd*e <sup>-k*AFC_tc</sup> )... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)			
LTAMULT_afc	EXP((0.5*LN(cvh <sup>2</sup> +1))-2.326*LN(cvh <sup>2</sup> +1) <sup>0.5</sup> )			
LTA_afc	wla_afc*LTAMULT_afc			
WLA_cfc	(.011/e <sup>-k*CFC_tc</sup> ) + [(CFC_Yc*Qs*.011/Qd*e <sup>-k*CFC_tc</sup> )... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)			
LTAMULT_cfc	EXP((0.5*LN(cvd <sup>2</sup> /no_samples+1))-2.326*LN(cvd <sup>2</sup> /no_samples+1) <sup>0.5</sup> )			
LTA_cfc	wla_cfc*LTAMULT_cfc			
AML_MULT	EXP(2.326*LN((cvd <sup>2</sup> /no_samples+1) <sup>0.5</sup> )-0.5*LN(cvd <sup>2</sup> /no_samples+1))			
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)			
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)			