

Application Type Renewal
 Facility Type Non-Municipal
 Major / Minor Minor

**NPDES PERMIT FACT SHEET
INDIVIDUAL SEWAGE**

Application No. PA0032824
 APS ID 1117499
 Authorization ID 1491667

Applicant and Facility Information

Applicant Name	<u>PA DOT Bureau of Project Delivery</u>	Facility Name	<u>PA DOT Safety Rest 38</u>
Applicant Address	<u>400 North Street 6th Floor</u>	Facility Address	<u>I-80 Westbound</u>
Applicant Contact	<u>Harrisburg, PA 17105</u>	Facility Contact	<u>Mifflin Twp, PA 17814</u>
Applicant Phone	<u>(717) 951-8685</u>	Facility Phone	<u>(570) 387-4250</u>
Client ID	<u>62162</u>	Site ID	<u>263256</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Mifflin Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Columbia</u>
Date Application Received	<u>July 3, 2024</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>July 11, 2024</u>	If No, Reason	
Purpose of Application	<u>Renewal of a NPDES Permit</u>		



Summary of Review

The subject treated sewage discharge serves Rest Areas 37 and 38 along I-80 in Mifflin Township, Columbia County. A map of the discharge location is attached.

Sludge use and disposal description and location(s): The facility's digested sludge is sent to other facilities for further processing. Per the application 2 dry tons were disposed in the previous year.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
✓		 Keith C. Allison / Project Manager	February 5, 2025
✓		 Nicholas W. Hartranft, P.E. / Environmental Engineer Manager	February 5, 2025

Discharge, Receiving Waters and Water Supply Information

Outfall No. 001
Latitude 41° 0' 49.76"
Quad Name Mifflinville, PA
Wastewater Description: Sewage Effluent

Design Flow (MGD) 0.013
Longitude -76° 15' 8.29"
Quad Code 1035

Receiving Waters Unnamed Tributary to Nescopeck Creek (CWF)
NHD Com ID 65639891
Drainage Area 1.07

Q₇₋₁₀ Flow (cfs) 0.0879
Elevation (ft) 824
Watershed No. 5-D
Existing Use N/A
Exceptions to Use None
Assessment Status Attaining Use(s)
TMDL Status Final

Stream Code 28103
RMI 2.5
Yield (cfs/mi²) 0.0822
Gage No. 1538000.
Wapwallopen Creek @ Wapwallopen, PA
Q₇₋₁₀ Basis 0.018
Slope (ft/ft) Chapter 93 Class.
CWF Existing Use Qualifier
N/A Exceptions to Criteria
None

Name Little Nescopeck Creek

Nearest Downstream Public Water Supply Intake
PWS Waters Susquehanna River
PWS RMI 138.06

Danville Municipal Water Authority
Flow at Intake (cfs) 1511
Distance from Outfall (mi) 27.9

Changes Since Last Permit Issuance: None. The above existing stream and drainage characteristics are adequate and unchanged.

Other Comments: No downstream water supply is expected to be affected by the discharge at this time with the limitations and monitoring proposed.

Treatment Facility Summary				
Treatment Facility Name: PA DOT Rest Area 38 - I-80 West				
WQM Permit No.	Issuance Date			Permit Coverage:
1993401	Original - 4/30/93			Flow Equalization Tank
	A-1 – 12/23/21			Dechlorination
	A-2 – 4/22/24			Plant upgrades
1972401	2/8/07			Liquid Chlorine Disinfection
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary	Extended Aeration	Chlorine With Dechlorination	0.013
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.013	66.7	Not Overloaded	Holding Tank	Landfill

Changes Since Last Permit Issuance: WQM Permit No. 1993401 A-2 was issued on April 22, 2024 for replacing the existing treatment process including comminutor, bar screen, two 8,475-gallons EQ tanks, two 10,510-gallon anoxic tanks, two 8,019-gallon aeration tanks, two final clarifiers, tertiary filtration, UV disinfection, post aeration, and aerated sludge storage.

Other Comments: The existing treatment process consists of equalization, two aeration basins, two clarifiers, two sand filters, chlorination, and two aerated sludge digesters.

Compliance History

DMR Data for Outfall 001 (from January 1, 2024 to December 31, 2024)

Parameter	DEC-24	NOV-24	OCT-24	SEP-24	AUG-24	JUL-24	JUN-24	MAY-24	APR-24	MAR-24	FEB-24	JAN-24
Flow (MGD) Average Monthly	0.00481	0.00464	0.0051	0.00766	0.008	0.00922	0.00727	0.0034	0.00718	0.0061	0.00497	0.00399
pH (S.U.) Instantaneous Minimum	7.19	7.4	7.0	6.51	6.94	6.3	7.0	7.14	6.4	6.4	6.9	6.9
pH (S.U.) Instantaneous Maximum	7.91	8.0	7.86	8.05	8.62	8.0	8.1	7.96	7.7	7.7	8.2	8.2
DO (mg/L) Instantaneous Minimum	7.65	8.63	8.13	7.72	7.61	7.75	5.58	6.0	6.26	6.26	7.06	6.4
TRC (mg/L) Average Monthly	0.1	0.069	0.088	0.21	0.21	0.17	0.06	0.08	0.5	0.07	0.07	0.09
TRC (mg/L) Instantaneous Maximum	0.93	0.35	0.55	0.92	0.94	1.6	0.29	0.34	1.6	0.44	0.5	0.63
CBOD5 (mg/L) Average Monthly	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.71	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
CBOD5 (mg/L) Instantaneous Maximum	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0	4.42	< 3.0	< 3.0	< 3.0	< 3.0	< 3.0
TSS (mg/L) Average Monthly	< 2.2	< 1.8	< 2.6	2.4	< 3.4	< 1.6	< 1.6	< 1.6	< 1.8	3.14	< 1.6	2.4
TSS (mg/L) Instantaneous Maximum	2.8	2.0	3.6	2.4	< 1.6	1.6	4.42	< 1.6	< 2.0	4.67	1.6	3.2
Fecal Coliform (No./100 ml) Geometric Mean	< 1.0	< 1.0	< 1.0	< 156	2.0	4.0	< 13.0	3	7.0	< 2	< 1.0	< 1.0
Fecal Coliform (No./100 ml) Instantaneous Maximum	< 1.0	1.0	< 1.0	2419*	3.1	6.3	161.6	5.2	7.5	< 3	< 1.0	< 1.0
Ammonia (mg/L) Average Monthly	< 3.202	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1488	< 0.1	0.1	1.979	< 0.1	< 0.1	< 0.163
Ammonia (mg/L) Instantaneous Maximum	6.303	< 0.1	< 0.1	0.1	< 0.1	0.1975	< 0.1	0.1	2.08	< 0.1	< 0.1	0.225

*- Effluent Violation

Compliance History, Cont'd

Effluent Violations for Outfall 001, from: February 1, 2024 To: December 31, 2024

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
Fecal Coliform	09/30/24	IMAX	2419	No./100 ml	1000	No./100 ml

Compliance History, Cont'd

Summary of Inspections:	The facility has been inspected approximately annually by the Department over the past permit term. The most recent inspection on January 29, 2025 identified an eDMR effluent violation.
Other Comments:	A query in WMS found open violations for the permittee in eFACTS for the permittee as listed in Attachment B including at this facility for effluent violations.

Existing Effluent Limitations and Monitoring Requirements

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	12.0	XXX	25.0	2/month	Grab

Development of Effluent Limitations

Outfall No. 001 Design Flow (MGD) 0.013
Latitude 41° 0' 53.00" Longitude -76° 15' 8.00"
Wastewater Description: Sewage Effluent

Technology-Based Limitations

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD ₅	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

Comments: The above limits are applicable and are included in the existing permit.

Water Quality-Based Limitations

DO, CBOD₅ and NH₃-N

The WQM7.0 model allows the Department to evaluate point source discharges of dissolved oxygen (DO), carbonaceous BOD (CBOD₅), and ammonia-nitrogen (NH₃-N) into free-flowing streams and rivers. To accomplish this, the model simulates two basic processes: the mixing and degradation of NH₃-N in the stream and the mixing and consumption of DO in the stream due to the degradation of CBOD₅ and NH₃-N. The discharge has an existing water quality-based NH₃-N limitation of 12 mg/L. WQM7.0 modeling was performed (see Attachment C) for the discharge to the Unnamed Tributary to Nescopeck Creek and verified that no limitations are necessary beyond the existing limits.

Total Residual Chlorine

The attached modeling shows that the technology-based limit of 0.5 mg/L is adequate to protect the receiving waters (See Attachment D).

Water Quality Toxics Management

No additional reasonable potential analysis has been performed to determine additional parameters for limitations or monitoring for this minor treatment plant with no industrial flows.

Chesapeake Bay/Nutrient Requirements

A portion of the Chesapeake Bay and many of its tidal tributaries have been listed as impaired under Section 303(d) of the Water Pollution Control Act, 33 U.S.C. §1313(d). Total Nitrogen and Total Phosphorus cap loads have been established for significant dischargers in Pennsylvania to reduce the total nutrient load to the Bay and meet State of Maryland Water Quality Standards. This facility is considered a Phase V, non-significant Chesapeake Bay discharger and as such no nutrient cap loadings have been established for the facility pursuant to the Phase III Watershed Implementation Plan. Because no recent nutrient data is available for the discharge annual nutrient monitoring will be required at this time.

Best Professional Judgment (BPJ) Limitations

Comments: No additional BPJ limits are necessary at this time beyond the water quality and technology-based limits noted above.

E. Coli

Annual e. coli monitoring will be required at this time due to changes to Chapter 93 of the Department's regulations and Department policy.

Anti-Backsliding

No limitations in this proposed draft permit have been made less stringent consistent with the anti-backsliding requirements of the Clean Water Act and 40 CFR 122.44(l).

Proposed Effluent Limitations and Monitoring Requirements

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (386-0400-001), SOPs and/or BPJ.

Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.

Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) ⁽¹⁾		Concentrations (mg/L)				Minimum ⁽²⁾ Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	Continuous	Metered
pH (S.U.)	XXX	XXX	6.0 Inst Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	Report Inst Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.5	XXX	1.6	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
TSS	XXX	XXX	XXX	30.0	XXX	60.0	2/month	Grab
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	25.0	XXX	50.0	2/month	Grab
Ammonia May 1 - Oct 31	XXX	XXX	XXX	12.0	XXX	25.0	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab
Total Phosphorus	XXX	XXX	XXX	XXX	Report Daily Max	XXX	1/year	Grab

Compliance Sampling Location: Outfall 001

Other Comments: E. coli, Total Nitrogen, and Total Phosphorus monitoring is new as mentioned above.


Tools and References Used to Develop Permit	
<input checked="" type="checkbox"/>	WQM for Windows Model (see Attachment C)
<input type="checkbox"/>	Toxics Management Spreadsheet (see Attachment [REDACTED])
<input checked="" type="checkbox"/>	TRC Model Spreadsheet (see Attachment D)
<input type="checkbox"/>	Temperature Model Spreadsheet (see Attachment [REDACTED])
<input type="checkbox"/>	Water Quality Toxics Management Strategy, 361-0100-003, 4/06.
<input checked="" type="checkbox"/>	Technical Guidance for the Development and Specification of Effluent Limitations, 386-0400-001, 10/97.
<input type="checkbox"/>	Policy for Permitting Surface Water Diversions, 386-2000-019, 3/98.
<input checked="" type="checkbox"/>	Policy for Conducting Technical Reviews of Minor NPDES Renewal Applications, 386-2000-018, 11/96.
<input type="checkbox"/>	Technology-Based Control Requirements for Water Treatment Plant Wastes, 386-2183-001, 10/97.
<input type="checkbox"/>	Technical Guidance for Development of NPDES Permit Requirements Steam Electric Industry, 386-2183-002, 12/97.
<input type="checkbox"/>	Pennsylvania CSO Policy, 386-2000-002, 9/08.
<input type="checkbox"/>	Water Quality Antidegradation Implementation Guidance, 391-0300-002, 11/03.
<input type="checkbox"/>	Implementation Guidance Evaluation & Process Thermal Discharge (316(a)) Federal Water Pollution Act, 386-2000-008, 4/97.
<input checked="" type="checkbox"/>	Determining Water Quality-Based Effluent Limits, 386-2000-004, 12/97.
<input checked="" type="checkbox"/>	Implementation Guidance Design Conditions, 386-2000-007, 9/97.
<input checked="" type="checkbox"/>	Technical Reference Guide (TRG) WQM 7.0 for Windows, Wasteload Allocation Program for Dissolved Oxygen and Ammonia Nitrogen, Version 1.0, 386-2000-016, 6/2004.
<input type="checkbox"/>	Interim Method for the Sampling and Analysis of Osmotic Pressure on Streams, Brines, and Industrial Discharges, 386-2000-012, 10/1997.
<input type="checkbox"/>	Implementation Guidance for Section 95.6 Management of Point Source Phosphorus Discharges to Lakes, Ponds, and Impoundments, 386-2000-009, 3/99.
<input type="checkbox"/>	Technical Reference Guide (TRG) PENTOXSD for Windows, PA Single Discharge Wasteload Allocation Program for Toxics, Version 2.0, 386-2000-015, 5/2004.
<input checked="" type="checkbox"/>	Implementation Guidance for Section 93.7 Ammonia Criteria, 386-2000-022, 11/97.
<input type="checkbox"/>	Policy and Procedure for Evaluating Wastewater Discharges to Intermittent and Ephemeral Streams, Drainage Channels and Swales, and Storm Sewers, 386-2000-013, 4/2008.
<input checked="" type="checkbox"/>	Implementation Guidance Total Residual Chlorine (TRC) Regulation, 386-2000-011, 11/1994.
<input type="checkbox"/>	Implementation Guidance for Temperature Criteria, 386-2000-001, 4/09.
<input type="checkbox"/>	Implementation Guidance for Section 95.9 Phosphorus Discharges to Free Flowing Streams, 386-2000-021, 10/97.
<input type="checkbox"/>	Implementation Guidance for Application of Section 93.5(e) for Potable Water Supply Protection Total Dissolved Solids, Nitrite-Nitrate, Non-Priority Pollutant Phenolics and Fluorides, 386-2000-020, 10/97.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Determining Stream and Point Source Discharge Design Hardness, 386-2000-005, 3/99.
<input type="checkbox"/>	Implementation Guidance for the Determination and Use of Background/Ambient Water Quality in the Determination of Wasteload Allocations and NPDES Effluent Limitations for Toxic Substances, 386-2000-010, 3/1999.
<input checked="" type="checkbox"/>	Design Stream Flows, 386-2000-003, 9/98.
<input type="checkbox"/>	Field Data Collection and Evaluation Protocol for Deriving Daily and Hourly Discharge Coefficients of Variation (CV) and Other Discharge Characteristics, 386-2000-006, 10/98.
<input type="checkbox"/>	Evaluations of Phosphorus Discharges to Lakes, Ponds and Impoundments, 386-3200-001, 6/97.
<input checked="" type="checkbox"/>	Pennsylvania's Chesapeake Bay Tributary Strategy Implementation Plan for NPDES Permitting, 4/07.
<input type="checkbox"/>	SOP: [REDACTED]
<input type="checkbox"/>	Other: [REDACTED]

Attachments:

- Discharge Location Map
- List of Open Violations
- WQM7.0 Model
- TRC Model

PA DOT Rest Area 38

NPDES Permit No. PA0032824
Mifflin Twp, Columbia Co.



Google Earth

Image © 2025 Airbus

Image © 2025 Airbus

Open Violations for Client ID#62162

FACILITY	INSP PROGRAM	PROGRAM	VIOLATION		INSP REGION
		SPECIFIC ID	DATE	VIOLATION	
PA DOT WESTMORELAND CNTY RD SYS	WRM Water Obstructions & Encroachments	E65-556	1/14/2025	105.44 [693.9/693.18] Permittee has failed to perform work according to specifications as approved.	SWRO
PA DOT REST AREA 38 - I-80 WEST	WPC NPDES	PA0032824	1/29/2025	NPDES - Violation of effluent limits in Part A of permit	NCRO

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05D	28103	Trib 28103 to Nescopeck Creek			2.500	824.00	1.07	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.082	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
	PADOT 38	PA0032824	0.0130	0.0000	0.0000	0.000	25.00	7.00		
Parameter Data										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	3.00	8.24	0.00	0.00					
	NH3-N	12.00	0.00	0.00	0.70					

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name			RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
05D	28103	Trib 28103 to Nescopeck Creek			1.500	729.00	1.51	0.00000	0.00	<input checked="" type="checkbox"/>
Stream Data										
Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	Stream pH (°C)
Q7-10	0.082	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.00
Q1-10		0.00	0.00	0.000	0.000					
Q30-10		0.00	0.00	0.000	0.000					
Discharge Data										
	Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH		
			0.0000	0.0000	0.0000	0.000	25.00	7.00		
Parameter Data										
	Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)					
	CBOD5	25.00	2.00	0.00	1.50					
	Dissolved Oxygen	3.00	8.24	0.00	0.00					
	NH3-N	25.00	0.00	0.00	0.70					

WQM 7.0 Hydrodynamic Outputs

<u>SWP Basin</u>			<u>Stream Code</u>			<u>Stream Name</u>						
05D			28103			Trib 28103 to Nescopeck Creek						
RMI	Stream Flow	PWS With	Net Stream Flow	Disc Analysis Flow	Reach Slope	Depth	Width	W/D Ratio	Velocity	Reach Trav Time	Analysis Temp	Analysis pH
	(cfs)	(cfs)	(cfs)	(cfs)	(ft/ft)	(ft)	(ft)		(fps)	(days)	(°C)	
Q7-10 Flow												
2.500	0.09	0.00	0.09	.0201	0.01799	.354	4.61	13.02	0.07	0.923	20.93	7.00
Q1-10 Flow												
2.500	0.06	0.00	0.06	.0201	0.01799	NA	NA	NA	0.05	1.121	21.32	7.00
Q30-10 Flow												
2.500	0.12	0.00	0.12	.0201	0.01799	NA	NA	NA	0.08	0.799	20.72	7.00

WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	6		

WQM 7.0 D.O.Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
05D	28103	Trib 28103 to Nescopeck Creek		
<u>RMI</u> 2.500	<u>Total Discharge Flow (mgd)</u> 0.013	<u>Analysis Temperature (°C)</u> 20.931	<u>Analysis pH</u> 7.000	
<u>Reach Width (ft)</u> 4.610	<u>Reach Depth (ft)</u> 0.354	<u>Reach WDRatio</u> 13.023	<u>Reach Velocity (fps)</u> 0.066	
<u>Reach CBOD5 (mg/L)</u> 6.28	<u>Reach Kc (1/days)</u> 0.867	<u>Reach NH3-N (mg/L)</u> 2.23	<u>Reach Kn (1/days)</u> 0.752	
<u>Reach DO (mg/L)</u> 7.267	<u>Reach Kr (1/days)</u> 24.572	<u>Kr Equation</u> Owens	<u>Reach DO Goal (mg/L)</u> 6	
<u>Reach Travel Time (days)</u> 0.923	<u>Subreach Results</u>			
	TravTime (days)	CBOD5 (mg/L)	NH3-N (mg/L)	D.O. (mg/L)
	0.092	5.78	2.08	8.10
	0.185	5.31	1.94	8.10
	0.277	4.89	1.81	8.10
	0.369	4.50	1.69	8.10
	0.461	4.14	1.58	8.10
	0.554	3.81	1.47	8.10
	0.646	3.50	1.37	8.10
	0.738	3.22	1.28	8.10
	0.831	2.96	1.20	8.10
	0.923	2.72	1.12	8.10

WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>		<u>Stream Code</u>	<u>Stream Name</u>						
05D	28103	Trib 28103 to Nescopeck Creek							
NH3-N Acute Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
2.500	PADOT 38	15.03	24	15.03	24	0	0		
NH3-N Chronic Allocations									
RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction		
2.500	PADOT 38	1.8	12	1.8	12	0	0		
Dissolved Oxygen Allocations									
RMI	Discharge Name	CBOD5 Baseline (mg/L)	CBOD5 Multiple (mg/L)	NH3-N Baseline (mg/L)	NH3-N Multiple (mg/L)	Dissolved Oxygen Baseline (mg/L)	Dissolved Oxygen Multiple (mg/L)	Critical Reach	Percent Reduction
2.50	PADOT 38	25	25	12	12	3	3	0	0

WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
05D	28103	Trib 28103 to Nescopeck Creek					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
2.500	PADOT 38	PA0032824	0.013	CBOD5	25		
				NH3-N	12	24	
				Dissolved Oxygen			3

TRC_CALC

TRC EVALUATION

Input appropriate values in A3:A9 and D3:D9

0.0879	= Q stream (cfs)	0.5	= CV Daily
0.013	= Q discharge (MGD)	0.5	= CV Hourly
30	= no. samples	1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream	1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge	15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value	720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)		=Decay Coefficient (K)
Source	Reference	AFC Calculations	CFC Calculations
TRC	1.3.2.iii	WLA_afc = 1.413	1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373	5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.527	5.1d
Source	Effluent Limit Calculations		
PENTOXSD TRG	5.1f	AML MULT = 1.231	
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.500	BAT/BPJ
		INST MAX LIMIT (mg/l) = 1.635	
WLA_afc	(.019/e(-k*AFC_tc)) + [(AFC_Yc*Qs*.019/Qd*e(-k*AFC_tc))... ...+ Xd + (AFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT_afc	EXP((0.5*LN(cvh^2+1))-2.326*LN(cvh^2+1)^0.5)		
LTA_afc	wla_afc*LTAMULT_afc		
WLA_cfc	(.011/e(-k*CFC_tc)) + [(CFC_Yc*Qs*.011/Qd*e(-k*CFC_tc))... ...+ Xd + (CFC_Yc*Qs*Xs/Qd)]*(1-FOS/100)		
LTAMULT_cfc	EXP((0.5*LN(cvd^2/no_samples+1))-2.326*LN(cvd^2/no_samples+1)^0.5)		
LTA_cfc	wla_cfc*LTAMULT_cfc		
AML MULT	EXP(2.326*LN((cvd^2/no_samples+1)^0.5)-0.5*LN(cvd^2/no_samples+1))		
AVG MON LIMIT	MIN(BAT_BPJ,MIN(LTA_afc,LTA_cfc)*AML_MULT)		
INST MAX LIMIT	1.5*((av_mon_limit/AML_MULT)/LTAMULT_afc)		