

Application Type Renewal  
 Facility Type Non-Municipal  
 Major / Minor Minor

**NPDES PERMIT FACT SHEET  
INDIVIDUAL SEWAGE**

Application No. PA0032913  
 APS ID 1028929  
 Authorization ID 1336935

**Applicant and Facility Information**

Applicant Name	<u>Scenic MHP, LLC</u>	Facility Name	<u>Scenic MHP STP</u>
Applicant Address	<u>24 Bogle Avenue</u> <u>North Arlington, NJ 07031-4726</u>	Facility Address	<u>156 Shenango Park Road</u> <u>Transfer, PA 16154</u>
Applicant Contact	<u>Nicholas Burgagni</u>	Facility Contact	<u>Marvin McAfoose</u>
Applicant Phone	<u>(201) 424-3202</u>	Facility Phone	<u>(724) 699-4070</u>
Client ID	<u>302782</u>	Site ID	<u>244061</u>
Ch 94 Load Status	<u>Not Overloaded</u>	Municipality	<u>Pymatuning Township</u>
Connection Status	<u>No Limitations</u>	County	<u>Mercer</u>
Date Application Received	<u>November 30, 2020</u>	EPA Waived?	<u>Yes</u>
Date Application Accepted	<u>December 14, 2020</u>	If No, Reason	<u>-</u>
Purpose of Application	<u>Individual NPDES permit renewal for a minor sewage facility.</u>		

**Summary of Review**

Act 14 – Proof of notification were submitted and received.

There are two open violations for subject client no. 302782 for exceeding part A effluent limitations as of 12/17/2021. A COA will be executed with the issuance of the final permit, which will resolve the two open violations.

Monitoring frequencies for DO, pH, and TRC are being increased from 1/week on the previous renewal to 1/day in order to comply with Table 6-3 from the Permit Writers Manual and current department practices.

This facility is currently submitting eDMR reports.

Sludge use and disposal description and location(s): Septage must be pumped and hauled off-site by a septage hauler for land application under a general permit authorized by DEP or disposal at an STP.

Public Participation

DEP will publish notice of the receipt of the NPDES permit application and a tentative decision to issue the individual NPDES permit in the *Pennsylvania Bulletin* in accordance with 25 Pa. Code § 92a.82. Upon publication in the *Pennsylvania Bulletin*, DEP will accept written comments from interested persons for a 30-day period (which may be extended for one additional 15-day period at DEP's discretion), which will be considered in making a final decision on the application. Any person may request or petition for a public hearing with respect to the application. A public hearing may be held if DEP determines that there is significant public interest in holding a hearing. If a hearing is held, notice of the hearing will be published in the *Pennsylvania Bulletin* at least 30 days prior to the hearing and in at least one newspaper of general circulation within the geographical area of the discharge.

Approve	Deny	Signatures	Date
X		Jon F. Bucha Jonathan F. Bucha / Civil Engineer General	December 17, 2021
X		Justin C. Dickey Justin C. Dickey, P.E. / Environmental Engineer Manager	December 22, 2021

Discharge, Receiving Waters and Water Supply Information			
Outfall No.	<u>001</u>	Design Flow (MGD)	<u>.02</u>
Latitude	<u>41° 18' 29"</u>	Longitude	<u>-80° 25' 59"</u>
Quad Name	<u>Sharpsville</u>	Quad Code	<u>0802</u>
Wastewater Description: <u>Sewage Effluent</u>			
Receiving Waters	<u>Brush Run (WWF)</u>	Stream Code	<u>36035</u>
NHD Com ID	<u>130034224</u>	RMI	<u>0.565</u>
Drainage Area	<u>4.0 mi<sup>2</sup></u>	Yield (cfs/mi <sup>2</sup> )	<u>0.011</u>
Q <sub>7-10</sub> Flow (cfs)	<u>0.044</u>	Q <sub>7-10</sub> Basis	<u>Pymatuning Ck @ Orangeville</u>
Elevation (ft)	<u>925 (Google Earth)</u>	Slope (ft/ft)	<u>-</u>
Watershed No.	<u>20-A</u>	Chapter 93 Class.	<u>WWF</u>
Existing Use	<u>-</u>	Existing Use Qualifier	<u>-</u>
Exceptions to Use	<u>-</u>	Exceptions to Criteria	<u>-</u>
Assessment Status	<u>Attaining Use(s)</u>		
Cause(s) of Impairment	<u>-</u>		
Source(s) of Impairment	<u>-</u>		
TMDL Status	<u>-</u>	Name	<u>-</u>
Background/Ambient Data		Data Source	
pH (SU)	<u>7.6</u>		<u>8/13/86 dry stream determination for Sunnyview MHP</u>
Temperature (°C)	<u>25</u>		<u>WWF</u>
Hardness (mg/L)	<u>-</u>		<u>-</u>
Other: NH <sub>3</sub> -N	<u>0.1</u>		<u>default</u>
Nearest Downstream Public Water Supply Intake	<u>Aqua PA Shenango Valley</u>		
PWS Waters	<u>Shenango River</u>	Flow at Intake (cfs)	<u>143.8</u>
PWS RMI	<u>28.88</u>	Distance from Outfall (mi)	<u>6</u>

Changes Since Last Permit Issuance: Updates were made to drainage areas and elevations using the most recent versions of Streamstats and Google Earth.

The 24-hour discharge flow used to calculate the Sunnyview MHP dry stream reach on the previous permit renewal was 0.058 mgd, which resulted from converting the 16-hour flow twice from the permitted design flow of 0.025 mgd. This was corrected on this permit renewal (i.e. 24 hr flow = 0.025 \* 24/16 = 0.038 mgd), therefore the dry stream reach for Sunnyview MHP was re-modeled on this permit renewal. The difference in outcome was negligible.

Other Comments: This treatment facility is capable of meeting effluent requirements with proper maintenance and operation.

Treatment Facility Summary				
<b>Treatment Facility Name:</b> Scenic MHP				
<b>WQM Permit No.</b>		<b>Issuance Date</b>		
4311401 T-1		Sep 24, 2013		
4311401		June 12, 2011		
Waste Type	Degree of Treatment	Process Type	Disinfection	Avg Annual Flow (MGD)
Sewage	Secondary With Ammonia Reduction	Activated Sludge	Hypochlorite	0.02
Hydraulic Capacity (MGD)	Organic Capacity (lbs/day)	Load Status	Biosolids Treatment	Biosolids Use/Disposal
0.02	34	Not Overloaded	Concentration	Other WWTP

Changes Since Last Permit Issuance: No changes to the treatment facility since the previous permit renewal.

Other Comments: Treatment consists of a comminutor with bar screen, extended aeration, clarifier, sludge handling, chlorination (liquid feed) and dichlorination (sodium sulfate).

WQM permit no. 368S030 was canceled on September 25, 2013, due to all components of the treatment facility now being permitted under WQM permit no. 4311401 T-1.

Compliance History

DMR Data for Outfall 001 (from November 1, 2020 to October 31, 2021)

Parameter	OCT-21	SEP-21	AUG-21	JUL-21	JUN-21	MAY-21	APR-21	MAR-21	FEB-21	JAN-21	DEC-20	NOV-20
Flow (MGD) Average Monthly	0.003	0.0025	0.002	0.003	0.003	0.003	0.0024	0.0026	0.002	0.003	0.003	0.003
pH (S.U.) Minimum	7.38	7.54	6.92	7.32	7.08	7.35	6.24	6.53	6.54	6.11	6.51	6.08
pH (S.U.) Maximum	7.81	8.20	7.74	7.81	7.52	7.93	7.58	7.56	7.95	6.71	7.08	6.78
DO (mg/L) Minimum	4.39	4.49	4.10	4.18	4.28	5.89	8.76	6.54	4.14	4.08	4.08	4.23
TRC (mg/L) Average Monthly	0.21	0.226	0.14	0.13	0.17	0.19	0.16	0.24	0.19	0.19	0.18	0.20
TRC (mg/L) Instantaneous Maximum	0.36	0.48	0.25	0.24	0.25	0.26	0.23	0.32	0.24	0.24	0.24	0.31
CBOD5 (mg/L) Average Monthly	2.47	4.04	2.43	2.96	3.52	3.5	25	4.1	2.1	2.6	2.1	2.0
TSS (mg/L) Average Monthly	4.5	3.0	3.5	5.83	3.75	7.0	32.5	4.5	26.0	4.5	9.0	8.5
Fecal Coliform (No./100 ml) Geometric Mean	1	1	1	1	1	1	1	1	1	1	1	1
Fecal Coliform (No./100 ml) Instantaneous Maximum	1	1	1	1	1	1	1	1	1	1	1	1
Total Nitrogen (mg/L) Average Monthly		7.54			6.64			14.2			17.95	
Ammonia (mg/L) Average Monthly	3.2	0.1	6.21	9.74	3.47	2.02	8.7	9.7	8.68	0.19	1.05	0.18
Total Phosphorus (mg/L) Average Monthly		1.35			1.71			1.65			1.06	

**Compliance History**

**Effluent Violations for Outfall 001, for: 2020 and 2021**

Parameter	Date	SBC	DMR Value	Units	Limit Value	Units
TRC	03/31/21	Avg Mo	0.24	mg/L	0.23	mg/L
TSS	04/30/21	Avg Mo	32.5	mg/L	30	mg/L
Ammonia	06/30/21	Avg Mo	3.47	mg/L	2.5	mg/L
Ammonia	04/30/21	Avg Mo	8.7	mg/L	7.5	mg/L
Ammonia	10/31/21	Avg Mo	3.2	mg/L	2.5	mg/L
Ammonia	08/31/21	Avg Mo	6.21	mg/L	2.5	mg/L
Ammonia	03/31/21	Avg Mo	9.7	mg/L	7.5	mg/L
Ammonia	02/28/21	Avg Mo	8.68	mg/L	7.5	mg/L
Ammonia	07/31/21	Avg Mo	9.74	mg/L	2.5	mg/L
Ammonia	10/31/2020	Avg Mo	2.66	mg/L	2.5	mg/L
TSS	10/31/2020	Avg Mo	43	mg/L	30	mg/L
Ammonia	9/30/2020	Avg Mo	6.7	mg/L	2.5	mg/L
Fecal	7/31/2020	imax	2419	No./100 mL	1000	No./100 mL
Ammonia	7/31/2020	Avg Mo	6.6	mg/L	2.5	mg/L
Ammonia	5/31/2020	Avg Mo	7	mg/L	2.5	mg/L
Dissolved Oxygen	4/30/2020	Minimum	3.39	mg/L	4	mg/L

Summary of Inspections: A site inspection on 5/29/2020 resulted in numerous violations for this treatment facility listed in Table A on the following page. A follow up inspection on 11/30/2021, which noted violations were not addressed.

Other Comments: The operator has discussed the possibility of fertilizer from the adjacent golf course infiltrating the effluent and being a cause of effluent violations. Influent sampling would have to be conducted to determine if there are any differences during normal influent flow compared to influent flow during periods of inflow and infiltration.

**Table A: Violations from Compliance Inspection on 5/29/2020**

1. **25 Pa. Code 271.918:** Failure to maintain sludge records for at least 5 years.  
Sludge hauling manifests were requested and not provided. Only Sewage Sludge / Biosolids Production and Disposal Supplemental Reports from the end of 2014 & for 2015 were provided at the inspection.
2. **25 Pa. Code 302.1201:** Circuit rider failed to make available the general work plan and/or the system specific management plan.  
General Work Plan was not available.
3. **25 Pa. Code 302.1201:** Circuit rider failed to make available the general work plan and/or the system specific management plan.  
System Specific Management Plan was not available.
4. **25 Pa. Code 302.1202:** Owner failed to provide a copy of current NPDES/WQM permit to all available operators.  
A copy of current permits should be provided to the operator.
5. **25 Pa. Code 302.1202:** Operator failed to comply with the Act or Chapter 302 regulations  
Any violations should be reported to the responsible official.
6. **25 Pa. Code 91.21:** Failure to apply for and/or obtain a WQM permit for the construction or installation of facilities or equipment  
An application to amend WQM Permit 4311401 is required to continue using the erosion chlorinator.
7. **25 Pa. Code 92a.41(a)(12):** Failure to notify DEP of planned physical changes to a facility  
Requirements for WQM Permit amendment were discussed.
8. **25 Pa. Code 92a.41(a)(12):** Failure to submit monitoring reports or properly complete monitoring reports.  
Required supplemental reports were discussed and provided via email.
9. **25 Pa. Code 92a.41(a)(12):** Failure to submit a required DMR supplemental report.  
Sewage Sludge/Biosolids Production & Disposal Supplemental Reports are not being submitted monthly as required.
10. **25 Pa. Code 92a.41(a)(5):** Failure to maintain permitted treatment units in operable condition  
Only one of two blowers is operational; a new motor and started switch are needed. The operator indicated the owner will be notified to initiate repairs.
11. **25 Pa. Code 92a.61(c):** Failure to monitor pollutants as required by the NPDES permit.  
Permit requires 8-hour composite samples for some parameters. Operator indicated composite samples consist of only 2 grabs.  
Manual, flow proportioned composite sampling guidance has been provided to the operator in the past.
12. **P.L. 1987, No. 394, Sec 611:** Failure to comply with the terms and conditions of a WQM permit  
An erosion chlorinator was installed in place of the originally installed liquid chlorine feed system.

**Development of Effluent Limitations**

Outfall No. 001 Design Flow (MGD) .02  
 Latitude 41° 18' 29" Longitude -80° 25' 59"  
 Wastewater Description: Sewage Effluent

**Technology-Based Limitations**

The following technology-based limitations apply, subject to water quality analysis and BPJ where applicable:

Pollutant	Limit (mg/l)	SBC	Federal Regulation	State Regulation
CBOD <sub>5</sub>	25	Average Monthly	133.102(a)(4)(i)	92a.47(a)(1)
	40	Average Weekly	133.102(a)(4)(ii)	92a.47(a)(2)
Total Suspended Solids	30	Average Monthly	133.102(b)(1)	92a.47(a)(1)
	45	Average Weekly	133.102(b)(2)	92a.47(a)(2)
pH	6.0 – 9.0 S.U.	Min – Max	133.102(c)	95.2(1)
Fecal Coliform (5/1 – 9/30)	200 / 100 ml	Geo Mean	-	92a.47(a)(4)
Fecal Coliform (5/1 – 9/30)	1,000 / 100 ml	IMAX	-	92a.47(a)(4)
Fecal Coliform (10/1 – 4/30)	2,000 / 100 ml	Geo Mean	-	92a.47(a)(5)
Fecal Coliform (10/1 – 4/30)	10,000 / 100 ml	IMAX	-	92a.47(a)(5)
Total Residual Chlorine	0.5	Average Monthly	-	92a.48(b)(2)

**Water Quality-Based Limitations**

The following limitations were determined through water quality modeling (output files attached):

Parameter	Limit (mg/l)	SBC	Model
Ammonia Nitrogen (May 1 – Oct 31)	2.2	Avg Monthly	WQM 7.0 (v1.1)
Ammonia Nitrogen (Nov 1 – Apr 30)	6.6	Avg Monthly	WQM 7.0 (v1.1)
Total Residual Chlorine	0.21	Avg Monthly	TRC_Calc Spreadsheet
Total Residual Chlorine	0.5	imax	TRC Spreadsheet (2016)

Comments: Water quality modeling for ammonia nitrogen has determined that an effluent limitation of 2.2 mg/L is required to protect the stream quality. Wintertime ammonia nitrogen limits were determined by using a seasonal multiplier of 3 times the summertime average monthly limit according to the Establishing Effluent Limitations SOP.

TRC limits on the previous permit renewal were 0.23 mg/L average monthly with an imax of 0.5 mg/L. Calculations for this permit renewal has an average monthly TRC limit of 0.21 mg/L and 0.70 mg/L imax. The TRC imax will continue the 0.5 mg/L limit from the previous renewal in order to continue protecting the stream uses and considering eDMR data.

**Best Professional Judgment (BPJ) Limitations**

Comments: Monitoring for Total Nitrogen, Total Phosphorus, and E. Coli is based on Ch. 92a.61 and the Departments SOP for Establishing Effluent Limitations for Individual Sewage Permits (SOP No. BPNPSM-PMT-033). E. Coli monitoring of 1/year is a new addition to this permit renewal. Total Nitrogen and Total Phosphorus monitoring frequencies will remain at 2/quarter based on eDMR data and compliance history. The two quarterly samples are to be collected within the same calendar month. Quarterly sampling is based on the calendar quarter.

**Anti-Backsliding**

Anti-Backsliding considerations do not apply since the effluent limitations have not been relaxed from the previous permit renewal.

**Proposed Effluent Limitations and Monitoring Requirements**

The limitations and monitoring requirements specified below are proposed for the draft permit, and reflect the most stringent limitations amongst technology, water quality and BPJ. Instantaneous Maximum (IMAX) limits are determined using multipliers of 2 (conventional pollutants) or 2.5 (toxic pollutants). Sample frequencies and types are derived from the "NPDES Permit Writer's Manual" (362-0400-001), SOPs and/or BPJ.

**Outfall 001, Effective Period: Permit Effective Date through Permit Expiration Date.**


Parameter	Effluent Limitations						Monitoring Requirements	
	Mass Units (lbs/day) <sup>(1)</sup>		Concentrations (mg/L)				Minimum <sup>(2)</sup> Measurement Frequency	Required Sample Type
	Average Monthly	Average Weekly	Minimum	Average Monthly	Maximum	Instant. Maximum		
Flow (MGD)	Report	XXX	XXX	XXX	XXX	XXX	1/week	Measured
pH (S.U.)	XXX	XXX	6.0 Daily Min	XXX	XXX	9.0	1/day	Grab
DO	XXX	XXX	4.0 Daily Min	XXX	XXX	XXX	1/day	Grab
TRC	XXX	XXX	XXX	0.21	XXX	0.5	1/day	Grab
CBOD5	XXX	XXX	XXX	25.0	XXX	50	2/month	8-Hr Composite
TSS	XXX	XXX	XXX	30.0	XXX	60	2/month	8-Hr Composite
Fecal Coliform (No./100 ml) Oct 1 - Apr 30	XXX	XXX	XXX	2000 Geo Mean	XXX	10000	2/month	Grab
Fecal Coliform (No./100 ml) May 1 - Sep 30	XXX	XXX	XXX	200 Geo Mean	XXX	1000	2/month	Grab
E. Coli (No./100 ml)	XXX	XXX	XXX	XXX	XXX	Report	1/year	Grab
Total Nitrogen	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	2/quarter*	8-Hr Composite
Ammonia Nov 1 - Apr 30	XXX	XXX	XXX	6.6	XXX	13.2	2/month	8-Hr Composite
Ammonia May 1 - Oct 31	XXX	XXX	XXX	2.2	XXX	4.4	2/month	8-Hr Composite
Total Phosphorus	XXX	XXX	XXX	Report Avg Qrtly	XXX	XXX	2/quarter*	8-Hr Composite

Compliance Sampling Location: Outfall 001 after disinfection.

\* The two quarterly samples shall be collected within the same calendar month. Quarterly sampling shall be based on the calendar quarter.



### Attachment A – eMAP Stream Designation



## ATTACHMENT B

### StreamStats REPORT – RMI 0.565 On Brush Run

Region ID:	PA
Workspace ID:	PA20211207150128582000
Clicked Point (Latitude, Longitude):	41.30719, -80.43443
Time:	2021-12-07 10:01:47 -0500




Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	4	square miles
ELEV	Mean Basin Elevation	1072	feet

## ATTACHMENT C

### StreamStats REPORT – RMI 0.47 On Brush Run

Region ID: PA  
 Workspace ID: PA20211207150622434000  
 Clicked Point (Latitude, Longitude): 41.30545, -80.43347  
 Time: 2021-12-07 10:06:42 -0500



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	4.09	square miles
ELEV	Mean Basin Elevation	1071	feet

## ATTACHMENT D

### StreamStats REPORT – RMI 0.001 On Brush Run

Region ID:	PA
Workspace ID:	PA20211207151212209000
Clicked Point (Latitude, Longitude):	41.30010, -80.43396
Time:	2021-12-07 10:12:33 -0500



Basin Characteristics			
Parameter Code	Parameter Description	Value	Unit
DRNAREA	Area that drains to a point on a stream	4.24	square miles
ELEV	Mean Basin Elevation	1068	feet

**ATTACHMENT E**  
**WQM 7.0 MODEL OUTPUT FILE**

**WQM 7.0 Effluent Limits**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20A	36035	BRUSH RUN					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.565	Scenic MHP	PA0032913	0.000	CBOD5	25		
				NH3-N	2.28	4.56	
				Dissolved Oxygen			3
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.470	Sunnyview MHP	PA0032905	0.000	CBOD5	24.57		
				NH3-N	1.89	3.78	
				Dissolved Oxygen			4

**WQM 7.0 D.O.Simulation**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>		
20A	36035	BRUSH RUN		
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.565	0.030	22.433		7.421
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
5.956	0.350	17.008		0.043
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
13.81	1.382	1.22		0.844
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
5.209	19.552	Owens		5
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.134	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.013	13.52	1.21	5.60
	0.027	13.25	1.19	5.91
	0.040	12.97	1.18	6.15
	0.054	12.71	1.17	6.35
	0.067	12.45	1.15	6.51
	0.080	12.19	1.14	6.64
	0.094	11.94	1.13	6.75
	0.107	11.70	1.11	6.84
	0.121	11.46	1.10	6.91
	0.134	11.22	1.09	6.98
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>		<u>Analysis pH</u>
0.470	0.068	21.498		7.451
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>		<u>Reach Velocity (fps)</u>
7.076	0.378	18.707		0.056
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>		<u>Reach Kn (1/days)</u>
16.39	1.417	1.40		0.786
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>		<u>Reach DO Goal (mg/L)</u>
5.817	19.718	Owens		5
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>			
0.511	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>
	0.051	15.16	1.34	6.47
	0.102	14.03	1.29	6.81
	0.153	12.99	1.24	7.01
	0.204	12.02	1.19	7.17
	0.255	11.12	1.14	7.30
	0.306	10.29	1.10	7.41
	0.358	9.52	1.05	7.52
	0.409	8.81	1.01	7.54
	0.460	8.16	0.97	7.54
	0.511	7.55	0.93	7.54

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36035	BRUSH RUN	0.565	925.00	4.00	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.011	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.60	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Scenic MHP	PA0032913	0.0000	0.0000	0.0300	0.000	20.00	7.30

Parameter Data					
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)	
CBOD5	25.00	2.00	0.00	1.50	
Dissolved Oxygen	3.00	7.54	0.00	0.00	
NH3-N	25.00	0.10	0.00	0.70	

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36035	BRUSH RUN	0.470	919.00	4.09	0.00000	0.00	<input checked="" type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.011	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.60	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Sunnyview MHP	PA0032905	0.0000	0.0000	0.0380	0.000	20.00	7.50

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	24.57	2.00	0.00	1.50
Dissolved Oxygen	2.66	7.54	0.00	0.00
NH3-N	24.79	0.10	0.00	0.70



**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36035	BRUSH RUN	0.001	896.00	424.00	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY	Trib Flow	Stream Flow	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary Temp (°C)	pH	Stream Temp (°C)	pH
	(cfsm)	(cfs)	(cfs)									
Q7-10	0.011	0.00	0.00	0.000	0.000	0.0	0.00	0.00	25.00	7.80	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin	Stream Code	Stream Name										
20A	36035	BRUSH RUN										
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.565	0.04	0.00	0.04	.0464	0.01196	.35	5.96	17.01	0.04	0.134	22.43	7.42
0.470	0.04	0.00	0.04	.1052	0.00929	.378	7.08	18.71	0.06	0.511	21.50	7.45
<b>Q1-10 Flow</b>												
0.565	0.03	0.00	0.03	.0464	0.01196	NA	NA	NA	0.04	0.149	21.89	7.39
0.470	0.03	0.00	0.03	.1052	0.00929	NA	NA	NA	0.05	0.544	21.07	7.44
<b>Q30-10 Flow</b>												
0.565	0.06	0.00	0.06	.0464	0.01196	NA	NA	NA	0.05	0.122	22.82	7.44
0.470	0.06	0.00	0.06	.1052	0.00929	NA	NA	NA	0.06	0.482	21.84	7.46

### WQM 7.0 Modeling Specifications

Parameters	Both	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	5		

### WQM 7.0 Wasteload Allocations

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20A	36035	BRUSH RUN

#### NH3-N Acute Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.565	Scenic MHP	9.24	14.79	9.24	14.33	2	3
0.470	Sunnyview MHP	7.7	11.42	9.28	11.07	2	3

#### NH3-N Chronic Allocations

RMI	Discharge Name	Baseline Criterion (mg/L)	Baseline WLA (mg/L)	Multiple Criterion (mg/L)	Multiple WLA (mg/L)	Critical Reach	Percent Reduction
0.565	Scenic MHP	1.22	2.66	1.22	2.28	2	14
0.470	Sunnyview MHP	1.13	2.21	1.28	1.89	2	14

#### Dissolved Oxygen Allocations

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.56	Scenic MHP	25	25	2.28	2.28	3	3	0	0
0.47	Sunnyview MHP	24.57	24.57	1.89	1.89	4	4	0	0

## ATTACHMENT F

### WQM 7.0 MODEL OUTPUT FILE (Sunnyview Dry Stream Reach)

#### WQM 7.0 Effluent Limits

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>					
20A	36035	BRUSH RUN					
RMI	Name	Permit Number	Disc Flow (mgd)	Parameter	Effl. Limit 30-day Ave. (mg/L)	Effl. Limit Maximum (mg/L)	Effl. Limit Minimum (mg/L)
0.019	Sunnyview	PA0032905	0.000	CBOD5	25		
				NH3-N	25	50	
				Dissolved Oxygen			2

#### WQM 7.0 D.O. Simulation

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>			
20A	36035	BRUSH RUN			
<u>RMI</u>	<u>Total Discharge Flow (mgd)</u>	<u>Analysis Temperature (°C)</u>	<u>Analysis pH</u>		
0.019	0.038	20.000	7.500		
<u>Reach Width (ft)</u>	<u>Reach Depth (ft)</u>	<u>Reach WDRatio</u>	<u>Reach Velocity (fps)</u>		
1.588	0.374	4.251	0.099		
<u>Reach CBOD5 (mg/L)</u>	<u>Reach Kc (1/days)</u>	<u>Reach NH3-N (mg/L)</u>	<u>Reach Kn (1/days)</u>		
24.98	1.500	24.98	0.700		
<u>Reach DO (mg/L)</u>	<u>Reach Kr (1/days)</u>	<u>Kr Equation</u>	<u>Reach DO Goal (mg/L)</u>		
2.005	28.521	Owens	NA		
<u>Reach Travel Time (days)</u>	<u>Subreach Results</u>				
0.011	<u>TravTime (days)</u>	<u>CBOD5 (mg/L)</u>	<u>NH3-N (mg/L)</u>	<u>D.O. (mg/L)</u>	
	0.001	24.94	24.96	2.08	
	0.002	24.90	24.94	2.15	
	0.003	24.85	24.92	2.22	
	0.004	24.81	24.90	2.29	
	0.006	24.77	24.88	2.36	
	0.007	24.73	24.86	2.42	
	0.008	24.69	24.84	2.48	
	0.009	24.65	24.82	2.54	
	0.010	24.61	24.80	2.60	
	0.011	24.57	24.79	2.66	

Input Data WQM 7.0

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36035	BRUSH RUN	0.019	923.00	0.05	0.00000	0.00	<input type="checkbox"/>

Stream Data

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data

Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
Sunnyview	PA0032905	0.0000	0.0000	0.0380	0.000	20.00	7.50

Parameter Data

Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)
CBOD5	25.00	0.00	0.00	1.50
Dissolved Oxygen	2.00	8.24	0.00	0.00
NH3-N	25.00	0.00	0.00	0.70

**Input Data WQM 7.0**

SWP Basin	Stream Code	Stream Name	RMI	Elevation (ft)	Drainage Area (sq mi)	Slope (ft/ft)	PWS Withdrawal (mgd)	Apply FC
20A	36035	BRUSH RUN	0.001	919.00	0.06	0.00000	0.00	<input checked="" type="checkbox"/>

**Stream Data**

Design Cond.	LFY (cfsm)	Trib Flow (cfs)	Stream Flow (cfs)	Rch Trav Time (days)	Rch Velocity (fps)	WD Ratio	Rch Width (ft)	Rch Depth (ft)	Tributary		Stream	
									Temp (°C)	pH	Temp (°C)	pH
Q7-10	0.001	0.00	0.00	0.000	0.000	0.0	0.00	0.00	20.00	7.50	0.00	0.00
Q1-10		0.00	0.00	0.000	0.000							
Q30-10		0.00	0.00	0.000	0.000							

Discharge Data							
Name	Permit Number	Existing Disc Flow (mgd)	Permitted Disc Flow (mgd)	Design Disc Flow (mgd)	Reserve Factor	Disc Temp (°C)	Disc pH
		0.0000	0.0000	0.0000	0.000	25.00	7.00
Parameter Data							
Parameter Name	Disc Conc (mg/L)	Trib Conc (mg/L)	Stream Conc (mg/L)	Fate Coef (1/days)			
CBOD5	25.00	2.00	0.00	1.50			
Dissolved Oxygen	3.00	8.24	0.00	0.00			
NH3-N	25.00	0.00	0.00	0.70			

**WQM 7.0 Hydrodynamic Outputs**

SWP Basin	Stream Code	Stream Name										
20A	36035	BRUSH RUN										
RMI	Stream Flow (cfs)	PWS With (cfs)	Net Stream Flow (cfs)	Disc Analysis Flow (cfs)	Reach Slope (ft/ft)	Depth (ft)	Width (ft)	W/D Ratio	Velocity (fps)	Reach Trav Time (days)	Analysis Temp (°C)	Analysis pH
<b>Q7-10 Flow</b>												
0.019	0.00	0.00	0.00	.0588	0.04209	.374	1.59	4.25	0.10	0.011	20.00	7.50
<b>Q1-10 Flow</b>												
0.019	0.00	0.00	0.00	.0588	0.04209	NA	NA	NA	0.00	0.000	0.00	0.00
<b>Q30-10 Flow</b>												
0.019	0.00	0.00	0.00	.0588	0.04209	NA	NA	NA	0.00	0.000	0.00	0.00

**WQM 7.0 Modeling Specifications**

Parameters	D.O.	Use Inputted Q1-10 and Q30-10 Flows	<input checked="" type="checkbox"/>
WLA Method	EMPR	Use Inputted W/D Ratio	<input type="checkbox"/>
Q1-10/Q7-10 Ratio	0.64	Use Inputted Reach Travel Times	<input type="checkbox"/>
Q30-10/Q7-10 Ratio	1.36	Temperature Adjust Kr	<input checked="" type="checkbox"/>
D.O. Saturation	90.00%	Use Balanced Technology	<input checked="" type="checkbox"/>
D.O. Goal	2		

**WQM 7.0 Wasteload Allocations**

<u>SWP Basin</u>	<u>Stream Code</u>	<u>Stream Name</u>
20A	36035	BRUSH RUN

**Dissolved Oxygen Allocations**

RMI	Discharge Name	<u>CBOD5</u>		<u>NH3-N</u>		<u>Dissolved Oxygen</u>		Critical Reach	Percent Reduction
		Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)	Baseline (mg/L)	Multiple (mg/L)		
0.02	Sunnyview	25	25	25	25	2	2	0	0

### Attachment G – Discharge pH

Scenic MHP							
Pymatuning Twp, Mercer County							
PA0032913							
Discharge pH							
Date	pH min	pH max	10 <sup>-</sup> pH min	10 <sup>-</sup> pH max	& pH max)	-Log (Ave pH)	
Sep-21	7.54	8.2	2.884E-08	6.3096E-09	1.7575E-08	7.8	
Aug-21	6.92	7.74	1.2023E-07	1.8197E-08	6.9212E-08	7.2	
Jul-21	7.32	7.81	4.7863E-08	1.5488E-08	3.1676E-08	7.5	
Sep-20	7.21	7.72	6.166E-08	1.9055E-08	4.0357E-08	7.4	
Aug-20	6.77	7.7	1.6982E-07	1.9953E-08	9.4888E-08	7.0	
Jul-20	7.21	7.74	6.166E-08	1.8197E-08	3.9928E-08	7.4	
Sep-19	7.2	7.4	6.3096E-08	3.9811E-08	5.1453E-08	7.3	
Aug-19	7.24	7.32	5.7544E-08	4.7863E-08	5.2704E-08	7.3	
Jul-19	7.18	7.29	6.6069E-08	5.1286E-08	5.8678E-08	7.2	
Sep-18	7.32	7.38	4.7863E-08	4.1687E-08	4.4775E-08	7.3	
					Median:	7.3	

### Attachment H – TRC\_Calc Spreadsheet

<b>TRC EVALUATION</b>				
Input appropriate values in A3:A9 and D3:D9				
0.044	= Q stream (cfs)		0.5	= CV Daily
0.02	= Q discharge (MGD)		0.5	= CV Hourly
30	= no. samples		1	= AFC_Partial Mix Factor
0.3	= Chlorine Demand of Stream		1	= CFC_Partial Mix Factor
0	= Chlorine Demand of Discharge		15	= AFC_Criteria Compliance Time (min)
0.5	= BAT/BPJ Value		720	= CFC_Criteria Compliance Time (min)
0	= % Factor of Safety (FOS)			=Decay Coefficient (K)
Source	Reference	AFC Calculations		Reference
TRC	1.3.2.iii	WLA_afc = 0.473		1.3.2.iii
PENTOXSD TRG	5.1a	LTAMULT_afc = 0.373		5.1c
PENTOXSD TRG	5.1b	LTA_afc = 0.176		5.1d
				WLA_cfc = 0.453
				LTAMULT_cfc = 0.581
				LTA_cfc = 0.264
Source	Effluent Limit Calculations			
PENTOXSD TRG	5.1f	AML_MULT = 1.231		
PENTOXSD TRG	5.1g	AVG MON LIMIT (mg/l) = 0.217		AFC
		INST MAX LIMIT (mg/l) = 0.709		
WLA_afc	$(.019/e^{-k \cdot AFC\_tc}) + [(AFC\_Yc \cdot Qs \cdot .019 / Qd \cdot e^{-k \cdot AFC\_tc}) \dots + Xd + (AFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_afc	$EXP((0.5 \cdot LN(cvh^2 + 1)) - 2.326 \cdot LN(cvh^2 + 1)^{0.5})$			
LTA_afc	wla_afc * LTAMULT_afc			
WLA_cfc	$(.011/e^{-k \cdot CFC\_tc}) + [(CFC\_Yc \cdot Qs \cdot .011 / Qd \cdot e^{-k \cdot CFC\_tc}) \dots + Xd + (CFC\_Yc \cdot Qs \cdot Xs / Qd)] \cdot (1 - FOS / 100)$			
LTAMULT_cfc	$EXP((0.5 \cdot LN(cvd^2 / no\_samples + 1)) - 2.326 \cdot LN(cvd^2 / no\_samples + 1)^{0.5})$			
LTA_cfc	wla_cfc * LTAMULT_cfc			
AML_MULT	$EXP(2.326 \cdot LN((cvd^2 / no\_samples + 1)^{0.5}) - 0.5 \cdot LN(cvd^2 / no\_samples + 1))$			
AVG MON LIMIT	MIN(BAT_BPJ, MIN(LTA_afc, LTA_cfc) * AML_MULT)			
INST MAX LIMIT	$1.5 \cdot ((av\_mon\_limit / AML\_MULT) / LTAMULT\_afc)$			